

APPENDIX A  
NOTICE OF DEVIATION

Texas Utilities Electric Company  
Comanche Peak, Unit 1

Docket: 50-445/84-15  
Construction Permit: CPPR-126

Based on the results of an NRC inspection conducted during the period of March 1 through April 30, 1984, and in accordance with NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following deviation was identified:

Deviation From a Commitment to NRC

The FSAR, page 1 A(B)-14, in response to question Q421.19 commits the licensee to Regulatory Guide 1.33, Revision 2, February 1978. The Regulatory Guide endorses ANSI N-18.7-1976, as an acceptable method of compliance with the program requirements of Appendix B to 10 CFR 50. The licensee's commitment took no exceptions nor proposed an acceptable alternative to this commitment for the area of safety-related maintenance instructions; thus, all provisions of the Regulatory Guide and ANSI Standard as they pertain to PWR's apply.

In deviation from the above, the licensee has developed a program and specific maintenance instructions that have not been reviewed and approved by the Station Operations Review Committee (445/8415-01).

Texas Utilities Electric Company is hereby requested to submit to this office, within 30 days of the date of this Notice of Deviation, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further deviation from commitments made to the Commission; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: July 30, 1984