

A-23

50348/364 - CIVP

DOCKETED
USNHC

2/20/92

92 MAR 13 P4:17

0060306

FNP-0-ETP-4108
October 20, 1983
Revision 0OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCHFARLEY NUCLEAR PLANT
ENGINEERING TECHNICAL PROCEDURE

FNP-0-ETP-4108

SAFETY

RELATED

FNP ENVIRONMENTAL QUALIFICATION PROGRAM

SUPERCEDED

Approved:

1/16/93
Systems Performance & Planning Superintendent

Date Issued: _____

Diskette #ETP-47

NUCLEAR REGULATORY COMMISSION

Docket No. 50-348/34-Civ-8 Official Docket No. 23
In the matter of Alabama River Company

Staff _____ IDENTIFIED 1:05 p.m. 2/20/92
Applicant ✓ RECEIVED 1:05 p.m. 2/20/92
Intervenor _____ RECEIVED _____
Const'n Off'y _____ DATE 2/20/92
Contractor _____ Witness _____
Other _____
Reporter L. Estep

0060607

— 2 —

1. Procedure Number FNP-6.6TP-A117 Revision Number 0
Procedure Title FNP ENVIRONMENTAL QUALIFICATION
PROGRAM

- ### 2. *Exercise*

- 2.1 Procedure Page Numbers Affected by Change APPENDIX "J" PAGE 2

- 2.2 Description of Changes REPLACE PAGE 2 OF APPENDIX I
WITH PAGE OF THIS CHANGE

- 2.3 Reason for Change VENDOR CHANGED MODEL NO OF BOOT
EA-799-2CC52 TO
EA-799-2CC93. NETS HAS VERIFIED THAT THIS
CHANGE DOES NOT AFFECT ENVIRONMENTAL QUALIFICA-

3. Prepared By , GPE Sury, Date 3-23-84

4. Reviewed By 1911 Money, Date Sept 5, 3/23/84
Signature J, Title , Date

- #### 5. Cross-Disciplinary/POBC Review

Group Signature Title Date
Main Lyonball GPE I 3-23-84

6. Temporary Change Approval (Signatures/Date)

- Member Group Staff**
Shift Foreman
Senior Reactor Operator
Plant Manager

12-22-81

7. Final Approval (Signature/Date, required within 60 days of temporary approval)

- Group Supervisor
Plant Superintendent
NSAER
Vice President -
Nuclear Generation

Plant Manager

Robert Langford | 5-23-30

Figure 1

0060508

FALCON NUCLEAR PLANT
NUCLEAR SAFETY EVALUATION CHECK LIST
10 CFR 50.59

(1) UNIT N/A(2) CHECK LIST APPLICABLE TO: FNP-C-ETP-41C8 Revision 0 TCN

(3) SAFETY EVALUATION - PART A

The procedure, procedure change or modification to which this evaluation is applicable represents:

- (3.1) Yes No ✓ A change to the plant as described in the FSAR?
- (3.2) Yes No ✓ A change to procedures as described in the FSAR?
- (3.3) Yes No ✓ A test or experiment not described in the FSAR?
- (3.4) Yes No ✓ A change to the Technical Specifications or Operating License?

If the answer to question 3.1, 3.2 or 3.3 is "YES," complete Item (4) and attach a 10 CFR 50.55 evaluation. If the answer to all of the above is "No," omit Item (4) and Item (9). If the answer to Question 3.4 is "Yes," complete a 10 CFR 50.52 check list.

(4) SAFETY EVALUATION - PART B

- (4.1) Yes No Will the probability of an accident previously evaluated in the FSAR be increased?
- (4.2) Yes No Will the consequences of an accident previously evaluated in the FSAR be increased?
- (4.3) Yes No May the possibility of an accident which is different than any already evaluated in the FSAR be created?
- (4.4) Yes No Will the probability of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?
- (4.5) Yes No Will the consequences of a malfunction of equipment important to safety different than any already evaluated in the FSAR be increased?
- (4.6) Yes No May the possibility of a malfunction of equipment important to safety different than any already evaluated in the FSAR be created?
- (4.7) Yes No Will the margin of safety as defined in the basis to any Technical Specification be reduced?

If the answer to any of the above questions is "Yes," an unreviewed safety question is involved. Explain the basis for each answer provided in Section 4.

(5) REMARKS: (Attach additional pages if necessary) CHANGE VENDOR
MODEL NUMBER AS APPROVED BY NETS.

(6) PREPARED BY:	<u>J. M. May</u>	DATE	<u>3-23-84</u>
(7) REVIEWED BY:	<u>J. M. May</u>	DATE	<u>3/23/84</u>
(8) PORG REVIEW:	<u>J. M. May</u>	DATE	
(9) NORB REVIEW:	<u>J. M. May</u>	DATE	

DISTRIBUTION

Original: Document Control File A216226

Preventative Maintenance Requirements
Page 2

- Top cover gasket kit; EA-749-20021
- Bottom cover gasket kit; EA-749-20026
- Contact carrier kit; EA-749-20032
- Contact block kit; EA-749-20036
- Boot and retaining ring kit; EA-749-20043

See the attached IAMCO maintenance instructions. Tables 1 and 2 of "Environmental Qualification Surveillance" provides the frequency for these maintenance activities.

TCR
QA

ASCO solenoid Valves: NPB316, NPB320, NPB321, 206-381

Requirement: Replace the coil, all resilient parts and manual operator assembly (optional feature). To order spare part kits, coils and manual operator assemblies, specify the valve catalog number, serial number and voltage. See attached ASCO maintenance instructions. Tables 1 and 2 of "Environmental Qualification Surveillance" provides the frequency for the maintenance activities.

Indeterminate Life Equipment

Equipment: Barton transmitters; models 763 and 764
Foxboro transmitters; models E11GM (MCA) and E13DM
GEMS Delavel transmitters; XM-36495
GEMS Delavel level sensor; XM-54854
GEMS Delavel level switch; LS-36497
Target Rock solenoids; 79AB001.

Requirement: The qualified life and environmental qualification preventive maintenance activities will be determined following the completion of ongoing qualification test of analogous or similar equipment and subsequent evaluation of test results.

1010

FARLEY NUCLEAR PLANT
ENGINEERING TECHNICAL PROCEDURE
FNP-0-ETP-4108

FNP ENVIRONMENTAL QUALIFICATION PROGRAM

1.0 Purpose

This procedure assigns responsibility and describes the process for implementation of the FNP Environmental Qualification Program.

2.0 Environmentally Qualified Equipment Documentation

Basic documents and records used to establish program controls are: (1) Master List of Environmentally Qualified Equipment, (2) Environmental Qualification Test Report List, (3) Environmental Qualification Test Reports, (4) Component Maintenance and Replacement Schedule, (5) Specifications, and (6) Environmental Qualification Surveillance Records.

2.1 Master List of Environmentally Qualified Equipment

This list identifies by system, plant ID number, generic name, manufacturer, model number, and location components required to be environmentally qualified. Revisions and changes to this list are prepared and reviewed by NETS and approved by the Systems Performance Superintendent. This list is included as Appendices I and II of this procedure.

2.2 Environmental Qualification Test Report List

This list identifies approved environmental qualification test reports and the components to which they apply. Revisions and changes to the list shall be prepared and reviewed by NETS and approved by the Systems Performance Superintendent. This list is included as Appendix III of this procedure.

2.3 Environmental Qualification Test Reports

Environmental Qualification Test Reports provide the technical basis for determining the qualified life of an environmentally qualified component. NETS (Design and Licensing) will ensure that a complete review of the qualification documents is performed. The review of the vendors test

029931727

0060G11

FNP-0-ETP-4108

reports and other qualification documents should demonstrate their acceptability to the specific Farley requirements.

The appropriate organization, chosen by NETS (Design and Licensing), performing the technical evaluations will determine if the test reports and other vendor information such as component material lists sufficiently demonstrates the capability of the subject equipment to withstand the stresses of a harsh environment resulting from a postulated LOCA or high energy line break at FNP.

The reviewing organization will complete an Environmental Qualification Report Evaluation (Figure 1), Component Evaluation Work Sheet (CEWS) (Figure 2), and the necessary calculations to document the results of the evaluation. The Environmental Qualification Report Evaluation, CEWS and the calculations will be forwarded to NETS (Design and Licensing) including a summary of the technical adequacy of the vendor's test reports and information. As a minimum, the reviewing organization will also generate the environmental maintenance requirements including the identity of the subcomponents requiring periodic replacement, their replacement frequency, life category, and appropriate service manual and procedures for inclusion into plant procedures.

The CEWS should be completed to the extent practical without specifying the application of the instrument. The format of the CEWS will document the results of the test report and provide APCo the means to update the regulatory responses as desired. Calculations performed by Westinghouse, Bechtel or SCS are not required at this time to be forwarded to NETS (Design and Licensing) if appropriately referenced in the evaluation summary, but must be retained in their engineering files subject to APCo evaluations and audits. All calculations performed by other organizations must be forwarded to NETS (Design and Licensing).

If the subject equipment is authorized for purchase, NETS (Design and Licensing) will forward the Environmental Qualification Report Evaluation, CEWS, appropriate calculations, evaluation summaries, and vendor test reports and information to the Systems Performance Superintendent for review to verify proper

incorporation in the Environments. Qualification Test Report List. The Systems Performance Superintendent shall forward these documents to FNP Document Control for permanent retention.

2.4 Component Maintenance and Replacement Schedule

The Component Maintenance and Replacement Schedule provides the qualified life of each component included in the environmental qualification program. A component's qualified life is determined from engineering calculations using test report data. The Component Maintenance and Replacement Schedule is prepared and reviewed by NETS and approved by the Systems Performance Superintendent. This schedule is maintained as a controlled document in the FNP Document Control system. This schedule is used for scheduling PM tasks and replacement of environmentally qualified components. This list is included as Appendix IV of this procedure.

2.5 PM Specifications

The environmental qualification PM specifications identify the manufacturer, model, and required maintenance activities for all environmentally qualified components. Preventive Maintenance Specifications will be prepared and reviewed by NETS and forwarded to the Systems Performance Superintendent for approval and incorporation in the environmental qualification files maintained by Document Control. This list is included as Appendix V of this procedure.

2.6 Environmental Qualification Surveillance Records

2.6.1 The Specimen Surveillance Checklist (Figure 3) is used to document examination of environmentally qualified components. This checklist is completed by Maintenance personnel performing examinations described in Section 3.0. Completed Specimen Surveillance Checklists are forwarded to Systems Performance for review. Following review by Systems Performance these checklists are forwarded to Document Control for retention in the environmental qualification files.

2.6.2 Document Summary Sheets

In concert with the reviews of the Specimen Surveillance Checklist for

indeterminate life equipment. Systems Performance will complete a review of other documentation that may provide insights to the condition of the equipment. These documents will include: completed maintenance work requests; operating logs and data; completed Technical Specification surveillance tests; preventive maintenance plans and schedules; vendor information and notices concerning equipment utilization, function, capabilities, maintenance, defects and non-compliances; regulatory documents concerning adverse test reports, vendor anomalies, and service information; other Document Summary Sheets; and utility group information. Due to the number of documents involved, consideration should be selectively given to those documents having significant relevance to environmental qualification or the specific equipment under review to avoid diluting these efforts with inconsequential material. The review shall be documented on the Document Summary Sheet (Figure 4) for future reference.

A Document Summary Sheet may be completed for limited or 40-year life equipment at the discretion of the Systems Performance Supervisor, when evidence of unexpected aging is identified by a review of the Specimen Surveillance Checklist or other documentation.

3.0 Environmental Qualification Surveillance

Although the term "surveillance" is used in IEB 79-01B to describe the monitoring of age degradation, it should not be construed as an additional safety related surveillance test required by the Technical Specifications. It should be noted, the surveillance program discussed herein does not include or supersede any Technical Specification requirements.

There are three types of equipment addressed by the program: equipment with an indeterminate life but, in all other aspects, is qualified; equipment with a limited life; and equipment with 40-year life (see Tables 1 and 2 of the Component Maintenance and Replacement Schedule). Each of these categories will have an incremental increase in surveillance requirements to

compensate for the susceptibility to, or indeterminate aspects of, the aging degradation. The functional capability of 40-year life equipment, as with all equipment, is presently subject to the normal cognitive responsibilities of plant personnel; no additional surveillance requirements will be specified by this program. Limited life equipment will include a documented examination of a sample of the subcomponents (specimen) replaced at the end of their documented life. The equipment with an indeterminate life will include an examination of a specimen as well as a completion of a documented evaluation of in-house records providing insights to the condition of the equipment.

3.1 Maintenance Responsibilities

3.1.1 Maintenance shall perform required visual examination of environmentally qualified components. The purpose of the examination is to identify aging degradation. Evidence of degradation will include, but not be limited to, leakage or other indications of failure; discoloration other than stain from extrinsic matter; surface degradation such as cracking, bubbling, adhesiveness, corrosion, diffusion, moldering, and loss of elasticity or other properties critical to the intended function of the specimen; excessive deformation such as elongation or loss of general dimensional integrity. The Specimen Surveillance Checklist (Figure 3) will be used to document examination of the specimen. Maintenance will forward all completed Specimen Surveillance Checklists to Systems Performance for review and evaluation. The Specimen Surveillance Checklist is completed in accordance with the following instructions.

INSTRUCTIONS FOR COMPLETING SPECIMEN SURVEILLANCE CHECKLIST

IDENTITY

TPNS No.

Enter the complete TPNS number, including the system identifier from which the specimen is chosen.

Date

Date specimen is examined.

0060615

FNP-O-ETP-4108

Component	Generic name of the component (e.g., limit switch, solenoid, etc.).
Manufacturer	Name of company that provided component.
Model	Manufacturer's model number of the component.
Unit	Unit 1 or 2.
Location	Containment or Auxiliary Building.

AUTHORIZATION

WA

Number of work authorization that authorizes the activity.

EXAMINATION

Specimen	Identity of subcomponent under examination (e.g., cover gaskets, coil etc.).
Part Number	Enter the manufacturer's part number of the specimen if known and the manufacturer if different from the component.
Failure	Describe any evidence of the specimen having failed to perform its intended function.
Discoloration	Describe any specimen discoloration other than stains from extrinsic matter.
Surface Degradation	Describe any degradation of the specimen critical to its intended function.
Geometric Deformation	Describe any deformation of the specimen other than that attributed to accidental impact or dismantling.
Other Evidence	Describe any other indications of degradation important to the function of the specimen not addressed above, or any general remarks on the condition of the specimen.
Results	Examiner shall summarize the capabilities of the specimen and component discernible by the examination.
Examiner	Signature of the individual designated to perform examination.

Maintenance Supervisor	Signature of Maintenance Supervisor who ensures adequate examination was completed.
Recommendation	Systems Performance reviewer will provide a scheme to resolve any identified degradation.
Reviewer	Signature of Systems Performance personnel who has reviewed checklist.
Systems Performance Supervisor	Signature of Supervisor to ensure a complete evaluation and adequate recommendation.

- 3.1.2 The PM Coordinator shall prepare a Preventive Maintenance Task Sheet for each required environmental qualification PM task. Required environmental qualification PM tasks are identified by the list of PM Specifications described in section 2.5 of this procedure. Appropriate maintenance procedures and vendor service manuals to perform the maintenance will be referenced by the task description. Parts, components, and subassemblies subject to the visual examination described in section 3.1.1 are identified as replacement parts in the PM Specification list.
- 3.1.3 The PM Coordinator shall schedule environmental qualification PM tasks. Environmental qualification PM tasks may not be deferred past the end of the qualified life of a component. The qualified life of an environmentally qualified component is listed in the Component Maintenance and Replacement Schedule described in section 2.4. The Maintenance Supervisor shall be responsible for notifying Systems Performance and NETS (Design and Licensing) of any delays in replacing components at the end of their qualified life. NETS will evaluate the consequences of the delays to replace components and document justification of interim operation.
- 3.1.4 The PM Coordinator will select components which are to be subjected to the examination described in section 3.1.1. The choice of components may be random or may be based on suspicious operation.

0 2 9 9 3 1 / 3 4

0060617

FNP-0-ETP-4108

regulatory notification, vendor information, etc. Only one component from each manufacturer's generic model is necessary unless more stringent surveillance requirements have been prescribed by Systems Performance. Manufacturer's generic models located both inside and outside the containment will be sampled separately, i.e., a specimen from inside the containment will not negate the need for a specimen from outside the containment, and vice versa.

- 3.1.5 Environmentally qualified components with an indeterminate life that are replaced as a result of failure shall be subjected to the examination described in section 3.1.3 to determine if age degradation contributed to the failure. Parts to be examined will be determined by analysis of the available information on the known material used in construction and test reports of the vendor's analogous equipment with an established life.
- 3.1.6 Efforts will be made to ensure that corrective maintenance will not compromise the qualification status of the equipment identified on the Equipment Master List. For such equipment, the Maintenance Planners will include a statement on the Maintenance Work Request that the subject equipment is environmentally qualified and replacement parts will be replacement-in-kind commodities.
- 3.2 Systems Performance Group Surveillance Responsibilities
- 3.2.1 Maintenance will forward all Specimen Surveillance Checklists to Systems Performance. The checklists will be reviewed by Systems Performance for indications of degradation affecting the functional capabilities of the material. To assess the significance of any concerns, Systems Performance will review the Document Summary Sheets prepared in accordance with Section 2.6.2 of this program.
- 3.2.2 Systems Performance will complete the recommendations section of the appropriate surveillance checklist by

addressing such matters as: no aging identified and no action necessary, increase or decrease surveillance of similar components, further document review, replace components, etc. The completed checklists will be forwarded to Document Control for retention in the environmental qualification file.

- 3.2.3 Systems Performance Group Problem Report will be prepared by Systems Performance for concerns (identified in accordance with step 3.2.2 of this program) to be resolved within the plant staff or NETS (Design and Licensing) such as procedural changes, increased surveillance, etc. The Systems Performance Group Problem Report shall clearly identify the concern and recommend the action to be taken for resolution.

Systems Performance, and NETS (Design and Licensing) as requested, will review the response to the Problems Report and determine if the concern has adequately been resolved. The problem report and resolution will be forwarded to Document Control for retention in the environmental qualification file.

- 3.2.4 Upon the receipt of a Systems Performance Group Problem Report, the Superintendent of Nuclear Design and Licensing will ensure the necessary actions are undertaken to complete the response. If an engineering study is deemed necessary, coordination with an outside engineering service may be desirable. The response to the Systems Performance Group Problem Report, as well as the results and recommendations of associated engineering studies, will be documented by a Problem Report Response Sheet and forwarded to the Systems Performance Supervisor. Recommendations may include: no significant concerns identified and no action necessary, procedure revisions, modification of qualified life, alternative vendors, design changes, etc. Significant defects and noncompliances will be evaluated for potential reportability under 10CFR50 part 21. NETS (Design and

Licensing) will prepare justification for interim operation for reportable concerns.

3.2.5 Systems Performance will be responsible to coordinate the implementation of the recommendations from the engineering studies. The accountability of the recommendations should be documented by preparation of Systems Performance Group Problem Reports, PCR's, WR's, etc. The engineering studies and recommendations, PCR's, Systems Performance Group Problem Reports, and other documents providing evidence of resolution of environmental qualifications concerns will be forwarded to Document Control for permanent retention in the appropriate central file location.

4.0 Procurement Control

- 4.1 Material Requisitions and Purchase Orders for environmentally qualified items shall be processed in accordance with AP-9 instructions for procurement of safety related QA review Code "A" items.
- 4.2 Environmental qualification requirements shall be considered as part of the QA requirements. For environmentally qualified components required QA documentation shall include a certificate of compliance to the specified test report from the vendor. The test report number and revision date shall be stated in the certificate of compliance. A statement of conformance to IEEE 323-1974 or other codes and standards addressing environmental testing, unless accompanied by test data, is not sufficient.
- 4.3 A requisitioned subcomponent that is not included in the total plant numbering system shall satisfy the environmental requirements of the equipment having a TFNS No. for which the subcomponent is a constituent part. As an example, the coil of a solenoid will be qualified to the environmental test report for the solenoid and documented by requesting a certificate of conformance from the vendor. The test report requirements will be obtained from the Equipment Master List and Acceptable Test Report List via the solenoid's TFNS No. and manufacturer.
- 4.4 All cable will be procured according to standard operating procedure and will be environmentally

qualified. As with all other environmentally qualified equipment purchases, the test reports from vendors with equipment presently installed at FNP as identified on the Acceptable Test Report List will be referenced on the FNP Material Requisition; new vendors will be provided the standard FNP specific environmental conditions with which compliance should be established. Previous suppliers will be required to provide a certificate of compliance to the test report specified on the Acceptable Test Report List and new vendors will be required to submit their environmental qualification test reports for review. Cable will not necessarily be obtained from the original manufacturer; therefore, the manufacturers and model numbers for cables are not listed on the Equipment Master List. This will allow the design and installation of cables utilizing the FNP cable codes regardless of the manufacturer's cable available onsite.

- 4.5 The Material Supervisor will stamp the X-Req. as follows: "PLEASE DO NOT SUBSTITUTE. NATURE OF THIS REQUIREMENT IS SPECIFIC AND DOES NOT ALLOW SUBSTITUTION."

5.0 Design Control

- 5.1 A PCN will address environmental qualification if the design change:
- Affects equipment identified on the Equipment Master List; or
 - Adds equipment essential to mitigate the consequences of a LOCA or HELB while exposed to the harsh environment resulting therefrom (the only areas of a harsh environment are the containment and main steam valve room); or
 - Responds to a PCR referencing a Specimen Surveillance Checklist or a Document Summary Sheet.

The design organization will ensure that PCN's addressing environmental qualification adequately consider the Farley specific environmental conditions, maintenance, installation configuration, submergence level, interfaces with other components, etc. The PCN shall specify the manufacturer and model number of equipment and components, other than cable, and identify any special environmentally qualified material such as gaskets.

and seals. The PCN must clearly state that the equipment is to be environmentally qualified.

As design organizations, Bechtel and SCS will prepare engineered requisitions for all environmentally qualified equipment that is identified by the PCN and not on the Acceptable Test Report List. The engineered requisition will include the license and code requirements, the primary vendor and model number, special material requirements, and a part description that clearly identifies the components to be environmentally qualified. Additionally, the engineered requisition will request a certificate of conformance and a copy of the qualification test report. The procurement of all other environmentally qualified equipment will be in accordance with "Procurement Control".

- 5.2 NETS (Design and Licensing) will review PCM's to ensure that the engineering designs provided by the design organization are adequate to resolve the existing conditions described on the corresponding PCR's. In particular, the reviews should consider whether additions and deletions to the scope of environmentally qualified equipment and the selection of manufacturers not identified on the Acceptable Test Report List are necessary and acceptable. As determined necessary from their review NETS shall prepare changes to (1) the Master List of Environmentally Qualified Equipment, (2) the Environmental Qualification Test Report List, (3) Environmental Qualification Test Reports, (4) The Component Maintenance and Replacement Schedule, and (5) PM Specifications as described in Section 2.0 of this procedure.

0060621

APPENDIX I

MASTER LIST OF ENVIRONMENTAL QUALIFIED EQUIPMENT
UNIT 1

0 2 4 2 5 - 1 / 3 2

LIST OF EFFECTIVE PAGES

0000622

PAGE NO.	REVISION NO.										
	0	1	2	3	4	5	6	7	8	9	10
1	X										
2	X										
3	X										
4	X										
5	X										
6	X										
7	X										
8	X										
9	X										
10	X										
11	X										
12	X										
13	X										
14	X										
15	X										
16	X										
17	X										
18	X										
19	X										
20	X										
21	X										
22	X										
23	X										
24	X										
25	X										

LIST C. ELITE TIVE PAGES

0060623

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1Section C.2.1
Sheet 1

0000024

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS
SYSTEM: REACTOR COOLANT INSTRUMENTATION

B-13

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENT		LOCATION
				FLO	ELEV.	
W1B13TE412A	RTD	Rosemount	176KF	CDMT	124'-0"	
W1B13TE412D	RTD	Rosemount	176KF	CDMT	124'-0"	
W1B13TE422B	RTD	Rosemount	176KF	CDMT	124'-0"	
W1B13TE422D	RTD	Rosemount	176KF	CDMT	124'-0"	
W1B13TE432B	RTD	Rosemount	176KF	CDMT	124'-0"	
W1B13TE432D	RTD	Rosemount	176KF	CDMT	124'-0"	
Q1T52B012	Penetration	General Electric	100 Series	CDMT	143'-0"	
Q1T52B028	Penetration	General Electric	100 Series	CDMT	143'-0"	
Q1T52B030	Penetration	General Electric	100 Series	CDMT	143'-0"	
11TB001	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
11TB002	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
21TB003	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
21TB004	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
31TB001	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
31TB002	Terminal Block	Siemens Co.	Type ZWH	CDMT	>115'	
1V1V5002B.D	Inst. Cables			CDMT	>115'	
1V2V5002B.D	Inst. Cables			CDMT	>115'	
1V3V5002B.D	Inst. Cables			CDMT	>115'	

0060625

MASTER LIST

△ New Sheet
 Section 2
 Sheet 2

Joseph M. Farley Nuclear Plant Unit 1

(CLASS I ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: S13 - Reactor Coolant EGRESS (Head Vent) WIREC-A0733, Section II B.1

COMPONENT					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	BLDG.
Q1B128V2213A	Solenoid Valve	TAYST	79AB001	CTMT	>115'-0"
Q1B128V2213B	Solenoid Valve	TAYST	79AB001	CTMT	>115'-0"
Q1B128V2214A	Solenoid Valve	TAYST	79AB001	CTMT	>115'-0"
Q1B128V2214B	Solenoid Valve	TAYST	79AB001	CTMT	>115'-0"
Q1T52B014-A	Control Penetrations	General Electric	100 Series	CTMT	>115'-0"
IVAL51453	Control Cable			CTMT	>115'-0"
IVAL51454	Control Cable			CTMT	>115'-0"
11TB007	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"
Q1B128V2213A-JB	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"
IVAL51455	Control Cable			CTMT	>115'-0"
IVAL51456	Control Cable			CTMT	>115'-0"
Q1B128V2214A-JB	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"
Q1T52B016-B	Control Penetration	General Electric	100 Series	CTMT	>115'-0"
IVAL51457	Control Cable			CTMT	>115'-0"
IVAL51458	Control Cable			CTMT	>115'-0"
11TB025	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"
Q1B128V2213B-JB	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"
IVAL51459	Control Cable			CTMT	>115'-0"
IVAL51460	Control Cable			CTMT	>115'-0"
Q1B128V2214B-JB	Terminal Block	SEASER	Type ZWM	CTMT	>115'-0"

MASTER LIST

0000026

⚠ New Sheet
Section 4
Sheet 1

Joseph M. Farley Nuclear Plant Unit 1

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: B13/B31 Pressurizer Safety Valve Position Indication NUREG-0737, II.D.3

COMPONENT				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
IVY00H174A	Cable			CTMT >115'-0"
Q1B130001-B	Terminal Box	States Company	Type EWM	CTMT >115'-0"
IVB130990	Cable			CTMT >115'-0"
IVB13099H	Cable			CTMT >115'-0"
IVB13099J	Cable			CTMT >115'-0"
Q1T52B025-B	Ctrl. Penet.	General Electric	100 Series	CTMT >115'-0"
Q1T52B022-B	Ctrl. Penet.	General Electric	100 Series	CTMT >115'-0"
Q1B13252034	Position Switch	NAMCO	EA-180	CTMT >115'-0"
Q1B13252035	Position Switch	NAMCO	EA-180	CTMT >115'-0"
Q1B13252036	Position Switch	NAMCO	EA-180	CTMT >115'-0"
N1B31250444B	Limit Switch	NAMCO	EA-180	CTMT >115'-0"
N1B31250445A	Limit Switch	NAMCO	EA-180	CTMT >115'-0"
N1B315V0444BA-B/JB	Junction Box	States Company	Type EWM	CTMT >115'-0"
N1B315V0445AA-A/JB	Junction Box	States Company	Type EWM	CTMT >115'-0"
Q1T52B007A	Control Penetration	General Electric	100 Series	CTMT >115'-0"
IVY00H174A	Cable			CTMT >115'-0"
IVY00H174A	Control Penetr.	General Electrical	100 Series	CTMT >115'-0"
IVY00H174A	Control Penetr.	General Electrical	100 Series	CTMT >115'-0"
IVY00H174A	Control Table			CTMT >115'-0"
IVY00H174A	Control Table			CTMT >115'-0"

MASTER LIST

0060327

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.2
Sheet 4

(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: REACTOR COOLANT SYSTEM - STEAM GENERATOR

B-21

COMPONENTS					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				BLOC	ELEV
N1B21PT402	Press. Transmitter	Barton	763	CTMT	129'
N1B21PT403	Press. Transmitter	Barton	763	CTMT	129'
N1B21TE410	RTD	Rosemount	176KS	CTMT	122'-9"
N1B21TE413	RTD	Rosemount ³	176KS	CTMT	122'-9"
N1B21TE420	RTD	Rosemount	176KS	CTMT	122'-9"
N1B21TE423	RTD	Rosemount	176KS	CTMT	122'-9"
N1B21TE430	RTD	Rosemount	176KS	CTMT	122'-9"
N1B21TE433	RTD	Rosemount	176KS	CTMT	122'-9"
Q1T52B012	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B030	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B040	Penetration	General Electric	100 Series	CTMT	143'-0"
11TB001	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
11TB002	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
11TB004	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
21TB001	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
21TB002	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
21TB005	Terminal Block	Statco Co.	Type ZWM	CTMT	>115'
1VYV5031B	Instr. Cables			CTMT	>115'
1VYV5033B	Instr. Cables			CTMT	>115'
1V1V5002E,F,G	Instr. Cables			CTMT	>115'
1V2V5002E,F,G	Instr. Cables			CTMT	>115'

MASTER LIST

0060028

Section C.2.3
Sheet 3

Joseph M. Farley Nuclear Plant Unit 1

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: REACTOR COOLANT SYSTEM - PRIMARIZER

B-31

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				ELD	ELV
Q1B31SV8047 (MV8047)	Solenoid Valve	ABCO	MF831654V	CTMT	118'-0"
N1B31Z88047 (MV8047)	Limit Switch	KAMCO	EA-180	CTMT	118'-0"
Q1T52B022	Penetration	General Electric	100 Series	CTMT	143'
Q1T52B038	Penetration	General Electric	100 Series	CTMT	143'
N1B31SV8047-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	>115'
Q1B31LT459	Level Transmitter	Barton	764	CTMT	132'
Q1B31LT460	Level Transmitter	Barton	764	CTMT	132'
Q1B31LT461	Level Transmitter	Barton	764	CTMT	132'
Q1B31PT455	Pressure Transmitter	Foxboro	E11GM(HCA)	CTMT	166'-6"
Q1B31PT456	Pressure Transmitter	Foxboro	E11GM(HCA)	CTMT	166'-6"
Q1B31PT457	Pressure Transmitter	Foxboro	E11GM(HCA)	CTMT	166'-6"
1VBL5078C	Control Cable			CTMT	>115'
1VBQ5021E	Control Cable			CTMT	>115'
Q1T52B012	Penetration	General Electric	100 Series	CTMT	143'
Q1T52B028	Penetration	General Electric	100 Series	CTMT	143'
Q1T52B030	Penetration	General Electric	100 Series	CTMT	143'
Q1T52B040	Penetration	General Electric	100 Series	CTMT	143'
1V1V5031D	Instr. Cable			CTMT	>115'
1V1V50U2U	Instr. Cable			CTMT	>115'
1V2V5002T,U	Instr. Cables			CTMT	>115'
1V3V5002T, U	Instr. Cables			CTMT	>115'

MASTER LIST

 New Sheet

Section
1001

0060529

Joseph M. Farley Nuclear Plant Unit 1

IC CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM B31 - Pressure Vessel and Safety Valves NUREG-0737, II.D.1

MASTER LIST

0060330

Section C.2.4
Sheet 7

Joseph M. Farley Nuclear Plant Unit 1

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: FEEDWATER CONTROL SYSTEM

C-22

COMPONENTS					
PLANT ID NUMBER	GENERAL NAME	MANUFACTURER	MODEL	LOCATION	
				BLDG.	ELEV.
1VAL50610	Control Cable			Mn. Stm.	
				Room	Z 131'
1VBL50340, D	Control Cables			Mn. Stm.	
				Room	Z 131'
1VXL50728	Control Cable			Mn. Stm.	
				Room	Z 131'
1VAL50628	Control Cable			Mn. Stm.	
				Room	Z 131'
1VBL50358, D	Control Cables			Mn. Stm.	
				Room	Z 131'
1VXL5073A	Control Cable			Mn. Stm.	
				Room	Z 131'
Q1C22LT474	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT475	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT476	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT484	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT485	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT486	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT494	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT495	Level Transmitter	Barton	764	CTMT	159'
Q1C22LT496	Level Transmitter	Barton	764	CTMT	159'
Q1C22FT474	Flow Transmitter	Foxboro	E13DM	CTMT	180'
Q1C22FT475	Flow Transmitter	Foxboro	E13DM	CTMT	180'
Q1C22FT484	Flow Transmitter	Foxboro	E13DM	CTMT	180'
Q1C22FT485	Flow Transmitter	Foxboro	E13DM	CTMT	180'
Q1C22FT494	Flow Transmitter	Foxboro	E13DM	CTMT	180'
Q1C22FT495	Flow Transmitter	Foxboro	E13DM	CTMT	180'
217528010	Penetration	General Electric	100 Series	CTMT	143'
217528012	Penetration	General Electric	100 Series	CTMT	143'
217528028	Penetration	General Electric	100 Series	CTMT	143'
217528030	Penetration	General Electric	100 Series	CTMT	143'

MASTER LIST

0000631

Section C.2.4

Show # 8

Joseph M. Farley Nuclear Plant Unit — 1

(CLASS II) ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER BOTH NORMAL AND FAULT CONDITIONS.

SYSTEM: WATER-CONTROLS

C-22

Joseph M. Farley Nuclear Plant Unit 1

View Sheet
Section C.2.4
Sheet 9

0060632

(CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
 SYSTEM: FEEDWATER CONTROL SYSTEM

C-22

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		LOCATION
				BLOC	ELEV.	
N1C222SV0478 (FCV478)	Limit Switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0478A (FCV478)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0478B (FCV478)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0488 (FCV488)	Limit switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0488A (FCV488)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0488B (FCV488)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0498 (FCV498)	Limit Switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0498A (FCV498)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0498B (FCV498)	Solenoid Valve	ASCO	HT8300B58RU	Mn. Sta Room	> 131'	
N1C222SV0479 (FCV479)	Limit Switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0479A (FCV479)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	130'	
N1C222SV0479B (FCV479)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	130'	
N1C222SV0489 (FCV489)	Limit Switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0489A (FCV489)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	> 131'	
N1C222SV0489B (FCV489)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	> 131'	
N1C222SV0499 (FCV499)	Limit Switch	NAMCO	EA-170	Mn. Sta Room	> 131'	
N1C222SV0499A (FCV499)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	> 131'	
N1C222SV0499B (FCV499)	Solenoid Valve	ASCO	HV-202-301-3U	Mn. Sta Room	> 131'	
N1C222SV0478A-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Sta Room	> 131'	
N1C222SV0488A-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Sta Room	> 131'	
N1C222SV0499A-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Sta Room	> 131'	
217140608	Control Cable			Mn. Sta Room	> 131'	
217140213	Control Cable			Mn. Sta Room	> 131'	
217145071A	Control Cable			Mn. Sta Room	> 131'	

0060633

MASTER LIST

△ New Sheet
 Section 5
 Sheet 10

Joseph M. Farley Nuclear Plant Unit 1

CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: D21 - HIGH RADIATION CONFINEMENT RADIATOR NUREG-0737, II.P.1.3

COMPONENT				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
IVA15011E	Cable			ALDA 115V
IVA15011G	Cable			GTMT >15'-0"
Q1D21RE0027A-A	Radiation Detector	Victronen	877-1	GTMT >115'-0"
IVB15009E	Cable			GTMT >115'-0"
IVB15009G	Cable			GTMT >115'-0"
Q1D21RE0027B-A	Radiation Detector	Victronen	877-1	GTMT >115'-0"
Q1T521009-A	GTMT Panel	Westinghouse		GTMT >115'-0"
Q1T521011-A	GTMT Panel	Westinghouse		GTMT >115'-0"

Note 2 - Cables have been qualified alone with detector.

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.5

Section 1.1

00605334

(CLASS I E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
SYSTEM: SAFEGUARD SYSTEMS, RHR LMST

Page 10

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 10060035
Section C, 2.6
Sheet 12(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
SYSTEM: CONTAINMENT COOLING AND PURGE

F-12, F-14, F-13

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
Q1E14V002(MOV3660)	1" Motor Operated Globe Valve	LIMITECQUE	SMR-000	CTMT ELEV.
Q1E14V004(MOV3318B)	1" Motor Operated Globe Valve	LIMITECQUE	SMR-000	CTMT 134'-6"
Q1P132S3196(HV3196)	Limit Switch	NAMCO	EA-180	CTMT 116'-0"
Q1P135V2867D(HV2867)	Solenoid Valve	ASCO	NP831654V	CTMT 129'-0"
Q1P132S2867B(HV2867)	Limit Switch	NAMCO	EA-740	CTMT 129'-0"
Q1P132S3197(HV3197)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q1P135V2866B(HV2866)	Solenoid Valve	ASCO	NP831654V	CTMT 129'-0"
Q1P132S2866D(HV2866)	Limit Switch	NAMCO	EA-740	CTMT 129'-0"
Q1E12SV3999A(HV3999A)	Solenoid Valve	ASCO	NP8316A74E	CTMT <105'
Q1E12ZS3999A(HV3999A)	Limit Switch	NAMCO	EA-180	CTMT <105'
Q1E12SV3999B(HV3999B)	Solenoid Valve	ASCO	NP8316A74E	CTMT <105'
Q1E12ZS3999B(HV3999B)	Limit Switch	NAMCO	EA-180	CTMT <105'
Q1E12M001A(H001A)	CTMT Clr. Fan Motor	Joy Mfg. Co.	Type P	CTMT 155'-0"
Q1E12M001B(H001B)	CTMT Clr. Fan Motor	Joy Mfg. Co.	Type P	CTMT 155'-0"
Q1E12M001C(H001C)	CTMT Clr. Fan Motor	Joy Mfg. Co.	Type P	CTMT 155'-0"
Q1E12M001D(H001D)	CTMT Clr. Fan Motor	Joy Mfg. Co.	Type P	CTMT 155'-0"
Q1T52B005	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B007	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B002	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B006	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B041	Penetration	General Electric	100 Series	CTMT 143'-0"
Q1T52B020	Penetration	General Electric	100 Series	CTMT 143'-0"

MASTER LIST

DCE0G36

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.6
Sheet 13

ICLAM IE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: CONTAINMENT COOLING AND RITGE

E-12, E-14, P-13

COMPONENTS					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	ELEV.
Q1P138V3196-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	>115'
Q1T52B022	Penetration	General Electric	100 Series	CTMT	143"
Q1P138V2867B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	>115'
Q1P138V3197-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	>115'
Q1P138V2866B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	>115'
Q1E128V3999A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	<115'
Q1T52B025	Penetration	General Electric	100 Series	CTMT	143"
Q1E128V3999B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	<115'
Q1T52B001	Penetration	General Electric	100 Series	CTMT	143"
Q1T52B023	Penetration	General Electric	100 Series	CTMT	143"
IVAFU-R5Q	Power Cable			CTMT	>115'
IVAFU-R5D	Control Cable			CTMT	>115'
IVAQ5048Y	Control Cable			CTMT	>115'
IVXR5005H	Control Cable			CTMT	>115'
IVAFU-J4Q	Power Cable			CTMT	>115'
IVAFU-J4D	Control Cable			CTMT	>115'
IVAQ5009C	Control Cable			CTMT	>115'
IVYR5066B	Instrument Cable			CTMT	>115'
IVBL5008C,D,K,L	Control Cables			CTMT	>115'
IVBQ5010J	Control Cable			CTMT	>115'
IVYR5035D	Control Cable			CTMT	>115'
IVBL5008X,W	Control Cables			CTMT	>115'
IVBQ5012Y	Control Cable			CTMT	>115'
IVYR5035Y	Control Cable			CTMT	>115'
IVAL5122C	Control Cable			CTMT	>115'

MASTER LIST

00000037

Section 5.2.6

Sheet 14

Joseph M. Farley Nuclear Plant Unit 1

(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CONTAINMENT COOLING AND PIPING

Ex.12. Ex.14. P.13.

MEMORIAL

0060338

Joseph M. Farley Nuclear Plant Unit _____

Section C.2.7
Sheet 15

SYSTEM: HYDROGEN RECOMBINATION SYSTEM

3-17

GCEGG39

112000

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.8
Sheet 16

(CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CONTAINMENT POST LOCA AIR SYSTEM: SATEL

1-19

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
				FLOOR
Q1E19M001A (C001A)	Mixing Fan Motor	Joy Mfr. Co.	TYPE P	CTMT 155'-0"
Q1E19M001B (C001B)	Mixing Fan Motor	Joy Mfr. Co.	TYPE P	CTMT 155'-0"
Q1E19M001C (C001C)	Mixing Fan Motor	Joy Mfr. Co.	TYPE P	CTMT 155'-0"
Q1E19M001D (C001D)	Mixing Fan Motor	Joy Mfr. Co.	TYPE P	CTMT 155'-0"
Q1T52B002	Penetration	General Electric	100 Series	CTMT 163'-0"
Q1T52B014	Penetration	General Electric	100 Series	CTMT 163'-0"
Q1T52B015	Penetration	General Electric	100 Series	CTMT 163'-0"
Q1T52B017	Penetration	General Electric	100 Series	CTMT 163'-0"
IVATA-350	Power Cable			CTMT >115'
IVATA-350	Power Cable			CTMT >115'
IVATA-140	Power Cable			CTMT >115'
IVATA-130	Power Cable			CTMT >115'

MASTER LIST

0060540

Section C.2.9
Sheet 17

Joseph M. Farley Nuclear Plant Unit 1

(ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CYANICAL AND VOLINE CONTROL / SAFETY INJECTION

E-21

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				FLOOR	LEVEL
Q1E21V038A (MOV8808A)	12" Motor Operated Gate Valve	LIMITECHUS	EMB-4	CTMT	111'-6"
Q1E21V038B (MOV8808B)	12" Motor Operated Gate Valve	LIMITECHUS	EMB-4	CTMT	112'-6"
Q1E21V038C (MOV8808C)	12" Motor Operated Gate Valve	LIMITECHUS	EMB-4	CTMT	113'-6"
Q1E21SV8871 (HV8871)	Solenoid Valve	ASCO	NPS21654V	CTMT	128'-0"
Q1E21288871 (HV8871)	Limit Switch	NAMCO	EA-180	CTMT	128'-0"
Q1E21V249A (MOV8149A)	3" Motor Operated Gate Valve	LIMITECHUS	EMB-00	CTMT	123'
N1E21288149A (HV8149A)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q1E21SV8149AB (HV8149A)	Solenoid Valve	ASCO	206-381-6RF	CTMT	111'-0"
N1E21288149B (HV8149B)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q1E21SV8149BB (HV8149B)	Solenoid Valve	ASCO	206-381-6RF	CTMT	111'-0"
N1E21288149C (HV8149C)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q1E21SV8149CB (HV8149C)	Solenoid Valve	ASCO	206-381-6RF	CTMT	111'-0"
Q1T52B002	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B004	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
N1E21SV8871-A/JB	Terminal Block	Statco Co.	Type ZWM	CTMT	> 116'-0"
Q1E21288808AB	Limit Switch	NAMCO	EA-180	CTMT	111'-6"
Q1E21288808BB	Limit Switch	NAMCO	EA-180	CTMT	112'-6"
Q1E21288808CB	Limit Switch	NAMCO	EA-180	CTMT	113'-6"
Q1T52B014	Penetration	General Electric	100 Series	CTMT	143'-0"
N1E21SV8149AA-A/JB	Terminal Block	Statco Co.	Type ZWM	CTMT	> 116'-0"
N1E21SV8149BA-A/JB	Terminal Block	Statco Co.	Type ZWM	CTMT	> 116'-0"

CCCC641

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1

Section C, 2, 9

Sheet 18

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: CHEMICAL AND SOLVENT CONTROL/SAFETY INJECTION

P. 21

MASTER LIST

00000642

Section C.2.10
Sheet 19

Joseph M. Farley Nuclear Plant Unit 1

CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: REACTOR CAVITY POST LOCA DILUTION SYSTEM

F-22

0000643

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.11
Sheet 20

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: POST ACCIDENT CONTAINMENT COMBUSTIBLE GAS CONTROL.

E-23

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				BLDG	FLOOR
Q1E23V021 (MOV3536)	2" Motor Operated Gate Valve	Limitorque	SMR-00	CTMT	116'-6"
Q1E23V003 (MOV3530Y)	6" Motor Operated Gate Valve	Limitorque	SMR-00	CTMT	130'-6"
Q1E23V022A (MOV3528A)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	126'-6"
Q1E23V022B (MOV3528B)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	126'-6"
Q1E23V022C (MOV3528C)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	126'-6"
Q1E23V022D (MOV3528D)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	126'-6"
Q1E23V025A (MOV3835A)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	1'6"-6"
Q1E23V025B (MOV3835B)	3/4" Motor Operated Globe Valve	Limitorque	SMR-000	CTMT	1'6"-6"
Q1T52B005	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B017	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B015	Penetration	General Electric	100 Series	CTMT	143'-0"
1VAFU-W4Q	Power Cable			CTMT	>115'
1VBFU-N2Q	Power Cable			CTMT	>115'
1VAFU-W4C	Control Cable			CTMT	>115'
1VAED06E	Control Cable			CTMT	>115'
1VBFFV-N2C	Control Cable			CTMT	>115'
1VBEE09E	Control Cable			CTMT	>115'
1VBFFV-Y5Q	Power Cable			CTMT	>115'
1VBFFV-Y5C	Control Cable			CTMT	>115'
1VBFFV-Y4Q	Power Cable			CTMT	>115'

MASTER LIST

8060644

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.11
Sheet 21

CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
SYSTEM: _____

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.12
Sheet 22

(CLASSIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: LIQUID WASTE DISPOSAL SYSTEM

G-21

SP90900

COMPONENTS					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				BLDG.	ELEV.
Q1G21SV3376 (HV3376)	Solenoid Valve	ASCO	NP8316A74V	GTMT	109'-0"
Q1G212S3376 (HV3376)	Limit Switch	NAMCO	EA-180	GTMT	109'-0"
N1G212S1003B (LCV1003)	Limit Switch	NAMCO	EA-180	GTMT	110'-0"
N1G21SV1003B (LCV1003)	Solenoid Valve	ASCO	206-381-6RF	GTMT	110'-0"
Q1G21SV7126 (HV7126)	Solenoid Valve	ASCO	NP831654V	GTMT	117'-0"
Q1G212S7126 (HV7126)	Limit Switch	NAMCO	EA-180	GTMT	117'-0"
Q1T52B038	Penetration	General Electric	100 Series	GTMT	143'-0"
Q1T52B041	Penetration	General Electric	100 Series	GTMT	143'-0"
Q1G21SV3376-B/JB	Terminal Block	States Co.	Type ZWM	GTMT	116'-0"
Q1T52B019	Penetration	General Electric	100 Series	GTMT	143'-0"
N1G21SV1003A-A/JB	Terminal Block	States Co.	Type ZWM	GTMT	>116'-0"
N1G21SV7126-A/JB	Terminal Block	States Co.	Type ZWM	GTMT	>116'-0"
IVBL5045C	Control Cable			GTMT	>115'
IVB05030J	Control Cable			GTMT	>115'
IVYR5066G	Instrument Cable			GTMT	>115'
IVAL5037D	Control Cable			GTMT	>115'
IVAQ5021J	Control Cable			GTMT	>115'
IVAL5036C	Control Cable			GTMT	=115'
IVAQ5020J	Control Cable			GTMT	=115'
					-
					-
					-
					-
					-

MASTER LIST

⚠ New Sheet
Section 7
Sheet - 23

Joseph M. Farley Nuclear Plant Unit 1

(CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: G-21 - Liquid Waste Disposal (Narrow Range Containment Supp Level)

NUREG-0737, II.F.1.S

GPO : 1974 OMB 87-11

MASTER LIST

0060547

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.13
Sheet 24

(CLASS I E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: MAIN STEAM

N-11

0 2 9 9 3 1 7 6 5

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
				BLDG. ELEV.
Q1N112S3369A (HV3369A)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11SV3369AC (HV3369A)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3369B (HV3369B)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11SV3369BC (HV3369B)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3369C (HV3369C)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11SV3369CC (HV3369C)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3370A (HV3370A)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11EV3370AC (HV3370A)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3370B (HV3370B)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11SV3370BC (HV3370B)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3370C (HV3370C)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room 128'
Q1N11SV3370CC (HV3370C)	Solenoid Valve	ASCO	NP8316E36V	Mn. Stm. Room ≥131'
Q1N112S3368A (HV3368A)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room ≥131'
Q1N11SV3368AA (HV3368A)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N112S3368B (HV3368B)	Limit Switch	NAMCO	EA-180	Mn. Stm. Room ≥131'
Q1N11SV3368BA (HV3368B)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N112S3368C (HV3368C)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room ≥131'
Q1N11SV3368CA (HV3368C)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N11SV3976A (HV3976A)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N112S3976A (HV3976A)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room ≥131'
Q1N11SV3976B (HV3976B)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N112S3976B (HV3976B)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room ≥131'
Q1N11SV3976C (HV3976C)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm. Room ≥131'
Q1N112S3976C (HV3976C)	Limit Switch	NAMCO	EA- 180	Mn. Stm. Room ≥131'
Q1N11SV3369AA-A/JR	Terminal Block	States Co.	Type ZWM	Mn. Stm. Room ≥131'

MASTER LIST

0060548

Section C.2.13
Sheet 25

Joseph M. Farley Nuclear Plant Unit 1

(CLA 4818 ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: MAIN STREAM

頁·11

MASTER LIST

0060049
Section C 2.14
Sheet 26

Joseph M. Farley Nuclear Plant Unit 1

(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: AUXILIARY STEAM

N-12

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
				BLDG ELEV
QIN12SV3234A (HV3234A)	Solenoid Valve	ASCO	NP8320A186V	MN, STM ROOM ≥131'
QIN122S3234A (HV3434A)	Limit Switch	NAMCO	EA-180	MN, STM ROOM ≥131'
QIN123V3234B (HV3234B)	Solenoid Valve	ASCO	NP8320A186V	MN, STM ROOM ≥131'
QIN122S3234B (HV3234B)	Limit Switch	NAMCO	EA-180	MN, STM ROOM ≥131'
QIN12SV3235A (HV3235A)	Solenoid Valve	ASCO	NP8321A2V	MN, STM ROOM ≥131'
QIN122S3235A (HV3235A)	Limit Switch	NAMCO	EA-180	MN, STM ROOM ≥131'
QIN12SV3235B (HV3235B)	Solenoid Valve	ASCO	NP8321A2V	MN, STM ROOM ≥131'
QIN122S3235B (HV3235B)	Limit Switch	NAMCO	EA-180	MN, STM ROOM ≥131'
QIN12SV3234A-A/JB	Terminal Block	States Co.	Type ZWM	MN, STM ROOM ≥131'
QIN12SV3234B-B/JB	Terminal Block	States Co.	Type ZWM	MN, STM ROOM ≥131'
QIN12SV3235A-A/JB	Terminal Block	States Co.	Type ZWM	MN, STM ROOM ≥131'
QIN12SV3235B-B/JB	Terminal Block	States Co.	Type ZWM	MN, STM ROOM ≥131'
IVAL5003B	Control Cable			MN, STM ROOM ≥131'
IVAQ5011A	Control Cable			MN, STM ROOM ≥131'
IVXR5007F	Control Cable			MN, STM ROOM ≥131'
IVBL5007B	Control Cable			MN, STM ROOM ≥131'
IVBQ5013B	Control Cable			MN, STM ROOM ≥131'
IVYR5033E	Control Cable			MN, STM ROOM ≥131'
IVAL5004C	Control Cable			MN, STM ROOM ≥131'
IVAQ5010D	Control Cable			MN, STM ROOM ≥131'
IVNR5003A,B *	Instrument Cables			MN, STM ROOM ≥131'
IVBL5005C	Control Cable			MN, STM ROOM ≥131'
IVBQ5011B	Control Cable			MN, STM ROOM ≥131'
IVQKJ183C,D,G,H	Control Cables			MN, STM ROOM ≥131'

029931167

MASTER LIST

CC60650

Section C.2.15
Sheet 27

Joseph M. Farley Nuclear Plant Unit 1

ICLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: MAIN FEEDWATER AND CONDENSATE

M-21

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				SLDG.	ELEV.
QIN21V001A-B (MOV3232A)	14" Motor Operated Stop-Check Globe V1	Limiterque	SMB-4T	Mn. Sdm. Room	> 131'
QIN21V001B-B (MOV3232B)	14" Motor Operated Stop-Check Globe V1	Limiterque	SMB-4T	Mn. Sdm. Room	> 131'
QIN21V001C-B (MOV3232C)	14" Motor Operated Stop-Check Globe V1	Limiterque	SMB-4T	Mn. Sdm. Room	> 131'
QIN21LSH2828A	Level Switch	Gems	LS-36497	Mn. Sdm. Room	127' - 6"
QIN21LSH2828B	Level Switch	Gems	LS36487	Mn. Sdm. Room	127' - 6"
QIN21LSH2828C	Level Switch	Gems	LS-36497	Mn. Sdm. Room	127' - 6"
QIN21LSH2829A	Level Switch	Gems	LS-36497	Mn. Sdm. Room	127' - 6"
QIN21LSH2829B	Level Switch	Gems	LS-36497	Mn. Sdm. Room	127' - 6"
QIN21LSH2829C	Level Switch	Gems	LS-36497	Mn. Sdm. Room	127' - 6"
LIB034	Terminal Block	States Co.	Type ZWM	Mn. Sdm. Room	> 131'
IVALS120A,B,C,D	Control Cable			Mn. Sdm. Room	> 131'
IYBL5292A, B, C	Control Cable			Mn. Sdm. Room	> 131'
IYBFV-K20	Power Cable			Mn. Sdm. Room	> 131'
IYBFV-K30	Power Cable			Mn. Sdm. Room	> 131'
IYBFV-L20	Power Cable			Mn. Sdm. Room	> 131'
IYBFV-K2A	Control Cable			Mn. Sdm. Room	> 131'
IYBFV-K3A	Control Cable			Mn. Sdm. Room	> 131'
IYBFV-L2A	Control Cable			Mn. Sdm. Room	> 131'

MASTER LIST

0060651

Section C.2.16
Sheet 28

Joseph M. Farley Nuclear Plant Unit 1

(ICLASS IE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: AUXILIARY FEEDWATER

N-23

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION ELEV.
QIN23V011A (MOV3350A)	4" Motor Operated Stop-Check Globe VI	Limitorque	SMB-1	Mn. Stm Room Z 131'
QIN23V011B (MOV3350B)	4" Motor Operated Stop-Check Globe VI	Limitorque	SMB-1	Mn. Stm Room Z 131'
QIN23V011C (MOV3350C)	4" Motor Operated Stop-Check Globe VI	Limitorque	SMB-1	Mn. Stm Room Z 131'
QIN23ZS322BA (HV3228A)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV322BAA (HV3228A)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23ZS322BB (HV3228B)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV322BBA (HV3228B)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23ZS322BC (HV3228C)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV322BCA (HV3228C)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23ZS3227A (HV3227A)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV3227AA (HV3227A)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23ZS3227B (HV3227B)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV3227BA (HV3227B)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23ZS3227C (HV3227C)	Limit Switch	NAMCO	EA-180	Mn. Stm Room Z 131'
QIN23SV3227CA (HV3227C)	Solenoid Valve	ASCO	NP8320A196E	Mn. Stm Room Z 131'
QIN23SV3228AA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
QIN23SV3228BA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
QIN23SV3228BCA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
QIN23SV3227AA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
QIN23SV3227BA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
QIN23SV3227CA-A/JB	Terminal Block	States Co.	Type ZWM	Mn. Stm Room Z 131'
IVAFU-U-Q	Power Cable			Mn. Stm Room Z 131'
IVAFU-U3Q	Power Cable			Mn. Stm Room Z 131'
IVAFU-T2Q	Power Cable			Mn. Stm Room Z 131'
IVAFU-U4A, D	Control Cables			Mn. Stm Room Z 131'

MASTER LIST

0060652

Joseph M. Farley Nuclear Plant Unit 1Section C.2.16
Sheet 29

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: AUXILIARY FEEDWATER

N-23

COMPONENTS				LOCATION
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	BLDG. ELEV.
1VAFU-USA, D	Control Cables			Mn. Stm Room > 131'
1VAFU-I2A, D	Control Cables			Mn. Stm Room > 131'
1VAL5007B	Control Cable			Mn. Stm Room > 131'
1VAL5008B	Control Cable			Mn. Stm Room > 131'
1VAL5009B	Control Cable			Mn. Stm Room > 131'
1VAL5007C	Instrument Cable			Mn. Stm Room > 131'
1VAL5008C	Instrument Cable			Mn. Stm Room > 131'
1VAL5009C	Instrument Cable			Mn. Stm Room > 131'
1VAQ5010E, K	Control Cables			Mn. Stm Room > 131'
1VAQ5012E, K	Control Cables			Mn. Stm Room > 131'
1VAQ5014E, K	Control Cables			Mn. Stm Room > 131'
1VXR5007K, L, M	Control Cables			Mn. Stm Room > 131'
1VAL5013C	Control Cable			Mn. Stm Room > 131'
1VAL5014C	Control Cable			Mn. Stm Room > 131'
1VAL5015C	Control Cable			Mn. Stm Room > 131'
1VAL5013D	Instrument Cable			Mn. Stm Room > 131'
1VAL5014D	Instrument Cable			Mn. Stm Room > 131'
1VAL5015D	Instrument Cable			Mn. Stm Room > 131'
1VAQ5048H, K	Control Cables			Mn. Stm Room > 131'
1VAQ5006C, H	Control Cables			Mn. Stm Room > 131'
1VAQ5008C, H	Control Cables			Mn. Stm Room > 131'
1VXR5007G, H, J	Control Cables			Mn. Stm Room > 131'

MASTER LIST

0060653
Section C.2.17
Sheet 30

Joseph M. Farley Nuclear Plant Unit 1

CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: CHEMICAL INJECTION SYSTEM

- 2 -

COMPONENTS				LOCATION
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	ELEV.
QIN258V3772A (HV3772A)	Solenoid Valve	ASCO	NP8316A74V	Mn. Stb. Room ➤ 131'
Q1M25283772A (HV3772A)	Limit Switch	NAMCO	EA-180	Mn. Stb. Room ➤ 131'
QIN258V3772B (HV3772B)	Solenoid Valve	ASCO	NP8316A74V	Mn. Stb. Room ➤ 131'
Q1M25283772B (HV3772B)	Limit Switch	NAMCO	EA-180	Mn. Stb. Room ➤ 131'
QIN258V3772C (HV3772C)	Solenoid Valve	ASCO	NP8316A74V	Mn. Stb. Room ➤ 131'
Q1N25283772C (HV3772C)	Limit Switch	NAMCO	EA-180	Mn. Stb. Room ➤ 131'
Q1N258V3772A-A/JB	Terminal Block	States Co.	Type ZHM	Mn. Stb. Room ➤ 131'
Q1N258V3772B-A/JB	Terminal Block	States Co.	Type ZHM	Mn. Stb. Room ➤ 131'
Q1N258V3772C-A/JB	Terminal Block	States Co.	Type ZHM	Mn. Stb. Room ➤ 131'
IVAL5075A	Control Cable			Mn. Stb. Room ➤ 131'
IVAL5077A	Control Cable			Mn. Stb. Room ➤ 131'
IVAL5078A	Control Cable			Mn. Stb. Room ➤ 131'
IQAQ5030E	Control Cable			Mn. Stb. Room ➤ 131'
IQAQ5031E	Control Cable			Mn. Stb. Room ➤ 131'
IQAQ5032E	Control Cable			Mn. Stb. Room ➤ 131'
IUXRS5008G, H, J	Control Cable			Mn. Stb. Room ➤ 131'

MASTER LIST

0060654

Joseph M. Farley Nuclear Plant Unit 1Section C 2.18
Sheet 31

(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: SAMPLING SYSTEM

P-13

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				LOCATION	BLDG.
Q1P155V3103 (HV3103)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3103 (HV3103)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3765 (HV3765)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3765 (HV3765)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3766 (HV3766)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3766 (HV3766)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3179A (HV3179A)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3179A (HV3179A)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3179B (HV3179B)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3179B (HV3179B)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3179C (HV3179C)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3179C (HV3179C)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3180A (HV3180A)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3180A (HV3180A)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3180B (HV3180B)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3180B (HV3180B)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3180C (HV3180C)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3180C (HV3180C)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3181A (HV3181A)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3181A (HV3181A)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3181B (HV3181B)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3181B (HV3181B)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3181C (HV3181C)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"
Q1P152S3181C (HV3181C)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1P155V3184 (HV3184)	Solenoid Valve	ASCO	NPB320A184V	CTMT	129'-0"

MASTER LIST

0060655

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.18
Sheet 22

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: SAMPLING SYSTEM

P-15

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				LOCATION	
				BLDG.	ELEV.
Q1P152B3104 (HV3104)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1P15SV3101-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3765-A/JB	Terminal Block	States Co., General Electric	Type ZWM	CTMT	131'-9"
Q1T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1P15SV3766-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3179A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3179B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3179C-B/JB	Terminal Block	States Co., General Electric	Type ZWM	CTMT	131'-9"
Q1T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1P15SV3180A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3180B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3180C-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3181A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3181B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3181C-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
Q1P15SV3104-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	131'-9"
IVAL5063B	Control Cable			CTMT	>115'
IVAQ5049H	Control Cable			CTMT	>115'
IVXR50108	Control Cable			CTMT	>115'
IVAL5063B	Control Cable			CTMT	>115'
IVAQ5032J	Control Cable			CTMT	>115'
IVXR5010F	Control Cable			CTMT	>115'
IVAL5066A	Control Cable			CTMT	>115'
IVAQ5033J	Control Cable			CTMT	>115'

MASTER LIST

0000856

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.18
Shares 33

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POTENTIALLY ACCIDENT-PRONE)

SYSTEM: SAMPLING SYSTEM

P-15

MASTER LIST

0060657

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.19
Sheet 24

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: SERVICE WATER

P-16

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				BLDG.	ELEV.
Q1P16V207A (MOV3441A)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-6"
Q1P16V207B (MOV3441B)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-6"
Q1P16V207C (MOV3441C)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	122'-6"
Q1P16V207D (MOV3441D)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	122'-6"
Q1P16V081 (MOV2131)	6" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-6"
Q1T52B005	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B015	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B014	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
1VBFV-J4Q	Power Cable			CTMT	>115'
1VBFV-J4D	Control Cable			CTMT	>115'
1VB05007D	Control Cable			CTMT	>115'
1VYR400AB,D	Control Cables			CTMT	>115'
1VYKB164B,C	Control Cables			CTMT	>115'
1VBFV-J5Q	Power Cable			CTMT	>115'
1VBFV-J5D	Control Cable			CTMT	>115'
1VB05009D	Control Cable			CTMT	>115'
1VAFU-K5Q	Power Cable			CTMT	>115'
1VAFU-K5D	Control Cable			CTMT	>115'
1VAQ5007D	Control Cable			CTMT	>115'
1VYR400AB,D,F	Control Cables			CTMT	>115'
1VYKB164B,C	Control Cables			CTMT	>115'
1VAFU-W2Q	Power Cable			CTMT	>115'

0060658

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1

Section C.2.19
Sheet 35

(CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM — SERVICE WATER

P. 6

0060659

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 1Section C.2.20
Sheet 26

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: COMPONENT COOLING WATER

P-17

COMPONENTS					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				BLDG	FLEV.
Q1P17V097 (MOV3046)	6" Motor Operated Gate Valve	Limitercuse	SMB-00	CTMT	130'-6"
Q1P17SV3184 (HV3184)	Solenoid Valve	ASCO	NPS316A76V	CTMT	122'-6"
Q1P172S3184 (HV3184)	Limit Switch	NAMCO	EA-180	CTMT	122'-6"
Q1P17SV3443 (HV3443)	Solenoid Valve	ASCO	NPS316A74V	CTMT	129'-0"
Q1P172S3443 (HV3443)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q1T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1P17SV2184-B/JB	Terminal Block	States Co.	Type ZWH	CTMT	>115'-0"
Q1T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1T52B041	Penetration	General Electric	100 Series	CTMT	143'-0"
Q1P17SV3443-A/JB	Terminal Block	States Co.	Type ZWH	CTMT	>115'-0"
1VBFV-C3Q	Power Cable			CTMT	>115'
1VBFV-C3D	Control Cable			CTMT	>115'
1VBQ5017C	Control Cable			CTMT	>115'
1VYR5006F	Control Cable			CTMT	>115'
1VBL5009C,P,E,F	Control Cables			CTMT	>115'
1VBQ5017H	Control Cable			CTMT	>115'
1VYR5035B	Control Cable			CTMT	>115'
1VAL5055C	Control Cable			CTMT	>115'
1VA05029H	Control Cable			CTMT	>115'
1VYR5064F	Control Cable			CTMT	>115'

0060660

APPENDIX II

MASTER LIST OF ENVIRONMENTAL QUALIFIED EQUIPMENT
UNIT 2

0 2 9 9 3 1 7 7 8

029931779

LIST OF EFFECTIVE PAGES

0060661

PAGE NO.	REVISION NO.										
	0	1	2	3	4	5	6	7	8	9	10
1	X										
2	X										
3	X										
4	X										
5	X										
6	X										
7	X										
8	X										
9	X										
10	X										
11	X										
12	X										
13	X										
14	X										
15	X										
16	X										
17	X										
18	X										
19	X										
20	X										
21	X										
22	X										
23	X										
24	X										
25	X										

LIST OF EFFECTIVE PAGES

0060662

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.1
Sheet 1

0060663

(CLASS I ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: REACTOR COOLANT INSTRUMENTATION

8-13

0060664

MASTER LIST

△ New Sheet
 Section 2
 Sheet 2

Joseph M. Farley Nuclear Plant Unit 2

(CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
 SYSTEM: Reactor Coolant System (Head Vane)

NUREG-0737, II.B.1

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
Q2B13SV2213A	Solenoid Valve	Target	79AB001	CTMT >115'-0"
Q2B13SV2213B	Solenoid Valve	Target	79AB001	CTMT >115'-0"
Q2B13SV2214A	Solenoid Valve	Target	79AB001	CTMT >115'-0"
Q2B13SV2214B	Solenoid Valve	Target	79AB001	CTMT >115'-0"
Q2T52B014-A	Control Penetration	General Electric	100 Series	CTMT >115'-0"
2VAL5145B	Control Cable			CTMT >115'-0"
2VAL5145C	Control Cable			CTMT >115'-0"
A2TB007	Terminal Block	States	Type ZWM	CTMT >115'-0"
Q2B13SV2213A-JB	Terminal Block	States	Type ZWM	CTMT >115'-0"
2VAL5146B	Control Cable			CTMT >115'-0"
2VAL5146C	Control Cable			CTMT >115'-0"
Q2B13SV2214A-JB	Terminal Block	States	Type ZWM	CTMT >115'-0"
Q2T52B016-B	Control Penetration	General Electric	100 Series	CTMT >115'-0"
2VEL5145B	Control Cable			CTMT >115'-0"
2VEL5145C	Control Cable			CTMT >115'-0"
*****	Terminal Block	States	Type ZWM	CTMT >115'-0"
Q2B13SV2213B-JB	Terminal Block	States	Type ZWM	CTMT >115'-0"
2VEL5146B	Control Cable			CTMT >115'-0"
2VEL5146C	Control Cable			CTMT >115'-0"
Q2B13SV2214B-JB	Terminal Block	States	Type ZWM	CTMT >115'-0"

0060665

MASTER LIST

△ New Sheet
Section 4
Sheet 2

Joseph M. Farley Nuclear Plant Unit 2

(CLASS I E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: B13/B31 PRESENT Safety Valve Position Indication NUREG-0737, II.D.3

COPIES/VENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION BLDG. ELEV.
2VYKH174A	Cable			CTMT >115'-0"
Q2B130001-B	Terminal Box	EINSTEIN COMPANY	Type ZWM	CTMT >115'-0"
2VBL50990	Cable			CTMT >115'-0"
2VBL5099H	Cable			CTMT >115'-0"
2VBL5099J	Cable			CTMT >115'-0"
Q2T52N025-B	Cont. Penet.	General Electric	100 Series	CTMT >115'-0"
Q2T52E022-B	Cont. Penet.	General Electric	100 Series	CTMT >115'-0"
Q2B13252034	Position switch	NAMCO	EA-180	CTMT >115'-0"
Q2B13252035	Position switch	NAMCO	EA-180	CTMT >115'-0"
Q2B13252036	Position switch	NAMCO	EA-180	CTMT >115'-0"
N2B312504/4B	Limit switch	NAMCO	EA-180	CTMT >115'-0"
N2B3125044SA	Limit switch	NAMCO	EA-180	CTMT >115'-0"
N2B315V044BA-B/JB	Junction Box	States Company	Type ZWM	CTMT >115'-0"
N2B315V044SAA-A/JB	Junction Box	States Company	Type ZWM	CTMT >115'-0"
Q2T52B019-A	Control Penetr.	General Electric	100 Series	CTMT >115'-0"
Q2T52B038-B	Control Penetr.	General Electric	100 Series	CTMT >115'-0"
2VAL5025D	Control Cable			CTMT >115'-0"
2VBL5020D	Control Cable			CTMT >115'-0"
QAT352B007A	Control Penetr.	General Electric	100 Series	CTMT >115'-0"
2VYKH174A	Cable			CTMT >115'-0"

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.2
Sheet 4

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM REACTOR COOLANT SYSTEM - STEAM GENERATOR

B-21

0060606

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				BLDG	ELEV
N2B21PT402	Press. Transmitter	Barton	763	CTMT	116'-0"
N2B21PT403	Press. Transmitter	Barton	763	CTMT	116'-0"
N2B21TE410	RTD	Rosemount	176KS	CTMT	122'-9"
N2B21TE413	RTD	Rosemount	176KS	CTMT	122'-9"
N2B21TE420	RTD	Rosemount	176KS	CTMT	122'-9"
N2B21TE423	RTD	Rosemount	176KS	CTMT	122'-9"
N2B21TE430	RTD	Rosemount	176KS	CTMT	122'-9"
N2B21TE433	RTD	Rosemount	176KS	CTMT	122'-9"
Q2T52B040	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B012	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B030	Penetration	General Electric	100 Series	CTMT	143'-0"
12TB001	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
12TB003	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
12TB004	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
22TB001	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
22TB002	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
22TB003	Terminal Block	States Co.	Type ZWM	CTMT	122'-9"
2V1V50031E	Instr. Cables			CTMT	122'-9"
2V1V50032E	Instr. Cables			CTMT	122'-9"
2V1V5002E, F, G	Instr. Cables			CTMT	122'-9"
2V2V5002E, F, G	Instr. Cables			CTMT	122'-9"

0 0 2 9 9 3 1 7 8 5

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

Section C.2.3
Sheet 5

ICLASE II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM REACTOR COOLANT SYSTEM - PRESSURIZER

1-31

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				LOCATION	BLDG
Q2B315VB047 (HVB047)	Solenoid Valve	ASCO	NP831654E	CTMT	118'-0"
N2B312B047 (HVB047)	Limit Switch	NAMCO	EA-180	CTMT	118'-0"
Q2T52B002	Penetration	General Electric	100 Series	CTMT	147'-0"
Q2T52B028	Penetration	General Electric	100 Series	CTMT	147'-0"
N2B315VB047-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	118'-0"
Q2B31LT459	Level Transmitter	Barton	764	CTMT	116'-0"
Q2B31LT460	Level Transmitter	Barton	764	CTMT	116'-0"
Q2B31LT461	Level Transmitter	Barton	764	CTMT	116'-0"
Q2B31PT455	Pressure Transmitter	Barton	763 1"	CTMT	116'-0"
Q2B31PT456	Pressure Transmitter	Barton	763 1"	CTMT	116'-0"
Q2B31PT457	Pressure Transmitter	Barton	763 1"	CTMT	116'-0"
ZVBL50780	Control Cable				116'-0"
ZVBC5021E	Control Cable				6 above
					116'-0"
Q2T52B012	Penetration	General Electric	100 Series	CTMT	147'-0"
Q2T52B028	Penetration	General Electric	100 Series	CTMT	147'-0"
Q2T52B030	Penetration	General Electric	100 Series	CTMT	147'-0"
Q2T52B040	Penetration	General Electric	100 Series	CTMT	147'-0"
ZVYV5031D	Instr. Cable				116'-0"
ZV1V5002U	Instr. Cable				6 above
ZV2V5002T, U	Instr. Cables				116'-0"
ZV3V5002T, U	Instr. Cables				6 above
					116'-0"
					6 above

Joseph M. Farley Nuclear Plant Units 2

MASTER LIST

△ New Sheet
Section 3
Sheet 6

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS
SYSTEM: B31- Pressurizer Relief and Safety Valves NUREG-0737, II.D.1 DDC-200

Joseph M. Farley Nuclear Plant Unit

MASTER LIST

Section C.2.6
Sheet 7EQUIPMENT LISTED IS ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS:
SYSTEM: FILTRATION CONTROL SYSTEM

C-22

0060003

1/87
1-
M
9
0
2
0

PLANT ID NUMBER (FCV478)	GENERIC NAME	COMPONENTS		LOCATION
		MANUFACTURER	MODEL	
N2C225V0478A (FCV478)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478A (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478B (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478B (FCV478)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478B (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478B (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478B (FCV478)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478B (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478B (FCV478)	Solenoid Valve	ASCO	HV-206-381-2RU	AUX. Bldg.
N2C225V0478A (FCV479)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478A (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478B (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478B (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478A (FCV479)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478B (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478B (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478A (FCV479)	Limit Switch	NAMECO	EA-180	AUX. Bldg.
N2C225V0478A (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478B (FCV479)	Solenoid Valve	ASCO	HV-206-381-4U	AUX. Bldg.
N2C225V0478A-A/JB	Terminal Block	States Co.	Type ZVM	AUX. Bldg.
N2C225V0478A-A/JB	Terminal Block	States Co.	Type ZVM	AUX. Bldg.
N2C225V0478A-A/JB	Terminal Block	States Co.	Type ZVM	AUX. Bldg.
2VAL5060B	Control Cable			AUX. Bldg.
2VBL4025B	Control Cable			AUX. Bldg.
2VBL5071A	Control Cable			AUX. Bldg.

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

SECTION C.2.6
Sheet 4ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS:
SYSTEM FEEDWATER CONTROL SYSTEM

C-22

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		022993178
				LOCATION	ITEM	
2VAL50610	Control Cable			BLDG	F11V	
2VB15034C, D	Control Cables			AUX.		
2VX15072B	Control Cable			Aux., Bldg.	121'-0"	
2VAL50628	Control Cable			AUX., Bldg.	121'-0"	
2VB15035B, D	Control Cables			AUX., Bldg.	121'-0"	
2VX15073A	Control Cable			AUX., Bldg.	121'-0"	
Q2C22LT474	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT475	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT476	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT484	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT485	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT486	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT494	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT495	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22LT496	Level Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT474	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT475	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT484	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT485	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT494	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2C22FT495	Flow Transmitter	Barton	764	CTMT	121'-0"	
Q2T52B010	Penetration	General Electric	100 Series	CTMT	121'-0"	
Q2T52B012	Penetration	General Electric	100 Series	CTMT	121'-0"	
Q2T52B028	Penetration	General Electric	100 Series	CTMT	121'-0"	
Q2T52B030	Penetration	General Electric	100 Series	CTMT	121'-0"	

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.4
Sheet 9

CLASS 1B ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS
SYSTEM: FEEDWATER CONTROL SYSTEM

C-72

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

△ New Sheet
Section 5
Sheet 10

(CLASS I) ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS:
SYSTEM: D21 - High Range Containment Radiation; NUREG-0737, II.F.1.3

MASTER LIST

Joseph M. Farley Nuclear Plant Unit _____

△ New Sheet
Section 7
Sheet 11

0060673

(CLASSE I ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)
SYSTEM: G-21 Liquid Waste Disposal (Narrow Range Containment Pump Level) HUREG-0737

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.5
Sheet 12 of

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER PORTHOLE ATTEMPTED APPROXIMATELY

SYSTEM — SAFEGUARD SYSTEMS, INC./LURE

3-11

0060674

Joseph M. Farley Nuclear Plant Unit 3

MASTER LIST

SECTION C.2.6
Sheet 3

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

ITEM CONTAINMENT COOLING AND PURGE

E-12, E-14, F-13

0060675

COMPONENTS					LOCATION
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	ELDG	FLEX
Q2E16V002 (MOV3660)	1" Motor Operated Globe Valve	Limitotrol	EMB-000	CTMT	134'-6"
Q2I14V004 (MOV33100)	1" Motor Operated Globe Valve	Limitotrol	EMB-000	CTMT	116'-0"
DELETED -					
Q2P13283196 (HV3196)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q2P138V2867A (HV2867)	Solenoid Valve	ASCO	NPB31654V	CTMT	129'-0"
Q2P13752867D (HV2867)	Limit Switch	NAMCO	EA-740	CTMT	129'-0"
DELETED -					
Q2P13283197 (HV3197)	Limit Switch	NAMCO	EA-180	CTMT	129'-0"
Q2P138V2866B (HV2866)	Solenoid Valve	ASCO	NPB31654V	CTMT	129'-0"
Q2P132828666D (HV2866)	Limit Switch	NAMCO	EA-740	CTMT	129'-0"
Q2E12283999A (HV3999A)	Solenoid Valve	ASCO	NPB316A74E	CTMT	89'-4"
Q2E12283999A (HV3999A)	Limit Switch	NAMCO	EA-180	CTMT	89'-4"
Q2E1228V3999B (HV3999B)	Solenoid Valve	ASCO	NPB316A74E	CTMT	91'-4"
Q2E12283999B (HV3999B)	Limit Switch	NAMCO	EA-180	CTMT	91'-4"
Q2E12M001A (M001A)	CTMT Clr. Fan Motor	Joy Mfr. Co.	Type P	CTMT	155'-0"
Q2E12M001B (M001B)	CTMT Clr. Fan Motor	Joy Mfr. Co.	Type P	CTMT	155'-0"
Q2E12M001C (M001C)	CTMT Clr. Fan Motor	Joy Mfr. Co.	Type P	CTMT	155'-0"
Q2E12M001D (M001D)	CTMT Clr. Fan Motor	Joy Mfr. Co.	Type P	CTMT	155'-0"
Q2T52B005	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B002	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B006	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B041	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"

MASTER LIST

Section C.2.6
Sheet 14

Joseph M. Farley Nuclear Plant Unit 2

(CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CONTAINMENT COOLING AND FUSION

E-12, E-14, E-13

00603-75

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				BLDG	ELEV
Q2P135V3196-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	129'-0"
Q2T52B022	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P135V2867B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	129'-0"
Q2P135V3197-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	129'-0"
Q2P135V2866B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	129'-0"
Q2E125V3999A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	118'
Q2T52B025	Terminal Block	States Co.	Type ZWM	CTMT	118'
Q2E125V3999B-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	118'
Q2T52B001	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B023	Penetration	General Electric	100 Series	CTMT	143'
2VATU-R50	Power Cable			CTMT	Varies
2VATU-R55	Control Cable			CTMT	Varies
2VAQ504BT	Control Cable			CTMT	Varies
2VXR5005H	Control Cable			CTMT	Varies
2VATU-J40	Power Cable			CTMT	Varies
2VATU-J40	Control Cable			CTMT	Varies
2VAQ5009C	Control Cable			CTMT	Varies
2VYR5066B	Instrument Cable			CTMT	Varies
2VBL5008C,D,E,I	Control Cables			CTMT	Varies
2VBC5010J	Control Cable			CTMT	Varies
2VYR5035D	Control Cable			CTMT	Varies
2VBL5008X,W	Control Cables			CTMT	Varies
2VBC5012F	Control Cable			CTMT	Varies
2VYR5035F	Control Cable			CTMT	Varies
2VAL5122C	Control Cable			CTMT	Varies

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.6
Sheet 15 of

(C) CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: CONTAINMENT COOLING AND FUSSE

$T = 32$, $E = 14$, $\theta = 12$

0060677

CE D-1374 1/80

MASTER LIST

Section 5.2.7
Sheet 16

Joseph M. Farley Nuclear Plant Unit 2

SC 1.16 ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: HYDROGEN RECOMBINATION SYSTEM

-17-

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.8
Sheet 17 of _____

(CLASSE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER ANY

SYSTEM: CONTAINMENT POST LOGA AIR MIXING SYSTEM

- 2 - 19

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.9
Sheet 1A

0060680

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS
ITEM: CHEMICAL AND VOLUME CONTROL/FAULT INJECTION

E-21

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				EL20	EL47
Q2E21V038A (H0V8058A)	12" Motor Operated Gate Valve	LIMITORQUE	SLB-4	CTMT	111'-6"
Q2E21V038B (H0V8058B)	12" Motor Operated Gate Valve	LIMITORQUE	SLB-4	CTMT	112'-6"
Q2E21V038C (H0V8058C)	12" Motor Operated Gate Valve	LIMITORQUE	SLB-4	CTMT	112'-6"
Q2E21SV8871 (HV8871)	Solenoid Valve	ASCO	WP831654V	CTMT	122'-0"
Q2E21Z8871 (HV8871)	Limit Switch	NAMCO	EA-180	CTMT	122'-0"
Q2E21V249A (HV8112)	3" Motor Operated Gate Valve	LIMITORQUE	SLB-30	CTMT	122'
N2E21Z88149A (HV8149A)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q2E21SV8149AB (HV8149A)	Solenoid Valve	ASCO	WP831654V	CTMT	111'-0"
N2E21Z88149B (HV8149B)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q2E21SV8149BB (HV8149B)	Solenoid Valve	ASCO	WP831654V	CTMT	111'-0"
N2E21Z88149C (HV8149C)	Limit Switch	NAMCO	EA-180	CTMT	111'-0"
Q2E21SV8149CB (HV8149C)	Solenoid Valve	ASCO	WP831654V	CTMT	111'-0"
Q2T52B002	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B006	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
N2E21SV8871-A/JB	Junction Box	States Co.	Type ZWM	CTMT	143'-0"
Q2E21Z8808AB	Limit Switch	NAMCO	EA-180	CTMT	111'-6"
Q2E21Z8808BB	Limit Switch	NAMCO	EA-180	CTMT	112'-6"
Q2E21Z8808CB	Limit Switch	NAMCO	EA-180	CTMT	112'-6"
Q2T52B014	Penetration	General Electric	100 Series	CTMT	143'-0"
N2E21SV8149AA-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	116'-0"
N2E21SV8149BA-A/JB	Terminal Box	States Co.	Type ZWM	CTMT	116'-0"

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2Section C 2.9
Sheet 19 of _____

(CLASS IE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CHEMICAL AND VOLUME CONTROL/SAFETY INJECTION

E-21

1990900

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
N2E21BV8149CA-A/JB	Terminal Block	States Co.	Type ZVM	FLDG 116'-0" 6 above
2VAFU-Z2Q	Power Cable			CTMT Varies
2VAFU-Z2D, G	Control Cables			CTMT Varies
2VAQ5023E	Control Cable			CTMT "varies
2VOKA163B	Control Cable			CTMT Varies
2VBPFV-S2Q	Power Cable			CTMT Varies
2VBPFV-S2D, G	Control Cables			CTMT Varies
2VBQ5024C	Control Cable			CTMT Varies
2VYKA161B	Control Cable			CTMT Varies
2VAFU-Z3Q	Power Cable			CTMT Varies
2VAFU-Z3D, G	Control Cables			CTMT Varies
2VAQ5024E	Control Cable			CTMT Varies
2VXA163D	Control Cable			CTMT Varies
2VAL5049C	Control Cable			CTMT Varies
2VAQ5022H	Control Cable			CTMT Varies
2VAFU-T4Q	Power Cable			CTMT Varies
2VAFU-T4D	Control Cable			CTMT Varies
2VAQ5018E	Control Cable			CTMT Varies
2VAL5042F	Control Cable			CTMT Varies
2VAL5042G	Control Cable			CTMT Varies
2VAQ5022F	Control Cable			CTMT Varies
2VAL5043F	Control Cable			CTMT Varies
2VAL5043G	Control Cable			CTMT Varies
2VAQ5023C	Control Cable			CTMT Varies
2VAL50447	Control Cable			CTMT Varies

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

Section C.2.9
Sheet 20 of

(C) CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM: CHEMICAL AND VOLUME CONTROL/SAFETY INJECTION

1-21

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

Section C.2.10
Sheet 21 of

(CLASSES OF ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

REACTOR CAVITY POST LOCA DILUTION SYSTEM

1-22

JOSEPH M. FARLEY NUCLEAR PLANT UNIT 2

MASTER LIST

0060684

Section C.2,
Sheet 22

ICLASS 1B ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITION
SYSTEM: POST ACCIDENT CONTAINMENT COMBUSTIBLE GAS CONTROL

R-23

PLANT ID NUMBER	GENERIC NAME	COMPONENTS	MANUFACTURER	MODEL	LOCATION
Q2E23V021 (MOV3536)	2" Motor Operated Globe Valve	Limitorsube	SMB-00	BLDG FL	CTMT 116'-0"
Q2E23V003 (MOV3530)	6" Motor Operated Globe Valve	Limitorsube	SMB-00	CTMT	120'-0"
Q2E23V022A (MOV3528A)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2E23V002B (MOV3528B)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2E23V022C (MOV3528C)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2E23V022D (MOV3528D)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2E23V025A (MOV3835A)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2E23V025B (MOV3835B)	3/4" Motor Operated Globe Valve	Limitorsube	SMB-000	CTMT	126'-6"
Q2T52B005	Penetration	Limitorsube	SMB-000	CTMT	126'-6"
Q2T52B017	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B015	Penetration	General Electric	100 Series	CTMT	143'-0"
2VAPU-W40	Power Cable	1" Rise	CTMT	143'-0"	
2VAPU-N20	Power Cable	CTMT	143'-0"		
2VAPU-W40	Power Cable	CTMT	5 above		
2VAPD06F	Control Cable	CTMT	5 above		
2VBPFV-N20	Control Cable	CTMT	5 above		
2VBEEZ09F	Control Cable	CTMT	5 above		
2VBPFV-Y30	Control Cable	CTMT	5 above		
2VBPFV-Y30	Power Cable	CTMT	5 above		
2VBPFV-Y40	Control Cable	CTMT	5 above		
	Power Cable	CTMT	5 above		

MASTER LIST

0060085 Section C.2.11
Sheet 22 of

Joseph M. Farley Nuclear Plant Unit 2

(CLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS)

SYSTEM POST ACCIDENT CONTAINMENT COMBUSTIBLE GAS CONTROL

X-23

PLANT NO. NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				BLDG	ELEV
Q2E23V021 OM0V3536	3" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	116'-6"
Q2E23V003 OM0V3530	6" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	120'-6"
Q2E23V022A (MOV3528A)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2E23V002B (MOV3528B)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2E23V022C (MOV3528C)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2E23V022D (MOV3528D)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2E23V025A (MOV3625A)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2E23V025B (MOV3625B)	3/4" Motor Operated Globe Valve	Limitorque	SMB-000	CTMT	126'-6"
Q2T52B005	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B017	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B015	Penetration	General Electric	100 Series	CTMT	143'-0"
2VAFU-W40	Power Cable				116'-0"
2VBFU-N20	Power Cable				116'-0"
2VAFU-W40	Control Cable				6 above
2VAED06E	Control Cable				116'-0"
2VBZD09E	Control Cable				6 above
2VBZV-N20	Control Cable				116'-0"
2VBZV-Y50	Power Cable				6 above
2VBZV-Y50	Control Cable				116'-0"
2VBZV-Y40	Power Cable				6 above

002299933 1804

MASTER LIST 0060686

Joseph M. Farley Nuclear Plant Unit 2

Section C.2.11
Sheet 23 of

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: POST ACCIDENT CONTAINMENT COMBUSTIBLE GAS CONTROL

029931806
029920

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0060687 Section C.2.12
Sheet 24 of

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: LIQUID WASTE DISPOSAL SYSTEM

C-21

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	COMPONENTS		LOCATION
			ITEM	ELEV	
Q2G218V3376 (MV2376)	Solenoid Valve	ASCO	WF8316A74E	CTMT	109'-0"
Q2G21283376 (MV2376)	Limit Switch	MAMCO	EA-180	CTMT	109'-0"
M2G21281003 (LCV1003)	Limit Switch	MAMCO	EA-180	CTMT	110'-0"
M2G218V1003B (LCV1003)	Solenoid Valve	ASCO	206-381-6KJ	CTMT	110'-0"
Q2G218V7126 (MV7126)	Solenoid Valve	ASCO	WF8316A54E	CTMT	117'-0"
Q2G21287126 (MV7126)	Limit Switch	MAMCO	EA-180	CTMT	117'-0"
Q2T528028	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T528041	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2G218V3376-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	116'-0"
Q2T528019	Penetration	General Electric	100 Series	CTMT	143'-0"
M2G218V1003A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	116'-0"
M2G218V7126-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	116'-0"
ZVAL5045C	Control Cable			CTMT	6 above
ZVAL5030J	Control Cable			CTMT	6 above
ZVAL5066G	Instrument Cable			CTMT	6 above
ZVAL5037D	Control Cable			CTMT	6 above
ZVA05021J	Control Cable			CTMT	6 above
ZVAL5036C	Control Cable			CTMT	6 above
ZVA05020J	Control Cable			CTMT	>115'

029931807

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0060688

Section C.2. L2
Sheet 25

CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

ITEM: MAIN STREAM

W-11

PLANT ID NUMBER (HV)	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		LOCATION
				LDG	LLV	
Q2N11251169A (HV3369A)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1128V3369AC (HV3369A)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253369B (HV3369B)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1125V3369BC (HV3369B)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253369C (HV3369C)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1128V3369CC (HV3369C)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253370A (HV3370A)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1125V3370AC (HV3370A)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253370B (HV3370B)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1128V3370BC (HV3370B)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253370C (HV3370C)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	127'-5"	
DELETED						
Q2N1128V3370CC (HV3370C)	Solenoid Valve	ASCO	NP8316E16V	Mn. Stm Room	135'-0"	
Q2N11253368A (HV3368A)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	131'-7"	
Q2N1125V3368AA (HV3368A)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm Room	131'-7"	
Q2N11253368B (HV3368B)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	131'-7"	
Q2N1125V3368BA (HV3368B)	Solenoid Valve	ASCO	NP8321A1V	Mn. Stm Room	131'-7"	
Q2N11253368C (HV3368C)	Limit Switch	NAMCO	EA-180	Mn. Stm Room	131'-7"	
Q2N1125V3368CA (HV3368C)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm Room	131'-7"	
Q2N1125V3368DA (HV3368D)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm Room	131'-7"	

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0060689

Section C.2.13
Sheet 26

CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

ITEM: MAIN STREAM

B-11

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		LOCATION
				TYPE	ROOM	
Q2N11233976A (HV3976A)	Limit Switch	NAMCO	EA-180	Mn. Stm	131'-7"	BLDG ELEY
Q2N11233976B (HV3976B)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm	131'-7"	Room
Q2N11233976B (HV3976B)	Limit Switch	NAMCO	EA-180	Mn. Stm	131'-7"	Room
Q2N11233976C (HV3976C)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm	131'-7"	Room
Q2N11233976C (HV3976C)	Limit Switch	NAMCO	EA-180	Mn. Stm	131'-7"	Room
Q2N115V3369AA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	131'-0"	Room
Q2N115V3369BA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	131'-0"	Room
Q2N115V3369CA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	131'-0"	Room
Q2N115V3370AA-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3370BA-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3370CA-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3368AA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3368BA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3368CA-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3374A-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
Q2N115V3376C-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	137'-0"	Room
2VAL5019E, P	Control Cables			Mn. Stm	135'	Room
2VAL5045C	Control Cable			Mn. Stm	135'	Room & above
2VAQ5013A	Control Cable			Mn. Stm	135'	Room & above

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

Section C.2.13
Sheet 27 of

ICLASS IIE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: MATH STEAM

0000690

N-11

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		LOCATION
				BLDG	FLOOR	
2VAT0001C, D, E	Control Cable			Mn. Stm	127'-5"	
2VAL5020E, F	Control Cable			Room	6 above	
2VAL5046C	Control Cable			Mn. Stm	127'-5"	
2VAQ5015A	Control Cable			Room	6 above	
2VAL5021E, F	Control Cable			Mn. Stm	127'-5"	
2VAL5047C	Control Cable			Room	6 above	
2VBL5011C	Control Cable			Mn. Stm	127'-5"	
2VBL5011C	Control Cable			Room	6 above	
2VBL5011C	Control Cable			Mn. Stm	127'-5"	
2VBL5011C	Control Cable			Room	6 above	
2VB40000, G, H	Control Cable			Mn. Stm	127'-5"	
2VBL5011E, D	Control Cable			Room	6 above	
2VBL5022C	Control Cable			Mn. Stm	127'-5"	
2VBQ5015D	Control Cable			Room	6 above	
2VBL5012E, D	Control Cable			Mn. Stm	127'-5"	
2VBL5023C	Control Cable			Room	6 above	
2VBQ5017E	Control Cable			Mn. Stm	127'-5"	
2VAL5045B	Control Cable			Room	6 above	
2VAQ5012B	Control Cable			Mn. Stm	127'-5"	
2VXR5008A	Control Cable			Room	6 above	
2VAL5046B	Control Cable			Mn. Stm	127'-5"	
2VAQ5015B	Control Cable			Room	6 above	
2VXR5008B	Control Cable			Mn. Stm	127'-5"	
2VAL5047B	Control Cable			Room	6 above	
2VAQ5017B	Control Cable			Mn. Stm	127'-5"	

Joseph M. Farley Nuclear Plant, Unit 2

MASTER LIST

0060691

Section C.2.13
Sheet 25 of 25

ICLASS 12 ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

四一

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0060692

Section C.2.14
Sheet 29

RELAYS IN ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

ITEM: AUXILIARY STEAM

E-12

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS		LOCATION
				BLDG	FLOOR	
Q2N12SV3234A (HV3234A)	Solenoid Valve	ASCO	NP8320A186V	Mn. Stm		
Q2N122S3234A (HV3234A)	Limit Switch	NAMCO	EA-180	Room	135'-0"	
Q2N125V3234B (HV3234B)	Solenoid Valve	ASCO	NP8320A186V	Mn. Stm	134'-0"	
Q2N122S3234B (HV3234B)	Limit Switch	NAMCO	EA-180	Room	135'-0"	
Q2N125V3235A (HV3235A)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm	135'-0"	
Q2N122S3235A (HV3235A)	Limit Switch	NAMCO	EA-180	Room	134'-0"	
Q2N125V3235B (HV3235B)	Solenoid Valve	ASCO	NP8321A2V	Mn. Stm	140'-0"	
Q2N122S3235B (HV3235B)	Limit Switch	NAMCO	EA-180	Room	135'-0"	
Q2N125V3234A-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	135'-0"	
Q2N125V3234B-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	135'-0"	
Q2N125V3235A-A/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	135'-0"	
Q2N125V3235B-B/JB	Terminal Block	States Co.	Type FWM	Mn. Stm	135'-0"	
2VAL5003B	Control Cable			Mn. Stm	135'-0"	
2VAQ5011A	Control Cable			Mn. Stm	135'-0"	
2VTR5007F	Control Cable			Mn. Stm	135'-0"	
2VBL5007H	Control Cable			Mn. Stm	135'-0"	
2VRS5013B	Control Cable			Mn. Stm	135'-0"	
2VTR5033E	Control Cable			Mn. Stm	135'-0"	
2VAL5004C	Control Cable			Mn. Stm	135'-0"	
2VAQ5010D	Control Cable			Mn. Stm	135'-0"	
2VNR5003A, B	Instrument Cables			Mn. Stm	135'-0"	
2VBL5003C	Control Cable			Mn. Stm	135'-0"	
2VRS5011B	Control Cable			Mn. Stm	135'-0"	
2VTRJ183C, D, E, F	Control Cables			Mn. Stm	135'-0"	

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

006069 Section F.2.15
Sheet 30 of

(C) CLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

YATIM MAIN FEEDWATER AND COMPENSATE

N. 93

0060694

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

Section C.2.16
Sheet 31ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS
ITEM AUXILIARY FEEDWATER

I-23

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
				FLOOR	STORY
Q2N23V001LA (MOV3350A)	4" Motor Operated Flow-Check Globe V1	LIMITEUR	SMR-1	Mn. Stm	137'-5"
Q2N23V001B (MOV3350B)	4" Motor Operated Flow-Check Globe V1	LIMITEUR	SMR-1	Mn. Stm	137'-5"
Q2N23V001C (MOV3350C)	4" Motor Operated Flow-Check Globe V1	LIMITEUR	SMR-1	Mn. Stm	137'-5"
Q2N23S3228A (HV3228A)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3228AA (HV3228A)	Solenoid Valve	ASCO	NP8320A163V	Mn. Stm	135'-0"
Q2N23S3228B (HV3228B)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3228BAA (HV3228B)	Solenoid Valve	ASCO	NP8320A166V	Mn. Stm	135'-0"
Q2N23S3228BC (HV3228C)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3228BCA (HV3228C)	Solenoid Valve	ASCO	NP8320A168V	Mn. Stm	135'-0"
Q2N23S3227A (HV3227A)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3227AA (HV3227A)	Solenoid Valve	ASCO	NP8320A168V	Mn. Stm	135'-0"
Q2N23S3227B (HV3227B)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3227BA (HV3227B)	Solenoid Valve	ASCO	NP8320A168V	Mn. Stm	135'-0"
Q2N23S3227C (HV3227C)	Limit Switch	NAMCO	EA-180	Mn. Stm	135'-0"
Q2N23S3227CA (HV3227C)	Solenoid Valve	ASCO	NP8320A168V	Mn. Stm	135'-0"
Q2N23S3228AA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
Q2N23S3228BA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
Q2N23S3228CA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
Q2N23S3227AA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
Q2N23S3227BA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
Q2N23S3227CA-A/JB	Terminal Block	STATES CO.	Type ZWM	Mn. Stm	144'-0"
2VAFU-U60	Power Cable			Mn. Stm	135'-0"
2VAFU-U50	Power Cable			Mn. Stm	135'-0"
2VAFU-I30	Power Cable			Mn. Stm	135'-0"
2VAFU-U6A, D	Control Cables			Mn. Stm	135'-0"
				Room	6 above

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST 0060695

Section C.2.16
Sheet 12 of 1

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

ITEM: AUXILIARY FEEDWATER

N-23

4-18-1993-0299

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
2VAFU-USA, D	Control Cables			BLDG ELEV Mn. Stm 135'-0" Room 6 above
2VAFU-12A, D	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAL5007B	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5008B	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5009B	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5007C	Instrument Cables			Mn. Stm 135'-0" Room 6 above
2VAL5008C	Instrument Cable			Mn. Stm 135'-0" Room 6 above
2VAL5009C	Instrument Cables			Mn. Stm 135'-0" Room 6 above
2VAQ5010E, K	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAQ5012E, K	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAQ5014E, K	Control Cables			Mn. Stm 135'-0" Room 6 above
2VMCR5007K, L, M	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAL5013C	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5014C	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5015C	Control Cable			Mn. Stm 135'-0" Room 6 above
2VAL5013D	Instrument Cable			Mn. Stm 135'-0" Room 6 above
2VAL5014D	Instrument Cable			Mn. Stm 135'-0" Room 6 above
2VAL5015D	Instrument Cable			Mn. Stm 135'-0" Room 6 above
2VAQ5048H, K	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAL5006C, H	Control Cables			Mn. Stm 135'-0" Room 6 above
2VAQ5008C, H	Control Cables			Mn. Stm 135'-0" Room 6 above
2VMCR5007G, H, J	Control Cables			Mn. Stm 135'-0" Room 6 above

卷之三

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2

0000696 Section C.2.17
Sheet 33

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: CHEMICAL INJECTION SYSTEM

四-2

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0000697

Section C.2.1B
Sheet 34SYSTEM: BALLOON SYSTEM
P-19

COMPONENTS				
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION
Q2P138V3103 (WV2103)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283103 (WV2103)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3763 (WV2763)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283763 (WV2763)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3766 (WV2766)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283766 (WV2766)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3179A (WV2179A)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283179A (WV2179A)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3179B (WV2179B)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283179B (WV2179B)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3179C (WV2179C)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283179C (WV2179C)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3180A (WV2180A)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283180A (WV2180A)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3180B (WV2180B)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283180B (WV2180B)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3180C (WV2180C)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283180C (WV2180C)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3181A (WV2181A)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283181A (WV2181A)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3181B (WV2181B)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283181B (WV2181B)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3181C (WV2181C)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283181C (WV2181C)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"
Q2P158V3181D (WV2181D)	Solenoid Valve	ASCO	NP8320A184V	CTMT 129'-0"
Q2P15283181D (WV2181D)	Limit Switch	NAMCO	EA-180	CTMT 129'-0"

MASTER LIST

Joseph M. Farley Nuclear Plant Unit 2Section C.2.1B
Sheet 35 of _____

0060098

ICLASS 1E ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: SAMPLING SYSTEM

P-15

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				LOCATION	ELEV
Q2F152B3104 (HV3104)	Limit Switch	NAMCo	EA-180	CTMT	129'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P158V3103-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3765-A/JB	Junction Box	States Co.	Type ZWM	CTMT	135'-0"
Q2T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P158V3766-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3179A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3179B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3179C-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P158V3180A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3180B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3180C-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3181A-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3181B-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3181C-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
Q2P158V3104-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	135'-9"
2VAL5063B	Control Cable			CTMT	129'-0"
2VAQ5049H	Control Cable			CTMT	6 above
2VXR5010B	Control Cable			CTMT	129'-0"
2VAL5065B	Control Cable			CTMT	6 above
2VAQ5032J	Control Cable			CTMT	129'-0"
2VXR5010F	Control Cable			CTMT	6 above
2VAL5066A	Control Cable			CTMT	129'-0"
2VAQ5033J	Control Cable			CTMT	6 above

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0060699

Section C.2.18
Sheet 35 of

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: SAMPLING SYSTEM

P-18

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST 0060700

Section C.2.19
Sheet 37 of

ICLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: SERVICE WATER

P-16

PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	COMPONENTS	
				LOCATION	ELEV
Q:PI16V207A (MOV3441A)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-0"
Q:PI16V207B (MOV3441B)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	120'-0"
Q:PI16V207C (MOV3641C)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-0"
Q:PI16V207D (MOV3441D)	10" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-0"
Q:PI16V081 (MOV3131)	6" Motor Operated Gate Valve	Limitorque	SMB-00	CTMT	130'-0"
Q2T52B005	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B015	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B007	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B014	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
2VBFV-J4Q	Power Cable				130'-0"
2VBFV-J4D	Control Cable			CTMT	6 above
2VBQ5007D	Control Cable			CTMT	6 above
2VTR4006B, D	Control Cables			CTMT	6 above
2VTX8164B, C	Control Cables			CTMT	6 above
2VBFV-J5Q	Power Cable			CTMT	6 above
2VBFV-J5D	Control Cable			CTMT	6 above
2VBQ5009D	Control Cable			CTMT	6 above
2VAFU-K6Q	Power Cable			CTMT	6 above
2VAFU-K6D	Control Cable			CTMT	6 above
2VAC5007D	Control Cable			CTMT	6 above
2VTR5005B, D, F	Control Cables			CTMT	6 above
2VOL3164B, C	Control Cables			CTMT	6 above
2VAFU-W2Q	Power Cable			CTMT	6 above

Joseph M. Farley Nuclear Plant Unit 2

MASTER LIST

0069701

Section C.2.19
Sheet 38 of

(CLASS II ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER NORMAL OPERATING CONDITIONS)

SYSTEM — SERVICE WATER

7-16

Joseph M. Farley Nuclear Plant U

MASTER LIST

0060702

Section C.2.20
Sheet 19

ECLASS IE ELECTRICAL EQUIPMENT REQUIRED TO FUNCTION UNDER POSTULATED ACCIDENT CONDITIONS

SYSTEM: COMPONENT COOLING WATER

P-17

COMPONENTS					
PLANT ID NUMBER	GENERIC NAME	MANUFACTURER	MODEL	LOCATION	
Q2P17V097 (MOV3046)	6" Motor Operated Gate Valve	Limiterque	FMB-00	BLDG	ELEV
Q2P17SV3184 (HV3184)	Solenoid Valve	ASCO	NP8316A77V	CTMT	130'-6"
Q2P172S3184 (HV3184)	Limit Switch	MAMCO	EA-180	CTMT	118'-0"
Q2P17SV3443 (HV3443)	Solenoid Valve	ASCO	NP8316A74V	CTMT	129'-0"
Q2P172S3443 (HV3443)	Limit Switch	MAMCO	EA-180	CTMT	129'-0"
Q2T52B016	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B038	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B020	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P17SV3184-B/JB	Terminal Block	States Co.	Type ZWM	CTMT	118'-0"
Q2T52B019	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2T52B041	Penetration	General Electric	100 Series	CTMT	143'-0"
Q2P17SV3443-A/JB	Terminal Block	States Co.	Type ZWM	CTMT	129'-0"
2VBFV-C3Q	Power Cable			CTMT	118'-0"
2VBFV-C3D	Control Cable			CTMT	5 above
2V303017C	Control Cable			CTMT	118'-0"
2VYR3006T	Control Cable			CTMT	5 above
2VBL3009G.R.EAT	Control Cables			CTMT	118'-0"
2VHQ3017H	Control Cable			CTMT	5 above
2VDR3025B	Control Cable			CTMT	118'-0"
2VAL3035C	Control Cable			CTMT	5 above
2VAC5029H	Control Cable			CTMT	118'-0"
2VYR3064T	Control Cable			CTMT	5 above

0060703

APPENDIX III

ENVIRONMENTAL QUALIFICATION TEST REPORT LIST

0 2 9 9 3 1 6 2 2

LIST OF EFFECTIVE PAGES

0060704

0 2 9 9 3 - 1 8 2 3

02993 102

Page 1

ATTACHMENT
ACCEPTABLE TEST REPORT LIST

MANUFACTURER

Automatic Switch Company (ASCO)

Barton

Boston Insulated Wire and
Cable Company

MODEL	INSTRUMENT	TEST REPORTS
NP Series	Solenoid Valves	Automatic Switch Company Test Report AQS21678/TR, Rev. A, dated July, 1979
206 Series	Solenoid Valves	Automatic Switch Company Test Report AQS21678/TR Rev. A, dated July, 1979
763 Lot 1	Pressure Transmitter	RS-TMA-1950 RS-TMA-2120
764 Lot 1	Level Transmitter	RS-TMA-1950 RS-TMA-2120
763 Lot 2	Pressure Transmitter	MCAP-9885-En- vironmental Qualification of ITT/Barton Transmitters
764 Lot 2	Level Transmitter	MCAP-9885-En- vironmental Qualification of ITT/Barton Transmitters
ESS-1802	Instrument Cable	Boston Insulated Wire and Cable Company Test Report 73E062, dated 09-07-73

0060705

02993 1825

Page 2

ATTACHMENT 4
ACCEPTABLE TEST REPORT LIST

MANUFACTURER	MODEL	INSTRUMENT	TEST REPORTS
Foxboro	E11GM(MCA)	Pressure Transmitter	WCAP 8541-Topical Report Seismic and Environmental Testing of Foxboro Transmitters
	E13DM	Flow Transmitters	WCAP-9157- Environmental Qualification of Safety Related Class IE Process Instrumentation
GEMS Delavel	XM-36495	Level Transmitters	FIRL Test Report F-C3834 dated 03-74 Isomedix Test Report for GEMS Liquid Level Sensor dated 11-75
	LS-36497	Level Switch	FIRL Test Report F-C3834 dated 03-74 Isomedix Test Report for GEMS Liquid Sensor date 11/75

0060706

02993 1826

ATTACHMENT 4
ACCEPTABLE TEST REPORT LIST

Page 3

MANUFACTURER	MODEL	INSTRUMENT	TEST REPORTS
General Electric	100 Series	Penetrations	General Electric Company Report - Low Voltage Electrical Containment Qualification Test Report
Joy Manufacturing	Type P	Containment Fan Motor	Joy Manufacturing Company Qualification Test Report X-604
Limitorque		Motor Operations	Limitorque Corporation Test Report 600456, dated 12-06-75
			Limitorque Corporation Technical Report No. F-C3441, dated 09-72
			Limitorque Corporation Technical Report No. F-C2232-01, dated 11-68

6020900

02993 1827

ATTACHMENT 4
ACCEPTABLE TEST REPORT LIST

Page 4

MANUFACTURER	MODEL	INSTRUMENT	TEST REPORTS
NAMCO	EA-180	Limit Switch	ACME-Cleveland Development Company Qualification Report No. .../105. Revision 3, dated 08-28-80
	EA-740	Limit Switch	ACME-Cleveland Development Company Report. "Qualification of NAMCO Controls Limit Switch Model EA-740 to IEEE Standards 344 (1975), 323 (1974) and 382 (1972)." Revision 1, dated 02-22-79
Okonite	R/R	Control and Power Cable	Okonite Company Engineering Report No. 141, dated 02-29-71 Okonite Company Engineering Report No. R-1, dated 07-03-78 Okonite Report No. APFNPO183 dated 01-12-83

00607408



0 2 9 9 3 1 8 2 8

ATTACHMENT 4
ACCEPTABLE TEST REPORT LIST

Page 5

MANUFACTURER	MODEL	INSTRUMENT	TEST REPORTS
Rutt-Mount	176 KF	RTD	WCAP 9157 - Environmental of Safety Related Class IE Process Instrumentation
	176 KS	RTD	WCAP 9157- Environmental Qualification of Safety Related Class IE Process Instrumentation
States	Type ZWM	Terminal Block	Wyle Laboratories MEQ Test Report 44354-1, dated 03-08-79
Victoreen	877-1	Radiation Monitor	Victoreen Test Report 950.301, dated 06-19-81

6020900

0 2 9 9 3 1 8 2 9

ATTACH - 4
ACCEPTABLE TEST REPORT LIST

MANUFACTURER

MODEL

INSTRUMENT

TEST REPORTS

△ NEW SHEET

Page 6

Westinghouse

N/A

Penetration

PEM-TR-79-07

dated 01-25-79

Technical Report and Qualification
Data for Low Voltage Control
and Instrument Electrical
Penetrations.

0060710

0060711

APPENDIX IV

COMPONENT, MAINTENANCE AND REPLACEMENT SCHEDULE

0 2 9 9 3 8 3 0

LIST OF EFFECTIVE PAGES

0060712

0299301831

**DETERMINATE LIFE EQUIPMENT
UNIT 1**

Page 1

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/yr
GEMS Detaval	QIE111T3594A 3594B	Level Trans.	XH-36495	CTMT	*	12/77	
	QIG211T3282A-A 3282B-B	Level Sensor	XH-54854	CTMT		11/79	
	QIN211SH2828A 2828B 2828C 2829A 2829B 2829C	Level Switch	LS-36497	M S RM		12/77	
	QIB135V2213A 2213B 2214A 2214B	Solenoid Valve	79AB001	CTMT	*	11/79	

*To be determined following the completion of ongoing qualification tests of analogous or similar equipment and subsequent evaluation of test results.

120900

0 2101945 31304813

Page 1

MANUFACTURER	PLATE I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
NAMCO	Q1N23253227A 3227B 3227C 3228A 3228B 3228C Q1N25253772A 3772B 3772C Q1P13252866B 2867B 3196 3197 Q1P15253103 3104 3179A 3179B 3179C 3180A 3180B 3180C 3181A 3181B 3181C 3765 3766 Q1P17253184 3443	Limit Switch	EA-180	HS RM	18 Yrs	03/82	03/00
			EA-180	HS RH	18 Yrs	03/82	3/00
			EA-740	CTNT	6.1 Yrs	12/77	01/84
			EA-180		6.1 Yrs	11/79	12/85
			EA-180	CTNT	6.1 Yrs	11/79	12/85
Rosemount	NIB131E4128 4120 4228 4220 4328 4320 NIB211E410 413 420 423 430 433	RTD	176KF	CTNT	6.1 Yrs	11/79	12/85
			176KS	CTNT	10 Yrs	12/77	12/87
					Under Eval.	12/77	12/03-00

**O 120 DEGRADATE EQUIPMENT
UNIT 1**

Page 3

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
Barton Lot 1	QIB21PT402 403	Press. Trans.	763	CTNT	*	11/79	
	QIB31LT450 460	Level Trans.	764	CTNT		11/79	
	461						
	QIC22LT474 475	Level Trans.	764	CTNT		11/79	
	476						
	484						
	485						
	486						
	494						
	495						
Foxboro	496						
	QIB31LT477 48	Level Trans.	764	CTNT		11/79	
	4						
	QIB31PT4 456	Press. Trans.	E136M (MCA)	CTNT	*	12/77	
	457						
	QIC22FT474 475	Flow Trans.	E13DM	CTNT		12/77	
	484						
	485						
	494						
	495						

0060715

*To be determined following the completion of ongoing qualification tests of analogous or similar equipment and subsequent evaluation of test results.

U 2 LIMITED EQUIPMENT
UNIT 1

Page 4

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/yr
ASCO	NIB315V04448A 044489 0445AA 0445AB QIB315V8047 NIC225V0478A 04788 0479A 0479B 0488A 0488B 0489A 0489B 0498A 0498B 0499A 0499B QIE125V3999A 3999B QIE215V8149AB 8149BB 8149CB 8871 QIG215V3376 7126 NIG215V1003B QIN115V3368AA 3368BA 3368CA 3369AC 3369BC 3369CC 3370AC 3370BC 3370CC 3976A 3976B 3976C QIA125V3234A 3234B 3235A	Solenoid Valve	NP831654V NP831654V HY-2063812RVU HY-2063814RVU HY-2063812RVU HY-2063814RVU HY-2063812RVU HY-2063814RVU HY-2063812RVU HY-2063814RVU CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT CTMT NP831654V NP831654V NP831654V 206-381-6RF NP831654V NP831654V 206-381-6RF NP8321A2V NP8316E36V NP8321A2V NP8320A136V NP8321A2V	M S RM M S RM	8 Yrs 8 Yrs 18 Yrs 8 Yrs 18 Yrs	03/81 11/79 03/82 11/87 3/00 To be re- placed at 4th R.O. 12/77 04/80 04/80 04/80 11/79 03/82 11/87 3/00 0060716	03/89 11/87 3/00 12/85 04/80 04/80 04/80 11/87 3/00 3/00

0 2. ດົກເຈີນ ຕິດຕະຫຼາດ

Page 5

0 2 LINEAR TYPE EQUIPMENT
UNIT 1

Page 6

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL. MONTH/YEAR	MAINT. MONTH/YR
MAMCO*	Q1813Z52034 2035 2036	Limit Switch	EA-180	CTNT	6.1 Yrs	11/79	12/85
	Q1831Z504449 0449		EA-180	CTNT	6.1 Yrs	11/79	12/85
	H1831Z58047		EA-180	CTNT	6.1 Yrs	11/79	12/85
	H1C2ZZ50478 0479 3488 0439 0498 0499		EA-180	H S RM	18 Yrs	03/82	3/00
	QIE1ZZ53999A 3999B		EA-180	CTNT	6.1 Yrs	11/79	12/85
	HIE21Z58149A 8149B 8149C		EA-180	CTNT	6.1 Yrs	11/79	12/85
	QIE21Z58808AB 8808BB 8808CB 8871		EA-180	CTNT	8 Yrs	03/82	03/90
	QIG21Z53376 7126		EA-180	CTNT	6.1 Yrs	11/79	12/85
	HIG21Z51003B		EA-180	CTNT	6.1 Yrs	11/79	12/85
	QIN11Z53368A 3368B 3368C 3369A 3369B 3369C 3370A 3370B 3370C 3976A 3976B 3976C		EA-180	H S RM	8 Yrs	03/82	03/90
	QIN12Z53234A 3234B 3235A 3235B			H S RM	18 Yrs	03/82	03/90

0 21 ప్రాథమిక శాస్త్ర ఏమీలు
UNIT 1

Page 2

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
MANCO	Q1M23Z53227A 3227B 3227C 3228A 3228B 3228C Q1M25Z53772A 3772B 3772C Q1P13Z52866B 2867B 3196 3197 Q1P15Z53103 3104 3179A 3179B 3179C 3180A 3180B 3180C 3181A 3181B 3181C 3765 3766 Q1P17Z53184 3443	Limit Switch	EA-180	MS RM	18 Yrs	03/82	03/00
Rosemount	#1B13TE412B 4120 422B 422D 432B 432D #1B21TE410 413 420 423 430 433	RTD	176KF	CTMT	10 Yrs	12/77	12/87
			176KS	CTMT	Under Eval.	12/77	6/10/00 4/14/00

0240-YEAR-LIFE EQUIPMENT
UNIT 1

Page 8

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
Cable	Cable manufacturers are subject to change without notice. Cable is adequately identified by IPMS No. in the Equipment Master List. No maintenance activi- ties are required.	----	---	CTMT and MS RM	40 Yrs	12/77	N/A
G.E.	Q1T52B001 B002 B005 B006 B007 B009 B010 B011 B012 B014 B015 B016 B017 B019 B020 B022 B023 B024 B025 B028 B030 B038 B040 B041 B042	Penetration	1000 Series	CTMT	40 Yrs	12/77	N/A

0060720

0 24002 REGD SITE EQUIPMENT
UNIT 1

Page 9

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL. MONTH/YEAR	Maint. MONTH/YR
Joy Mfg. Co.	Q1E17H001A	CIMT Circ Fan	Type P	CIMT	40 yrs	12/77	N/A
	MO01B						
	MO01C						
	MO01D						
	Q1E17H001A	Mixing Fan Mtr					
	MO01B						
	MO01C						
	MO01D						
Limiterorque	Q1E22H001A	Dist Fan Mtr					
	MO01B						
	MO01C						
	MO01D						
	Q1E14H00V3660	Motor Operator	SMB-009	CIMT	40 yrs	12/77	N/A
	33188			CIMT			
	Q1E21H00V8808A						
	88088						
	8808C						
	8112						
	Q1E22H00V3872A						
	38728						
	Q1E23H00V3528A						
	35288						
	3528C						
	35280						
	3530						
	3536						
	3835A						
	38358						
	Q1E21H00V3232A						
	32328						
	3232C						
	Q1E23H00V3250A						
	33508						
	3350C						
	Q1P16H00V3131						
	3441A						
	3441B						
	3441C						
	3441D						
	Q1P17H00V3046						
	SMB-00			CIMT			

0000721

O 30 YEAR DIFE EQUIPMENT
UNIT 1

Page 10.

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	Maint. MONTH/yr
States Co	1118001 8002 8003 8004 2118001 8002 8003 8004 8005 3118001 8002 A118007 8034 B118025 Q1813G001-B SV2213A-A/JB 2213B-B/JB 2214A-JB 2214B-B/JB N1B31SY0444BA-B/JB 0445AA-A/JB 8047-B/JB R1C225Y0478A-A/JB 0488A-A/JB 0498A-A/JB Q1E12SY3999A-A/JB 3999B-B/JB N1E21SY8149AA-A/JB 8149BA-A/JB 8149CA-A/JB 8871-A/JB Q1G21SY3376-B/JB N1G21SY1003A-A/JB 7126-A/JB Q1H11SY3368AA-A/JB 3368BA-A/JB 3368CA-A/JB 3369AA-A/JB 3369BA-A/JB 3369CA-A/JB	Terminal Block	Type ZWM	CTNT	40 Yrs	12/77	N/A
				M S RM			
				CTNT			
				CTNT			
				CTNT			
				M S RM			
				CTNT			
				CTNT			
				CTNT			
				M S RM			
				CTNT			
				M S RM			

0060300
2270722

0 209128 Distr. Unit 1

Page 11

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL.	MAIN
							MONT/H MONTH/YEAR
States Co	QIN115W3370AA-B/JB	Terminal Block	Type 2W	W S RW	40 yrs.	12/77	N/A
	3370BA-B/JB						
	3370CA-B/JB						
	3976A-B/JB						
	3976B-B/JB						
	3976C-B/JB						
	QIN125W3234A-A/JB						
	3234B-B/JB						
	3235A-A/JB						
	3235B-B/JB						
	QIN235W3227AA-A/JB						
	32270A-A/JB						
	3227CA-A/JB						
	3228AA-A/JB						
	3228BA-A/JB						
	3228CA-A/JB						
	QIN255W3772A-A/JB						
	3772B-A/JB						
	3772C-A/JB						
	2866B-B/JB						
	3196-B/JB						
	3197-B/JB						
	QIP155W3103-A/JB						
	3104-A/JB						
	3179A-A/JB						
	3179B-A/JB						
	3179C-B/JB						
	3180A-A/JB						
	3180B-A/JB						
	3180C-B/JB						
	3181A-A/JB						
	3181B-A/JB						
	3181C-A/JB						
	3765-A/JB						
	3766-A/JB						
	QIP175W3184-B/JB						
	3443-A/JB						

006072

0 2402 YEAR LIFE EQUIPMENT3
UNIT 1

Page 12

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
Victoreen	Q102IRE0027A-A 0027B-B	Rad. Dect.	877-1	CTMT	40 Yrs	12/77	N/A
Westinghouse	Q1E17G001A G001B	H ₂ Recomb Htrs	Type A	CTMT	40 Yrs	12/77	N/A

42200-03

DETERMINATION OF EQUIPMENT
UNIT 2

Page 13

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL. MONTH/YEAR	MAINT.- MONTH/YR
Barton Lot 2	Q2B21PT402 403 Q2B31PT455 456 457 Q2B31LT459 460 461 Q2C22F1474 475 484 485 494 495 Q2C22LT474 475 476 484 485 486 494 495 496 Q2N31LT477 487 497	Press. Trans. Press. Trans. Level Trans. Flow Trans. Level Trans.	763 763 764 764 764	CTMT	*	07/81	
							0060725

*To be determined following the completion of ongoing qualification tests of analogous or similar equipment and subsequent evaluation of test results.

THE HISTORY OF THE CHINESE IN AMERICA

0 2 LIBRARY OF THE STATE OF KANSAS
MAY 11 1968

Page 13.

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTALLED MONTH/YEAR	MAINT. MONTH/YR
ASCO	Q2N115Y3368AA 3368BA 3368CA 3369AC 3369BC 3369CC 3370AC 3370BC 3370CC 3976A 3976B 3976C Q2N125Y3234A 3234B 3235A 3235B Q2N235Y3227AA 3227BA 3227CA 3228AA 3228BA 3228CA Q2N255Y3772A 3772B 3772C Q2P135Y2866B 2867B Q2P155Y3103 3104 3179A 3179B 3179C 3180A 3180B 3180C 3181A 3181B 3181C 3765 3766 Q2P175Y3184 3443	Solenoid Valve	NP8321A2Y NP8316E36Y NP8321A2Y NP8320A186Y NP8321A2Y NP8320A186Y NP8316A74Y NP831654Y NP8320A184Y NP8316A74Y NP8316A74Y	M S RM M S RM M S RM M S RM CTMT CTMT M S RM CTMT CTMT CTMT	18 Yrs 18 Yrs 18 Yrs 18 Yrs 8 Yrs 8 Yrs 18 Yrs 8 Yrs 8 Yrs 8 Yrs	07/81 07/81 07/81 07/81 07/81 07/81 07/81 07/81 07/81 07/81	07/99 07/99 07/99 07/99 07/89 07/89 07/99 07/89 07/89 07/89

02194703117 UNIT 2

Page 16.

MANUFACTURER	ITEM # I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTALLED MONTH/YEAR	MAINTENANCE MONTH/YEAR
NAMCO	Q2813/504448 0445A 2034 2035 2036 M2C22/50478 0479 0488 0489 0498 0499 Q2E12/53999A 39998 8149A 8149B 8149C 8808A8 8808B8 8808C8 8871 M2621/510038 Q2621/53376 7126 Q2M11/53368A 33688 3368C 3369A 3369B 3369C 3370A 3370B 3370C 39160 3916C Q2M12/53234A 3234B 3235A 3235B	Limit Switch	EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	CIMI NS RM	6-1 Yrs 18 Yrs	07/81 07/91	08/87 07/99
			EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	CIMI	6-1 Yrs	07/81	08/87
			EA-180	NS RM	18 Yrs	07/81	07/99
			EA-180	NS RM	18 Yrs	07/81	07/99
						0000728	

0 2 LIMTED LIFE EQUIPMENT
UNIT 2

Page 17

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
MARCO	QZN23Z53227A 3227B 3227C 3228A 3228B 3228C	Limit Switch	EA-180	M S RM	10 Yrs	07/81	07/99
	QZN25Z53772A 3772B 3772C		EA-180	M S RM	18 Yrs	07/81	07/99
	QZP13Z528668 2867B 3196 3197		EA-180	CTMT	6.1 Yrs	07/81	08/87
	QZP15Z53103 3765 3766 3179A 3179B 3179C 3180A 3180B 3180C 3104 3181A 3181B 3181C		EA-180	CTMT	6.1 Yrs	07/87	08/87
	QZP17Z53184 3443		EA-180	CTMT	6.1 Yrs	07/81	08/87

0 2 LIMITED LIFE EQUIPMENT
UNIT 2

Page 18

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/YR
Rosemount	N2B13TE412B 4120 4228 4220 4328 4320 N2B21TE410 413 420 423 430 433	RTD	176KF	CTMT	10 Yrs	07/81	07/91
			176KS	CTMT	Under Eval.	07/81	----

0000730

02 49-12A LIFE EQUIPMENT
UNIT 2

Page 19.

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL MONTH/YEAR	MAINT. MONTH/yr
Cable G.E.	<p>Cable manufacturers are subject to change without notice. Cable is adequately identified by IPMS No. in the Equipment Master List. No maintenance activities are required.</p> <p>Q2152B001 8002 8005 8006 8007 8009 8010 8011 8012 8014 8015 8016 8017 8019 8020 8022 8023 8024 8025 8028 8030 8038 8040 8041 8042</p>	Penetration	100 Series	CTMT	40 Yrs	07/81	N/A

卷四百零二

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL. MONTH/YEAR	MAINT. MONTH/YR
Joy Manuf	Q2E12M001A M001B M001C M001D Q2E19M001A M001B M001C M001D Q2E22M001A M001B Q2E14M00Y3318B 3660 Q2E21M00Y8083A 8088B 8088C 8112 Q2E22M00Y3872A 3872B Q2E23M00Y3528A 3528B 3528C 3528D 3530 3536 3835A 3835B Q2N21M00Y3232A 3232B 3232C Q2N23M00Y3350A 3350B 3350C QZP16M00Y3131 3441A 3441B 3441C 3441D QZP17M00Y3046	CTMT C Fan Mtr Type P Mixing Fan Mtr Dilu Fan Mtr Mot. Valve Op.	SMB-000 SMB-4 SMB-00 SMB-00 SMB-000 SMB-00 SMB-4T SMB-1 SMB-00	CTMT CTMT CTMT CTMT	40 yrs 40 yrs 40 yrs	07/81 07/81	N/A N/A 0060732

0 240-1003111 EQUATION 2
UNIT 2

Page 21

O 2 49-YEAR LIFE INSURANCE
UNIT 2

Page 22

0 2 degrees until 2

Page 23

MANUFACTURER	PLANT I.D. NUMBER	GENERIC NAME	MODEL	LOCATION	LIFE	DATE INSTAL. MONTH/YEAR	MAINT. MONTH/YR
State	Q2P155V3181C-A/JB 3765-A/JB 3766-A/JB	Terminal Block and Junction Box	Type ZMM	H S RM	40 yrs	07/81	N/A
Victoreen	Q2P175V3184-B/JB 3443-A/JB	CINT					
	Q2D21RE0027A-A 0027B-B	Rad. Det.	877-1	CINT	40 yrs	07/81	N/A
Westinghouse	Q2E17G001A 6001B	H ₂ Recomb. Htr	Type A	CINT	40 yrs	07/81	N/A

0000736

APPENDIX V

PREVENTIVE MAINTENANCE SPECIFICATIONS

02993 1855

LIST OF EFFECTIVE PAGES

0000777

02993-1856

Attachment 2
Preventive Maintenance Requirement

0000738

40-Year Life Equipment

Equipment: States terminal blocks; Type ZMW
Limitorque motor operators; SMB-00, -000, -1, -4, -4T
General Electric penetrations; 100 series
Westinghouse hydrogen recombiners; Type A
Joy Manufacturing containment cooler fan motors; Type P
Victoreen radiation detectors; model 877-1.

Requirement: No environmental qualification preventive maintenance activities are required.

Limited Life Equipment

Rosemount RTD's; 176KS and 176KF

Requirement: No environmental qualification preventive maintenance activities are required.

NAMCO Limit Switches; EA-180

Requirement: Clean contacts, lubricate moving parts (lubrication procedure EA-181-10160) and replace the following:

- Top cover gasket; EA-181-10102
- Bottom cover gasket; EA-181-10120
- Contact lever kit; EA-181-10130
- Contact block kit; EA-181-10140
- Boot kit; EA-181-10151
- Lever shaft and o-ring assembly kits; EA-181-10170 (for standard switches) or EA-181-10171 (for short travel switches; EA-180-X4302, -X5302, -X6302)

See the attached NAMCO maintenance instructions Tables 1 and 2 of "Environmental Qualification Surveillance" provide the frequency for these maintenance activities.

NAMCO Limit Switches: EA-740

Requirement: Clean contacts, lubricate moving parts (lubrication procedure EA-749-20019) and replace the following:

Preventative Maintenance Requirements
Page 2

0000739

- Top cover gasket kit; EA-749-20021
- Bottom "O" ring gasket kit; EA-749-20026
- Contact screw kit; EA-749-20032
- Contact block kit; EA-749-20036
- Boot and retaining ring kit; EA-749-20042

See the attached NAMCO maintenance instructions. Tables 1 and 2 of "Environmental Qualification Surveillance" provides the frequency for these maintenance activities.

ASCO Solenoid Valves: NP8316, NP8320, NP8321, 206-381

Requirement: Replace the coil, all resilient parts and manual operator assembly (optional feature). To order spare part kits, coils and manual operator assemblies, specify the valve catalog number, serial number and voltage. See attached ASCO maintenance instructions. Tables 1 and 2 of "Environmental Qualification Surveillance" provides the frequency for the maintenance activities.

Indeterminate Life Equipment

Equipment: Barton transmitters; models 763 and 764
Foxboro transmitters; models E11GM (MCA) and E13DM
GEMS Delaval transmitters; XM-36495
GEMS Delaval level sensor; XM-54854
GEMS Delaval level switch; LS-36497
Target Rock solenoids; 79AB001.

Requirement: The qualified life and environmental qualification preventive maintenance activities will be determined following the completion of ongoing qualification tests of analogous or similar equipment and subsequent evaluation of test results.

0299-1858