January 29, 1992

Docket No. 50-400 License No. NPF-63

Carolina Power and Light Company ATTN: Mr. Lynn W. Eury Executive Vice President Power Supply P. O. Box 1551 Raleigh, NC 27602

Gentlemen:

SUBJECT: CHANGES TO YOUR QUALITY ASSURANCE (QA) PROGRAM FOR SHEARCH HARPIS

We have completed our review of the changes addressed in your letter (NLS-91-123) dated July 25, 1991. We have also reviewed your letter (NLS-91-316) dated November 27, 1991, which provided clarification to questions raised by the NRC in our letter dated October 10, 1991.

We have concluded that the revised QA program, if properly implemented, will continue to meet the requirements of 10 CFR 50, Appendix B. While the commitments are acceptable, there is one implementation aspect of the revised QA program that will be monitored by the NRC. This involves the revision to the program which eliminated the QA organization from in-line review and approval of processes related to engineering documents. The revision is acceptable based on your statement that supervisory personnel will ensure that individuals assigned to perform the reviews are qualified and competent in the subject matter.

We appreciate your cooperation with us. Should you have any questions concerning this letter please contact F. Jape of my staff at (404) 331-4182.

Sincerely,
Original signed by
Caudle A. Julian/for

Albert F. Gibson, Director Division of Reactor Safety

cc: R. B. Richey, Vice President Harris Nuclear Project Box 165 New Hill, NC 27562

(cc cont'd - see page 2)

9204670322 920312 PDR ADDCK 05000400 PDR (cc cont'd) C. S. Hinnant General Manager Harris Nuclear Plant Box 165 New Hill, NC 27362

C. S. Olexik, Jr., Manager Regulatory Compliance Harris Nuclear Project P. D. Box 165 New H111, NC 27562

H. Ray Starling Manager - Legal Department Carolina Power and Light Co. P. O. Box 1551 Raleigh, NC 27602

Dayne H. Brown, Director Division of Radiation Protection N. C. Department of Environment, Health & Natural Resources P. O. Box 27687 Raleigh, NC 27611-7687

bcc: J. Johnson, RII H. Christensen, RII B. Mozafari, NRR Document Control Desk J. Spraul, NRR

> NRC Resident Inspector U.S. Nuclear Regulatory Commission Route 1, Box 315B New Hill, NC 27562

RII: DRS