

2. Accordingly, Facility Operating License No. DPR-65 is hereby amended by modifying paragraph 2.C.(3) on page 4 to read as follows:

(3) Fire Protection

The licensee shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report and as approved in the SER dated September 19, 1978, and supplements dated October 21, 1980, November 11, 1981, October 31, 1985, April 15, 1986, January 15, 1987, April 29, 1988, July 17, 1990, and November 3, 1995, subject to the following provisions.

The licensee may make changes to the approved Fire Protection Program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.


The license is also amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 191, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Phillip F. McKee, Director  
Project Directorate I-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachments: 1. Page 4 of License  
2. Changes to the Technical Specifications

Date of Issuance: November 3, 1995

\*Page 4 is attached, for convenience, for the composite license to reflect this change.

Correction Letter: November 24, 1995

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>		<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>		
3/4.2.1	LINEAR HEAT RATE . . . . .	3/4 2-1
3/4.2.2	Deleted	
3/4.2.3	TOTAL INTEGRATED RADIAL PEAKING FACTOR - $F_r^T$ . . . . .	3/4 2-9
3/4.2.4	AZIMUTHAL POWER TILT . . . . .	3/4 2-10
3/4.2.5	Deleted	
3/4.2.6	DNB MARGIN . . . . .	3/4 2-13
<u>3/4.3 INSTRUMENTATION</u>		
3/4.3.1	REACTOR PROTECTIVE INSTRUMENTATION . . . . .	3/4 3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION . . . . .	3/4 3-10
3/4.3.3	MONITORING INSTRUMENTATION . . . . .	3/4 3-26
	Radiation Monitoring . . . . .	3/4 3-26
	Incore Detectors . . . . .	3/4 3-30
	Seismic Instrumentation . . . . .	3/4 3-32
	Meteorological Instrumentation . . . . .	3/4 3-36
	Remote Shutdown Instrumentation . . . . .	3/4 3-39
	Accident Monitoring . . . . .	3/4 3-46
	Radioactive Liquid Effluent Monitoring Instrumentation . . . . .	3/4 3-50
	Radioactive Gaseous Effluent Monitoring Instrumentation . . . . .	3/4 3-56
<u>3/4.4 REACTOR COOLANT SYSTEM</u>		
3/4.4.1	COOLANT LOOPS AND COOLANT CIRCULATION . . . . .	3/4 4-1
	Startup and Power Operation . . . . .	3/4 4-1
	Hot Standby . . . . .	3/4 4-1a
	Shutdown . . . . .	3/4 4-1b
	Reactor Coolant Pumps - Shutdown . . . . .	3/4 4-1d

## ADMINISTRATIVE CONTROLS

### Meeting Frequency

- 6.5.1.4 The PORC shall meet at least once per calendar month and as convened by the PORC Chairperson.

### Quorum

- 6.5.1.5 A quorum of the PORC shall consist of the Chairperson, or Vice Chairperson, or Senior Vice President -- Millstone Station and four members including alternates.

### Responsibilities

- 6.5.1.6 The PORC shall be responsible for:
- a. Review of 1) all procedures, except common site procedures, required by Specification 6.8 and changes thereto, 2) any other proposed procedures or changes thereto as determined by the Nuclear Unit Director to affect nuclear safety.
  - b. Review of all proposed tests and experiments that affect nuclear safety.
  - c. Review of all proposed changes to Sections 1.0 - 5.0 of these Technical Specifications.
  - d. Review of all proposed changes or modifications to plant systems or equipment that affect nuclear safety.
  - e. Investigation of all violations of the Technical Specifications and preparation and forwarding of a report covering evaluation and recommendations to prevent recurrence to the Executive Vice President-Nuclear and to the Chairperson of the Nuclear Safety Assessment Board.
  - f. Review of all REPORTABLE EVENTS.
  - g. Review of facility operations to detect potential safety hazards.
  - h. Performance of special reviews and investigations and reports thereon as requested by the Chairperson of the Nuclear Safety Assessment Board.
  - i. Render determinations in writing if any item considered under 6.5.1.6(a) through (d) above, as appropriate and as provided by 10CFR50.59 or 10CFR50.92, constitutes an unreviewed safety question or requires a significant hazards consideration determination.
  - j. Review of the fire protection program and implementing procedure.

## ADMINISTRATIVE CONTROLS

### Meeting Frequency

6.5.2.4 The SORC shall meet at least once per six months and as convened by the SORC Chairperson.

### Quorum

6.5.2.5 A quorum of the SORC shall consist of the Chairperson or Vice Chairperson and five members including alternates.

### Responsibilities

6.5.2.6 The SORC shall be responsible for:

- a. Review of 1) all common site procedures required by Specification 6.8 and changes thereto, 2) any other proposed procedures or changes thereto as determined by the Senior Vice President — Millstone Station to affect site nuclear safety.
- b. Review of all proposed changes to Section 6.0 "Administrative Controls" of these Technical Specifications.
- c. Performance of special reviews and investigations and reports as requested by the Chairperson of the Nuclear Safety Assessment Board.
- d. Review of the Plant Security Plan and implementing procedures<sup>7</sup> and shall submit changes to the Chairperson of the Nuclear Safety Assessment Board.
- e. Review of the Emergency Plan and implementing procedures and shall submit recommended changes to the Chairperson of the Nuclear Safety Assessment Board.
- f. Review of all common site proposed tests and experiments that affect nuclear safety.
- g. Review of all common site proposed changes or modifications to systems or equipment that affect nuclear safety.
- h. Render determinations in writing or meeting minutes if any item considered under 6.5.2.6(a) through (g) above, as appropriate and as provided by 10CFR50.59 or 10CFR50.92, constitutes an unreviewed safety question or requires a significant hazards consideration determination.
- i. Review of the common site fire protection program and implementing procedures.

### Authority

6.5.2.7 The SORC shall:

- a. Recommend to the Senior Vice President— Millstone Station written approval or disapproval in meeting minutes of items considered under 6.5.2.6(a) through (g) above.