

PILGRIM NUCLEAR POWER STATION

Procedure No. 5.4.6

PRIMARY CONTAINMENT VENTING AND PURGING
UNDER EMERGENCY CONDITIONS

REVIEWERS AND APPROVERS

<i>Thomas A. Trana</i>	3/16/92
Procedure Writer	Date
<i>Robert W. Horvath</i>	3/16/92
Technical Reviewer	Date
<i>Thomas A. Trana</i>	3/16/92
Validator	Date
<i>Thomas Trana & P.D. Smith</i>	3/16/92
Procedure Owner	Date
N/A	
OAD Manager	Date
<i>Charles W. Math</i>	3/18/92
ORC Chairman	Date
<i>W. Allen Smith</i>	3/14/92
Plant Manager	Date

SAFETY REVIEW REQUIRED

ORC REVIEW REQUIRED/
NOT REQUIRED

Effective Date: 3-20-92

- (2) Containment Atmosphere Dilution System Torus Isolation valves
(C170 and C171) Special Key CR-V.
- SV-5083A, TORUS ISOLATION VALVE
 - SV-5084A, TORUS ISOLATION VALVE
 - SV-5083B, TORUS ISOLATION VALVE
 - SV-5084B, TORUS ISOLATION VALVE

CAUTION

When performing the following, refer to Emergency Classifications
1. -100. Reference EAL 3.4.1.4, EAL 3.5.1.4, and EAL 3.5.2.4.

If additional venting capacity is required,

AND primary containment pressure is \geq 30 psig,

THEN VENT the Torus, bypassing SGTS as follows:

(1) CLOSE OR VERIFY CLOSED the following valves:

- AO-5042A, TORUS PURGE EXHAUST ISOL VLV
- AO-5041A, TORUS NORMAL EXHAUST ISOL VLV
- AO-5041B, TORUS NORMAL EXHAUST ISOL VLV
- SV-5083A, TORUS ISOLATION VALVE
- SV-5084A, TORUS ISOLATION VALVE
- SV-5083B, TORUS ISOLATION VALVE
- SV-5084B, TORUS ISOLATION VALVE

(2) PLACE the fan control switches for SGTS Exhaust Fans VEX-210A
AND VEX-210B to "OFF".

(3) CLOSE OR VERIFY CLOSED the following valves:

- AO-N-112, TRAIN B OUTL DMPR
- AO-N-108, TRAIN A OUTL DMPR

(4) OPEN AO-5042B, TORUS PURGE EXHAUST ISOL VLV, bypassing
isolation interlocks according to PNPS 5.3.21, "Bypassing
Selected Interlocks", Attachment 12.