

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Washington Nuclear Plant - Unit 2 DOCKET NUMBER (2) 050003971 OF 02 PAGE (3) 1 OF 02

TITLE (4) Missed Fire Watch During Unusual Event

EVENT DATE (8)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (9)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
07	28	84	84	076	00	08	08	84		050000
07	28	84	84	076	00	08	08	84		050000

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8. (Check one or more of the following) (11)

OPERATING MODE (9) 4	20.402(b)	20.406(e)	90.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 0.0	20.406(a)(1)(i)	50.36(e)(1)	50.73(a)(2)(v)	73.71(e)
	20.406(a)(1)(ii)	50.36(e)(2)	90.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	20.406(a)(1)(iii)	X 50.73(a)(2)(i)	90.73(a)(2)(viii)(A)	
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	90.73(a)(2)(viii)(B)	
	20.406(a)(1)(v)	90.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12) NAME R. L. Koenigs, Compliance Engineer TELEPHONE NUMBER 509377-2501

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) Ext. 2279

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC
X	IC	-	-	N					

SUPPLEMENTAL REPORT EXPECTED (14) YES (if not, complete EXPECTED SUBMISSION DATE) NO EXPECTED SUBMISSION DATE (15)

ABSTRACT (Limit to 400 spaces or approximately fifteen single-space typewritten lines) (16)

During the declaration of an Unusual Event subsequent to finding a possible bomb, an hourly fire watch tour was not performed. The tours resumed immediately upon termination of the unusual event status and only one tour was omitted.

IE22
1/1

8408200132 840808
PDR ADOCK 05000397
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 8 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 7 1 6	- 0 1 0 0	1 2	OF 0 1 2

TEXT (If more space is required, use additional NRC Form 386A's) (17)

Plant Conditions

- a) Reactor Power - 0%
- b) Operational Mode - 4

Event

On 7/28/84 a suspected bomb was found in the Plant and an Unusual Event declared. Response procedures for this event direct all personnel outside the Control Room to report to a central location. This precluded the fire watch from making the scheduled hourly tour required by Technical Specifications 3.7.6.2 and 3.7.7.

Immediate Corrective Action

Upon termination of the Unusual Event, the fire watch tours resumed as scheduled.

Long Term Corrective Action

This is considered an appropriate response to the situation, with emergency response procedures taking precedence. No further action is contemplated. The Unusual Event was reported under Security Event Report SER #84-003.

Safety Significance

There is no safety significance attached to the missed fire watch tour as no fire existed and fire brigade response was still available. Also, only one tour was missed and normal fire watch tours were immediately recommenced upon termination of the Unusual Event.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

August 8, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-076

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-076 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

Very truly yours,



J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-076

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

IE22
11