

TABLE 4.4-4 (Continued)

TABLE NOTATIONS

Until the specific activity of the Reactor Coolant System is restored within its limits.

* Sample to be taken after a minimum of 2 EFPD and 20 days of POWER OPERATION have elapsed since reactor was last subcritical for 48 hours or longer.

** A gross radioactivity analysis shall consist of the quantitative measurement of the total specific activity of the reactor coolant except for radionuclides with half-lives less than 10 minutes and all radioiodines. The total specific activity shall be ~~measured as the~~ the ~~gross~~ beta-gamma activity ~~and the total~~ ~~specific activity~~ in the sample within 2 hours after the sample is taken and extrapolated back to when the sample was taken. Determination of the contributors to the gross specific activity shall be based upon those energy peaks identifiable with a 95% confidence level. The latest available data may be used for pure beta-emitting radionuclides.

*** A radiochemical analysis for \bar{E} shall consist of the quantitative measurement of the specific activity for each radionuclide, except for radionuclides with half-lives less than 10 minutes and all radioiodines, which is identified in the reactor coolant. The specific activities for these individual radionuclides shall be used in the determination of \bar{E} for the reactor coolant sample. Determination of the contributors to \bar{E} shall be based upon those energy peaks identifiable with a 95% confidence level.

TABLE 4.4-4 (Continued)

TABLE NOTATIONS

- # Until the specific activity of the Reactor Coolant System is restored within its limits.
- * Sample to be taken after a minimum of 2 EFPD and 20 days of POWER OPERATION have elapsed since reactor was last subcritical for 48 hours or longer.
- ** A gross radioactivity analysis shall consist of the quantitative measurement of the total specific activity of the reactor coolant except for radionuclides with half-lives less than 10 minutes and all radioiodines. The total specific activity shall be the beta-gamma activity in the sample within 2 hours after the sample is taken and extrapolated back to when the sample was taken. Determination of the contributors to the gross specific activity shall be based upon those energy peaks identifiable with a 95% confidence level. The latest available data may be used for pure beta-emitting radionuclides.
- *** A radiochemical analysis for \bar{E} shall consist of the quantitative measurement of the specific activity for each radionuclide, except for radionuclides with half-lives less than 10 minutes and all radioiodines, which is identified in the reactor coolant. The specific activities for these individual radionuclides shall be used in the determination of \bar{E} for the reactor coolant sample. Determination of the contributors to \bar{E} shall be based upon those energy peaks identifiable with a 95% confidence level.