

November 17, 1995

Mr. J. E. Cross
Senior Vice President
Nuclear Power Division
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

SUBJECT: BEAVER VALLEY SERVICE WATER INSPECTION 95-18

Dear Mr. Cross:

This letter transmits the report of an inspection at the Beaver Valley Station, conducted by Mr. M. Buckley and others from September 25 to October 5, 1995. The inspection focused on issues important to public health and safety, specifically, the actions taken to correct previously-identified findings from your service water system self-assessment previously conducted in July 1994. At the conclusion of the inspection, the preliminary findings were discussed with you and other members of the Duquesne staff.

Sound corrective actions were observed with respect to the self-assessment findings, and those actions were consistent with the items in Generic Letter (GL) 89-13, "Service Water System Problems Affecting Safety-Related Equipment." Comprehensive solutions to improve upon emergency diesel generator cooling flow margins were observed, and good progress with respect to heat exchanger performance monitoring was made.

No response to this letter is required. Your cooperation with us in this matter is appreciated, and we would be pleased to discuss any questions you have concerning this inspection.

Sincerely,

A. Blough/for

Eugene M. Kelly, Chief
Systems Engineering Branch
Division of Reactor Safety

Docket Nos. 50-334
50-412

Enclosure: Combined Inspection Report Nos.
50-334/95-18 and 50-412/95-18

010013

951201017B 951117
PDR ADOCK 05000334
Q PDR

LEO/
11

Mr. J. E. Cross

2

cc w/encl:

- G. S. Thomas, Vice President, Nuclear Services
- T. P. Noonan, Vice President, Nuclear Operations
- B. T. Tuite, General Manager, Nuclear Operations Unit
- K. L. Ostrowski, Manager, Quality Services Unit
- R. Brosi, Manager, Nuclear Safety Department
- H. R. Caldwell, General Superintendent, Nuclear Operations
- M. Clancy, Mayor
- D. Screnci, PAO (2)
- NRC Resident Inspector
- Commonwealth of Pennsylvania
- State of Ohio

Distribution w/encl:

- Region I Docket Room (with concurrences)
- PUBLIC
- Nuclear Safety Information Center (NSIC)
- J. Wiggins, DRS
- E. Kelly, DRS
- P. Eselgroth, DRP
- S. Stewart, DRP
- M. Kalamon, DRP
- D. Kern, Surry Site, RII
- DRS Files (2)

Distribution w/encl (VIA E-MAIL):

- J. Stolz, NRR
- D. Brinkman, NRR
- W. Dean, OEDO
- Inspection Program Branch, NRR (IPAS)

DOCUMENT NAME: A: BV951818.INS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	RI/DRR	RI/DRS	E	RI/	RI/
NAME	MBuckley <i>MB</i>	PEselgroth <i>PE</i>	EKelly		BCONGIT	
DATE	11/07/95 <i>11/9/95</i>	11/17/95	11/13/95		11/17/95	11/ /95

OFFICIAL RECORD COPY