

McGuire Unit 2 Cycle 10
Core Operating Limits Report
November 1995
(rev. 2)

Duke Power Company

		Date
Prepared By:	<u><i>JMA</i></u>	<u>Nov 28, 1995</u>
Checked By:	<u><i>Donna H. Sawyer</i></u>	<u>November 28, 1995</u>
Checked By:	<u><i>Christy L. Ray</i></u>	<u>Nov. 28, 1995</u>
Approved By:	<u><i>RH Clark</i></u>	<u>Nov. 28, 1995</u>

QA Condition 1

NOTE

The contents of this document have been reviewed to verify that no material herein either directly or indirectly changes or affects the results and conclusions presented in the 10CFR50.59 M2C10 Reload Safety Evaluation (calculation file: MCC-1552.08-00-0250).

McGuire 2 Cycle 10 Core Operating Limits Report

REVISION LOG

<u>Revision</u>	<u>Effective Date</u>	<u>Effective Pages</u>	<u>COLR</u>
Original Issue, Revisions 1,2	Superseded	N/A	M2C09
Revision 3	December 9, 1994	Pages 4-8, 12-19	M2C10
Revision 4	July 13, 1995	Page 11	M2C10, rev. 1
Revision 5	November 28, 1995	Pages 1-3, 9, 10, 19	M2C10, rev. 2

McGuire 2 Cycle 10 Core Operating Limits Report

INSERTION SHEET FOR REVISION 4

Remove pages

Pages 1-3, 9, 10, 19

Insert Rev. 4 pages

Pages 1-3, 9, 10, 19 (rev. 5)

McGuire 2 Cycle 10 Core Operating Limits Report

3.1 Tech Spec 3/4.1.2.5 - Borated Water Source - Shutdown

3.1.1 Volume and boron concentrations for the Boric Acid Storage System and the Refueling Water Storage Tank (RWST) during modes 5 & 6:

<u>Parameter</u>	<u>Limit</u>
Boric Acid Storage System minimum contained borated water volume for LCO 3.1.2.5a	8,884 gallons 12.8% level
Boric Acid Storage System minimum boron concentration for LCO 3.1.2.5a	7,000 ppm
Boric Acid Storage System minimum water volume required to maintain SDM at 7,000 ppm	585 gallons
Refueling Water Storage Tank minimum contained borated water volume for LCO 3.1.2.5b	26,000 gallons 33.3 inches
Refueling Water Storage Tank minimum boron concentration for LCO 3.1.2.5b	2,175 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,175 ppm	3,500 gallons

McGuire 2 Cycle 10 Core Operating Limits Report

3.2 Tech Spec 3/4.1.2.6 - Borated Water Source - Operating

3.2.1 Volume and boron concentrations for the Boric Acid Storage System and the Refueling Water Storage Tank (RWST) during modes 1, 2, 3, & 4:

<u>Parameter</u>	<u>Limit</u>
Boric Acid Storage System minimum contained borated water volume for LCO 3.1.2.6a	20,520 gallons 38.6% level
Boric Acid Storage System minimum boron concentration for LCO 3.1.2.6a	7,000 ppm
Boric Acid Storage System minimum water volume required to maintain SDM at 7,000 ppm	9,851 gallons
Refueling Water Storage Tank minimum contained borated water volume for LCO 3.1.2.6b	91,000 gallons 116.4 inches
Refueling Water Storage Tank minimum boron concentration for LCO 3.1.2.6b	2,175 ppm
Refueling Water Storage Tank maximum boron concentration for LCO 3.5.5b	2,275 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,175 ppm	57,107 gallons

3.3 Tech Spec 3/4.1.3.5 - Shutdown Rod Insertion Limit

3.3.1 The shutdown rods shall be withdrawn to at least 222 steps.

3.4 Tech Spec 3/4.1.3.6 - Control Rod Insertion Limits

3.4.1 The control rod banks shall be limited to physical insertion as shown in Figure 2.

3.5 Tech Spec 3/4.2.1 - Axial Flux Difference

3.5.1 The Axial Flux Difference (AFD) Limits are provided in Figure 3.

McGuire 2 Cycle 10 Core Operating Limits Report

3.10 Tech Spec 3/4.9.1 - Refueling Operations - Boron Concentration

3.10.1 Minimum boron concentrations for the filled portions of the Reactor Coolant System and refueling canal. Applicable for mode 6 with the reactor vessel head closure bolts less than fully tensioned, or with the head removed.

<u>Parameter</u>	<u>Limit</u>
Refueling boron concentration for the filled portions of the Reactor Coolant System and refueling canal for LCO 3.9.1.b.	2175 ppm

3.11 Tech Spec 3/4.9.12 - Fuel Storage - Spent Fuel Storage Pool

3.11.1 Minimum boron concentration limit for the spent fuel pool. Applicable when fuel is stored in the spent fuel pool.

<u>Parameter</u>	<u>Limit</u>
Spent fuel pool minimum boron concentration for LCO 3.9.12	2175 ppm

Note:

Data contained in Tables in the Appendix to this document were generated in the McGuire 2 Cycle 10 Maneuvering Analysis calculational file (MCC-1553.05-00-0165). The McGuire Reactor Engineering Group will control this information via computer file(s) and should be contacted if there is a need to access this information.