

ENCLOSURE

NOTICE OF DEVIATION

Mississippi Power and Light Company
Grand Gulf

Docket No. 50-416
License No. NPF-13-

The following deviation was identified during an inspection conducted on March 28-30, 1984.

Paragraph 7.4.2.4.2 of your Equal Safety Analysis Report states the instrumentation and control components required for remote shutdown, which are not normally in operation, will be periodically tested.

Contrary to the above, as of March 30, 1984, no surveillance procedure had been established to periodically test the remote shutdown control components and they had not been tested since preoperational testing.

Please provide, in writing within 30 days of the date of this Notice, a description of corrective actions regarding these deviations, actions taken to avoid further deviations, and the dates when these actions were or will be completed.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: APR 24 1984