



*H. Selver*

**Florida  
Power**  
CORPORATION

August 8, 1984  
3F0884-03

Director of Nuclear Reactor Regulation  
Attention: George W. Rivenbark, Acting Chief  
Operating Reactors Branch #4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72  
NUREG-0737, Item II.B.2  
Plant Shielding

Dear Sir:

At the meeting of February 15, 1984, at Crystal River Unit 3, Florida Power Corporation updated the NRC on the status of selected NUREG-0737 items.

During the meeting, the question was asked if the scenario of boron precipitation decay heat system flow into the reactor hot leg is covered in the emergency operating procedures. FPC responded by ensuring that this concern would be covered. Operating Procedure OP-404 titled "Decay Heat Removal System" addresses this concern.

Sincerely,

G. R. Westafer  
Manager, Nuclear Operations  
Licensing and Fuel Management

EMG/feb

cc: Mr. J. P. O'Reilly  
Regional Administrator, Region II  
Office of Inspection & Enforcement  
U.S. Nuclear Regulatory Commission  
101 Marietta Street N.W., Suite 2900  
Atlanta, GA 30323

8408200311 840808  
PDR ADGCK 05000302  
F PDR

A046  
/10