

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 050003917	PAGE (3) 1 OF 012
--	--------------------------------	----------------------

TITLE (4)
Unscheduled Actuations of Control Room Emergency Filtration Unit

EVENT DATE (8)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (6)																																												
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)																																										
07	20	84	84	077	000	08	08	84			05000																																										
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;">OPERATING MODE (9)</td> <td style="width:15%;">4</td> <td style="width:15%;">THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)</td> <td style="width:15%;"><input type="checkbox"/> 20.402(b)</td> <td style="width:15%;"><input checked="" type="checkbox"/> 20.406(e)</td> <td style="width:15%;"><input checked="" type="checkbox"/> 50.73(a)(2)(iv)</td> <td style="width:15%;"><input type="checkbox"/> 73.71(b)</td> </tr> <tr> <td>POWER LEVEL (10)</td> <td>000</td> <td></td> <td><input type="checkbox"/> 20.406(a)(1)(i)</td> <td><input type="checkbox"/> 50.38(e)(1)</td> <td><input type="checkbox"/> 50.73(a)(2)(v)</td> <td><input type="checkbox"/> 73.71(e)</td> </tr> <tr> <td></td> <td></td> <td></td> <td><input type="checkbox"/> 20.406(a)(1)(ii)</td> <td><input type="checkbox"/> 50.38(e)(2)</td> <td><input type="checkbox"/> 50.73(a)(2)(vi)</td> <td><input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)</td> </tr> <tr> <td></td> <td></td> <td></td> <td><input type="checkbox"/> 20.406(a)(1)(iii)</td> <td><input type="checkbox"/> 50.73(a)(2)(i)</td> <td><input type="checkbox"/> 50.73(a)(2)(vii)(A)</td> <td>50.72(b)(2)(ii)</td> </tr> <tr> <td></td> <td></td> <td></td> <td><input type="checkbox"/> 20.406(a)(1)(iv)</td> <td><input type="checkbox"/> 50.73(a)(2)(ii)</td> <td><input type="checkbox"/> 50.73(a)(2)(vii)(B)</td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td><input type="checkbox"/> 20.406(a)(1)(v)</td> <td><input type="checkbox"/> 50.73(a)(2)(iii)</td> <td><input type="checkbox"/> 50.73(a)(2)(ix)</td> <td></td> </tr> </table>												OPERATING MODE (9)	4	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)	<input type="checkbox"/> 20.402(b)	<input checked="" type="checkbox"/> 20.406(e)	<input checked="" type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)	POWER LEVEL (10)	000		<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 50.38(e)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(e)				<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 50.38(e)(2)	<input type="checkbox"/> 50.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)				<input type="checkbox"/> 20.406(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(vii)(A)	50.72(b)(2)(ii)				<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(vii)(B)					<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(ix)	
OPERATING MODE (9)	4	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)	<input type="checkbox"/> 20.402(b)	<input checked="" type="checkbox"/> 20.406(e)	<input checked="" type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)																																															
POWER LEVEL (10)	000		<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 50.38(e)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(e)																																															
			<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 50.38(e)(2)	<input type="checkbox"/> 50.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)																																															
			<input type="checkbox"/> 20.406(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(vii)(A)	50.72(b)(2)(ii)																																															
			<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(vii)(B)																																																
			<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(ix)																																																

LICENSEE CONTACT FOR THIS LER (12)
NAME: R. L. Koenigs, Compliance Engineer
TELEPHONE NUMBER: 510931771-1251011
AREA CODE: 51093
Ext. 2279

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
B	ILL	IRIA	K10210	N					

SUPPLEMENTAL REPORT EXPECTED (14)
 YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)
MONTH: | DAY: | YEAR: |

ABSTRACT (Limit to 400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

A Control Room Emergency Filtration Unit (an ESF system) was automatically actuated on 7/20/84 and 7/21/84 due to spikes on a corresponding Control Room Outside Air Radiation Monitor.

In response to each event, after verifying that radiation levels were not above normal background, the emergency filtration unit and the radiation monitor were reset and returned to a normal lineup.

These events were verbally reported to the NRC (2339 hours 7/20/84 and 1250 hours 7/21/84) in accordance with 10CFR50.72(b)(2)(ii).

IE22
11

8408200341 840808
PDR ADOCK 05000397
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 8 4	LER NUMBER (8)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		84	0717	010	02	OF 02

TEXT (if more space is required, use additional NRC Form 388A's) (17)

Plant Conditions

- a) Plant Mode - 4
- b) Power Level - 0

Event

The Division II Control Room Emergency Filtration Unit (WMA-FN-54B) was automatically actuated on 7/20/84 (2323 hours) and on 7/21/84 (1145 hours) by High-High radiation alarms originating from an outside air intake radiation monitor (WOA-RIS-31B).

Immediate Corrective Action

Normal background levels were observed at the Division I and Division II radiation monitors. The associated recorder (WOA-RR-32) in each case revealed that monitor 31B and received a spurious spike of sufficient magnitude to trip the High-High alarm. The alarms were promptly reset and the EST system returned to normal. Notification was given to the NRC in accordance with the requirements of 10CFR50.72(b)(2)(ii).

Long Term Corrective Action

The spike on 7/20/84 was found to have been caused by the remote operation of a reactor core isolation cooling valve (RCIC-V-113). The operation of this valve had previously caused ESF system actuation (Ref. LER 84-030). Installation design of previously installed noise suppression devices was determined to have been incorrect and are currently being reworked.

Investigations failed to determine the origin of the spike on 7/21/84. Investigation and resolution of noise problems are continuing on the Radiation Monitoring and interfacing systems (Ref. LER 84-067).

Safety Significance

There were no safety consequences associated with these events. All Plant systems performed as required during the events.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

August 8, 1984

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-077

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-077 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

This is the follow-up report to the verbal notification given at 1250 hours on July 21, 1984.

Very truly yours,



J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:
Licensee Event Report No. 84-077

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

JE22
1/1