JUL 3 1 1984

Docket 50-354:CPPR-120

Public Service Electric & Gas Company ATTN: Mr. T. J. Martin Vice-President Engineering and Construction 80 Park Plaza - 17C Newark, New Jersey 07101

Gentlemen:

Subject: Resident Inspection 50-354/84-05 (5/14/84 - 6/24/84)

This routine inspection of the Hope Creek Generating Station was of open NRC items, raceway and support installation, torus modifications, nonconformance and deficiency trending, rework control, housekeeping, training, cable pulling and terminations, and other work in progress.

Apparent violations of NRC requirements were identified for failure to tie-wrap electrical cable as required, for unauthorized modification of conduit support anchor bolt torquing, and for Control Room console shimming and welding deficiencies. Please reply to these matters in accordance with the enclosed Appendix A. That reply is not subject to clearance by the Office of Management and Budget under the Paperwork Reduction Act of 1980, PL 96-511.

This transmittal will be made public unless you notify this office, within 10 days of the date of this letter, that you intend to request withholding of information under 10 CFR 2.790(b)(1). That notification may be made to the Supervisor, Files, Mail and Records, USNRC Region I, at (215) 337-5223.

Your cooperation with us is app .ated.

Sincerely,

Griginal Signed, By

Richard W. Starostecki, Director Division of Project and Resident

Programs

Enclosures:

Appendix A, Notice of Violation
 Inspection Report No. 50-354 '84-05

cc w/encls:
A. E. Giardino, Manager, Quality Assurance Engineering and Construction
R. L. Mittl, General Manager, Nuclear Assurance and Regulation Hope Creek Hearing Service List
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Scate of New Jersey

bcc w/encls.
Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
Director, DETP
DPRP Section Chief
J. Grant, DPRP

RI:DPRP RI:DPRP McCabe/dmg:djh Greenman W N 3 7/30/84 7/84

RI:DPRP Starostecki