

1901 Chouteau Avenue  
Post Office Box 149  
St. Louis, Missouri 63166  
314-621-3222

**UNION  
ELECTRIC**

November 29, 1995



U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Gentlemen:

ULNRC- 03297

**DOCKET NUMBER 50-483  
CALLAWAY PLANT  
REVISION TO TECHNICAL SPECIFICATION 3/4.6.1.7.4  
CONTAINMENT VENTILATION SYSTEM**

Reference: ULNRC-3151, dated February 24, 1995

The referenced letter transmitted an amendment application to revise Technical Specification (T/S) Surveillance Requirement 4.6.1.7.4 and its associated Bases to delete the requirement to verify quarterly that the measured leakage rate is less than 0.05 times the maximum allowable leakage rate for each 18-inch containment mini-purge supply and exhaust isolation valve.

Union Electric hereby withdraws the amendment application submitted in the above referenced letter. This withdrawal is based on recent discussions between the NRC Staff and Union Electric Co. and our commitment to convert to the NUREG-1431, Rev. 1, Standard Technical Specifications. Although the NUREG-1431, Rev. 1, Standard Technical Specifications do not contain this surveillance requirement, our existing T/S requirements will be followed until the conversion is implemented.

Very truly yours,

Donald F. Schnell

JMC/mlo

050016

9512040371 951129  
PDR ADDCK 05000483  
P PDR

ADD

STATE OF MISSOURI )  
                          )           S S  
CITY OF ST. LOUIS )

Donald F. Schnell, of lawful age, being first duly sworn upon oath says that he Senior Vice President-Nuclear and an officer of Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Donald F. Schnell  
Donald F. Schnell  
Senior Vice President  
Nuclear

SUBSCRIBED and sworn to before me this 28<sup>th</sup> day  
of November, 1995.

Barbara J. Pfaff  
BARBARA J. PFAFF  
NOTARY PUBLIC - STATE OF MISSOURI  
MY COMMISSION EXPIRES APRIL 22, 1997  
ST. LOUIS COUNTY

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

M. H. Fletcher  
Professional Nuclear Consulting, Inc.  
19041 Raines Drive  
Derwood, MD 20855-2432

L. Joe Callan  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive  
Suite 400  
Arlington, TX 76011-8064

Senior Resident Inspector  
Callaway Resident Office  
U.S. Regulatory Commission  
RR#1  
Steedman, MO 65077

Kristine M. Thomas (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E16  
11555 Rockville Pike  
Rockville, MD 20852-2738

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

bcc: D. Shafer/A160.761  
/QA Record (CA-758)

E210.01  
DFS/Chrono  
D. F. Schnell  
J. E. Birk  
J. V. Laux  
R. D. Affolter  
G. L. Randolph  
R. J. Irwin  
P. M. Barrett  
J. D. Blosser  
A. C. Passwater  
D. E. Shafer  
W. E. Kahl  
S. Wideman (WCNOC)  
F. C. Wilks, PE (Bechtel)  
H. D. Bono  
NSRB (Patty Reynolds)  
J. M. Chapman  
A140.001.002(1147)