



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20585-0001

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 121
License No. NPF-49

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated June 8, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 121, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Phillip F. McKee, Director
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: November 29, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 121

FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Appendix A, Technical Specifications, with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

xi
3/4 5-2
3/4 8-23

Insert

xi
3/4 5-2

←

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1	A.C. SOURCES
	Operating 3/4 8-1
TABLE 4.8-1	DIESEL GENERATOR TEST SCHEDULE 3/4 8-9
	Shutdown 3/4 8-10
3/4.8.2	D.C. SOURCES
	Operating 3/4 8-11
TABLE 4.8-2a	BATTERY SURVEILLANCE REQUIREMENTS 3/4 8-13
TABLE 4.8-2b	BATTERY CHARGER CAPACITY 3/4 8-14
	Shutdown 3/4 8-15
3/4.8.3	ONSITE POWER DISTRIBUTION
	Operating 3/4 8-16
	Shutdown 3/4 8-18
3/4.8.4	ELECTRICAL EQUIPMENT PROTECTIVE DEVICES
	Containment Penetration Conductor Overcurrent Protective Devices 3/4 8-19
	Motor-Operated Valves Thermal Overload Protection . . 3/4 8-21
	Motor-Operated Valves Thermal Overload Protection Not Bypassed 3/4 8-22
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1	BORON CONCENTRATION 3/4 9-1
3/4.9.2	INSTRUMENTATION 3/4 9-2
3/4.9.3	DECAY TIME 3/4 9-3
3/4.9.4	CONTAINMENT BUILDING PENETRATIONS 3/4 9-4
3/4.9.5	COMMUNICATIONS 3/4 9-5

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c. At least once per 31 days when the RCS pressure is above 1000 psig by verifying that the associated circuit breakers are locked in a deenergized position or removed.