

231 W Michigan, PO Box 2046, Milwaukee, WI 53201

(414) 2"1-2345

IE22

111

125

VPNPD-92-147 NRC-92-041 10 CFR 50.73

April 9, 1992

U. S. NUCLEAR REGULATORY COMMISSION Document Control Desk Mail Station P1-137 Washington, DC 20555

Gentlemen:

DOCKET 50-301 LICENSEE EVEN'T REPORT 92-001-00 IMPROPER CALIBRATION OF ONE CHANNEL OF OVER-TEMPERATURE DELTA T, RESULTING IN A TECHNICAL SPECIFICATION VIOLATION POINT BEACH NUCLEAR PLANT, UNIT 2

Enclosed is Licensee Event Report 92-001-00 for Point Beach Nuclear Plant, Unit 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i), "Any operation or condition prohibited by the plant's Technical Specifications." This report describes the improper calibration of one channel of overtemparature delta T, which resulted in a violation of the minimum operable channels and minimum degree of redundancy.

This report was initially submitted on March 17, 1992, but it was improperly numbered as Licensee Event Roport 92-003-00. This submittal is being made to rectify that error, and we request that LER 92-003-00 be withdrawn and replaced by 92-001-00.

Please contact us if there are any questions.

Sincerely,

ames John

James J. Zach Vice President Nuclear Power

9204140001 920409 PDR ADDCK 05000301

Enclosure

1.000.1

Ø.

Copies to NRC Resident Inspector NRC Regional Administrator