

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Dresden Nuclear Power Station Unit 3	DOCKET NUMBER (2) 0 5 0 0 0 2 4 9	PAGE (3) 1 OF 0 2
--	---	-----------------------------

TITLE (4)
East LPCI Submarine Door Found Open

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)							
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)					
0	7	16	8	4	4	0	0	5	0	0	0	0	5	0	0	0
									N/A		0	5	0	0	0	
											0	5	0	0	0	

OPERATING MODE (8) N	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)									
POWER LEVEL (10) 01010	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(a)	<input type="checkbox"/> 80.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 80.38(a)(1)	<input type="checkbox"/> 80.73(a)(2)(v)	<input type="checkbox"/> 73.71(e)						
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 80.38(a)(2)	<input type="checkbox"/> 80.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 80.73(a)(2)(i)	<input type="checkbox"/> 80.73(a)(2)(vii)(A)							
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 80.73(a)(2)(ii)	<input type="checkbox"/> 80.73(a)(2)(vii)(B)							
<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 80.73(a)(2)(iii)	<input type="checkbox"/> 80.73(a)(2)(x)								

LICENSEE CONTACT FOR THIS LER (12)

NAME Mark Leahy (X-422)	TELEPHONE NUMBER
	AREA CODE: 8115 NUMBER: 914 121-29210

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS
A									

SUPPLEMENTAL REPORT EXPECTED (14)

<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE) <input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15) MONTH: 11 DAY: 12 YEAR: 1984
--	--

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (18)

With the unit shutdown for high pressure turbine repair, the east LPCI corner room submarine door was found open in violation of the Technical Specifications. Safety significance was minimal, since LPCI and core spray were not required to be operable and the door was immediately closed. The door had been left open by Stationmen working in the area earlier. It was emphasized to the Stationmen that the Technical Specifications require that these doors remain closed. An annunciator will be installed indicating that the door has been opened on all four submarine doors between the LPCI/core spray pump vaults and the torus basements.

8408210104 840813
PDR ADOCK 05000249
S PDR

IEZZ 111

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Dresden Nuclear Power Station Unit 3	DOCKET NUMBER (2) 0 5 0 0 0 2 4 9	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 0 5	- 0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

With the unit shutdown for turbine repair, the east LPCI corner room submarine door was found open. Safety significance was minimal since LPCI and core spray were not required to be operable. Previous similar occurrence was reported by R.O. 84-006 on Docket #050237.

A breathing air hose was found passing through the east LPCI corner room submarine door. The hose was left there by Stationmen working in the area earlier. The hose was removed and the door closed. It was emphasized to the Stationmen that the Technical Specifications require that this door remain closed.

To ensure that these four doors remain closed except for passage, annunciators will be installed, informing the control room operator that a door has been opened. These annunciators will be installed by September, 1985.



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

August 13, 1984

DJS Ltr #84-802

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report #84-005-0, Docket #050249 is being submitted as required by Technical Specification 6.6, NUREG 1022 and 10 CFR 50.73 (a)(2)(i)(B).

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III
Filer/NRC
File/Numerical

IE22
11