Update Report: Previous Report Date - April 18, 1983 . NRC FORM 366 (12-81) 10 CFR 50 U.S. NUCLEAR REGULATORY COMMISSION APPROVED BY OMB 3150-0011 LICENSEE EVENT REPORT CONTROL BLOCK (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 0 1 (5) CON'T REPORT L 6 0 5 0 0 0 3 8 7 0 0 3 1 9 8 3 0 0 8 0 2 8 4 9 0 1 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) [During a monthly surveillance on the "D" Diesel Generator, a fuel oil leak devel-0 2 0 3 oped on the 1L cylinder. The diesel was shutdown, the remaining A.C. electrical power sources were determined operable and the operability surveillance require-0 4 Iments were performed on the remaining diesel generators (Tech. Spec. 3.8.1.1). 0 5 The leaking fuel injector was sent to the vendor for examination. 0 6 There was no effects to the public health and safety. The event was a non-valid test per Reg. 0 7 Guide 1.108, Rev. 1. 0 8 8.0 COMP CODE SUBCODE CAUSE SUBCODE SUBCODE COMPONENT CODE E (12) (11) Z (15) Z (16) ELEL X (13) EN G I N E 14 0 9 19 20 12 13 1.8 OCCURRENCE REVISION REPORT SEQUENTIAL REPORT NO CODE TYPE NO EVENT YEAR 17 REPORT NUMBER 831 0 4 0 3 6 Х 1 28 30 31 32 MANUFACTURER 26 EFFECT ON PLANT SHUTDOWN METHOD ATTACHMENT SUBMITTED ACTION NPRD-4 PRIME COMP (22) HOURS FORM SUPPLIER ACTION N 23 N 24 Z 20 Z (21) 00 A 25 C | 6 | 3 | 4 A 18 Z 19 0 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) [The fuel oil was leaking around the injection pump's metering shaft. The diesel 1 0 [could have continued operating, however, it was shutdown to replace the pump with | 1 1 an identical unit. The replaced pump was sent to its vendor for repairs; upon 1 2 inspection, no damaged parts could be found. There have been no similar occur-3 1 rances either before or since this event. 1 4 METHOD OF FACILITY (30) (32) POWER OTHER STATUS DISCOVERY DESCRIPTION STATUS B (31) Operator Observation B (28) 1 0 0 (29) NA 1 5 12 10 1.8 44 ACTIVITY CONTENT (35) LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY Z 33 Z 34 NA NA 1 6 10 80 PERSONNEL EXPOSURES 11 44 NUMBER 0 0 0 0 0 Z 38 NA . 7 12 80 PERSONNEL INJURIES NUMBER 8408210290 840802 0 0 0 0 NA 1 8 PDR ADOCK 05000387 1.1 12 LOSS OF OR DAMAGE TO FACILITY PDR Z (42) 1 9 NA 80 PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY N (a) 20 NA PHONE (717)542-3239 NAME OF PREPARER B.L. Wilks Et.



August 2, 1984

- -- 11 -

Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

04 al 21 - 2 21 12

Dr. Thomas E. Murley Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION LICENSEE EVENT REPORT 83-046/03X-1 ER 100450 FILE 841-23 PLA-2266

Docket No. 50-387 License No. NPF-14

Dear Dr. Murley:

Attached is Licensee Event Report 83-046/03X-1. This event was originally determined to be reportable per Technical Specification 6.9.1.9.b, in that during the performance of a monthly surveillance test on the 'D' Diesel Generator, a fuel oil leak developed at the 1L cylinder causing the diesel to be shutdown. Revision 1 of the Licensee Event Report is provided for additional information concerning actions that were taken as a result of this event.

Weise,

H.W. Keiser Superintendent of Plant - Susquehanna

6LW/pjg

cc: Mr. R.H. Jacobs Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 52 Shickshinny, PA 18655

> U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555