

DMB

AUG 15 1984

Docket No. 50-456  
Docket No. 50-457

Commonwealth Edison Company  
ATTN: Mr. Cordell Reed  
Vice President  
Post Office Box 767  
Chicago, IL 60590

Gentlemen:

Thank you for your letter dated July 31, 1984, informing us of the steps you have taken to correct the items of noncompliance which we brought to your attention in Inspection Report No. 50-456/84-09 and 50-457/84-09 forwarded by our letter dated July 2, 1984.

With regard to Item 1, your response stated that the contractors will develop the procedures necessary to implement the additional specification requirements. Our follow-up inspection to resolve this finding will include confirming that qualitative and quantitative clearance criteria established for large bore piping, HVAC, and existing criteria for small bore piping will also be applied to the electrical contractor, as electrical installations may occur after piping and HVAC installations. We will also review the procedures to confirm that measures have been established to perform inspections for both past and future contractor installations. We understand that your final area walkdown by Sargent and Lundy will include a 100% inspection of all discipline component installations, as stipulated under Corrective Action to Avoid Further Noncompliance. Although no

8408210342 840815  
PDR ADDCK 05000456  
G PDR

JE01  
1/1

|         |                    |                |  |  |  |  |
|---------|--------------------|----------------|--|--|--|--|
| OFFICE  | RIII <i>RFW</i>    | RIII <i>WJ</i> |  |  |  |  |
| SURNAME | Warnick            | Forney         |  |  |  |  |
| DATE    | 8/7/84 <i>8/14</i> | 8/7/84         |  |  |  |  |

AUG 15 1984

further response is required, we hope the above comments clarify our understanding of your planned corrective actions, and the actions we will take to review the items of noncompliance for closure.

Your cooperation with us is appreciated.

Sincerely,

*RF Warnick*

R. F. Warnick, Chief  
Reactor Projects Branch 1

cc: D. L. Farrar, Director  
of Nuclear Licensing  
M. Wallace, Project Mana  
D. Shamblin, Constructic  
Superintendent  
J. F. Gudac, Station  
Superintendent

cc w/ltr dtd 7/31/84:  
DMB/Document Control Desk (RIDS)  
Resident Inspector, RIII  
Braidwood  
Resident Inspector, RIII Byron  
Phyllis Dunton, Attorney  
General's Office, Environmental  
Control Division  
Jane Whicher, Esq.