

South Carolina Electric & Gas Company P.O. Box 88 Jenkinsville, SC 29065 (803) 345-4040 John L. Skolds Vice President Nuclear Operations

April 15, 1992

Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 2055

Attention: Mr. G. F. Wunder

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)

DOCKET NO. 50/395

OPERATING LICENSE NO. NPF-12

TECHNICAL SPECIFICATION CHANGE - TSP 890022 ENGINEERED SAFETY FEATURES RESPONSE TIMES

In accordance with 10CFR50.90, South Carolina Electric & Gas Company (SCE&G) is submitting an amendment request to License NPF-12 to amend the Technical Specifications (TS) for VCSNS. The proposed change is a revision to Table 3.3-5, "Engineered Safety Features Response Times." The purpose of this change is to incorporate additional time requirements to account for the sequential stroking of the Refueling Water Storage Tank outlet isolation valves and the Volume Contro: Tank outlet isolation valves. These response times have been verified during the performance of past Response Time Surveillance Tests.

The amendment request is contained in the following enclosures:

Enclosure 1 Proposed TS Change

Enclosure 2 Description and Safety Evaluation

Enclosure 3 Determination of No Significant Hazards Consideration

The proposed TS change has been reviewed and approved by the Plant Safety Review Committee and the Nuclear Safety Review Committee.

I declare that the statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

Should you have any question concerning this issue, please call Mr. Manuel W. Gutierrez at (803) 345-4392 at your convenience.

Very truly yours.

John L. Skolds

MWG:JLS:1cd Enclosures

c: See Page 2

R

9204200130 9 PDR ADOCK 05000395 PDR PDR Document Control Desk TSP 890022 Page 2 of 2

c: O. W. Dixon Jr.
R. R. Mahan
R. J. White
S. D. Ebneter
G. F. Wunder
General Managers
NRC Res'dent Inspector
J. B. Knotts Jr.
H. G. Shealy
RTS (TRP 890022)
File (813.20)