

Southern Nuclear Operating Company
Post Office Box 1290
Birmingham, Alabama 35201
Telephone 205 668-5086



Southern Nuclear Operating Company
the southern electric system

J. D. Woodard
Vice President
Farley Project

April 15, 1992

Docket No. 50-348

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555


Joseph M. Farley Nuclear Plant
Unit 1
Monthly Operating Data Report

Gentlemen:

Attached is the March 1992 Monthly Operating Report for Joseph M. Farley Nuclear Plant Unit 1, as required by Section 6.9.1.10 of the Technical Specifications.

If you have any questions, please advise.

Respectfully submitted,


J. D. Woodard

AEJ:edb3014

Attachments

cc: Mr. S. D. Feneber
Mr. S. T. Hoffman
Mr. G. F. Maxwell

9204210012 920331
PDR ADDCK 05000348
R PDR

JE24 1/1

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 1
NARRATIVE SUMMARY OF OPERATIONS
March, 1992

There were no unit shutdowns or major power reductions during the month of March.

The following major safety-related maintenance was performed during the month:

1. Miscellaneous corrective and preventive maintenance was performed on the diesel generators.

OPERATING DATA REPORT

DOCKET NO. 50-348
 DATE April 6, 1992
 COMPLETED BY D. N. Morey
 TELEPHONE (205)899-5156

OPERATING STATUS

- | | |
|---|--|
| 1. Unit Name: <u>Joseph M. Farley - Unit 1</u>
2. Reporting Period: <u>March 1992</u>
3. Licensed Thermal Power (MWT): <u>2,652</u>
4. Nameplate Rating (Gross MWe): <u>860</u>
5. Design Electrical Rating (Net MWe): <u>829</u>
6. Maximum Dependable Capacity (Gross MWe): <u>855.7</u>
7. Maximum Dependable Capacity (Net MWe): <u>812.0</u>
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: <u>N/A</u>
9. Power Level To Which Restricted, If Any (Net MWe): <u>N/A</u>
10. Reasons For Restrictions, If Any: <u>N/A</u> | Notes
1) Cumulative data since 12-1-77, date of commercial operation. |
|---|--|

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	744.0	2,184.0	125,640.0
12. Number Of Hours Reactor Was Critical	744.0	2,184.0	98,094.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	3,650.0
14. Hours Generator On-Line	744.0	2,184.0	96,448.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,972,000.6	5,787,518.0	247,192,142.1
17. Gross Electrical Energy Generated (MWH)	639,764.0	1,884,984.0	79,669,746.0
18. Net Electrical Energy Generated (MWH)	607,732.0	1,790,174.0	75,204,972.0
19. Unit Service Factor	100.0	100.0	76.8
20. Unit Availability Factor	100.0	100.0	76.8
21. Unit Capacity Factor (Using MDC Net)	100.6	100.9	74.0
22. Unit Capacity Factor (Using DER Net)	98.5	98.9	72.2
23. Unit Forced Outage Rate	0.0	0.0	7.0

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refueling/Maintenance Outage, September 25, 1992, Approximately 60 Days

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>08/06/77</u>	<u>08/09/77</u>
INITIAL ELECTRICITY	<u>08/20/77</u>	<u>08/18/77</u>
COMMERCIAL OPERATION	<u>12/01/77</u>	<u>12/01/77</u>

DOCKET NO. 50-348

UNIT 1

DATE April 6, 1992

COMPLETED BY D. N. Morey

TELEPHONE (205)899-5156

MONTH March

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DA'LY POWER LEVEL (MWe-Net)
1	<u>816</u>	17	<u>818</u>
2	<u>818</u>	18	<u>815</u>
3	<u>816</u>	19	<u>813</u>
4	<u>815</u>	20	<u>819</u>
5	<u>813</u>	21	<u>819</u>
6	<u>810</u>	22	<u>822</u>
7	<u>805</u>	23	<u>819</u>
8	<u>805</u>	24	<u>820</u>
9	<u>816</u>	25	<u>819</u>
10	<u>816</u>	26	<u>817</u>
11	<u>821</u>	27	<u>817</u>
12	<u>820</u>	28	<u>820</u>
13	<u>820</u>	29	<u>818</u>
14	<u>820</u>	30	<u>814</u>
15	<u>819</u>	31	<u>817</u>
16	<u>822</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-348
 UNIT NAME J. M. FARLEY - UNIT 1
 DATE April 6, 1992
 COMPLETED BY D. N. MOREY
 TELEPHONE (205)899-5156

REPORT MONTH MARCH

NO.	DATE	TYPE ¹	DURATION (HOURS)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT #	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
-----	------	-------------------	---------------------	---------------------	--	-------------------------------	-----------------------------	--------------------------------	---

There were no unit shutdowns or major power reductions during the month of March.

¹F: Forced
 S: Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴Exhibit G-Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report(LER) File (NUREG-
 0161)

⁵Exhibit I -Same Source