



PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO. BOX 97
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

April 15, 1992
PY-CF1/NRR-1476 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Gentlemen:

Attached is the March 1992 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,

A handwritten signature in cursive script that reads 'Michael D. Lyster'.

Michael D. Lyster

MDL:DWC:ss

Attachment

cc: NRR Project Manager
USNRC Senior Resident Inspector - Perry
USNRC, Region III
Director, Office of Resource Management
Ohio EPA

9204210200 920331
PDR ADOCK 05000440
R PDR

Operating Company
Cleveland Electric Illuminating
Trudeo Edison

210020

Handwritten initials 'JL24' in the bottom right corner of the page.

CLEVELAND ELECTRIC ILLUMINATING COMPANY

FERRY NUCLEAR POWER PLANT

March 1, 1992 - March 31, 1992

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO. 50-440
UNIT Perry-1
DATE 04/15/92
Contact H. L. Hegrat
Telephone: (216)259-3737

MONTH March 1992

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	<u>1170</u>	17	<u>1161</u>
2	<u>1176</u>	18	<u>1157</u>
3	<u>1177</u>	19	<u>1175</u>
4	<u>1174</u>	20	<u>812</u>
5	<u>1169</u>	21	<u>0</u>
6	<u>1166</u>	22	<u>0</u>
7	<u>1165</u>	23	<u>0</u>
8	<u>1168</u>	24	<u>0</u>
9	<u>1159</u>	25	<u>0</u>
10	<u>1165</u>	26	<u>0</u>
11	<u>1178</u>	27	<u>0</u>
12	<u>1179</u>	28	<u>0</u>
13	<u>1178</u>	29	<u>0</u>
14	<u>1177</u>	30	<u>0</u>
15	<u>1174</u>	31	<u>0</u>
16	<u>1174</u>		

Operating Data Report

UNIT: PERRY-1
 DATE: 04/15/92

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: March 1992
3. Utility Contact: H. L. Hegrat (216, 259-3737)
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
None
10. Power Level To Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	This Month	Yr-to-Date	Cumulative
12. Hours In Reporting Period	744.0	2,184.0	28,292.0
13. Hours Reactor Was Critical	493.3	1,874.4	28,556.9
14. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
15. Hours Generator On-Line	482.6	1,824.7	27,718.6
16. Unit Reserve Shutdown Hours	0.0	0.0	0.0
17. Gross Thermal Energy (MWH)	1,690,907	6,412,741	95,045,630
18. Gross Electrical Energy (MWH)	580,692	2,209,243	32,704,645
19. Net Electrical Energy (MWH)	548,782	2,099,920	31,051,074
20. Unit Service Factor	64.9%	83.5%	72.4%
21. Unit Availability Factor	64.9%	83.5%	72.4%
22. Unit Capacity Factor (Using MDC Net)	63.3%	82.5%	70.6%
23. Unit Capacity Factor (Using DER Net)	61.9%	80.7%	68.1%
24. Unit Forced Outage Rate	0.0%	5.1%	7.9%
25. Forced Outage Hours	0.0	97.9	2,381.2
26. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):			

27. If Shut Down at end of Report Period, Estimated Date of Startup:
May 21, 1992

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March 1992

DOCKET NO. 50-449
 UNIT NAME Perry - 1
 DATE 04/15/92
 CONTACT H. L. Hegrat
 TELEPHONE (216)259-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
92-01	03/20/92	S	261.4	C	1	N/A	N/A	N/A	Commenced reactor shutdown to begin Refueling Outage #3.

SUMMARY: During March 1992, Perry-1 began the month at full power operation and continued at this level until 03/20/92, when a reactor shutdown was commenced to begin Refueling Outage #3.

- ¹ F: Forced
 S: Scheduled
- ² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

- ³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

- ⁴ Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG1022)
- ⁵ Exhibit I-Same Source