

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077-0004  
(412) 393-5206  
(412) 643-8069 FAX

GEORGE S. THOMAS  
Division Vice President  
Nuclear Services  
Nuclear Power Division

December 7, 1995

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Operating License Change Request No. 229**


Pursuant to 10 CFR 50.90, Duquesne Light Company requests an amendment to the above license in the form of changes to the technical specifications. The proposed changes will implement the requirements of Generic Letter (GL) 95-05 for voltage-based steam generator tube repair criteria.

The proposed technical specification changes are presented in Attachment A. The safety analysis (including the no significant hazards evaluation) is presented in Attachment B. A technical evaluation of the voltage-based repair criteria is presented in Attachment C. The first paragraph of Attachment C page 4 of 8 describes the confirmation rate for rotating pancake coil no detectable degradations (RPC NDD) left in service. For the next inspection, we are requesting NRC approval to apply the larger of 0.51 or the next inspection result as a fraction of RPC NDD indications included in the beginning of cycle distribution. This is consistent with GL 95-05 Section 2.b.1 which provides an option to apply a fraction of unconfirmed RPC NDD indications in the beginning of cycle voltage distribution.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee. The change was determined to be safe and does not involve a significant hazard consideration as defined in 10 CFR 50.92 based on the attached safety analysis.

Approval of this amendment is requested prior to the start of the Beaver Valley Power Station, Unit No. 1 eleventh refueling outage which is scheduled to start on March 23, 1996. An implementation date will be established prior to amendment issuance.

Sincerely,

  
George S. Thomas

030036

9512080131 951207  
PDR ADOCK 05000334  
P PDR

A001  
1/11

Beaver Valley Power Station, Unit No. 1  
Proposed Operating License Change Request No. 229  
Page 2

c: Mr. L. W. Rossbach, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. D. S. Brinkman, Sr. Project Manager  
Mr. W. P. Dornsife, Director BRP/DEP  
Mr. M. P. Murphy (BRP/DEP)

AFFIDAVIT FOR APPLICATION

OF AMENDMENT


COMMONWEALTH OF PENNSYLVANIA )

) SS:

COUNTY OF BEAVER )


**Subject: Beaver Valley Power Station, Unit No. 1  
BV-1 Docket No. 50-334, License No. DPR-66  
Proposed Operating License Change Request No. 229**

Before me, the undersigned notary public, in and for the County and Commonwealth aforesaid, this day personally appeared George S. Thomas, to me known, who being duly sworn according to law, deposes and says that he is Division Vice President, Nuclear Services of the Nuclear Power Division, Duquesne Light Company, he is duly authorized to execute and file the foregoing submittal on behalf of said Company, and the statements set forth in the submittal are true and correct to the best of his knowledge, information and belief.

  
George S. Thomas

Subscribed and sworn to before me

on this *7th* day of *December, 1995*

  
Notary Public

Notarial Seal  
Tracy A. Baczek, Notary Public  
Shippingport Boro, Beaver County  
My Commission Expires Aug. 16, 1997

Member, Pennsylvania Association of Notaries

ATTACHMENT A

Beaver Valley Power Station, Unit No. 1  
Proposed Technical Specification Change No. 229

---

The following is a list of the affected pages:

Affected Pages:	3/4 4-9
	3/4 4-10b
	3/4 4-10c
	3/4 4-10d
	3/4 4-13
	B 3/4 4-2a
	B 3/4 4-3g
	B 3/4 4-3h

(Proposed Wording)