

ENCLOSURE 1

NOTICE OF VIOLATION

Entergy Operations, Inc.  
Arkansas Nuclear One

Docket: 50-368  
License: NPF-6

During an NRC inspection conducted on September 17 through October 28, 1995, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions" (60 FR 34381; June 30, 1995), the violation is listed below:

Unit 2 Technical Specification 3.7.1.1, Table 3.7-5, states, in part, that main steam safety valve "lift set pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure."

Contrary to the above, between September 30 and October 9, 1995, the licensee determined that five of the main steam safety valves did not lift at their required Technical Specification lift setting because the valves had previously been adjusted and tested at the incorrect nominal operating temperature and pressure. As a result, the plant operated for an entire cycle with five inoperable main steam safety valves.

This is a Severity Level IV violation (Supplement I) (368/9508-01).

Pursuant to the provisions of 10 CFR 2.201, Entergy Operations, Inc. is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Your response may reference or include previous docketed correspondence, if the correspondence adequately addresses the required response. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown consideration will be given to extending the response time.

Because the response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if it is necessary to include such information, it should

clearly indicate the specific information that should not be placed in the PDR and provide the legal basis to support the request for withholding the information from the public.

Dated at Arlington, Texas,  
this 5<sup>th</sup> day of *December* 1995