




KANSAS GAS AND ELECTRIC COMPANY

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

August 8, 1984



Mr. D.R. Hunter, Chief
Reactor Project Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

KMLNRC 84-136
Re: Docket No. STN 50-482
Ref: KMLNRC 84-064 dated 4/18/84 to EHJohnson,
NRC, from GLKoester, KG&E
Subj: Supplemental Information for Final 10CFR50.55(e)
Report - Auxiliary Feedwater Turbine Control
Circuit

Dear Mr. Hunter:

This letter provides supplemental information to correct a statement concerning the corrective action for the Auxiliary Feedwater Turbine control circuitry. The Reference stated that a Field Rework Plan had been issued to modify the Wolf Creek circuitry to be compatible with the vendor supplied circuitry when in fact the Field Rework Plan altered the vendor supplied circuitry to be compatible with the Wolf Creek circuitry.

If you have any questions concerning this matter, please contact me or Mr. Otto Maynard of my staff.

Yours very truly,

Glenn L Koester

GLK:bb
xc: RCDeyoung
PO'Connor
HBundy

8408220158 840808
PDR ADOCK 05000482
S PDR

IE-27

70