

Nebraska Public Power District
DESIGN CALCULATIONS COVER SHEET

Title <u>Evaluation of Core Shroud Inspection Results</u>	Calculation No. <u>NEDC 95-191</u>
System/Structure <u>RPV</u>	Task Identification No. <u>N/A</u>
Component <u>Core Shroud</u>	Design Change No. <u>N/A</u>
Classification: <input checked="" type="checkbox"/> Essential <input type="checkbox"/> Non-Essential	Discipline <u>Civil/Structural</u>

Calc. Description:

The purpose of this calculation is to evaluate the results of General Electric's (GE) inspection of the CNS Core Shroud horizontal welds to determine if additional evaluation or NDE characterization is needed for the welds. The inspection results will be evaluated using the "Evaluation and Screening Criteria for the Cooper Shroud" developed by GE (see Attachment 2.4). Eight horizontal (circumferential) welds (H1, H2, H3, H4, H5, H6a, H6b, and H7) were inspected during CNS's 1995 refueling outage and are subject to this evaluation.

References: (See Sheet 2 of the Calculation)

1. USAR _____
2. TECH. SPECS. _____
3. Consult. Calculation: _____
4. NED Calculation: _____
5. Computer Program: _____

Attachments: (See Sheet 2 of the Calculation)

- A. _____
- B. _____
- C. _____
- D. _____
- E. _____

0	2	Original Issue	Perry K. Adelung 11-29-95	Atwood A. Browning 11-29-95	Atwood A. Browning 11-29-95	Darek J. Sujanowski 12-1-95
Rev.	Status	Revision Description	Prepared By/Date	Checked or Reviewed By/Date	Design Verification/Date	Approved By/Date
No.						

Status Code

1. As-Built
2. Information only
3. For Construction
4. Superseded or Deleted

9512110454 95120B
PDR ADDCK 05000298
P PDR

DESIGN CALCULATION CROSS REFERENCE INDEX

NEDC 95-191 Prepared By: Perry K. Adelung Checked/Reviewed By: Atwood A. Brown, mg

Date: November 29 1995 Date: 11-29 1995

* C = Change A = Addition D = Deletion

** Use modification document (DC, ESC, etc.) number when a calculation is associated with a modification. Otherwise, the CMDC database is normally specified.

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet 2 of 3Calc No. NEDC 95-191Prepared By: Perry K. Adelung PKAChecked/Reviewed By: Atwood A. Browning *AAB*Date:November 29,1995Date: November 29,1995**1.0 REFERENCES**

- 1.1 USAR - Section III-3.4.1.1 and IV-2.5.2
- 1.2 Technical Specifications - N/A
- 1.3 Consultant Calculation - N/A
- 1.4 NED Calculation - N/A
- 1.5 Computer Program - N/A
- 1.6 "BWR Core Shroud Inspection and Flaw Evaluation Guidelines", Rev. 1, GENE-523-113-0894

2.0 ATTACHMENTS

- 2.1 Evaluation of Weld Indications using Screening Criteria for Limit Load Method
- 2.2 Evaluation of Weld Indications using Screening Criteria for LEFM Method
- 2.3 General Electric Final Inspection Report
- 2.4 General Electric document GENE-523-174-1293, Rev. 2, "Evaluation and Screening Criteria for the Cooper Shroud"

3.0 PURPOSE

The purpose of this calculation is to evaluate the results of General Electric's (GE) inspection of the CNS Core Shroud horizontal welds to determine if additional evaluation or NDE characterization is needed for the welds. The inspection results will be evaluated using the "Evaluation and Screening Criteria for the Cooper Shroud" developed by GE (see Attachment 2.4). Eight horizontal (circumferential) welds (H1, H2, H3, H4, H5, H6a, H6b, and H7) were inspected during CNS's 1995 refueling outage and are subject to this evaluation.

4.0 CALCULATION INPUTS

- 4.1 GE inspection data (see Attachment 2.3)
- 4.2 Core Shroud thickness (t) = 1.5 inches (see Attachment 2.4)
- 4.3 Crack growth extension (Δa) = 0.6 inches for an 18 month fuel cycle (see Attachment 2.4). For the calculations in Attachments 2.1 and 2.2, $a = \Delta a$.
- 4.4 Allowable flaw lengths are specified in Attachment 2.4.

5.0 ASSUMPTIONS

- 5.1 All uninspected areas of a weld are conservatively assumed to be through-wall cracks for the entire uninspected length of the weld (e.g., for weld H1 the flaw length between $0 - 15.5^\circ = 15.5^\circ \times 1.65''/\circ = 25.58''$).
- 5.2 See sheet 7 of Attachment 2.4.

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet 3 of 3Calc No. NEDC 95-191Prepared By: Perry K. AdelungPKAChecked/Reviewed By: Atwood A. BrowningAABDate: November 29,1995Date: November 29,1995**6.0 METHODOLOGY****6.1 General**

The General Electric screening criteria document (Attachment 2.4) specifies two methods for determining if additional evaluation or NDE characterization is needed for the Core Shroud welds: 1) Limit Load Analysis and 2) Linear Elastic Fracture Mechanics (LEFM).

6.2 Limit Load Method

Inspection data is evaluated by calculating effective flaw lengths using established "proximity rule" equations and comparing these calculated flaw lengths with allowable flaw lengths. The allowable flaw lengths are for any 90° sector of the applicable weld. The application of the limit load effective length criteria is applied to two adjacent indications/flaws at a time. This methodology is explained in detail in Attachment 2.4.

6.3 LEFM Method

Inspection data is evaluated by calculating equivalent flaw lengths using established "proximity rule" equations and comparing these calculated flaw lengths with the allowable flaw length. The allowable flaw length is compared to the maximum single equivalent flaw length. The allowable flaw length was determined as described on sheet 25 of Attachment 2.4. The equivalent flaw length is described on sheets 18-19 of Attachment 2.4.

7.0 CALCULATIONS**7.1 Limit Load**

All eight horizontal welds were evaluated using the Limit Load screening criteria (reference section 5.0 of Attachment 2.4). The evaluation of welds H1, H2, H3, H4, H5, H6a, H6b, and H7 is included as Attachment 2.1.

7.2 LEFM

Three horizontal welds were evaluated using the LEFM screening criteria (reference section 5.0 of Attachment 2.4). The evaluation of welds H4, H5, and H6a is included as Attachment 2.2.

8.0 CONCLUSIONS

All evaluated welds meet the applicable Limit Load and/or LEFM screening criteria. No further evaluation or NDE characterization is necessary for any of the horizontal welds.

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet of Calc No. NEDC 95-191Prepared By: Perry K. Adelung PKA Checked/Reviewed By: Atwood A. Browning*AAB*Date: November 29 1995Date: November 29 1995**ATTACHMENT 2.1**

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 1 of 8

WELD DESIGNATION: H1 (REFERENCE SHEET 7 OF ATTACHMENT 2.3)

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flaw length for any one 90 degree sector = $18.69 - (a = 0.6) + 2.87 + 4.33 + (40 \text{ deg} \times 1.65^\circ/\text{deg}) + (a = 0.6) = 91.89^\circ$ (in sector 284.9 - 14.9 deg.)
 2. One degree = 1.65°

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 2 of 3

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flow length for any one 90 degree sector = $18.69 - (a = 0.6) + (40 \text{ deg} \times 1.65^\circ/\text{deg}) + (a = 0.6) = 84.69^\circ$ (in sector $284.9 - 14.9 \text{ deg.}$)
 2. One degree = 1.65°

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191

Attachment 2.1

Sheet 3 of 8

WELD DESIGNATION: H3 (REFERENCE SHEET 31 OF ATTACHMENT 2.3)

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flaw length for any one 90 degree sector = $17.79 - (a = 0.6) + 9.19 + (41.36 \text{ deg} \times 1.55^\circ/\text{deg}) + (a = 0.6) = 91.09^\circ$ (in sector 284.9 - 14.9 deg.)
 2. One degree = 1.55°

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 4 of 8

WELD DESIGNATION: H4 (REFERENCE SHEET 45 OF ATTACHMENT 2-3)

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flaw length for any one 90 degree sector = $41.81 - (a = 0.6) + (14.5 \text{ deg} \times 1.55''/\text{deg}) + (a = 0.6) = 64.29''$ (in sector 169.3 - 259.3 deg.)
 2. One degree = 1.55''

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191

Attachment 2.1

Sheet 5 of 8

WELD DESIGNATION: H5 (REFERENCE SHEET 56 OF ATTACHMENT 2.3)

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flow length for any one 90 degree sector = $46.46 - (a = 0.6) + (14.5 \text{ deg} \times 1.55''/\text{deg}) + (a = 0.6) = 68.94''$ (In sector 169.3 - 259.3 deg.)
 2. One degree = $1.55''$

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 6 of 8

WELD DESIGNATION: H6a (REFERENCE SHEET 69 OF ATTACHMENT 2.3)													
Indication Number	Indication Type (C or A)	Start Location (Azimuth)	End Location (Azimuth)	Indication Length L_i (in.)	Distance to Next Indication S_{i+1} (in.)	$2l + 2a$ (in.)	L_{eff} (C/C)		L_{eff} (C/A)		Adjusted Indication Number	Allowable L_i (in.) (Per any 90 deg. sector)	Results (Sat/Unsat)
							$L_{eff} = L_i + S + L_{i+1} + 2a$ ($S_{i+1} < 2l + 2a$)	$L_{eff} = L_i + 2a$ ($S_{i+1} > 2l + 2a$)	$L_{eff} = L_i + 2a$	$L_{i+1,eff} = L_{i+1} + 2a$			
*A + *D	C	334.8	15.5	63.09	236.39	4.2		64.29			H6a.1	90 Sat. (No 90 deg sector exceeds 90°)	
*B	C	169.3	203.5	53.01	48.92	4.2		54.21			H6a.2		
1	C	235.06	236.44	2.14	12.96	4.2		3.34			H6a.3		
*C	C	244.8	265.5	32.09	107.42	4.2		33.29			H6a.4		
					150.33	407.69							

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flow length for any one 90 degree sector = $54.21 - (a = 0.6) + 3.34 + (14.5 \text{ deg} \times 1.55^\circ/\text{deg}) + (a = 0.6) = 80.03''$ (in sector 169.3 - 259.3 deg.)
 2. One degree = 1.55°

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 7 of 8

WELD DESIGNATION: H6b (REFERENCE SHEET 82 OF ATTACHMENT 2.3)

Indication Number	Indication Type (C or A)	Start Location (Azimuth)	End Location (Azimuth)	Indication Length L_i (in.)	Distance to Next Indication S_{i+1} (in.)	$2t + 2a$	L_{eff} (C/C)		L_{eff} (C/A)		Adjusted Indication Number	Allowable L_i (in.) (Per any 90 deg. sector)	Results (Sat/Unsat)
							$L_{eff} = L_i + S + a$ ($S_{i+1} < 2t + 2a$)	$L_{eff} = L_i + 2a$ ($S_{i+1} > 2t + 2a$)	$L_{eff} = L_i + 2a$ ($S < 2t + a$)	$L_{eff} = L_{i+1} + 2a$ ($S > 2t + a$)			
"A + "D	C	334.8	15.5	63.09	238.39	4.2		64.29				H6b.1	87 Sat. (No 90 deg sector exceeds 87")
"B	C	169.3	203.5	53.01	64.02	4.2		54.21				H6b.2	
"C	C	244.8	265.5	32.09	107.42	4.2		33.29				H6b.3	
				148.19	409.83								

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flaw length for any one 90 degree sector = $54.21 - (a = 0.6) + (14.5 \text{ deg} \times 1.55^\circ/\text{deg}) + (a = 0.6) = 76.69^\circ$ (in sector 169.3 - 259.3 deg)
2. One degree = 1.55°

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING
SCREENING CRITERIA FOR
LIMIT LOAD METHOD**

NEDC 95-191
Attachment 2.1
Sheet 8 of 8

WELD DESIGNATION: H7 (REFERENCE SHEET 93 OF ATTACHMENT 2.3)												
Indication Number	Indication Type (C or A)	Start Location (Azimuth)	End Location (Azimuth)	Indication Length L_i (in.)	Distance to Next Indication S_{i+1} (in.)	$2t + 2a$ (in.)	L_{eff} (C/C)		L_{eff} (C/A)	Adjusted Indication Number	Allowable L_i (in.) (Per any 90 deg. sector)	Results (Sat/Unsat)
							$L_{eff} = L_i + S + a$ ($S_{i+1} < 2t + 2a$)	$L_{eff} = L_i + 2a$ ($S_{i+1} > 2t + 2a$)				
*A + *D	C	339.5	15.5	53.65	229.16	4.2		54.85		H7.1	80	Sat. (No 90 deg. sector exceeds 80")
*B	C	169.3	205.5	53.94	58.56	4.2		55.14		H7.2		
*C	C	244.8	285.5	60.64	80.46	4.2		61.84		H7.3		
				168.23	368.18							

* - Indicates an assumed indication in an uninspected area

Evaluation: 1. The maximum effective flaw length for any one 90 degree sector = $55.14 - (a = 0.6) + (14.5 \text{ deg} \times 1.49''/\text{deg}) + (a = 0.6) = 76.75''$ (in sector 169.3 - 259.3 deg.)
2. One degree = $1.49''$

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet of Calc No. NEDC 95-191Prepared By: Perry K. AdelungPKA Checked/Reviewed By: Atwood A. Browning*AAB*Date: November 29 1995Date: November 29 1995**ATTACHMENT 2.2**

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING SCREENING CRITERIA FOR
LEFM METHOD**

NEDC 95-191
Attachment 2.2
Sheet 1 of 3

WELD DESIGNATION: H4 (REFERENCE SHEET 45 OF ATTACHMENT 2.3)											
Indication Number	Indication Type (C or A)	Start Location (Azimuth)	End Location (Azimuth)	Indication Length L _i (in.)	Distance to Next Indication S _{i+1} (in.)	4a (in.)	L _{eq} (C/C)		Adjusted Indication Number	Equivalent Single Ind. Allowable L (in.)	Results (Sat/Unsat)
							L _{eq} = L _i + L _{i+1} + 4a (S _{i+1} < 0.75 (L _i + L _{i+1} + 4a))	L _{eq} = L _i + 2a (S _{i+1} > 0.75 (L _i + L _{i+1} + 4a))			
*A + *D	C	339.3	15.5	56.12	238.39	2.4		57.32	H4.1	235	Sat. (Max. single L _{eq} < 235°)
*B	C	169.3	195.5	40.61	76.42	2.4		41.81	H4.2		
*C	C	244.8	260	23.56	122.91	2.4		24.76	H4.3		
				120.29	437.72						

* - Indicates an assumed indication in an uninspected area

Note: One degree = 1.55"

CNS CORE SHROUD - EVALUATION OF WELD INDICATIONS USING SCREENING CRITERIA FOR LEFM METHOD

NEDC 95-191

Attachment 2.2

Sheet 2 of 3

WELD DESIGNATION: H5 (REFERENCE SHEET 56 OF ATTACHMENT 2.3)

* - Indicates an assumed indication in an uninspected area

Note: One degree = 1.55"

**CNS CORE SHROUD - EVALUATION OF
WELD INDICATIONS USING SCREENING CRITERIA FOR
LEFM METHOD**

NEDC 95-191

Attachment 2.2

Sheet 3 of 3

WELD DESIGNATION: H6a (REFERENCE SHEET 69 OF ATTACHMENT 2.3)

Indication Number	Indication Type (C or A)	Start Location (Azimuth)	End Location (Azimuth)	Indication Length L _i (in.)	Distance to Next Indication S _{i+1} (in.)	4a (in.)	L_{eq} (C/C)		Adjusted Indication Number	Equivalent Single Ind. Allowable L (in.)	Results (Sat/Unsat)
							$L_{eq} = L_i + L_{i+1} + 4a$ (S _{i+1} < 0.75 (L _i + L _{i+1} + 4a))	$L_{eq} = L_i + 2a$ (S _{i+1} > 0.75 (L _i + L _{i+1} + 4a))			
*A + *D	C	334.8	15.5	63.09	238.39	2.4		64.29	H6a.1	145	Sat. (Max. single $L_{eq} < 145^{\circ}$)
*B	C	169.3	203.5	53.01	48.92	2.4		54.21	H6a.2		
1	C	235.06	236.44	2.14	12.96	2.4	36.63		H6a.3		
*C	C	244.8	265.5	32.09	107.42	2.4		33.29	H6a.4		
				150.33	407.69						

* - Indicates an assumed indication in an uninspected area

Note: One degree = 1.55"

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet 1 of 11Calc No. NEDC 95-191

Prepared By: _____

Checked/Reviewed By: _____

1/0Date: 19 Date: 19 **ATTACHMENT 2.3**



NEDC 95-191

General Electric Company
3017 West 72nd St., Suite 201, Oak Brook, IL 60521
312 573-3925

PKA 12-5-95

GENE-THB95-01
December 4, 1995

cc:

Cooper Nuclear Station

C.R. Moeller

M. J. Spencer

Mr. Terry Ackerman
Programs Engineer
Nebraska Public Power District
Cooper Nuclear Station
P. O. Box 98
Brownville, Nebraska 68321

SUBJECT: GE NUCLEAR ENERGY REPORT, NEBRASKA PUBLIC POWER DISTRICT, COOPER NUCLEAR STATION, RFO16, SHROUD UT PROJECT, 1F5CN, OCTOBER & NOVEMBER 1995

Dear Mr. Ackerman:

GENE has reviewed the content of the subject report. This review was conducted by Robert Joffe and Ralph Edwards of our Inspection Services office. Based on the review, it has been determined that the information contained within the report should not have been marked "Proprietary."

Very truly yours,

Thomas H Black

Thomas H. Black
GE Site Services Manager
402/825-5665



GE Nuclear Energy


Nebraska Public Power District
Cooper Nuclear Station

RFO16

Shroud UT Project 1F5CN


October & November 1995

Prepared by:




Steve Stanford, Shroud Project Level III

Approved by:



Ricky Seals, GENE ISI Project Manager

Approved by:



Terry Ackerman, CNS Site Engineering



GE Nuclear Energy

NEDC 95-19 ATTACH 2.3

SHEET 2 OF 101

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Proprietary Information Notice

The Information contained in this document is not to be used for other than the purposes for which this document is furnished by GE Nuclear Energy, nor is this document (in whole or in part) to be reproduced or furnished to third parties (other than to carry out said purposes) or made public without the express written permission of GE Nuclear Energy.



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

NEDC 95-19 ATTACH 2.3

SHEET 3 OF 101

Table of Contents

Section 1	Preface
Section 2	Examination Data
Section 3	Calibration Data
Section 4	Procedures
Section 5	Certifications

Not included in this
Calculation

PKA
11-15-95



Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Preface

Introduction

During October and November of 1995, GE Nuclear Energy Inspection Services performed Shroud support weld UT examinations at Nebraska Public Power District's Cooper Nuclear Station site. The original scope of examinations scheduled were all of the areas accessible for scanning with the GE Shroud OD Tracker Scanner on shroud support horizontal welds H1, H2, H3, H4, H5, H6A, H6B and H7. After examination of each weld, Nebraska Public Power District was notified of any indications within 24 hours of final sizing and categorization, depending on relevancy. In the events of actual cracking, ultrasonic length and depth sizing were provided. Visual indications and examinations are documented under a separate IVVI Report for the In-vessel Visual Inspections.

All accessible areas of the eight welds referenced above were inspected ultrasonically with the GE OD Tracker System. Actual circumferential scan areas obtained varied depending on accessibility due to various obstructions that were encountered. These areas of inaccessibility are documented on the Smart 2000 examination data sheets provided within this report. Descriptions of circumferential coverage and limitations are also described in the Examination Summary Sheet provided with each weld examination package.

Examination results are documented by weld number, in stand alone sections, within this Shroud UT report. Each section covers the weld number referenced (e.g. H1, H2, etc.) and provides a summary of examination, ultrasonic data examination sheets indicating type of indications recorded, examination profiles illustrating ultrasonic coverage, documentation supporting any relevant findings, such as cracking, is well documented in the form of graphs, illustrations or charts displaying lengths and depths, and tables containing all critical information. The overall results of the scope of examinations can be found under the Examination Data section of this report and in table form, shown at the end of this preface section.

Procedure

The shroud was examined per "Procedure for Automated Ultrasonic Examination of Shroud Assembly Welds", UT-CNS-503V4, Revision 0. Work was performed per Nebraska Public Power District's work authorizations and in accordance with the GENE QA Manual QAM-003. Shroud inspectability was pre-determined from the Nebraska Public Power District Shroud OD Inspectability Study Report and is not referenced within this document. By utilizing this procedure a pre-inspection of the projected scan areas were documented in order to ensure that proper clearances were available for the shroud UT inspection tooling.

Equipment

The equipment utilized for the Shroud UT Examinations was the Smart 2000 Data Acquisition System, the GE Shroud OD Tracker Scanner, the GE Motion Controller and Tri-modal search units containing a combination of 45° Shear Wave, 60° Refracted Longitudinal, and OD Creeping Wave search units. Installation and use of this equipment is described in detail in the Procedures section of this Report. Related equipment requiring certifications can be found in the Certifications section of this report.



Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Limitations

Due to varying obstacles near the shroud outside diameter, and in close proximity to the welds that were examined, interferences in scanning were encountered. The Guide Rods, Core Spray Downcomers and Jet Pump Sensing Lines all posed scanning limitations at various locations of the welds. In addition to these limitations, the combination of welds with unfavorable geometric configurations did further contribute to loss of examination coverage. Every attempt was made to obtain the most extensive examination coverage possible.

Data Recording

All scan data has been digitized and recorded by the Smart 2000 Data Acquisition System onto 1 Gigabyte optical discs. The original data discs are to be provided to Nebraska Public Power District and are included as part of the Shroud Ultrasonic Examination Report, October / November 1995 - 1F5CN.

The flaw indications recorded were sized in circumferential length and thru-wall depth. A measurement of flaw maximum extension from the initiating surface, whether ID or OD, is supplied in actual crack height and length, as recorded. A maximum flaw depth reading, along with its corresponding circumferential position, was taken for each indication. Indications are referenced by Indication Number, for future reference. Start and stop positions of each indication are also supplied by their respective indication reference number for future comparison.

Summary

The following table summarizes the inspections performed and overall findings of the examinations. Detailed information of the examinations can be found in the Examination Data section of this report.

Weld	Scan %	Indications	Comments
H1	66.9	See Data	IGSCC or IASCC Cracking Recorded
H2	66.9	N/A	No Evidence of IGSCC or IASCC Cracking was recorded
H3	79.9	See Data	IGSCC or IASCC Cracking Recorded
H4	78.5	N/A	No Evidence of IGSCC or IASCC Cracking was recorded
H5	76.1	See Data	IGSCC or IASCC Cracking Recorded
H6A	73.4	See Data	IGSCC or IASCC Cracking Recorded
H6B	73.4	N/A	No Evidence of IGSCC or IASCC Cracking was recorded
H7	68.6	N/A	No Evidence of IGSCC or IASCC Cracking was recorded

All Scanning was performed with an index increment of 50% of the smallest active transducer element width (50% Overlap Method).

For flaw length and though-wall sizing information of relevant cracking, as well as other types of indications recorded such as weld defects and geometric indications, reference the "Examination Data" section of this report containing each of the weld's examination results.

	GE Nuclear Energy	EXAMINATION SUMMARY SHEET	REPORT NO.: SR-01
PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN		PROCEDURE: UT-CNS-503V4 N/A	REV: 0 FRR: N/A N/A N/A
SYSTEM: SHROUD ASSEMBLY WELDS		N/A	REV: N/A FRR: N/A N/A N/A
WELD NO.: H1		N/A	REV: N/A FRR: N/A N/A N/A
CONFIGURATION: SHROUD FLANGE TO PLATE		N/A	REV: N/A FRR: N/A N/A N/A
EXAMINER: T. ROCKWOOD LEVEL: III		<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT	
EXAMINER: C. MCKEAN LEVEL: II		<input checked="" type="checkbox"/> CIRCUMFERENTIAL	
EXAMINER: N/A LEVEL: N/A		<input type="checkbox"/> LONGITUDINAL <input type="checkbox"/> OTHER N/A	
DATA SHEET NO.(S): SD-23 THRU SD-29		CAL SHEET NO.(S): SC-31 THRU SC-33	

During the examination of the referenced weld, eight (8) indications associated with IGSCC/ASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The parameters for these indications are on the following page.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications along with the indications referenced.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications along with the indications referenced.

The OD creeping wave recorded non-relevant indications and inside surface geometry along with the indications referenced.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.65 inches per degree.

This examination was performed only from the plate side due to the shroud lug interferences which obstruct scanning on the shroud support flange side. This examination was also performed simultaneously with the H2 weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation lines.

The examination area that was interrogated by all angles was 240.90° (60.9%). 119.10° (33.1%) was not examined due to the above referenced obstructions.

<i>Stephanie Steppel</i> SUMMARY BY <i>H. Chellatt</i> GE REVIEWED BY	III LEVEL II LEVEL	11-11-95 DATE 11-11-95 DATE	<i>R. H.</i> GE INDEPENDENT REVIEW <i>X. B. Thom</i> UTILITY REVIEW	11/13/95 DATE 11/14/95 DATE	PAGE: 1 OF: 13 FORMAT 01 REV. A
--	-----------------------------	--------------------------------------	--	--------------------------------------	------------------------------------



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H1 Indication Data

Total Scan Length (Deg.)	240.90	Total Flaw Length (Deg.)	10.57
Total Scan Length (In.)	398.37	Total Flaw Length (In.)	17.48
Percentage of Weld Length Examined	66.9	Thickness (In.)	1.50
Percentage of Examined Weld Length Flawed	4.4	Circumference (In.)	595.33
Percentage of Total Weld Length Flawed	2.9	Inches per Degree	1.85

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Inches	Max. Depth Pos. (Deg.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
1	60.67	61.80	1.13	1.87	0.27	61.30	18.0	ID/Near	45° Shear	60° Long.
2	86.89	87.52	0.63	1.04	0.10	87.39	6.7	ID/Near	45° Shear	60° Long.
3	92.18	93.31	1.13	1.87	0.15	92.69	10.0	ID/Near	45° Shear	60° Long.
4	148.78	150.29	1.51	2.50	0.37	149.54	24.7	ID/Near	45° Shear	60° Long.
5	210.04	211.55	1.51	2.50	0.27	210.67	18.0	ID/Near	45° Shear	60° Long.
6	271.93	273.69	1.76	2.91	0.41	272.81	27.3	ID/Near	45° Shear	60° Long.
7	298.65	299.66	1.01	1.67	0.11	299.03	7.3	ID/Near	45° Shear	60° Long.
*8	329.03	330.92	1.89	3.13	0.49	329.66	32.7	ID/Near	45° Shear	60° Long.

*The deepest through-wall indication sized.

Areas Not Examined by All 3 Transducers

0° to 15.5°, 64.9° to 75.5°, 101.4° to 115.5°, 164.9° to 195.5°,
244.9° to 257.5°, 284.9° to 295.5° & 334.9° to 0° (Total of 119.1° Not Examined)


Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995


H1 - Typical Flaw Indication @ 329.66 Deg. .49 In. Max. Depth



NEDC 95-191 ATTACH 2.3
SHEET 8 OF 10
Page 3 of 13



GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET
(AUTOMATED WITH Smart 2000)

Indication # 8 on the ID below the weld.

SITE: COOPER	UNIT: 1	PROJECT NO.: 1F5CN	REPORT NO.: SR-01
WELD NO.: H-1	SEARCH UNIT: 60° RL	INDICATION NO.: 8	PAGE: 4 OF: 13




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H1

Areas Not Examined

Indication Areas






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H1 - Actual Examination Coverage - 45S, 60L, & ODCr



NEDC 95-191 ATTACH 2.3
SHEET 11 OF 10



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-23
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06.26 Time	N/A 45°	15.5 45°	0 Start°	12LS3	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 3 <input checked="" type="checkbox"/>	11/2 Date	N/A 60°	15.0 60°	10.5 Stop°	D-03/A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	N/A ODCR	14.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06.52 Time	N/A 45°	25.5 45°	0 Start°	12LS4	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 4 <input checked="" type="checkbox"/>	11/2 Date	N/A 60°	25.0 60°	10.5 Stop°	D-03/A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	N/A ODCR	24.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07.07 Time	N/A 45°	35.5 45°	0 Start°	12LS5	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 5 <input checked="" type="checkbox"/>	11/2 Date	N/A 60°	35.0 60°	10.5 Stop°	D-03/A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	N/A ODCR	34.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07.21 Time	N/A 45°	45.5 45°	0 Start°	12LS6	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 6 <input checked="" type="checkbox"/>	11/2 Date	N/A 60°	45.0 60°	10.5 Stop°	D-03/A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	N/A ODCR	44.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown.	

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>W. Webster</i> EXAMINER	LEVEL	DATE	<i>Stephen W. Stanford</i> GE INDEPENDENT REVIEW	DATE	PAGE: 7 OF: 13
<i>George E. Haugen</i> GE REVIEWED BY	LEVEL	DATE	<i>John M. O'Neil</i> UTILITY REVIEW	DATE	FORM U132.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-24
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0° Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:36 Time	N/A 45°	55.5 45°	0	12LS7	45° LKDN 45° LKUP 43	B, C, E, F	Indication # 1	
Lug Set # 7	11/2 Date	N/A 60°	55.0 60°	Start°		60° LKDN 60° LKUP 46	B, C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JL</i> Examiner's initials	N/A ODCR	54.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN ODCR LKUP 51	B, C, J		J = Shear Component to ID crown and Indication # 1.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:05 Time	N/A 45°	75.5 45°	0	12LS9	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 9	11/2 Date	N/A 60°	75.0 60°	Start°		60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HJS</i> Examiner's initials	N/A ODCR	74.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN ODCR LKUP 51	C, J		J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:20 Time	N/A 45°	85.5 45°	0	12LS10	45° LKDN 45° LKUP 43	B, C, E, F	Indications # 2 & # 3	
Lug Set # 10	11/2 Date	N/A 60°	85.0 60°	Start°		60° LKDN 60° LKUP 46	B, C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HJS</i> Examiner's initials	N/A ODCR	84.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN ODCR LKUP 51	B, C, J		J = Shear Component to ID crown and Indication # 2 & # 3.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:36 Time	N/A 45°	95.5 45°	0	12LS11	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 11	11/2 Date	N/A 60°	95.0 60°	Start°		60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HJS</i> Examiner's initials	N/A ODCR	94.4 ODCR	7.0 Stop°	D-03 / A	ODCR LKDN ODCR LKUP 51	C, J		J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>R. Alpha</i> EXAMINER	II	11-7-95 LEVEL DATE	<i>Stephen Steffan</i> GE INDEPENDENT REVIEW	11-9-95 DATE	PAGE: 8 OF: 13
<i>George E. Bergman</i> GE REVIEWED BY	III	11-9-95 LEVEL DATE	<i>K. M. Glenn</i> UTILITY REVIEW	11-9-95 DATE	FORM LT32 RS



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-25
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Weld Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Date	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:57 Time	N/A 45°	115.5 45°	0	12LS13	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 13	11/2 Date	N/A 60°	115.0 60°	Start°	D-03 / A	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	MBS Examiner's Initials	N/A ODCR	114.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:15 Time	N/A 45°	125.5 45°	0	12LS14	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 14	11/2 Date	N/A 60°	125.0 60°	Start°	D-03 / A	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	MBS Examiner's Initials	N/A ODCR	124.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:30 Time	N/A 45°	135.5 45°	0	12LS15	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 15	11/2 Date	N/A 60°	135.0 60°	Start°	D-03 / B	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	TMB Examiner's Initials	N/A ODCR	134.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:45 Time	N/A 45°	145.5 45°	0	12LS16	45° LKDN 45° LKUP	43	B, C, E, F	Indication # 4
Lug Set # 16	11/2 Date	N/A 60°	145.0 60°	Start°	D-03 / B	60° LKDN 60° LKUP	46	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	MBS Examiner's Initials	N/A ODCR	144.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 51		B, C, J	J = Shear Component to ID crown and Indication # 4.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

John Bok II 11/2/95 EXAMINER LEVEL DATE	Stephen Raymond III GE INDEPENDENT REVIEW	11-9-95 DATE
George E. Brown III 11-9-95 GE REVIEWED BY LEVEL DATE	John M. O'Brien K. B. Brown UTILITY REVIEW	11/14/95 DATE



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-26
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:58 Time	N/A 45°	155.5 45°	0 Start°	12LS17	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 17	11/2 Date	N/A 60°	155.0 60°	10.5 Stop°	D-03 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	HHS Examiner's Initials	N/A ODCR	154.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:32 Time	N/A 45°	195.5 45°	0 Start°	12LS21	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 21	11/2 Date	N/A 60°	195.0 60°	10.5 Stop°	D-03 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	HHS Examiner's Initials	N/A ODCR	194.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:48 Time	N/A 45°	205.5 45°	0 Start°	12LS22	45° LKDN 45° LKUP 43	B, C, E, F	Indication # 5	
Lug Set # 22	11/2 Date	N/A 60°	205.0 60°	10.5 Stop°	D-03 / B	60° LKDN 60° LKUP 46	B, C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	HHS Examiner's Initials	N/A ODCR	204.4 ODCR			ODCR LKDN ODCR LKUP 51	B, C, J	J = Shear Component to ID crown and Indication # 5.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:10 Time	N/A 45°	215.5 45°	0 Start°	12LS23	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 23	11/2 Date	N/A 60°	215.0 60°	10.5 Stop°	D-03 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	HHS Examiner's Initials	N/A ODCR	214.4 ODCR			ODCR LKDN ODCR LKUP 51	C, J	J = Shear Component to ID crown	

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>Stephen Belfi II</i> EXAMINER	LEVEL	DATE: 11/2/95	<i>Stephen D. Stearns III</i> GE INDEPENDENT REVIEW	DATE: 11-9-95	PAGE: 10 OF: 13
<i>David E. Hedges III</i> GE REVIEWED BY	LEVEL	DATE: 11-9-95	<i>John H. Jones K.B. Davis</i> UTILITY REVIEW	DATE: 11/14/95	FORM 1732.RD



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-27
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:21	N/A	225.5			45° LKDN			
Lug Set # 24	Time	45°	45°	0	12LS24	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/2	N/A	225.0	Start°		60° LKDN			
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	N/A	224.4	10.5 Stop°	D-03 / B	ODCR LKDN			
		ODCR	ODCR			ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:43	N/A	235.5			45° LKDN			
Lug Set # 25	Time	45°	45°	0	12LS25	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/2	N/A	235.0	Start°		60° LKDN			
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	N/A	234.4	10.5 Stop°	D-03 / B	ODCR LKDN			
		ODCR	ODCR			ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:08	N/A	257.5			45° LKDN			
Lug Set # 27	Time	45°	45°	2.0	12LS27	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/2	N/A	257.0	Start°		60° LKDN			
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	N/A	256.4	10.5 Stop°	D-03 / B	ODCR LKDN			
		ODCR	ODCR			ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:23	N/A	265.5			45° LKDN			
Lug Set # 28	Time	45°	45°	0	12LS28	45° LKUP	43	B, C, E, F	Indication # 6
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/2	N/A	265.0	Start°		60° LKDN			
	Date	60°	60°			60° LKUP	46	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	N/A	264.4	10.5 Stop°	D-03 / B	ODCR LKDN			
		ODCR	ODCR			ODCR LKUP 51		B, C, J	J = Shear Component to ID crown and Indication # 6.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

EXAMINER George E. Dohm III	LEVEL III	DATE 11-9-95	GE INDEPENDENT REVIEW J.W. Dohm III Z.B. Thomas	DATE 11-9-95	PAGE: 11 OF: 13
GE REVIEWED BY George E. Dohm III	LEVEL III	DATE 11-9-95	UTILITY REVIEW	DATE 11-9-95	FORM UT30.RP



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-28
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:35	N/A	275.5			45° LKDN			
	Time	45°	45°	0	12LS29	45° LKUP	43	C, E, F	
Lug Set # 29	11/2	N/A	275.0	Start°		60° LKDN			
	Date	60°	60°	10.5	D-03 / B	60° LKUP	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JSR</i> Examiner's initials	N/A	274.4	Stop°		ODCR LKDN			
	ODCR	ODCR				ODCR LKUP 5°		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:10	N/A	295.5			45° LKDN			
	Time	45°	45°	0	12LS31	45° LKUP	43	B, C, E, F	Indication # 7
Lug Set # 31	11/2	N/A	295.0	Start°		60° LKDN			
	Date	60°	60°	10.5	D-03 / B	60° LKUP	46	B, C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JSR</i> Examiner's initials	N/A	294.4	Stop°		ODCR LKDN			J = Shear Component to ID crown and Indication # 7.
	ODCR	ODCR				ODCR LKUP 51		B, C, J	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:26	N/A	305.5			45° LKDN			
	Time	45°	45°	0	12LS32	45° LKUP	43	C, E, F	Vertical seam @ end of scan.
Lug Set # 32	11/2	N/A	305.0	Start°		60° LKDN			
	Date	60°	60°	10.5	D-03 / B	60° LKUP	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JSR</i> Examiner's initials	N/A	304.4	Stop°		ODCR LKDN			
	ODCR	ODCR				ODCR LKUP 51		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:41	N/A	315.5			45° LKDN			
	Time	45°	45°	0	12LS33	45° LKUP	43	C, E, F	Vertical seam @ start of scan.
Lug Set # 33	11/2	N/A	315.0	Start°		60° LKDN			
	Date	60°	60°	10.5	D-03 / B	60° LKUP	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	<i>JSR</i> Examiner's initials	N/A	314.4	Stop°		ODCR LKDN			
	ODCR	ODCR				ODCR LKUP 51		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>Rebecca</i> EXAMINER	III	11-7-95	<i>Stephens</i> GE INDEPENDENT REVIEW	11-9-95	PAGE: 12 OF: 13
<i>Stephens</i> GE REVIEWED BY	III	11-9-95	<i>John C. Brown</i> UTILITY REVIEW	11-9-95	FORM UT31-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-01
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-29
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-31 THRU 33

Weld ID: H1 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:55 Time	N/A 45°	325.5 45°	0	12LS34	45° LKDN 45° LKUP	43	B, C, E, F	Indication # 8
Lug Set # 34	11/2 Date	N/A 60°	325.0 60°	Start°	D-03 / B	60° LKDN 60° LKUP	46	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	N/A ODCR	324.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 51		B, C, J	J = Shear Component to ID crown and Indication # 6.
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A	Time	45°	45°	Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	Stop°		ODCR LKDN ODCR LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A	Time	45°	45°	Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	Stop°		ODCR LKDN ODCR LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A	Time	45°	45°	Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	Stop°		ODCR LKDN ODCR LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A	Time	45°	45°	Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	Stop°		ODCR LKDN ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>Delegated</i> EXAMINER	III	11-7-95	<i>Stephen Thompson</i> GE INDEPENDENT REVIEW	11-9-95
<i>George E. Dufresne</i> GE REVIEWED BY	III	11-9-95	<i>John M. Green</i> UTILITY REVIEW	11-14-95



GE Nuclear Energy

EXAMINATION SUMMARY SHEET

REPORT NO.:
SR-02PROJECT: COOPER RFO16
SHROUD UT PROJECT 1F5CNPROCEDURE: UT-CNS-503V4 REV: 0 FRR: N/A
N/A
N/A

SYSTEM: SHROUD ASSEMBLY WELDS

N/A REV: N/A FRR: N/A
N/A
N/A

WELD NO.: H2

N/A REV: N/A FRR: N/A
N/A
N/A

CONFIGURATION: PLATE TO TOP GUIDE RING

EXAMINER: T. ROCKWOOD LEVEL: III

 MT PT UT VT

EXAMINER: C. MCKEAN LEVEL: II

 CIRCUMFERENTIAL

EXAMINER: N/A LEVEL: N/A

 LONGITUDINAL OTHER N/A

DATA SHEET NO.(S): SD-30 THRU SD-36

CAL SHEET NO.(S): SC-34 THRU SC-36

During the examination of the referenced weld, no indications associated with IGSCC/IASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications.

The OD creeping wave recorded non-relevant indications and inside surface geometry.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.65 inches per degree.

This examination was performed only from the plate side due to the narrow width of the top guide support ring. This examination was also performed simultaneously with H1 weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation lines.

The examination area that was interrogated by all angles was 240.90° (66.9%). 119.10° (33.1%) was not examined due to the above referenced obstructions.

SUMMARY BY

LEVEL III

DATE 11-11-95

GE REVIEWED BY

LEVEL III

DATE 11-11-95

GE INDEPENDENT REVIEW

UTILITY REVIEW

DATE 11-13-95

DATE 11-14-95

PAGE: 1 OF: 11



GE Nuclear Energy

Nebraska Public Power District
 Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H2 Indication Data

Total Scan Length (Deg.)	240.90	Total Flaw Length (Deg.)	0.00
Total Scan Length (in.)	398.37	Total Flaw Length (in.)	0.00
Percentage of Weld Length Examined	66.9	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	0.0	Circumference (in.)	595.33
Percentage of Total Weld Length Flawed	0.0	Inches per Degree	1.65

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Inches	Max. Depth Pos. (Deg.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
-------------------	---------------	-------------	----------------	---------------	-------------------	------------------------	---------------	--------------------	-------------------	------------------

No Relevant Indications Recorded

Areas Not Examined by All 3 Transducers

0° to 15.5°, 64.9° to 75.5°, 101.4° to 115.5°, 164.9° to 195.5°,
 244.9° to 257.5°, 284.9° to 295.5° & 334.9° to 0° (Total of 119.1° Not Examined)

Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H2

Areas Not Examined






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H2 - Actual Examination Coverage - 45S, 60L, & ODCr





GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-30
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:26 Time	14.4 45°	N/A 45°			45° LKDN 45° LKUP	46	C, E, F	
Lug Set # 3	11/2 Date	15.0 60°	N/A 60°	0 Start°	12LS3	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	15.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:52 Time	24.4 45°	N/A 45°			45° LKDN 45° LKUP	46	C, E, F	
Lug Set # 4	11/2 Date	25.0 60°	N/A 60°	0 Start°	12LS4	60° LKDN 60° LKUP	46	C, E, G	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	25.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J, G	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:07 Time	34.4 45°	N/A 45°			45° LKDN 45° LKUP	46	C, E, F	
Lug Set # 5	11/2 Date	35.0 60°	N/A 60°	0 Start°	12LS5	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	35.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:21 Time	44.4 45°	N/A 45°			45° LKDN 45° LKUP	46	C, E, F	
Lug Set # 6	11/2 Date	45.0 60°	N/A 60°	0 Start°	12LS6	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	45.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>John E. Shaffer</i> EXAMINER	LEVEL	DATE	<i>Stephen D. Stanford</i> GE INDEPENDENT REVIEW	DATE	PAGE: 5 OF: 11
<i>John E. Shaffer</i> GE REVIEWED BY	LEVEL	DATE	<i>J. H. A. S.</i> UTILITY REVIEW	DATE	FORM UT30 RS



GE Nuclear Energy

SHROUD ULTRASONIC EXAMINATION

DATA SHEET

(AUTOMATED with Smart 2000 OD TRACKER)

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-31
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder cw ccw	07:36 Time	54.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F, G C, E, G	
Lug Set # 7	11/2 Date	55.0 60°	N/A 60°	0 Start°	12LS7	60° LKDN 60° LKUP	46 46		
Lug Side cw ccw	<i>BR</i> Examiner's Initials	55.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J, G	J = Shear Component to ID crown.
Cylinder cw ccw	08:05 Time	74.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F	
Lug Set # 9	11/2 Date	75.0 60°	N/A 60°	0 Start°	12LS9	60° LKDN 60° LKUP	46 46	C, E	
Lug Side cw ccw	<i>MJS</i> Examiner's Initials	75.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder cw ccw	08:20 Time	84.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F	
Lug Set # 10	11/2 Date	85.0 60°	N/A 60°	0 Start°	12LS10	60° LKDN 60° LKUP	46 46	C, E	
Lug Side cw ccw	<i>MJS</i> Examiner's Initials	85.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder cw ccw	08:36 Time	94.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F	
Lug Set # 11	11/2 Date	95.0 60°	N/A 60°	0 Start°	12LS11	60° LKDN 60° LKUP	46 46	C, E	
Lug Side cw ccw	<i>MJS</i> Examiner's Initials	95.5 ODCR	N/A ODCR	7.0 Stop°	D-03 / A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17 60° LKUP 37 A - NO RECORDABLE INDICATIONS
 45° LKUP ODCR LKDN 37 B - NON-GEOMETRIC INDICATIONS
 60° LKDN 35 ODCR LKUP C - NON-RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
 E - INSIDE SURFACE GEOMETRY
 F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
 H - WELD CROWN GEOMETRY
 J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>Rebecca</i> EXAMINER	III	11-7-95 LEVEL DATE	<i>Stephen W. Hartman</i> GE INDEPENDENT REVIEW	11-9-95 DATE	PAGE: 6 OF: 11
<i>George E. Johnson</i> GE REVIEWED BY	III	11-9-95 LEVEL DATE	<i>John H. Hayes</i> UTILITY REVIEW	11-9-95 DATE	FORM UT32-03



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-32
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:57 Time	114.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 13	11/2 Date	115.0 60°	N/A 60°	0 Start°	12LS13	60° LKDN 60° LKUP	46 46		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/6 Examiner's Initials	115.5 ODCR	N/A ODCR	10.5 Stop°	D-03/A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:15 Time	124.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 14	11/2 Date	125.0 60°	N/A 60°	0 Start°	12LS14	60° LKDN 60° LKUP	46 46		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/6 Examiner's Initials	125.5 ODCR	N/A ODCR	10.5 Stop°	D-03/A	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:30 Time	134.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 15	11/2 Date	135.0 60°	N/A 60°	0 Start°	12LS15	60° LKDN 60° LKUP	46 46		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/6 Examiner's Initials	135.5 ODCR	N/A ODCR	10.5 Stop°	D-03/B	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:45 Time	144.4 45°	N/A 45°			45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 16	11/2 Date	145.0 60°	N/A 60°	0 Start°	12LS16	60° LKDN 60° LKUP	46 46		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/6 Examiner's Initials	145.5 ODCR	N/A ODCR	10.5 Stop°	D-03/B	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	60° LKUP 37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP 37	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP 35	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

Initials: <i>John B. Bell II</i>	Date: <i>11/2/95</i>	Initials: <i>Stephen D. Stanford III</i>	Date: <i>11-9-95</i>
EXAMINER: <i>John E. Hoffman</i>	LEVEL: <i>III</i>	EXAMINER: <i>GE INDEPENDENT REVIEW</i>	DATE: <i>11-9-95</i>
GE REVIEWED BY: <i>John E. Hoffman</i>	LEVEL: <i>III</i>	UTILITY REVIEW: <i>KB Thoms</i>	DATE: <i>11-9-95</i>
		PAGE: 7 OF: 11	



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-33
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:58	154.4	N/A			45° LKDN	46	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 17	11/2	155.0	N/A	0	12LS17	60° LKDN	46	C, E	
	Date	60°	60°	Start°		60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JB</i> Examiner's Initials	155.5	N/A	10.5	D-03/B	ODCR LKDN 51		C, J	J = Shear Component to ID crown
		ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:32	194.4	N/A			45° LKDN	46	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 21	11/2	195.0	N/A	0	12LS21	60° LKDN	46	C, E	
	Date	60°	60°	Start°		60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JB</i> Examiner's Initials	195.5	N/A	10.5	D-03/B	ODCR LKDN 51		C, J	J = Shear Component to ID crown.
		ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:48	204.4	N/A			45° LKDN	46	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 22	11/2	205.0	N/A	0	12LS22	60° LKDN	46	C, E	
	Date	60°	60°	Start°		60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JB</i> Examiner's Initials	205.5	N/A	10.5	D-03/B	ODCR LKDN 51		C, J	J = Shear Component to ID crown
		ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:10	214.4	N/A			45° LKDN	46	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 23	11/2	215.0	N/A	0	12LS23	60° LKDN	46	C, E	
	Date	60°	60°	Start°		60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JB</i> Examiner's Initials	215.5	N/A	10.5	D-03/B	ODCR LKDN 51		C, J	J = Shear Component to ID crown
		ODCR	ODCR	Stop°		ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP		A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>John Kelly II</i> EXAMINER	LEVEL	DATE	<i>Stephen D. Stanford II</i> GE INDEPENDENT REVIEW	DATE	PAGE: 3 OF: 11
<i>George E. Dickey III</i> GE REVIEWED BY	LEVEL	DATE	<i>John A. B. Brown</i> UTILITY REVIEW	DATE	FORM UT32 RS



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-34
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:21	224.4	N/A			45° LKDН	46	C, E, F	
	Time	45°	45°	0	12LS24	45° LKUP			
Lug Set # 24	11/2	225.0	N/A	Start*		60° LKDН	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	10.5	D-03 / B	60° LKUP			
				Stop*		ODCR LKDН 51		C, J	J = Shear Component to ID crown
						ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:43	234.4	N/A			45° LKDН	46	C, E, F	
	Time	45°	45°	0	12LS25	45° LKUP			
Lug Set # 25	11/2	235.0	N/A	Start*		60° LKDН	46	C, E, G	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	10.5	D-03 / B	60° LKUP			
				Stop*		ODCR LKDН 51		C, J	J = Shear Component to ID crown.
						ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:08	256.4	N/A			45° LKDН	46	C, E, F	
	Time	45°	45°	2.0	12LS27	45° LKUP			
Lug Set # 27	11/2	257.0	N/A	Start*		60° LKDН	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	10.5	D-03 / B	60° LKUP			
				Stop*		ODCR LKDН 51		C, J	J = Shear Component to ID crown
						ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:23	264.4	N/A			45° LKDН	46	C, E, F	
	Time	45°	45°	0	12LS28	45° LKUP			
Lug Set # 28	11/2	265.0	N/A	Start*		60° LKDН	46	C, E	
Lug Side <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	Date	60°	60°	10.5	D-03 / B	60° LKUP			
				Stop*		ODCR LKDН 51		C, J	J = Shear Component to ID crown
						ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDН	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDН	35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY

J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>John Kell</i>	II	11/2/95	<i>Stephen W. Stanford</i>	III	11-9-95	11-9-95	
EXAMINER	LEVEL	DATE	GE INDEPENDENT REVIEW		DATE		
<i>George E. Johnson</i>	III	11-9-95	<i>John W. Thompson</i>	IV	11-9-95	PAGE: 9	OF: 11
GE REVIEWED BY	LEVEL	DATE	UTILITY REVIEW		DATE		



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRN NO.: 0	DATA SHEET NO.: SD-35
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:35 Time	274.4 45°	N/A 45°	0	12LS29	45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 29	11/2 Date	275.0 60°	N/A 60°	Start°	D-03 / B	60° LKDN 60° LKUP	46 46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	TSR Examiner's Initials	275.5 ODCR	N/A ODCR	10.5 Stop°		ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:10 Time	294.4 45°	N/A 45°	0	12LS31	45° LKDN 45° LKUP	46 46	C, E, F C, E	
Lug Set # 31	11/2 Date	295.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46 46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	TSR Examiner's Initials	295.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / B	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:26 Time	304.4 45°	N/A 45°	0	12LS32	45° LKDN 45° LKUP	46 46	C, E, F C, E	Vertical seam @ end of scan.
Lug Set # 32	11/2 Date	305.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46 46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	TSR Examiner's Initials	305.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / B	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:41 Time	314.4 45°	N/A 45°	0	12LS33	45° LKDN 45° LKUP	46 46	C, E, F C, E	Vertical seam @ start of scan.
Lug Set # 33	11/2 Date	315.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46 46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	TSR Examiner's Initials	315.5 ODCR	N/A ODCR	10.5 Stop°	D-03 / B	ODCR LKDN 51 ODCR LKUP		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY

I - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

	III	11-2-95		GE INDEPENDENT REVIEW	11-9-95	
	III	11-9-95		UTILITY REVIEW	11-9-95	PAGE: 10 OF: 11



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-02
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-36
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-34 THRU 36

Weld ID: H2 Exam Surface: OD Stroke: 4.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 26.6" Wo Location: * LKDN @ WELD TOE ON H2

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start* / Stop*	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:55 Time	324.4 45°	N/A 45°	0	12LS34	45° LKDН	46	C, E, F	
Lug Set # 34	11/2 Date	325.0 60°	N/A 60°	Start*		45° LKUP		C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JR</i> Examiner's Initials	325.5 ODCR	N/A ODCR	10.5 Stop*	D-03 / B	60° LKDН	46	C, J	J = Shear Component to ID crown
						60° LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						ODCR LKDН			
Lug Set # N/A						ODCR LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw									
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDН			
Lug Set # N/A						45° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw						60° LKDН			
Examiner's Initials	ODCR	ODCR		Start*		60° LKUP			
						ODCR LKDН			
						ODCR LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDН			
Lug Set # N/A						45° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw						60° LKDН			
Examiner's Initials	ODCR	ODCR		Stop*		60° LKUP			
						ODCR LKDН			
						ODCR LKUP			
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDН			
Lug Set # N/A						45° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw						60° LKDН			
Examiner's Initials	ODCR	ODCR		Start*		60° LKUP			
						ODCR LKDН			
						ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINuity
45° LKUP		ODCR LKDН	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDН	35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY

J - OTHER (SEE COMMENTS)

REMARKS: * H1 & H2 were scanned simultaneously

<i>John Balloch</i> EXAMINER	III	11-7-95	<i>Stephen Hartman III</i> GE INDEPENDENT REVIEW	11-9-95	
<i>George E. Stofko Jr.</i> GE REVIEWED BY	III	11-9-95	<i>John Hartman</i> UTILITY REVIEW	11-9-95	PAGE: 11 OF: 11

	GE Nuclear Energy	EXAMINATION SUMMARY SHEET	REPORT NO.: SR-03
PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN	PROCEDURE: UT-CNS-503V4	REV: 0 FRR: N/A N/A N/A	
SYSTEM: SHROUD ASSEMBLY WELDS	N/A	REV: N/A FRR: N/A N/A N/A	
WELD NO.: H3	N/A	REV: N/A FRR: N/A N/A N/A	
CONFIGURATION: TOP GUIDE TO PLATE	N/A	REV: N/A FRR: N/A N/A N/A	
EXAMINER: T. ROCKWOOD LEVEL: III	<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT		
EXAMINER: C. MCKEAN LEVEL: II	<input checked="" type="checkbox"/> CIRCUMFERENTIAL		
EXAMINER: N/A LEVEL: N/A	WELD TYPE:	<input type="checkbox"/> LONGITUDINAL <input type="checkbox"/> OTHER N/A	
DATA SHEET NO.(S): SD-01 THRU SD-08	CAL SHEET NO.(S): SC-01 THRU SC-06		

During the examination of the referenced weld, eight (8) indications associated with IGSCC/ASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The parameters for these indications are on the following page.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications along with the indications referenced.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications along with the indications referenced.

The OD creeping wave recorded non-relevant indications and inside surface geometry along with the indications referenced.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.55 inches per degree.

This examination was performed from the plate side only due to the configuration of the top guide support ring.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, and shroud lifting lugs.

The examination area that was interrogated by all angles was 287.55° (79.9%). 72.45° (20.1%) was not examined due to the above referenced obstructions.

<i>Stephen D. Taylor</i> SUMMARY BY <i>Robert Schlecht</i> GE REVIEWED BY	LEVEL III DATE 11-11-95	<i>R. D.</i> GE INDEPENDENT REVIEW <i>Z.B. Thomas</i> UTILITY REVIEW	11/13/95 DATE 11/14/95 DATE	PAGE: 1 OF: 14 FORM UT-08 REV. 6
--	----------------------------	---	--------------------------------------	-------------------------------------



GE Nuclear Energy

Nebraska Public Power District
 Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H3 Indication Data

Total Scan Length (Deg.)	287.55	Total Flaw Length (Deg.)	42.73
Total Scan Length (in.)	445.41	Total Flaw Length (in.)	66.19
Percentage of Weld Length Examined	79.9	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	14.9	Circumference (in.)	557.63
Percentage of Total Weld Length Flawed	11.9	Inches per Degree	1.55

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Inches	Max. Depth Pos. (Deg.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
1	64.04	66.31	2.27	3.52	0.41	65.59	27.3	ID/Near	45° Shear	60° Long.
*2	75.05	79.38	4.33	6.71	0.73	77.02	48.7	ID/Near	45° Shear	60° Long.
3	114.93	120.01	5.08	7.87	0.62	117.77	41.3	ID/Near	45° Shear	60° Long.
4	129.51	134.80	5.29	8.19	0.60	131.55	40.0	ID/Near	45° Shear	60° Long.
**5	158.75	170.47	11.72	18.15	0.69	167.10	46.0	ID/Near	45° Shear	60° Long.
6	224.58	227.22	2.84	4.09	0.39	226.12	26.0	ID/Near	45° Shear	60° Long.
7	308.88	314.04	5.16	7.99	0.58	311.05	38.7	ID/Near	45° Shear	60° Long.
**8	333.54	339.78	8.24	9.67	0.54	334.91	38.0	ID/Near	45° Shear	60° Long.

** Length sizing of indications #5 & #8 are restricted by the limitation of the core spray downcomer.

* Deepest flawed area found.

Areas Not Examined by All 3 Transducers

0° to 15.60°, 169.40° to 194.20°, 284.90° to 295.60° & 338.65° to 0° (Total of 72.45° Not Examined)


Limitations: Core Spray Downcomers, Guide Pins, and Lifting Lugs



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H3 - Typical Flaw Indication @ 77.02 Deg. .73 In. Max Depth




NEDC 95-19 ATTACH 2.3
SHEET 32 OF 101



GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET (AUTOMATED WITH Smart 2000)



SITE: COOPER	UNIT: 1	PROJECT NO.: 1F5CN	REPORT NO.: SR-03
WELD NO.: H-3	SEARCH UNIT: 60° RL	INDICATION NO.: 2	PAGE: 4 OF 14




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H3

- █ Areas Not Examined
- █ Indication Areas






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H3 - Actual Examination Coverage - 45S, 60L, & ODCr



NEDC 95-19 ATTACH 2.3
SHEET 35 OF 101



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-01
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	05:40	N/A	15.6			45° LKDН			
Lug Set # 3	Time	45°	45°	0	3LS3	45° LKUP	45	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date <i>nyw</i>	N/A	15.0	Start°		60° LKDН			
		60°	60°			60° LKUP	49	C, E	
				10.5	D-02 / A	ODCR LKDН			
				Stop°		ODCR LKUP 55		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	05:50	N/A	25.6			45° LKDН			
Lug Set # 4	Time	45°	45°	0	3LS1	45° LKUP	45	E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date <i>nyw</i>	N/A	25.0	Start°		60° LKDН			
		60°	60°			60° LKUP	49	C, E	
				10.5	D-02 / A	ODCR LKDН			
				Stop°		ODCR LKUP 55		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:00	N/A	35.6			45° LKDН			
Lug Set # 5	Time	45°	45°	0	3LS5	45° LKUP	45	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date <i>nyw</i>	N/A	35.0	Start°		60° LKDН			
		60°	60°			60° LKUP	49	C, E	
				10.5	D-02 / A	ODCR LKDН			
				Stop°		ODCR LKUP 55		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:10	N/A	45.6			45° LKDН			
Lug Set # 6	Time	45°	45°	0	3LS6	45° LKUP	45	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date <i>nyw</i>	N/A	45.0	Start°		60° LKDН			
		60°	60°			60° LKUP	49	C, E	
				10.5	D-02 / A	ODCR LKDН			
				Stop°		ODCR LKUP 55		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDН	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>Stephanie</i> EXAMINER	LEVEL	DATE	<i>Stephen D. Steiner III</i> GE INDEPENDENT REVIEW	DATE	
<i>Stephanie</i> GE REVIEWED BY	LEVEL	DATE	<i>John B. Brown</i> UTILITY REVIEW	DATE	PAGE: 7 OF: 14



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-U2
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:20 Time	N/A 45°	55.6 45°	0	3LS7	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 1
Lug Set # 7	10/29 Date	N/A 60°	55.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nfw</i> Examiner's initials	N/A ODCR	54.4 ODCR	14.25 Stop°	D-02 / A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 1.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:20 Time	N/A 45°	65.6 45°	0	3LS8	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 2
Lug Set # 8	10/29 Date	N/A 60°	65.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nfw</i> Examiner's initials	N/A ODCR	64.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 2.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:40 Time	N/A 45°	75.6 45°	0	3LS9	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 2 continued
Lug Set # 9	10/29 Date	N/A 60°	75.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nfw</i> Examiner's initials	N/A ODCR	74.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 2.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:50 Time	N/A 45°	85.6 45°	0	3LS10	45° LKDН 45° LKUP	45	C, E, F	
Lug Set # 10	10/29 Date	N/A 60°	85.0 60°	Start°		60° LKDН 60° LKUP	49	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>BS</i> Examiner's initials	N/A ODCR	84.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDН ODCR LKUP 55		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINuity
45° LKUP	14	ODCR LKDН	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН		ODCR LKUP	38	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>nfw, hst</i> EXAMINER	LEVEL	DATE	<i>Stephen D. Shepard III</i> GE INDEPENDENT REVIEW	DATE	
<i>John E. Anderson</i> GE REVIEWED BY	LEVEL	DATE	<i>John E. Anderson</i> UTILITY REVIEW	DATE	PAGE: 8 OF: 14



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-03
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:05 Time	N/A 45°	95.6 45°	0	3LS11	45° LKDН 45° LKUP	45	C, E, F	
Lug Set # 11 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date Examiner's Initials	N/A 60°	95.0 60°	Start°		60° LKDН 60° LKUP	49	C, E	
				10.5 Stop°	D-02/A	ODCR LKDН ODCR LKUP 55		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:38 Time	N/A 45°	105.6 45°	0	3LS12	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 3
Lug Set # 12 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date Examiner's Initials	N/A 60°	105.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
				10.5 Stop°	D-02/A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 3.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:48 Time	N/A 45°	115.6 45°	0	3LS13	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 3 continued
Lug Set # 13 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date Examiner's Initials	N/A 60°	115.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
				10.5 Stop°	D-02/A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 3.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:59 Time	N/A 45°	125.6 45°	0	3LS14	45° LKDН 45° LKUP	45	B, C, E, F	Indication # 4
Lug Set # 14 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/29 Date Examiner's Initials	N/A 60°	125.0 60°	Start°		60° LKDН 60° LKUP	49	B, C, E	
				10.5 Stop°	D-02/A	ODCR LKDН ODCR LKUP 55		B, C, J	J = Shear Component to ID crown and Indication # 4.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDН	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН		ODCR LKUP	38	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

Stephen Bell II EXAMINER	LEVEL	DATE	Stephen D. Stanford III GE INDEPENDENT REVIEW	DATE	11-9-95
George Edwards III GE REVIEWED BY	LEVEL	DATE	Sub 11-9-95 XO, G. Edwards UTILITY REVIEW	DATE	4/4/95 PAGE: 9 OF: 14



GE Nuclear Energy

**JUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-04
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:09 Time	N/A 45°	135.6 45°	0	3LS15	45° LKDN 45° LKUP 45	C, E, F		
Lug Set # 15	10/29 Date	N/A 60°	135.0 60°	Start°		60° LKDN 60° LKUP 49	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HS</i> Examiner's Initials	N/A ODCR	134.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN ODCR LKUP 55	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:19 Time	N/A 45°	145.6 45°	0	3LS16	45° LKDN 45° LKUP 45	C, E, F		
Lug Set # 16	10/29 Date	N/A 60°	145.0 60°	Start°		60° LKDN 60° LKUP 49	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HS</i> Examiner's Initials	N/A ODCR	144.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN ODCR LKUP 55	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:29 Time	N/A 45°	155.6 45°	0	3LS17	45° LKDN 45° LKUP 45	B, C, E, F	Indication # 5 (see remarks)	
Lug Set # 17	10/29 Date	N/A 60°	155.0 60°	Start°		60° LKDN 60° LKUP 49	B, C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>HS</i> Examiner's Initials	N/A ODCR	154.4 ODCR	15.0 Stop°	D-02 / A	ODCR LKDN ODCR LKUP 55	B, C, J	J = Shear Component to ID crown and Indication # 5.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:40 Time	N/A 45°	194.2 45°	0	3LS21	45° LKDN 45° LKUP 43	B, C, E, F		
Lug Set # 21	10/26 Date	N/A 60°	193.6 60°	Start°		60° LKDN 60° LKUP 48	B, C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>W.W.</i> Examiner's Initials	N/A ODCR	193.0 ODCR	10.5 Stop°	D-01 / A	ODCR LKDN ODCR LKUP 50.5	B, C, J	J = Shear Component to ID crown.	

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN	14**	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * Length sizing Indication # 5 restricted by core spray downcomer limitation.
** Lug Set 21 had a reference gain of 18dB

<i>Mohamed Kabbah</i> EXAMINER	II	10/29/95	<i>Stephen D. Jaeger III</i> GE INDEPENDENT REVIEW	11-9-95
<i>John E. Doherty</i> GE REVIEWED BY	III	11-9-95	<i>John H. Thomas</i> UTILITY REVIEW	11-9-95
	LEVEL	DATE		DATE
	LEVEL	DATE		DATE

PAGE: 10 OF: 14

FORM U710 RD



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-05
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Date:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02-06 Time	N/A 45°	204.2 45°	0	3LS22	45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 22 <i>nyw</i>	10/26 Date	N/A 60°	203.6 60°	Start°	D-01/A	60° LKDН 60° LKUP	48	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nyw</i> Examiner's Initials	N/A ODCR	203.0 ODCR	10.5 Stop°		ODCR LKDН ODCR LKUP 50.5		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02-38 Time	N/A 45°	214.2 45°	0	3LS23	45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 23 <i>nyw</i>	10/26 Date	N/A 60°	213.6 60°	Start°	D-01/A	60° LKDН 60° LKUP	48	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nyw</i> Examiner's Initials	N/A ODCR	213.0 ODCR	10.5 Stop°		ODCR LKDН ODCR LKUP 50.5		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02-56 Time	N/A 45°	224.2 45°	0	3LS24	45° LKDН 45° LKUP	43	B, C, E, F	Indication # 6
Lug Set # 24 <i>nyw</i>	10/26 Date	N/A 60°	223.6 60°	Start°	D-01/A	60° LKDН 60° LKUP	48	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nyw</i> Examiner's Initials	N/A ODCR	223.0 ODCR	10.5 Stop°		ODCR LKDН ODCR LKUP 50.5		B, C, J	J = Shear Component to ID crown and Indication # 6.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04-26 Time	N/A 45°	234.2 45°	0	3LS25A	45° LKDН 45° LKUP	43	B, C, E, F	
Lug Set # 25 <i>nyw</i>	10/26 Date	N/A 60°	233.6 60°	Start°	D-01/A	60° LKDН 60° LKUP	48	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nyw</i> Examiner's Initials	N/A ODCR	233.0 ODCR	10.5 Stop°		ODCR LKDН ODCR LKUP 50.5		B, C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDН	18	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>nyw initials</i>	II	10-26-95	<i>Stephen Stanford III</i>	11-9-95	
EXAMINER	LEVEL	DATE	GE INDEPENDENT REVIEW	DATE	
<i>John E. Johnson</i>	III	11-9-95	<i>John E. Johnson</i>	4/4/95	PAGE: 11 OF: 14
GE REVIEWED BY	LEVEL	DATE	UTILITY REVIEW	DATE	FORM U712 RD



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4
REVISION / FRR NO.: 0

REPORT NO.: SR-03
DATA SHEET NO.: SD-06
CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: -1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04.39 Time	N/A 45°	234.2 45°			45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 25	10/26 Date	N/A 60°	233.6 60°	0 Start°	3LS25C	60° LKDН 60° LKUP	48	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>mpn</i> Examiner's Initials	N/A ODCR	233.0 ODCR	10.5 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50.5		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23.30 Time	N/A 45°	245.6 45°			45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 26	10/28 Date	N/A 60°	245.0 60°	0 Start°	3LS26	60° LKDН 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>mpn</i> Examiner's Initials	N/A ODCR	244.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23.50 Time	N/A 45°	255.6 45°			45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 27	10/28 Date	N/A 60°	255.0 60°	0 Start°	3LS27	60° LKDН 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>mpn</i> Examiner's Initials	N/A ODCR	254.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09.01 Time	N/A 45°	265.6 45°			45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 28	10/29 Date	N/A 60°	265.0 60°	0 Start°	3LS28	60° LKDН 60° LKUP	46	C, E	
L' Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>mpn</i> Examiner's Initials	N/A ODCR	264.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDН	14**	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: ** Lug Set 26 had a reference gain setting of 18 dB

<i>mpn</i> EXAMINER	LEVEL	DATE	<i>Stephen J. Slattery III</i> GE INDEPENDENT REVIEW	DATE	<i>11-9-95</i>
<i>George E. Baker Jr.</i> GE REVIEWED BY	LEVEL	DATE	<i>John J. Hayes</i> UTILITY REVIEW	DATE	<i>14/4/95</i>
				PAGE: <u>12</u> OF: <u>14</u>	



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-07
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	00:20 Time	N/A 45°	275.6 45°	0 Start°	3LS29	45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 29	10/29 Date	N/A 60°	275.0 60°	10.5 Stop°	D-01/A	60° LKDН 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MJN</i> Examiner's Initials	N/A ODCR	274.4 ODCR			ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:20 Time	N/A 45°	295.6 45°	0 Start°	3LS31	45° LKDН 45° LKUP	43	C, E, F	ODCR data says 295.4 should be 294.4 for start of data.
Lug Set # 31	10/29 Date	N/A 60°	295.0 60°	10.5 Stop°	D-01/A	60° LKDН 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MJN</i> Examiner's Initials	N/A ODCR	294.4 ODCR			ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:33 Time	N/A 45°	305.6 45°	0 Start°	3LS32	45° LKDН 45° LKUP	43	B, C, E, F	Indication # 7
Lug Set # 32	10/29 Date	N/A 60°	305.0 60°	10.5 Stop°	D-01/A	60° LKDН 60° LKUP	46	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MJN</i> Examiner's Initials	N/A ODCR	304.4 ODCR			ODCR LKDН ODCR LKUP 50		B, C, J	J = Shear Component to ID crown and Indication # 7.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:50 Time	N/A 45°	315.6 45°	0 Start°	3LS33	45° LKDН 45° LKUP	43	C, E, F	
Lug Set # 33	10/29 Date	N/A 60°	315.0 60°	10.5 Stop°	D-01/A	60° LKDН 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MJN</i> Examiner's Initials	N/A ODCR	314.4 ODCR			ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDН	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>MJN</i> EXAMINER	LEVEL	DATE	<i>Stephen D. Raymond III</i> GE INDEPENDENT REVIEW	DATE	PAGE: 13 OF: 14
<i>Stephan D. Raymond III</i> GE REVIEWED BY	LEVEL	DATE	<i>Z.B. Potts</i> UTILITY REVIEW	DATE	FORM UT32.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 CD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-03
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-08
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-01 THRU 06

Weld ID: H3 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.0"

Search Unit Separation (Front To Front): N/A Wo Location: LKUP @ TOE & .2" DOWN FROM TOE

Lug / Cell No.	Scan Data:	LKDН Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:00 Time	N/A 45°	325.6 45°	0	3LS34	45° LKDН 45° LKUP	43	B, C, E, F	Indication # 8.
Lug Set # 34	10/29 Date	N/A 60°	325.0 60°	Start°		60° LKDН 60° LKUP	46	B, C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	N/A ODCR	324.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50		B, C, J	J = Shear Component to ID crown and Indication # 8.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:16 Time	N/A 45°	332.6 45°	7.0	3LS34A	45° LKDН 45° LKUP	43	C, E, F	Indication # 8 continued.
Lug Set # 34	10/29 Date	N/A 60°	332.0 60°	Start°		60° LKDН 60° LKUP	46	C, E	Offsets in data incorrect - Actual positions are as entered on this sheet.
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MW</i> Examiner's Initials	N/A ODCR	331.4 ODCR	14.25 Stop°	D-01/A	ODCR LKDН ODCR LKUP 50		C, J	J = Shear Component to ID crown and Indication # 8.
Cylinder <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw						45° LKDН 45° LKUP			
Lug Set # N/A				Start°		60° LKDН 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw				Stop°		ODCR LKDН ODCR LKUP			
Cylinder <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw						45° LKDН 45° LKUP			
Lug Set # N/A				Start°		60° LKDН 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw				Stop°		ODCR LKDН ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDН	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDН	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDН	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>mw</i> EXAMINER	<i>III</i> LEVEL	<i>10/29/95</i> DATE	<i>Stephen W. Stangland III</i> GE INDEPENDENT REVIEW	<i>11-9-95</i> DATE	
<i>John E. Johnson</i> GE REVIEWED BY	<i>III</i> LEVEL	<i>11-9-95</i> DATE	<i>John E. Johnson</i> UTILITY REVIEW	<i>11-9-95</i> DATE	PAGE: <u>14</u> OF: <u>14</u>



GE Nuclear Energy

EXAMINATION SUMMARY SHEET

REPORT NO.:
SR-04

PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN	WELD NO.: H4	CONFIGURATION: PLATE TO PLATE
EXAMINER: T. ROCKWOOD	LEVEL: III	EXAMINER: C. MCKEAN
EXAMINER: N/A	LEVEL: N/A	DATA SHEET NO.(S): SD-09 THRU SD-15

PROCEDURE: UT-CNS-503V4	REV: 0	FRR: N/A N/A N/A
N/A	REV: N/A	FRR: N/A N/A N/A
N/A	REV: N/A	FRR: N/A N/A N/A
<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT <input checked="" type="checkbox"/> CIRCUMFERENTIAL <input type="checkbox"/> LONGITUDINAL <input type="checkbox"/> OTHER N/A		
CAL SHEET NO.(S): SC-07 THRU SC-12		

During the examination of the referenced weld, no indications associated with IGSCC/IASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The 45° shear wave recorded inside and outside surface weld crown geometry, weld discontinuities and non-relevant indications.

The 60° RL recorded inside surface weld crown geometry, weld discontinuities and non-relevant indications.

The OD creeping wave recorded non-relevant indications, weld discontinuities and inside surface geometry.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.55 inches per degree.

This examination was performed from both sides of the weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation lines.

The examination area that was interrogated by all angles was 282.40° (78.5%). 77.6° (21.5%) was not examined due to the above referenced obstructions.

SUMMARY BY <i>Kelchitt</i> GE REVIEWED BY	LEVEL III DATE 11-11-95	GE INDEPENDENT REVIEW BY <i>K.B. Brown</i> UTILITY REVIEW	DATE 11/13/95 DATE 11/14/95	PAGE: 1 OF: 11 FORM UT-08 REV. 6
---	----------------------------	---	--------------------------------	-------------------------------------



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO18 Shroud UT Project 1FSCN October/November 1995

Shroud Weld H4 Indication Data

Total Scan Length (Deg.)	282.40	Total Flaw Length (Deg.)	0.00
Total Scan Length (in.)	437.72	Total Flaw Length (in.)	0.00
Percentage of Weld Length Examined	78.5	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	0.0	Circumference (in.)	557.63
Percentage of Total Weld Length Flawed	0.0	Inches per Degree	1.55

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Pos. (Deg.)	Max. Depth Pos. (in.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
-------------------	---------------	-------------	----------------	---------------	------------------------	-----------------------	---------------	--------------------	-------------------	------------------

No Relevant indications Recorded

Areas Not Examined by All 3 Transducers

0° to 15.5°, 169.3° to 195.5°, 244.8° to 260.0°, & 339.3° to 0° (Total of 77.6° Not Examined)

Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H4

Areas Not Examined






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H4 - Actual Examination Coverage - 45S, 60L, & ODCr



NEDC 95-191 ATTACH 2,3
SHEET 47 OF 10



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-09
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23:27 Time	14.3 45°	15.6 45°	0	4LS3	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 3	10/29 Date	14.9 60°	15.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>C-1</i> Examiner's Initials	15.5 ODCR	14.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23:57 Time	24.3 45°	25.6 45°	0	4LS4	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 4	10/29 Date	24.9 60°	25.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>C-1</i> Examiner's Initials	25.5 ODCR	24.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:14 Time	34.3 45°	35.6 45°	0	4LS5	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 5	10/30 Date	34.9 60°	35.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>C-1</i> Examiner's Initials	35.5 ODCR	34.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:39 Time	44.3 45°	45.6 45°	0	4LS6	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 6	10/30 Date	44.9 60°	45.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>C-1</i> Examiner's Initials	45.5 ODCR	44.4 ODCR	10.5 Stop°	D-03 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>Chris H. McRae</i> EXAMINER	II	10/30/95 LEVEL DATE	<i>Steffen W. Steffan</i> GE INDEPENDENT REVIEW	III	11-8-95 DATE	
<i>George E. DeGroot</i> GE REVIEWED BY	III	11-9-95 LEVEL DATE	<i>John D. G. X. B. Glaves</i> UTILITY REVIEW		<i>11-14-95</i> DATE	PAGE: 5 OF: 11 FORM UT32-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-10
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:59	54.3	55.6			45° LKDN	43	C, E, F	
Lug Set # 7	Time	45°	45°	0	4LS7	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/30	54.9	55.0	Start°		60° LKDN	46	C, E	
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CJ</i> Examiner's Initials	55.5	54.4	10.5 Stop°	D-03/A	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:30	64.3	65.6			45° LKDN	43	C, E, F	
Lug Set # 8	Time	45°	45°	0	4LS8	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/30	64.9	65.0	Start°		60° LKDN	46	C, E	
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	65.5	64.4	10.5 Stop°	D-04/A	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:48	74.3	75.6			45° LKDN	43	C, E, F	
Lug Set # 9	Time	45°	45°	0	4LS9	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/30	74.9	75.0	Start°		60° LKDN	46	C, E	
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	75.5	74.4	10.5 Stop°	D-04/A	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:00	84.3	85.6			45° LKDN	43	C, E, F	
Lug Set # 10	Time	45°	45°	0	4LS10	45° LKUP	43	C, E, F	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/30	84.9	85.0	Start°		60° LKDN	46	C, E	
	Date	60°	60°			60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	85.5	84.4	10.5 Stop°	D-04/A	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>John Hause</i> EXAMINER	II	10/30/95 LEVEL DATE	<i>Stephen D. Steppel III</i> GE INDEPENDENT REVIEW	11-9-95 DATE
<i>George E. DeBartolo</i> GE REVIEWED BY	III	11-9-95 LEVEL DATE	<i>John H. Brown</i> UTILITY REVIEW	11-9-95 DATE



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-11
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: -1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:17 Time	94.3 45°	95.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 11	10/30 Date	94.9 60°	95.0 60°	0 Start°	4LS11	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	95.5 ODCR	94.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50 ODCR LKUP 50	50 50	C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:15 Time	104.3 45°	105.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 12	10/30 Date	104.9 60°	105.0 60°	0 Start°	4LS12	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CL</i> Examiner's Initials	105.5 ODCR	104.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50 ODCR LKUP 50	50 50	C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:25 Time	114.3 45°	115.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 13	10/30 Date	114.9 60°	115.0 60°	0 Start°	4LS13	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CL</i> Examiner's Initials	115.5 ODCR	114.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50 ODCR LKUP 50	50 50	C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:50 Time	124.3 45°	125.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 14	10/30 Date	124.9 60°	125.0 60°	0 Start°	4LS14	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>TS</i> Examiner's Initials	125.5 ODCR	124.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50 ODCR LKUP 50	50 50	C, J C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	60° LKUP 37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP 14	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>J. Wilhorts</i> EXAMINER	II	10-30-95 LEVEL DATE	<i>Stephen D. Stanford III</i> GE INDEPENDENT REVIEW	11-9-95 DATE	PAGE: 7 OF: 11
<i>John E. Sofield</i> GE REVIEWED BY	III	11-9-95 LEVEL DATE	<i>J. B. Thomas</i> UTILITY REVIEW	11-9-95 DATE	FORM UT32-R2



GE Nuclear Energy

SHROUD ULTRASONIC EXAMINATION

DATA SHEET

(AUTOMATED with Smart 2000 OD TRACKER)

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-12
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:05 Time	134.3 45°	135.6 45°	0 Start°	4LS15	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 15	10/30 Date	.9 60°	135.0 60°	10.5 Stop°	D-04/A	60° LKDN 60° LKUP	46 46	C, E C, E, G	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	135.5 ODCR	134.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:24 Time	144.3 45°	145.6 45°	0 Start°	4LS16	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 16	10/30 Date	144.9 60°	145.0 60°	10.5 Stop°	D-04/A	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	145.5 ODCR	144.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:38 Time	154.3 45°	155.6 45°	0 Start°	4LS17R	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 17	10/30 Date	154.9 60°	155.0 60°	15.0 Stop°	D-04/A	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	155.5 ODCR	154.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:50 Time	194.3 45°	195.6 45°	0 Start°	4LS21	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 21	10/30 Date	194.9 60°	195.0 60°	10.5 Stop°	D-04/A	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Examiner's Initials	195.5 ODCR	194.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>R. Polanco III</i> EXAMINER	LEVEL	DATE	<i>Stephen W. Thompson III</i> GE INDEPENDENT REVIEW	DATE	PAGE: 8 OF: 11
<i>George E. Johnson III</i> GE REVIEWED BY	LEVEL	DATE	<i>John H. Thomas III</i> UTILITY REVIEW	DATE	FORM UTS-10



GE Nuclear Energy

SHROUD ULTRASONIC EXAMINATION

DATA SHEET

(AUTOMATED with Smart 2000 OD TRACKER)

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-13
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder cw ccw	09:07	204.3	205.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F, G	
Lug Set # 22	10/30	204.9	205.0	0 Start°	4LS22	60° LKDN	46	C, E	
Lug Side cw ccw	Date	60°	60°			60° LKUP	46	C, E,	
	Examiner's Initials	205.5 ODCR	204.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50		C, J	
						ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder cw ccw	09:24	214.3	215.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 23	10/30	214.9	215.0	0 Start°	4LS23	60° LKDN	46	C, E	
Lug Side cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	215.5 ODCR	214.4 ODCR	10.5 Stop°	D-04/A	ODCR LKDN 50		C, J	
						ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder cw ccw	09:53	224.3	225.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 24	10/30	224.9	225.0	0 Start°	4LS24	60° LKDN	46	C, E	
Lug Side cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	225.5 ODCR	224.4 ODCR	10.5 Stop°	D-04/B	ODCR LKDN 50		C, J	
						ODCR LKUP 50		C, J	J = Shear Component to ID crown
Cylinder cw ccw	10:05	234.3	235.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 25	10/30	234.9	235.0	0 Start°	4LS25	60° LKDN	46	C, E	
Lug Side cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	235.5 ODCR	234.4 ODCR	10.5 Stop°	D-04/B	ODCR LKDN 50		C, J	
						ODCR LKUP 50		C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>John P. Palucco</i> EXAMINER	III	LEVEL	DATE 11-7-95	<i>Stephen D. Stanton</i> GE INDEPENDENT REVIEW	III	LEVEL	DATE 11-9-95
<i>John E. Baker</i> GE REVIEWED BY	III	LEVEL	DATE 11-9-95	<i>John E. Baker</i> UTILITY REVIEW	III	LEVEL	DATE 14/11/95
PAGE: 9 OF: 11							



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-14
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:06 Time	258.8 45°	260.1 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	Exam limited due to instrumentation lines.
Lug Set # 27	10/30 Date	259.4 60°	259.5 60°	4.5 Start°	4LS27	60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JSL Examiner's Initials	260.0 ODCR	258.9 ODCR	10.5 Stop°	D-04 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:36 Time	264.3 45°	265.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 28	10/30 Date	264.9 60°	265.0 60°	0 Start°	4LS28	60° LKDN 60° LKUP	46 46	C, E, G C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JSL Examiner's Initials	265.5 ODCR	264.4 ODCR	10.5 Stop°	D-04 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:52 Time	274.3 45°	275.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 29	10/30 Date	274.9 60°	275.0 60°	0 Start°	4LS29	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JSL Examiner's Initials	275.5 ODCR	274.4 ODCR	10.5 Stop°	D-04 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:53 Time	284.3 45°	285.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F, G	
Lug Set # 30	10/30 Date	284.9 60°	285.0 60°	0 Start°	4LS30	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JSL Examiner's Initials	285.5 ODCR	284.4 ODCR	10.5 Stop°	D-04 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	60° LKUP 37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP 14	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>John W. Daff</i> EXAMINER	III	11-7-95	<i>Stosh A. Stanford</i> GE INDEPENDENT REVIEW	11-9-95	PAGE: 10 OF: 11
<i>George E. Daff, Jr.</i> GE REVIEWED BY	III	11-9-95	<i>John W. Daff</i> UTILITY REVIEW	11-9-95	FORM U732-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-04
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-15
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-07 THRU 12

Weld ID: H4 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:05	294.3	295.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 31	10/30	294.9	295.0	0 Start°	4LS31	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°			60° LKUP	46	C, E,	
	Examiner's Initials	295.5	294.4	10.5 Stop°	D-04/B	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:17	304.3	305.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 32	10/30	304.9	305.0	0 Start°	4LS32	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	305.5	304.4	10.5 Stop°	D-04/B	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:28	314.3	315.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F	
Lug Set # 33	10/30	314.9	315.0	0 Start°	4LS33	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	315.5	314.4	10.5 Stop°	D-04/B	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	13:44	324.3	325.6			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP	43	C, E, F, G	
Lug Set # 34	10/30	324.9	325.0	0 Start°	4LS34	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°			60° LKUP	46	C, E	
	Examiner's Initials	325.5	324.4	15.0 Stop°	D-04/B	ODCR LKDN 50		C, J	
		ODCR	ODCR			ODCR LKUP 50		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>Stephanie Steffens</i> EXAMINER	LEVEL	DATE	<i>Stephanie Steffens</i> GE INDEPENDENT REVIEW	DATE	PAGE: 11 OF: 11
<i>George E. Johnson</i> GE REVIEWED BY	LEVEL	DATE	<i>John H. Jones</i> UTILITY REVIEW	DATE	FORM UT32.R3

	GE Nuclear Energy	EXAMINATION SUMMARY SHEET	REPORT NO.: SR-05
PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN	PROCEDURE: UT-CNS-503V4	REV: 0 FRR: N/A N/A N/A	
SYSTEM: SHROUD ASSEMBLY WELDS	N/A	REV: N/A FRR: N/A N/A N/A	
WELD NO.: H5	N/A	REV: N/A FRR: N/A N/A N/A	
CONFIGURATION: PLATE TO PLATE			
EXAMINER: T. ROCKWOOD LEVEL: III			
EXAMINER: C. MCKEAN LEVEL: II			
EXAMINER: N/A LEVEL: N/A			
DATA SHEET NO.(S): SD-16 THRU SD-22	CAL SHEET NO.(S): SC-13 THRU SC-18		

During the examination of the referenced weld, one (1) indication associated with IGSCC/IASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The parameters for this indication are on the following page.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications along with the referenced indication.

The OD creeping wave recorded non-relevant indications and inside surface geometry along with the referenced indication.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.55 inches per degree.

This examination was performed from both sides of the weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation pins.

The examination area that was interrogated by all angles was 273.90° (76.1%). 86.10° (23.9%) was not examined due to the above referenced obstructions.

SUMMARY BY <i>K. Schlitt</i> GE REVIEWED BY	LEVEL III DATE 11-11-95	GE INDEPENDENT REVIEW <i>R. D. Thomas</i> UTILITY REVIEW	DATE 11-11-95 DATE	PAGE: 1 OF: 13 FORM UT-09 REV. 6
---	----------------------------------	--	--------------------------	-------------------------------------



GE Nuclear Energy

Nebraska Public Power District
 Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H5 Indication Data

Total Scan Length (Deg.)	273.90	Total Flaw Length (Deg.)	1.76
Total Scan Length (In.)	424.55	Total Flaw Length (In.)	2.73
Percentage of Weld Length Examined	76.1	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	0.6	Circumference (in.)	557.63
Percentage of Total Weld Length Flawed	0.5	Inches per Degree	1.55

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth inches	Max. Depth Pos. (Deg.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
1	35.50	37.26	1.76	2.73	0.45	36.01	30.0	OD/Near	ODCr	60° Long.

Areas Not Examined by All 3 Transducers

0° to 15.50°, 169.3° to 198.5°, 244.8° to 265.5° & 339.3° to 0° (Total of 86.1° Not Examined)


Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H5 - Typical Flaw Indication @ 36.01 Deg. .45 In. Max Depth




NEDC 95-191 ATTACH 2.3
SHEET 57 OF 101



GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET (AUTOMATED WITH Smart 2000)



Indication # 1 on the OD above the weld.

SITE: COOPER	UNIT: 1	PROJECT NO.: 1FFCN	REPORT NO.: SR-05
WELD NO.: H-5	SEARCH UNIT: 60° RL	INDICATION NO.: 1	PAGE: 4 OF: 13




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H5

- █ Areas Not Examined
- Indication Areas






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H5 - Actual Examination Coverage - 45S, 60L, & ODCr



NEDC 95-191 ATTACH 2.3
SHEET 6C OF 101



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-16
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	20:47 Time	14.3 45°	15.6 45°	0	5LS3	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 3 <i>NPW</i>	10/30 Date	14.9 60°	15.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>NPW</i> Examiner's Initials	15.5 ODCR	14.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:13 Time	24.3 45°	25.6 45°	0	5LS4	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 4 <i>NPW</i>	10/30 Date	24.9 60°	25. 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>NPW</i> Examiner's Initials	25.5 ODCR	24.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:25 Time	34.3 45°	35.6 45°	0	5LS5	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 5 <i>NPW</i>	10/30 Date	34.9 60°	35.0 60°	Start°		60° LKDN 60° LKUP	46 46	B, C, E C, E	Indication # 1
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>NPW</i> Examiner's Initials	35.5 ODCR	34.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		B, C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:50 Time	44.3 45°	45.6 45°	0	5LS6	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 6 <i>NPW</i>	10/30 Date	44.9 60°	45.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>NPW</i> Examiner's Initials	45.5 ODCR	44.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>NPW</i> EXAMINER	II	10-30-95	<i>Stephen D. Hayford</i> GE INDEPENDENT REVIEW	11-9-95	
<i>John E. Doherty</i> GE REVIEWED BY	III	11-9-95	<i>John E. Doherty</i> UTILITY REVIEW	11-14-95	PAGE: 7 OF: 13



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4

REVISION / FRR NO.: 0

REPORT NO.: SR-05

DATA SHEET NO.: SD-17

CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indenor Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	22:07 Time	54.3 45°	55.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 7 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/30 Date <i>M.W.</i> Examiner's Initials	54.9 60°	55.0 60°	0 Start°	5LS7	60° LKDN 60° LKUP	46 46	C, E C, E,	
		55.5 ODCR	54.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	00:50 Time	64.3 45°	65.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 8 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>Ces</i> Examiner's Initials	64.9 60°	65.0 60°	0 Start°	5LS8	60° LKDN 60° LKUP	46 46	C, E C, E	
		65.5 ODCR	64.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:14 Time	74.3 45°	75.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 9 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>Ces</i> Examiner's Initials	74.9 60°	75.0 60°	0 Start°	5LS9	60° LKDN 60° LKUP	46 46	C, E C, E	
		75.5 ODCR	74.4 ODCR	10.5 Stop°	D-01/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:35 Time	84.3 45°	85.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 10 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>Ces</i> Examiner's Initials	84.9 60°	85.0 60°	0 Start°	5LS10	60° LKDN 60° LKUP	46 46	C, E C, E	
		85.5 ODCR	84.4 ODCR	10.5 Stop°	D-01/B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17 60° LKUP 37 A - NO RECORDABLE INDICATIONS
45° LKUP 14 ODCR LKDN 37 B - NON-GEOMETRIC INDICATIONS
60° LKDN 35 ODCR LKUP 38 C - NON-RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
E - INSIDE SURFACE GEOMETRY
F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
H - WELD CROWN GEOMETRY
J - OTHER (SEE COMMENTS)

REMARKS:

<i>M.W. Webster</i> EXAMINED <i>Stephen W. Raymond</i> GE REVIEWED BY	LEVEL III DATE 11-9-95	<i>George E. Anderson</i> GE INDEPENDENT REVIEW <i>K.B. Brown</i> UTILITY REVIEW	DATE 11-9-95 11-9-95	PAGE: 8 OF: 13 FORM UT32.R3
--	---------------------------------	---	----------------------------	--------------------------------



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-18
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	01:54 Time	94.3 45°	95.6 45°	0	SLS11	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 11 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>m/w</i>	94.9 60°	95.0 60°	Start°	D-01 / B	60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>m/w</i> Examiner's Initials	95.5 ODCR	94.4 ODCR	10.5 Stop°		ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:25 Time	104.3 45°	105.6 45°	0	5LS12	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 12 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>m/w</i>	104.9 60°	105.0 60°	Start°	D-01 / B	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>m/w</i> Examiner's Initials	105.5 ODCR	104.4 ODCR	10.5 Stop°		ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:40 Time	114.3 45°	115.6 45°	0	5LS13	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 13 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>m/w</i>	114.9 60°	115.0 60°	Start°	D-01 / B	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>m/w</i> Examiner's Initials	115.5 ODCR	114.4 ODCR	10.5 Stop°		ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:58 Time	124.3 45°	125.6 45°	0	5LS14	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 14 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	10/31 Date <i>m/w</i>	124.9 60°	125.0 60°	Start°	D-01 / B	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>m/w</i> Examiner's Initials	125.5 ODCR	124.4 ODCR	10.5 Stop°		ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>m/w websites</i>	<i>II</i>	<i>10-31-95</i>	<i>John E. Hoffman</i>	<i>11-9-95</i>
EXAMINER	LEVEL	DATE	GE INDEPENDENT REVIEW	DATE
<i>Stephew. Stevew</i>	<i>III</i>	<i>11-9-95</i>	<i>J. B. Brown</i>	<i>11-9-95</i>
GE REVIEWED BY	LEVEL	DATE	UTILITY REVIEW	DATE

PAGE: 9 OF: 13

FORM UT32.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-19
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: -1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:10 Time	134.3 45°	135.6 45°	0	5LS15	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 15	10/31 Date	134.9 60°	135.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nph</i> Examiner's Initials	135.5 ODCR	134.4 ODCR	10.5 Stop°	D-01 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:28 Time	144.3 45°	145.6 45°	0	5LS16	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 16	10/31 Date	144.9 60°	145.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nph</i> Examiner's Initials	145.5 ODCR	144.4 ODCR	10.5 Stop°	D-01 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:40 Time	154.3 45°	155.6 45°	0	5LS17	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 17	10/31 Date	154.9 60°	155.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>nph</i> Examiner's Initials	155.5 ODCR	154.4 ODCR	15.0 Stop°	D-01 / B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:45 Time	197.3 45°	198.6 45°	3.0	5LS21	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	Exam limited due to vibration lines
Lug Set # 21	10/31 Date	197.9 60°	198.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Steph</i> Examiner's Initials	198.5 ODCR	197.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	80° LKUP 37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP 14	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>nph</i> <i>Steph</i> EXAMINER	II	LEVEL	DATE	<i>Steph E. Anderson</i> GE INDEPENDENT REVIEW	11-9-95	DATE	
GE REVIEWED BY	III	LEVEL	DATE	<i>John H. Hayes</i> <i>John H. Hayes</i> UTILITY REVIEW	11/4/95	DATE	PAGE: 10 OF: 13

SHEET 65 OF 101



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-20
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE


Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name & # Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	18:08 Time	204.3 45°	205.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 22	10/31 Date	204.9 60°	205.0 60°	0 Start°	5LS22	60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	 Examiner's Initials	205.5 ODCR	204.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	18:20 Time	214.3 45°	215.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 23	10/31 Date	214.9 60°	215.0 60°	0 Start°	5LS23	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	 Examiner's Initials	215.5 ODCR	214.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	18:35 Time	224.3 45°	225.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 24	10/31 Date	224.9 60°	225.0 60°	0 Start°	5LS24	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	 Examiner's Initials	225.5 ODCR	224.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	18:44 Time	234.3 45°	235.6 45°			45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 25	10/31 Date	234.9 60°	235.0 60°	0 Start°	5LS25	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	 Examiner's Initials	235.5 ODCR	234.4 ODCR	10.5 Stop°	D-02 / A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

 EXAMINER Stephen D. Styler	LEVEL III	DATE 11-7-95	 GE INDEPENDENT REVIEW J.W. Thomas	DATE 11-9-95
GE REVIEWED BY	LEVEL III	DATE 11-9-95	UTILITY REVIEW	DATE 11-9-95



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-21
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23:50 Time	264.3 45°	265.6 45°	0 Start°	5LS28	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 28	10/31 Date	264.9 60°	265.0 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>W.H.</i> Examiner's Initials	265.5 ODCR	264.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	00:07 Time	274.3 45°	275.6 45°	0 Start°	5LS29	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 29	11/01 Date	274.9 60°	275.0 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>C.L.</i> Examiner's Initials	275.5 ODCR	274.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	20:40 Time	284.3 45°	285.6 45°	0 Start°	5LS30	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 30	10/31 Date	284.9 60°	285.0 60°	10.5 Stop°	D-02 / A	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	285.5 ODCR	284.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:02 Time	294.3 45°	295.6 45°	0 Start°	5LS31	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 31	10/31 Date	294.9 60°	295.0 60°	10.5 Stop°	D-02 / A	60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	295.5 ODCR	294.4 ODCR			ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>npr shots</i>	LEVEL	DATE	<i>George E. Daffner Jr.</i>	LEVEL	DATE	<i>11-9-95</i>
<i>Stephens Stephens</i>	LEVEL	DATE	<i>John B. Thomas</i>	LEVEL	DATE	<i>11-9-95</i>



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-05
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-22
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-13 THRU 18

Weld ID: H5 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.5"

Search Unit Separation (Front To Front): 4.5" Wo Location: LKDN @ WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:20 Time	304.3 45°	305.6 45°	0	5LS32	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 32	10/31 Date	304.9 60°	305.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E,	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	305.5 ODCR	304.4 ODCR	10.5 Stop°	D-02/A	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:35 Time	314.3 45°	315.6 45°	0	5LS33	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 33	10/31 Date	314.9 60°	315.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	315.5 ODCR	314.4 ODCR	10.5 Stop°	D-02/B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	21:50 Time	324.3 45°	325.6 45°	0	5LS34	45° LKDN 45° LKUP	43 43	C, E, F C, E, F	
Lug Set # 34	10/31 Date	324.9 60°	325.0 60°	Start°		60° LKDN 60° LKUP	46 46	C, E C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	325.5 ODCR	324.4 ODCR	15.0 Stop°	D-02/B	ODCR LKDN 50 ODCR LKUP 50		C, J C, J	J = Shear Component to ID crown
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A				Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw				Stop°		ODCR LKDN ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS:

<i>Spichler</i> EXAMINER	II	10-31-95	<i>Stage E. Schaefer</i> GE INDEPENDENT REVIEW	11-9-95	
<i>Shayell Standard</i> GE REVIEWED BY	III	11-9-95	<i>John H. O'Brien</i> UTILITY REVIEW	4/4/95	PAGE: 13 OF: 13



GE Nuclear Energy

		EXAMINATION SUMMARY SHEET		REPORT NO.:
PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN		PROCEDURE: UT-CNS-503V4		REV: 0 FRR: N/A N/A N/A
SYSTEM: SHROUD ASSEMBLY WELDS		N/A	REV: N/A	FRR: N/A N/A N/A
WELD NO.: H6A		N/A	REV: N/A	FRR: N/A N/A N/A
CONFIGURATION: PLATE TO CORE PLATE RING		N/A	REV: N/A	FRR: N/A N/A N/A
EXAMINER: T. ROCKWOOD LEVEL: III		<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT		
EXAMINER: C. MCKEAN LEVEL: II		<input checked="" type="checkbox"/> CIRCUMFERENTIAL		
EXAMINER: N/A LEVEL: N/A		<input type="checkbox"/> LONGITUDINAL <input type="checkbox"/> OTHER N/A		
DATA SHEET NO.(S): SD-37 THRU SD-43		CAL SHEET NO.(S): SC-19 THRU SC-24		

During the examination of the referenced weld, one (1) indication associated with IGSCC/ASCC was recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The parameters for this indication are on the following page.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications along with the referenced indication.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications along with the referenced indication.

The OD creeping wave recorded non-relevant indications and inside surface geometry along with the referenced indication.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.55 inches per degree.

This weld was examined from the plate side only, however additional scanning was performed across the weld and on the core plate ring side, directed away from the weld, and resulting in no relevant indications found. This was achieved because the examination was performed simultaneously with the H6B weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation lines.

The examination area that was interrogated by all angles was 264.40° (73.4%). 95.60° (26.6%) was not examined due to the above referenced obstructions.

<i>Stephen D. Hayes</i>	III	11-11-95	<i>R. D. Q.</i>	11/13/95	PAGE: 1 OF: 13
SUMMARY BY <i>J. Schlett</i>	LEVEL III	DATE 11-11-95	GE INDEPENDENT REVIEW <i>K.B. Brown</i>	DATE 11/14/95	FORM UT-09 REV. 6
GE REVIEWED BY	LEVEL	DATE	UTILITY REVIEW	DATE	



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project F5CN October/November 1995

Shroud Weld H6A Indication Data

Total Scan Length (Deg.)	264.40	Total Flaw Length (Deg.)	1.38
Total Scan Length (In.)	409.55	Total Flaw Length (In.)	2.14
Percentage of Weld Length Examined	73.4	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	0.5	Circumference (in.)	557.63
Percentage of Total Weld Length Flawed	0.4	Inches per Degree	1.55

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Inches	Max. Depth Pos. (Deg.)	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
1	235.06	236.44	1.38	2.14	0.33	235.50	22.0	OD/Near	ODCr	60° Long.

Areas Not Examined by All 3 Transducers

0° to 16.5°, 169.3° to 203.5°, 244.8° to 265.5° & 334.8° to 0° (Total of 95.6° Not Examined)


Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs



GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H6A - Typical Flaw Indication @ 235.5 Deg. .33 In. Max. Depth



Inside Surface


NEDC 95-191 ATTACH 2.2
SHEET 70 OF 101



nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET

(AUTOMATED WITH Smart 2000)



Indication # 1 on the ID above the weld.

SITE: COOPER	UNIT: 1	PROJECT NO.: 1F5CN	REPORT NO.: SR-06A
WELD NO.: H-6A	SEARCH UNIT: 60° RL	INDICATION NO.: 1	PAGE: <u>4</u> OF: <u>13</u>




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H6A

Areas Not Examined

Indication Areas






GE Nuclear Energy

*Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995*

H6A - Actual Examination Coverage - 45S, 60L, & ODCr





GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4

REVISION / FRR NO.: 0

REPORT NO.: SR-06A

DATA SHEET NO.: SD-37

CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:40 Time	14.3 45°	N/A 45°	0 Start°	6LS3	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 3 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's initials	15.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-01 / B	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:14 Time	24.3 45°	N/A 45°	0 Start°	6LS4	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 4 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's initials	25.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-01 / B	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:36 Time	34.3 45°	N/A 45°	0 Start°	6LS5	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 5 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's initials	35.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / A	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:22 Time	44.3 45°	N/A 45°	0 Start°	6LS6	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 6 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's initials	45.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / A	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY

REMARKS: * H6A & H6B were scanned simultaneously

<i>John Bell</i> EXAMINER <i>Stephen Shastany</i> GE REVIEWED BY	II LEVEL	11/9/95 DATE	<i>Any Edwards</i> GE INDEPENDENT REVIEW <i>Bob Brown</i> UTILITY REVIEW	11-9-95 DATE	PAGE: 7 OF: 13
	III LEVEL	11-9-95 DATE			FORM UT32.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4
REVISION / FRR NO.: 0

REPORT NO.: SR-06A
DATA SHEET NO.: SD-38
CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0° Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan db	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:42 Time	54.3 45°	N/A 45°	0 Start°	6LS7	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 7 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's Initials	55.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / A	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	14:25 Time	64.3 45°	N/A 45°	0 Start°	6LS8	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 8 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's Initials	65.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / B	60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	14:47 Time	74.3 45°	N/A 45°	0 Start°	6LS9	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 9 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date Examiner's Initials	75.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / B	60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23:30 Time	84.3 45°	N/A 45°	0 Start°	6LS10	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 10 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/2 Date Examiner's Initials	85.0 60° ODCR	N/A 60° ODCR	10.5 Stop°	D-05 / B	60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY

REMARKS: * H6A & H6B were scanned simultaneously

<i>[Signature]</i> EXAMINER	II	11-2-95 DATE	<i>[Signature]</i> GE INDEPENDENT REVIEW	11-9-95 DATE	PAGE: 8 OF: 13
<i>[Signature]</i> GE REVIEWED BY	III	11-9-95 DATE	<i>[Signature]</i> UTILITY REVIEW	11-9-95 DATE	FORM U732-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06A
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-39
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): " 6.375" Wo Location: " LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	00:04	94.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 11	11/3	95.0	N/A	0 Start°	6LS11	60° LKDN	46	C, E	
	Date	60°	60°			60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	95.5	N/A	10.5 Stop°	D-05 / B	ODCR LKDN 50		C, J	J = Shear Component to ID crown
			ODCR			ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:38	104.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 12	11/1	105.0	N/A	0 Start°	6LS12	60° LKDN	46	C, D, E	
	Date	60°	60°			60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	105.5	N/A	10.5 Stop°	D-05 / A	ODCR LKDN 50		C, J	J = Shear Component to ID crown.
			ODCR			ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:05	114.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 13	11/1	115.0	N/A	0 Start°	6LS13	60° LKDN	46	C, D, E	
	Date	60°	60°			60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>MH</i> Examiner's Initials	115.5	N/A	10.5 Stop°	D-05 / A	ODCR LKDN 50		C, J	J = Shear Component to ID crown.
			ODCR			ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:25	124.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 14	11/1	125.0	N/A	0 Start°	6LS14	60° LKDN	46	C, D, E	
	Date	60°	60°			60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>TJL</i> Examiner's Initials	125.5	N/A	10.5 Stop°	D-05 / A	ODCR LKDN 50		C, J	J = Shear Component to ID crown.
			ODCR			ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP		A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>Stephanie Webster</i> EXAMINER	LEVEL IF	DATE 11-3-95	<i>Stephanie Webster</i> GE INDEPENDENT REVIEW	DATE 11-9-95	PAGE: 9 OF: 13
<i>Stephanie Webster</i> GE REVIEWED BY	LEVEL III	DATE 11-9-95	<i>Stephanie Webster</i> UTILITY REVIEW	DATE 11-9-95	FORM UT32-R3

SHEET 77 OF 101



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503\4	REPORT NO.: SR-06A
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-40
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Under <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:48 Time	134.3 45°	N/A 45°	0	6LS15	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 15 <input checked="" type="checkbox"/> <input type="checkbox"/> Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date	135.0 60°	N/A 60°	Start° 1C.5 Stop°	D-05 / A	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:11 Time	144.3 45°	N/A 45°	0	6LS16	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 16 <input checked="" type="checkbox"/> <input type="checkbox"/> Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date	145.0 60°	N/A 60°	Start° 10.5 Stop°	D-05 / A	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:34 Time	154.3 45°	N/A 45°	0	6LS17	45° LKDN 45° LKUP	43 46	C, E, F C, D, E	
Lug Set # 17 <input checked="" type="checkbox"/> <input type="checkbox"/> Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/1 Date	155.0 60°	N/A 60°	Start° 15.0 Stop°	D-05 / B	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:22 Time	202.3 45°	N/A 45°	8.0	6LS21	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 21 <input checked="" type="checkbox"/> <input type="checkbox"/> Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/3 Date	203.0 60°	N/A 60°	Start° 10.5 Stop°	D-02 / B	60° LKDN 60° LKUP ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN 37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN 35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>[Signature]</i> EXAMINER: Stephen W. Steward	LEVEL: II	DATE: 11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW	DATE: 11-9-95	PAGE: 10 OF: 13
GE REVIEWED BY:	LEVEL: III	DATE: 11-9-95	<i>[Signature]</i> UTILITY REVIEW	DATE: 11-9-95	FORM UT32 RD

GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06A
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-41
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:43 Time	204.3 45°	N/A 45°	0 Start°	6LS22	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 22	11/3 Date	205.0 60°	N/A 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CJ</i> Examiner's Initials	205.5 ODCR	N/A ODCR			ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:09 Time	214.3 45°	N/A 45°	0 Start°	6LS23	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 23	11/3 Date	215.0 50°	N/A 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CJ</i> Examiner's Initials	215.5 ODCR	N/A ODCR			ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:47 Time	224.3 45°	N/A 45°	0 Start°	6LS24	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 24	11/3 Date	225.0 60°	N/A 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CJ</i> Examiner's Initials	225.5 ODCR	N/A ODCR			ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:11 Time	234.3 45°	N/A 45°	0 Start°	6LS25	45° LKDN 45° LKUP	43 46	B, C, E, F B, C, E	Indication # 1
Lug Set # 25	11/3 Date	235.0 60°	N/A 60°	10.5 Stop°	D-02 / B	60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>CJ</i> Examiner's Initials	235.5 ODCR	N/A ODCR			ODCR LKDN 50 ODCR LKUP		B, C, J	J = Shear Component to ID crown and Indication # 1.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY

REMARKS: * H6A & H6B were scanned simultaneously

<i>Chris H. McLean</i> EXAMINER <i>Stephanie Steigard</i> GE REVIEWED BY	II LEVEL	11/3/95 DATE	<i>Shay E. Hobson</i> GE INDEPENDENT REVIEW <i>John D. Thomas</i> UTILITY REVIEW	11-9-95 DATE	
	III LEVEL	11-9-95 DATE		11-9-95 DATE	PAGE: 11 OF: 13 FORM UT-32.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06A
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-42
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:09 Time	264.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 28	11/3 Date	265.0 60°	N/A 60°	0 Start°	6LS28	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	265.5 ODCR	N/A ODCR	10.5 Stop°	D-06/A	ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:31 Time	274.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 29	11/3 Date	275.0 60°	N/A 60°	0 Start°	6LS29	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	275.5 ODCR	N/A ODCR	10.5 Stop°	D-06/A	ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:09 Time	284.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 30	11/3 Date	285.0 60°	N/A 60°	0 Start°	6LS30	60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	285.5 ODCR	N/A ODCR	10.5 Stop°	D-02/B	ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:02 Time	294.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 31	11/3 Date	295.0 60°	N/A 60°	0 Start°	6LS31	60° LKDN 60° LKUP	46	C, E, G	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	295.5 ODCR	N/A ODCR	10.5 Stop°	D-02/B	ODCR LKDN 50 ODCR LKUP		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY

REMARKS: * H6A & H6B were scanned simultaneously

<i>John P. Costa</i> EXAMINER	III	LEVEL	11-7-95	<i>John E. Hoban, Jr.</i> GE INDEPENDENT REVIEW	11-9-95	DATE
<i>Stacy W. Sawyer</i> GE REVIEWED BY	III	LEVEL	11-9-95	<i>John E. Hoban, Jr.</i> UTILITY REVIEW	11-9-95	DATE
				PAGE: 12 OF: 13		



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06A
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-43
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-19 THRU 24

Weld ID: H6A Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:28	304.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 32	11/3	305.0	N/A	0	6LS32	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°	Start°		60° LKUP			
	J	305.5	N/A	10.5	D-06/A	ODCR LKDN 50		C, J	J = Shear Component to ID crown
	Examiner's Initials	ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:49	314.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 33	11/3	315.0	N/A	0	6LS33	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°	Start°		60° LKUP			
	J	315.5	N/A	10.5	D-06/A	ODCR LKDN 50		C, J	J = Shear Component to ID crown.
	Examiner's Initials	ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:10	324.3	N/A			45° LKDN	43	C, E, F	
	Time	45°	45°			45° LKUP			
Lug Set # 34	11/3	325.0	N/A	0	6LS34	60° LKDN	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°	Start°		60° LKUP			
	J	325.5	N/A	10.5	D-06/A	ODCR LKDN 50		C, J	J = Shear Component to ID crown.
	Examiner's Initials	ODCR	ODCR	Stop°		ODCR LKUP			
Cylinder <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw						45° LKDN			
	Time	45°	45°			45° LKUP			
Lug Set # N/A				Start°		60° LKDN			
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	Date	60°	60°	Stop°		60° LKUP			
	Examiner's Initials	ODCR	ODCR			ODCR LKDN			
						ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	17	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	37	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY
60° LKDN	35	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY

J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>[Signature]</i> EXAMINER	III	11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW	11-9-95	
<i>[Signature]</i> GE REVIEWED BY	III	11-9-95	<i>[Signature]</i> UTILITY REVIEW	11-9-95	PAGE: 13 OF: 13



GE Nuclear Energy

EXAMINATION SUMMARY SHEET

REPORT NO.:
SR-06BPROJECT: COOPER RFO16
SHROUD UT PROJECT 1F5CNPROCEDURE: UT-CNS-503V4 REV: 0 FRR: N/A
N/A
N/A

SYSTEM: SHROUD ASSEMBLY WELDS

N/A REV: N/A FRR: N/A
N/A
N/A

WELD NO.: H6B

N/A REV: N/A FRR: N/A
N/A
N/A

CONFIGURATION: CORE PLATE RING TO PLATE

N/A REV: N/A FRR: N/A
N/A
N/A

EXAMINER: T. ROCKWOOD LEVEL: III

 MT PT UT VT

EXAMINER: C. MCKEAN LEVEL: II

 CIRCUMFERENTIAL

EXAMINER: N/A LEVEL: N/A

 LONGITUDINAL OTHER N/A

DATA SHEET NO.(S): SD-44 THRU SD-50

CAL SHEET NO.(S): SC-25 THRU SC-30

During the examination of the referenced weld, no indications associated with IGSCC/IASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The parameters for these indications are on the following page.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications.

The OD creeping wave recorded non-relevant indications and inside surface geometry.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.55 inches per degree.

This weld was examined from the plate side only, however additional scanning was performed across the weld and on the core plate ring side, directed away from the weld, and resulting in no relevant indications found. Also the looking down transducer from the H6A examination achieved a limited scan with the transducer directed toward the weld, also resulting in no relevant indications found. This was achieved because the examination was performed simultaneously with the H6A weld.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs and instrumentation lines.

The examination area that was interrogated by all angles was 264.40° (73.4%). 95.60° (26.6%) was not examined due to the above referenced obstructions.

Stephen J. Snyder
SUMMARY BY
Bob Schmitt
GE REVIEWED BY

III 11-11-95
LEVEL DATE
III 11-11-95
LEVEL DATE

R. D. S.
GE INDEPENDENT REVIEW
Z. B. Brown
UTILITY REVIEW

11/13/95
DATE
11/14/95
DATE

PAGE: 1 OF: 11



GE Nuclear Energy

Nebraska Public Power District
 Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H6B Indication Data

Total Scan Length (Deg.)	264.40	Total Flaw Length (Deg.)	0.00
Total Scan Length (In.)	409.55	Total Flaw Length (In.)	0.00
Percentage of Weld Length Examined	73.4	Thickness (in.)	1.50
Percentage of Examined Weld Length Flawed	0.0	Circumference (in.)	557.63
Percentage of Total Weld Length Flawed	0.0	Inches per Degree	1.55

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Pos. (Deg.)	Max. Depth Inches	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
-------------------	---------------	-------------	----------------	---------------	------------------------	-------------------	---------------	--------------------	-------------------	------------------

No Relevant Indications Recorded

Areas Not Examined by All 3 Transducers

0° to 15.5°, 169.3° to 203.5°, 244.8° to 265.5° & 334.8° to 0° (Total of 95.6° Not Examined)

Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H6B

Areas Not Examined






GE Nuclear Energy

*Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995*

H6B - Actual Examination Coverage - 45S, 60L, & ODCr



NEDC 95-191 ATTACH 2.3
SHEET 84 OF 101



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06B
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-44
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:40 Time	N/A 45°	15.6 45°	0 Start°	6LS3	45° LKDN 45° LKUP 43	C, E, F, G		
Lug Set # 3	11/1 Date	N/A 60°	15.0 60°	10.5 Stop°	D-01 / B	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JBB</i> Examiner's Initials	N/A ODCR	14.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:14 Time	N/A 45°	25.6 45°	0 Start°	6LS4	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 4	11/1 Date	N/A 60°	25.0 60°	10.5 Stop°	D-01 / B	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JBB</i> Examiner's Initials	N/A ODCR	24.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:36 Time	N/A 45°	35.6 45°	0 Start°	6LS5	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 5	11/1 Date	N/A 60°	35.0 60°	10.5 Stop°	D-05 / A	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JBB</i> Examiner's Initials	N/A ODCR	34.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:22 Time	N/A 45°	45.6 45°	0 Start°	6LS6	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 6	11/1 Date	N/A 60°	45.0 60°	10.5 Stop°	D-05 / A	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JBB</i> Examiner's Initials	N/A ODCR	44.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

EXAMINER <i>Stephen W. Stayton</i>	LEVEL III	DATE 11-9-95	GE INDEPENDENT REVIEW <i>John E. DePauw</i>	DATE 11-9-95
GE REVIEWED BY <i>Stephen W. Stayton</i>	LEVEL III	DATE 11-9-95	UTILITY REVIEW <i>Z.B. Brown</i>	DATE 11-14-95
PAGE: 5 OF: 11				



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4

REVISION / FRR NO.: 0

REPORT NO.: SR-06B

DATA SHEET NO.: SD-45

CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:42 Time	N/A 45°	55.6 45°		6LS7	45° LKDN 45° LKUP 43		C, E, F	
Lug Set # 7	11/1 Date	N/A 60°	55.0 60°	0 Start°		60° LKDN 60° LKUP 46		C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	ZSR Examiner's Initials	N/A ODCR	54.4 ODCR	10.5 Stop°	D-05 / A	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	14:25 Time	N/A 45°	65.6 45°		6LS8	45° LKDN 45° LKUP 43		C, E, F	
Lug Set # 8	11/1 Date	N/A 60°	65.0 60°	0 Start°		60° LKDN 60° LKUP 46		C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	ZSR Examiner's Initials	N/A ODCR	64.4 ODCR	10.5 Stop°	D-05 / B	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	14:47 Time	N/A 45°	75.6 45°		6LS9	45° LKDN 45° LKUP 43		C, E, F	
Lug Set # 9	11/1 Date	N/A 60°	75.0 60°	0 Start°		60° LKDN 60° LKUP 46		C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	ZSR Examiner's Initials	N/A ODCR	74.4 ODCR	10.5 Stop°	D-05 / B	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	23:30 Time	N/A 45°	85.6 45°		6LS10	45° LKDN 45° LKUP 43		C, E, F	
Lug Set # 10	11/2 Date	N/A 60°	85.0 60°	0 Start°		60° LKDN 60° LKUP 46		C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	ZSR Examiner's Initials	N/A ODCR	84.4 ODCR	10.5 Stop°	D-05 / B	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>Alvaco</i> EXAMINER	III LEVEL	11-7-95 DATE	<i>Joe E. DeRosa</i> GE INDEPENDENT REVIEW	11-9-95 DATE	PAGE: 6 OF: 11
<i>Stephen J. Stanford</i> GE REVIEWED BY	III LEVEL	11-9-95 DATE	<i>John J. Thomas</i> UTILITY REVIEW	11-9-95 DATE	FORM UT32_R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4

REVISION / FRR NO.: 0

REPORT NO.: SR-06B

DATA SHEET NO.: SD-46

CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	00:04 Time	N/A 45°	95.6 45°	0	6LS11	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 11 <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11/3 Date	N/A 60°	95.0 60°	Start°		60° LKDN 60° LKUP	46	C, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	N/A ODCR	94.4 ODCR	10.5 Stop°	D-05 / B	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:38 Time	N/A 45°	105.6 45°	0	6LS12	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 12 <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11/1 Date	N/A 60°	105.0 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	N/A ODCR	104.4 ODCR	10.5 Stop°	D-05 / A	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:05 Time	N/A 45°	115.6 45°	0	6LS13	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 13 <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11/1 Date	N/A 60°	115.0 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>M.W.</i> Examiner's Initials	N/A ODCR	114.4 ODCR	10.5 Stop°	D-05 / A	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:25 Time	N/A 45°	125.6 45°	0	6LS14	45° LKDN 45° LKUP	43	C, E, F	
Lug Set # 14 <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11/1 Date	N/A 60°	125.0 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>E.R.</i> Examiner's Initials	N/A ODCR	124.4 ODCR	10.5 Stop°	D-05 / A	ODCR LKDN ODCR LKUP 50		C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	80° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>Whaleby</i> EXAMINED <i>Stephen W. Haywood</i> GE REVIEWED BY	II LEVEL DATE 11-3-95	<i>George E. Aufderheide</i> GE INDEPENDENT REVIEW <i>Z.B. Thomas</i> UTILITY REVIEW	11-9-95 DATE 11-14-95	PAGE: 7 OF: 11 FORM UT32-10
	III LEVEL DATE 11-9-95			



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06B
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-47
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:48 Time	N/A 45°	135.6 45°		6LS15	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 15	11/1 Date	N/A 60°	135.0 60°	0 Start°	D-05 / A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw		N/A ODCR	134.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:11 Time	N/A 45°	145.6 45°		6LS16	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 16	11/1 Date	N/A 60°	145.0 60°	0 Start°	D-05 / A	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw		N/A ODCR	144.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:34 Time	N/A 45°	155.6 45°		6LS17	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 17	11/1 Date	N/A 60°	155.0 60°	0 Start°	D-05 / B	60° LKDN 60° LKUP 46	C, D, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw		N/A ODCR	154.4 ODCR	15.0 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:22 Time	N/A 45°	203.6 45°		6LS21	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 21	11/3 Date	N/A 60°	203.0 60°	8.0 Start°	D-02 / B	60° LKDN 60° LKUP 46	C, E, G		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw		N/A ODCR	202.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	80° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP 38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

	LEVEL III	DATE 11-7-95		DATE 11-9-95	PAGE: 8 OF: 11
GE REVIEWED BY 	LEVEL III	DATE 11-9-95	UTILITY REVIEW 	DATE 11/14/95	FORM UT32.R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06B
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-48
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	02:43 Time	N/A 45°	205.6 45°	0	6LS22	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 22	11/3 Date	N/A 60°	205.0 60°	Start°	D-02 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Cm</i> Examiner's Initials	N/A ODCR	204.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:09 Time	N/A 45°	215.6 45°	0	6LS23	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 23	11/3 Date	N/A 60°	215.0 60°	Start°	D-02 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Cm</i> Examiner's Initials	N/A ODCR	214.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	03:47 Time	N/A 45°	225.6 45°	0	6LS24	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 24	11/3 Date	N/A 60°	225.0 60°	Start°	D-02 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Cm</i> Examiner's Initials	N/A ODCR	224.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown.	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:11 Time	N/A 45°	235.6 45°	0	6LS25	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 25	11/3 Date	N/A 60°	235.0 60°	Start°	D-02 / B	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Cm</i> Examiner's Initials	N/A ODCR	234.4 ODCR	10.5 Stop°		ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown.	

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN		ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY

REMARKS: * H6A & H6B were scanned simultaneously

Chin H. Makin II	LEVEL	DATE	<i>John E. Dufresne</i>	DATE	
EXAMINED			GE INDEPENDENT REVIEW		
<i>Stephanie Dauphin</i>	III	11-9-95	11-11-95	<i>J.C. Thomas</i>	DATE
GE REVIEWED BY	LEVEL	DATE	UTILITY REVIEW		PAGE: 9 OF: 11

GE Nuclear Energy				SHROUD ULTRASONIC EXAMINATION DATA SHEET (AUTOMATED with Smart 2000 OD TRACKER)					
SITE: COOPER		PROCEDURE NO.: UT-CNS-503V4			REPORT NO.: SR-06B				
UNIT: 1		REVISION / FRR NO.: 0			DATA SHEET NO.: SD-49				
PROJECT NO.: 1F5CN					CALIBRATION SHEET NO.: SC-25 THRU 30				
Weld ID: H6B		Exam Surface: OD		Stroke: 7.0"		Crown Width: ~ 1.5"			
Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE									
Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:09 Time	N/A 45°	285.6 45°	0	45° LKDN 45° LKUP 43	C, E, F			
Lug Set # 28	11/3 Date	N/A 60°	285.0 60°	Start°	6LS28	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	264.4 ODCR	10.5 Stop°	D-06 / A	ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	09:30 Time	N/A 45°	275.6 45°	0	45° LKDN 45° LKUP 43	C, E, F			
Lug Set # 29	11/3 Date	N/A 60°	275.0 60°	Start°	6LS29	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	274.4 ODCR	10.5 Stop°	D-06 / A	ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	06:09 Time	N/A 45°	285.6 45°	0	45° LKDN 45° LKUP 43	C, E, F			
Lug Set # 30	11/3 Date	N/A 60°	285.0 60°	Start°	6LS30	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	284.4 ODCR	10.5 Stop°	D-02 / B	ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:02 Time	N/A 45°	295.6 45°	0	45° LKDN 45° LKUP 43	C, E, F			
Lug Set # 31	11/3 Date	N/A 60°	295.0 60°	Start°	6LS31	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	294.4 ODCR	10.5 Stop°	D-02 / B	ODCR LKDN ODCR LKUP 50	C, J		J = Shear Component to ID crown
CALIBRATION dB:				EXAMINATION RESULTS LEGEND:					
45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE			G - WELD DISCONTINUITY		
45° LKUP	14	ODCR LKDN	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY			H - WELD CROWN GEOMETRY		
60° LKDN		ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY			J - OTHER (SEE COMMENTS)	
REMARKS:		* H6A & H6B were scanned simultaneously							
<i>[Signature]</i> EXAMINER		LEVEL III	DATE 11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW			DATE 11-9-95		
<i>[Signature]</i> GE REVIEWED BY		LEVEL III	DATE 11-9-95	<i>[Signature]</i> UTILITY REVIEW			DATE 11-4-95	PAGE: 10 OF: 11	



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-06B
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-50
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-25 THRU 30

Weld ID: H6B Exam Surface: OD Stroke: 7.0" Crown Width: ~ 1.5"

Search Unit Separation (Front To Front): * 6.375" Wo Location: * LKDN 2.5" BELOW H6A WELD TOE

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:28 Time	N/A 45°	305.6 45°	0 Start°	6LS32	45° LKDN 45° LKUP 43	C, E, F, G		
Lug Set # 32	11/3 Date	N/A 60°	305.0 60°	10.5 Stop°	D-06 / A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	304.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	07:49 Time	N/A 45°	315.6 45°	0 Start°	6LS33	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 33	11/3 Date	N/A 60°	315.0 60°	10.5 Stop°	D-06 / A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	314.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	08:10 Time	N/A 45°	325.6 45°	0 Start°	6LS34	45° LKDN 45° LKUP 43	C, E, F		
Lug Set # 34	11/3 Date	N/A 60°	325.0 60°	10.5 Stop°	D-06 / A	60° LKDN 60° LKUP 46	C, E		
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>[Signature]</i> Examiner's Initials	N/A ODCR	324.4 ODCR			ODCR LKDN ODCR LKUP 50	C, J	J = Shear Component to ID crown	
Cylinder <input type="checkbox"/> <input type="checkbox"/> cw ccw						45° LKDN 45° LKUP			
Lug Set # N/A				Start°		60° LKDN 60° LKUP			
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw				Stop°		ODCR LKDN ODCR LKUP			

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	60° LKUP	37	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN	14	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	ODCR LKUP	38	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * H6A & H6B were scanned simultaneously

<i>[Signature]</i> EXAMINER	III	11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW	11-9-95	PAGE: 11 OF: 11
<i>[Signature]</i> GE REVIEWED BY	III	11-9-95	<i>[Signature]</i> UTILITY REVIEW	11-9-95	FORM UT32-R3



GE Nuclear Energy

		EXAMINATION SUMMARY SHEET		REPORT NO.:
PROJECT: COOPER RFO16 SHROUD UT PROJECT 1F5CN		PROCEDURE: UT-CNS-503V4		REV: 0 FRR: N/A N/A N/A
SYSTEM: SHROUD ASSEMBLY WELDS		N/A		REV: N/A FRR: N/A N/A N/A
WELD NO.: H7		N/A		REV: N/A FRR: N/A N/A N/A
CONFIGURATION: PLATE TO PLATE		N/A		REV: N/A FRR: N/A N/A N/A
EXAMINER: T. ROCKWOOD	LEVEL: III			<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> VT
EXAMINER: C. MCKEAN	LEVEL: II			<input checked="" type="checkbox"/> CIRCUMFERENTIAL
EXAMINER: N/A	LEVEL: N/A			<input type="checkbox"/> LONGITUDINAL <input type="checkbox"/> OTHER N/A
DATA SHEET NO.(S): SD-51 THRU SD-56		CAL SHEET NO.(S): SC-37 THRU SC-39		

During the examination of the referenced weld, no indications associated with IGSCC/IASCC were recorded by the Smart 2000 system utilizing a TRI-MODAL search unit containing a 45° shear wave, OD creeping wave and 60° refracted longitudinal (RL) wave.

The 45° shear wave recorded inside and outside surface weld crown geometry and non-relevant indications.

The 60° RL recorded inside surface weld crown geometry and non-relevant indications.

The OD creeping wave recorded non-relevant indications and inside surface geometry.

Circumferential (L) dimensions were recorded in angular units. The conversion factor for linear units is 1.49 inches per degree.

This examination was performed from the plate side only due to the weld configuration of the lower plate support and the backing ring configuration.

This exam was limited to the areas scanned due to obstructions from the guide pins, core spray downcomers, shroud lifting lugs, instrumentation lines.

The examination area that was interrogated by all angles was 246.90° (68.6%). 113.10° (31.4%) was not examined due to the above referenced obstructions.

<i>Stephen D. Taylor</i>		III	11-11-95	<i>R. A.</i>		11/13/95	
SUMMARY BY <i>Hebbelitt</i>	LEVEL III	DATE 11-11-95		GE INDEPENDENT REVIEW <i>K.B. Thomas</i>	UTILITY REVIEW	DATE 11/14/95	PAGE: 1 OF: 10
GE REVIEWED BY <i>Hebbelitt</i>	LEVEL III	DATE 11-11-95					FORM UT-00 REV. 3



GE Nuclear Energy

Nebraska Public Power District
 Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H7 Indication Data

Total Scan Length (Deg.)	246.00	Total Flaw Length (Deg.)	0.00
Total Scan Length (In.)	368.44	Total Flaw Length (In.)	0.00
Percentage of Weld Length Examined	68.6	Thickness (In.)	1.50
Percentage of Examined Weld Length Flawed	0.0	Circumference (In.)	537.21
Percentage of Total Weld Length Flawed	0.0	Inches per Degree	1.49

Indication Number	Start Azimuth	End Azimuth	Length Degrees	Length Inches	Max. Depth Pos. (Deg.)	Max. Depth Inches	% of Thruwall	Initiating Surface	Length Transducer	Depth Transducer
-------------------	---------------	-------------	----------------	---------------	------------------------	-------------------	---------------	--------------------	-------------------	------------------

No Relevant Indications Recorded

Areas Not Examined by All 7 Transducers

0° to 15.5°, 169.3° to 205.5°, 244.8° to 285.5° & 339.5° to 0° (Total of 113.10° Not Examined)

Limitations: Guide Pins, Core Spray Downcomers, Instrumentation Lines and Lifting Lugs




GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

Shroud Weld H7

■ Areas Not Examined






GE Nuclear Energy

Nebraska Public Power District
Cooper Nuclear Station RFO16 Shroud UT Project 1F5CN October/November 1995

H7 - Actual Examination Coverage - 45S, 60L, & ODCr





GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-07
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-51
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 3.5" Crown Width: * ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	16:39 Time	14.3 45°	N/A 45°	0 Start°	7LS3	45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 3 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/3 Date	15.0 60°	N/A 60°	10.5 Stop°	D-07 / A	60° LKDN 60° LKUP	50	C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:01 Time	24.3 45°	N/A 45°	0 Start°	7LS4	45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 4 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/3 Date	25.0 60°	N/A 60°	10.5 Stop°	D-07 / A	60° LKDN 60° LKUP	50	C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:11 Time	34.3 45°	N/A 45°	0 Start°	7LS5	45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 5 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/3 Date	35.0 60°	N/A 60°	10.5 Stop°	D-07 / A	60° LKDN 60° LKUP	50	C, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	17:48 Time	44.3 45°	N/A 45°	0 Start°	7LS6R	45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 6 Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	11/3 Date	45.0 60°	N/A 60°	10.5 Stop°	D-07 / A	60° LKDN 60° LKUP	50	C, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	19	60° LKUP	A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP	ODCR LKDN	38	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	37	ODCR LKUP	C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

<i>[Signature]</i> EXAMINER: <i>[Signature]</i> GE REVIEWED BY: <i>[Signature]</i>	LEVEL: I	DATE: 11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW	DATE: 11-9-95	PAGE: 5 OF: 10
	LEVEL: III	DATE: 11-9-95	<i>[Signature]</i> UTILITY REVIEW	DATE: 11-14-95	FORM UT32-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER
UNIT: 1
PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4
REVISION / FRR NO.: 0

REPORT NO.: SR-07
DATA SHEET NO.: SD-52
CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 4.0" Crown Width: * ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	18:00 Time	54.3 45°	N/A 45°	0	7LS7	45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 7	11/3 Date	55.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JSD</i> Examiner's Initials	55.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:08 Time	64.3 45°	N/A 45°	0	7LS8	45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 8	11/4 Date	65.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Ces</i> Examiner's Initials	65.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	04:42 Time	74.3 45°	N/A 45°	0	7LS9	45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 9	11/4 Date	75.0 60°	N/A 60°	Start°		60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>Ces</i> Examiner's Initials	75.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	05:10 Time	84.3 45°	N/A 45°	0	7LS10	45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 10	11/4 Date	85.0 60°	N/A 60°	Start°		80° LKDN 80° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input type="checkbox"/> cw ccw	<i>Ces</i> Examiner's Initials	85.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 19 60° LKUP 38
 45° LKUP ODCR LKDN 38
 60° LKDN 37 ODCR LKUP

A - NO RECORDABLE INDICATIONS
 B - NON-GEOMETRIC INDICATIONS
 C - NON-RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
 E - INSIDE SURFACE GEOMETRY
 F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
 H - WELD CROWN GEOMETRY
 J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

<i>John W. Dwyer</i> EXAMINER	LEVEL <u>II</u>	DATE <u>11-7-95</u>	<i>George E. Johnson</i> GE INDEPENDENT REVIEW	DATE <u>11-9-95</u>	
<i>John W. Dwyer</i> GE REVIEWED BY	LEVEL <u>III</u>	DATE <u>11-9-95</u>	<i>Z.B. Thomas</i> UTILITY REVIEW	DATE <u>11-14-95</u>	PAGE: <u>6</u> OF: <u>10</u>



GE Nuclear Energy

SHROUD ULTRASONIC EXAMINATION

DATA SHEET

(AUTOMATED with Smart 2000 OD TRACKER)

SITE: COOPER
 UNIT: 1
 PROJECT NO.: 1F5CN

PROCEDURE NO.: UT-CNS-503V4
 REVISION / FRR NO.: 0

REPORT NO.: SR-07
 DATA SHEET NO.: SD-53
 CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 4.0" Crown Width: ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder cw ccw	05:42 Time	94.3 45°	N/A 45°			45° LKDN 45° LKUP	43 46	C, E, F C, E	
Lug Set # 11	11/4 Date	95.0 60°	N/A 60°	0 Start°	7LS11	60° LKDN 60° LKUP	46	C, J	J = Shear Component to ID crown.
Lug Side cw ccw	CWS Examiner's Initials	95.5 ODCR	N/A ODCR	10.5 Stop°	D-07/A	ODCR LKDN 50 ODCR LKUP			
Cylinder cw ccw	23:23 Time	104.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 12	11/3 Date	105.0 60°	N/A 60°	0 Start°	7LS12	60° LKDN 60° LKUP	46	C, D, E	
Lug Side cw ccw	CWS Examiner's Initials	105.5 ODCR	N/A ODCR	10.5 Stop°	D-07/A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder cw ccw	23:45 Time	114.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 13	11/3 Date	115.0 60°	N/A 60°	0 Start°	7LS13	60° LKDN 60° LKUP	46	C, D, E	
Lug Side cw ccw	CWS Examiner's Initials	115.5 ODCR	N/A ODCR	10.5 Stop°	D-07/A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder cw ccw	10:48 Time	124.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 14	11/4 Date	125.0 60°	N/A 60°	0 Start°	7LS14R	60° LKDN 60° LKUP	46	C, D, E	
Lug Side cw ccw	TDS Examiner's Initials	125.5 ODCR	N/A ODCR	10.5 Stop°	D-07/A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 19 60° LKUP 38
 45° LKUP 38 ODCR LKDN 38
 60° LKDN 37 ODCR LKUP 38

A - NO RECORDABLE INDICATIONS
 B - NON-GEOMETRIC INDICATIONS
 C - NON RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
 E - INSIDE SURFACE GEOMETRY
 F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
 H - WELD CROWN GEOMETRY
 J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

Chris H. McKee II EXAMINER	LEVEL	DATE	Stoyel E. Arthur Co GE INDEPENDENT REVIEW	DATE
Stephen D. Chapman III GE REVIEWED BY	LEVEL	DATE	John B. Thomas UTILITY REVIEW	DATE

PAGE: 7 OF: 10

FORM UT32-R3



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-07
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-54
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	10:58 Time	134.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 15	11/4 Date	135.0 60°	N/A 60°	0 Start°	7LS15R	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	135.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:06 Time	144.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 16	11/4 Date	145.0 60°	N/A 60°	0 Start°	7LS16R	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	145.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	11:17 Time	154.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 17	11/4 Date	155.0 60°	N/A 60°	0 Start°	7LS17R	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	155.5 ODCR	N/A ODCR	15.0 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	12:49 Time	204.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 22	11/4 Date	205.0 60°	N/A 60°	0 Start°	7LS22	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	JR Examiner's Initials	205.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 19 60° LKUP 38
45° LKUP 00CR LKDN 38
60° LKDN 37 00CR LKUP

A - NO RECORDABLE INDICATIONS
B - NON-GEOMETRIC INDICATIONS
C - NON-RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
E - INSIDE SURFACE GEOMETRY
F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
H - WELD CROWN GEOMETRY
J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

	LEVEL III	DATE 11-7-95		LEVEL III	DATE 11-9-95	PAGE: 8 OF: 10
EXAMINER 	LEVEL III	DATE 11-9-95	GE INDEPENDENT REVIEW 	LEVEL III	DATE 11-9-95	UTILITY REVIEW



GE Nuclear Energy

SHROUD ULTRASONIC EXAMINATION

DATA SHEET

(AUTOMATED with Smart 2000 OD TRACKER)

SITE: COOPER

PROCEDURE NO.: UT-CNS-503V4

REPORT NO.: SR-07

UNIT: 1

S.ON / FRR NO.: 0

DATA SHEET NO.: SD-55

PROJECT NO.: 1F5CN

CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 3.5" Crown Width: ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder cw ccw	13:00 Time	214.3 45°	N/A 45°			45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 23	11/4 Date	215.0 60°	N/A 60°	0 Start°	7LS23	60° LKDN 60° LKUP	46		
Lug Side cw ccw	<i>[Signature]</i> Examiner's Initials	215.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder cw ccw	13:15 Time	224.3 45°	N/A 45°			45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 24	11/4 Date	225.0 60°	N/A 60°	0 Start°	7LS24	60° LKDN 60° LKUP	46		
Lug Side cw ccw	<i>[Signature]</i> Examiner's Initials	225.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder cw ccw	13:20 Time	234.3 45°	N/A 45°			45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 25	11/4 Date	235.0 60°	N/A 60°	0 Start°	7LS25	60° LKDN 60° LKUP	46		
Lug Side cw ccw	<i>[Signature]</i> Examiner's Initials	235.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder cw ccw	15:43 Time	284.3 45°	N/A 45°			45° LKDN 45° LKUP	43 46	C, D, E, F C, D, E	
Lug Set # 30	11/4 Date	285.0 60°	N/A 60°	0 Start°	7LS30	60° LKDN 60° LKUP	46		
Lug Side cw ccw	<i>[Signature]</i> Examiner's Initials	285.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN 19 60° LKUP 38 A - NO RECORDABLE INDICATIONS
 45° LKUP 38 ODCR LKDN 38 B - NON-GEOMETRIC INDICATIONS
 60° LKDN 37 ODCR LKUP 38 C - NON-RELEVANT INDICATIONS

D - ACOUSTIC INTERFACE
 E - INSIDE SURFACE GEOMETRY
 F - OUTSIDE SURFACE GEOMETRY

G - WELD DISCONTINUITY
 H - WELD CROWN GEOMETRY
 J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

<i>[Signature]</i> EXAMINER	II	11-7-95	<i>[Signature]</i> GE INDEPENDENT REVIEW	11-9-95
Steph. Steger GE REVIEWED BY	LEVEL	DATE		DATE
	III	11-9-95	Job 1005 ZB Thomas UTILITY REVIEW	11-14-95
	LEVEL	DATE		DATE

PAGE: 9 OF: 10

FORM LT32-R1



GE Nuclear Energy

**SHROUD ULTRASONIC EXAMINATION
DATA SHEET
(AUTOMATED with Smart 2000 OD TRACKER)**

SITE: COOPER	PROCEDURE NO.: UT-CNS-503V4	REPORT NO.: SR-07
UNIT: 1	REVISION / FRR NO.: 0	DATA SHEET NO.: SD-56
PROJECT NO.: 1F5CN		CALIBRATION SHEET NO.: SC-37 THRU 39

Weld ID: H7 Exam Surface: OD Stroke: 3.5" Crown Width: * ~1.25"

Search Unit Separation (Front To Front): N/A Wo Location: LKDN @ BACKING RING

Lug / Cell No.	Scan Data:	LKDN Search Unit Start:	LKUP Search Unit Start:	Indexer Start° / Stop°	File Name and Disk / Side:	Search Unit	Scan dB	Results: (See Legend)	Comments:
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	15:53 Time	294.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 31	11/4 Date	295.0 60°	N/A 60°	0 Start°	7LS31	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	295.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	16:06 Time	304.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 32	11/4 Date	305.0 60°	N/A 60°	0 Start°	7LS32	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	305.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / A	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	16:14 Time	314.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 33	11/4 Date	315.0 60°	N/A 60°	0 Start°	7LS33	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	315.5 ODCR	N/A ODCR	10.5 Stop°	D-07 / B	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.
Cylinder <input checked="" type="checkbox"/> <input type="checkbox"/> cw ccw	16:26 Time	324.3 45°	N/A 45°			45° LKDN 45° LKUP	43	C, D, E, F	
Lug Set # 34	11/4 Date	325.0 60°	N/A 60°	0 Start°	7LS34	60° LKDN 60° LKUP	46	C, D, E	
Lug Side <input type="checkbox"/> <input checked="" type="checkbox"/> cw ccw	<i>JK</i> Examiner's Initials	325.5 ODCR	N/A ODCR	15.0 Stop°	D-07 / B	ODCR LKDN 50 ODCR LKUP		C, D, J	J = Shear Component to ID crown.

CALIBRATION dB:

EXAMINATION RESULTS LEGEND:

45° LKDN	19	60° LKUP		A - NO RECORDABLE INDICATIONS	D - ACOUSTIC INTERFACE	G - WELD DISCONTINUITY
45° LKUP		ODCR LKDN	38	B - NON-GEOMETRIC INDICATIONS	E - INSIDE SURFACE GEOMETRY	H - WELD CROWN GEOMETRY
60° LKDN	37	ODCR LKUP		C - NON-RELEVANT INDICATIONS	F - OUTSIDE SURFACE GEOMETRY	J - OTHER (SEE COMMENTS)

REMARKS: * Measurement of the backing ring.

<i>John W. Steffens</i> EXAMINER	III	LEVEL	DATE	<i>George E. Johnson</i> GE INDEPENDENT REVIEW	11-9-95	DATE
GE REVIEWED BY	III	LEVEL	DATE	<i>John W. Steffens</i> UTILITY REVIEW	11-9-95	DATE

Nebraska Public Power District
DESIGN CALCULATIONS SHEETSheet of Calc No. NEDC 95-191Prepared By: Checked/Reviewed By: Rev. DDate: 19 Date: 19 **ATTACHMENT 2.4**



GE Nuclear Energy

TECHNICAL SERVICES BUSINESS
GE Nuclear Energy
175 Curtner Avenue, San Jose, CA 95125

GENE-523-174-1293
Revision 2
DRF 137-0010-6
Class II
November 1995

Evaluation and Screening Criteria for the Cooper Shroud

Prepared by:

K. Faynshtein

K. Faynshtein, Engineer
Engineering & Licensing Consulting Services

Verified by:

W.F. Weitze

W. F. Weitze, Senior Engineer
Engineering & Licensing Consulting Services

Approved By:

H.S. Mehta

H.S. Mehta, Principal Engineer
Engineering & Licensing Consulting Services

NEDC 95-191 ATTACH 2.4

SHEET 2 OF 40

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT

Please Read Carefully

The only undertakings of the General Electric Company (GE) respecting information in this document are contained in the contract between Nebraska Public Power District and GE, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Nebraska Public Power District, or for any purpose other than that for which it is intended under such contract is not authorized; and with respect to any unauthorized use, GE makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

NEDC 95-191 ATTACH 2.4

Table of Contents

SHEET 3 OF 40

	<u>PAGE</u>
1.0 INTRODUCTION.....	1
2.0 LIMIT LOAD EFFECTIVE FLAW LENGTH.....	4
2.1 Proximity Rules.....	4
2.1.1 Case A: Circumferential Flaw -- No Axial Flaw	5
2.1.2 Case B: Circumferential Flaw -- Axial Flaw	6
2.1.3 Case C: No Circumferential Flaw -- Axial Flaw.....	7
2.2 Application of Limit Load Effective Flaw Length Criteria.....	7
3.0 STRUCTURAL ANALYSIS.....	12
3.1 Applied Loads and Calculated Stresses.....	12
3.2 LEFM Analysis	14
3.2.1 Determination of K_{Ic}	14
3.2.2 LEFM Equivalent Flaw Length.....	14
3.3 Limit Load Analysis	15
3.4 Shroud Thickness Considerations.....	16
3.5 References	17
4.0 ALLOWABLE THROUGH-WALL FLAWS	21
4.1 Allowable Through-Wall Circumferential Flaw Size	21
4.1.1 LEFM Analysis.....	21
4.1.2 Limit Load Analysis.....	22
4.2 Allowable Axial Flaw Size.....	23
4.2.1 LEFM Analysis.....	23
4.2.2 Limit Load.....	23
4.3 References	24
5.0 SCREENING CRITERIA	25
6.0 SUMMARY OF SCREENING CRITERIA.....	28
7.0 COOPER FIELD HISTORY	30
Appendix A: Cooper Materials/Chemistry Shroud Evaluation	31

NEDC 95-191 ATTACH 2.4

SHEET 4 OF 40

List of Tables

	<u>PAGE</u>
Table 1-1: Conservative Assumptions Included In Screening Evaluation	3
Table 2-1: Flaw Combinations Considered in Proximity Criteria	5
Table 3-1: Dynamic Bending Stresses at Shroud Welds.....	13
Table 3-2: Pressure Differences	13
Table 4-1: Stresses and Allowable Flaw Lengths at Shroud Welds.....	22
Table 7-1. Cooper Field History	30

List of Figures

	<u>PAGE</u>
Figure 2-1: ASME Code Proximity Criteria	8
Figure 2-2: Application of Proximity Procedure to Neighboring Circumferential Flaws	9
Figure 2-3: Application of Proximity Procedure to Neighboring Axial and Circumferential Flaws	10
Figure 2-4: Process for Determining Effective Flaw Length	11
Figure 3-1: Sketch Showing Typical Welds in the Core Shroud	18
Figure 3-2: Comparison of J-R Curves Developed for Two Irradiated Stainless Steel Specimens	19
Figure 3-3: Schematic Illustrating Flaw Interaction	20
Figure 5-1: Schematic Illustrating Cumulative Limit Load Effective Flaw Criterion for a 90° Sector	27
Figure 6-1: Schematic of Screening Criteria	29

1.0 INTRODUCTION

In preparation for the Cooper shroud inspection, Nebraska Public Power District has requested GE to develop screening criteria for indications that may be found at the shroud welds. Recently, indications have been discovered in some PWR shrouds as a result of in-vessel visual inspection (IVVI). When indications are found by IVVI, only the lengths of the indications are known. Given that non-destructive examination (NDE) of every visually detected indication would be difficult and time consuming, a method of screening indications for subsequent evaluation is required. This report presents such a screening criterion.

The guiding parameter used for the selection of the indications for further evaluation is the allowable through-wall flaw size, which already includes safety factors. If all of the visually detected indications are assumed to be through-wall, then the longest flaws, or combination of flaws, would have the limiting margin against the allowable through-wall flaw size. In reality, the indications are likely not through-wall, and therefore the criteria and methods presented in this report are conservative.

The result of this procedure will be the determination of the effective flaw lengths for the limit load criteria and equivalent flaw lengths for the linear elastic fracture mechanics (LEFM) criteria. These flaw lengths will be used to compare against the allowable flaw size and select indications for more detailed evaluation.

The determination of limit load effective flaw length is based on ASME Code, Section XI, Subarticle IWA-3300 (1989 Edition) proximity criteria. These criteria provide the basis for the combination of neighboring indications depending on various geometric dimensions. The proximity rules described here also conservatively assume that there is interaction between two perpendicular flaws. It is assumed that circumferential and axial indications could increase the limit load effective flaw length depending on the unflawed distance between them. This limit load effective circumferential flaw length must be compared against the allowable circumferential flaw length. The limit load effective axial flaw length would be compared against the allowable axial flaw length. Crack growth over a subsequent cycle is included in the limit load effective flaw length determination.

The determination of the LEFM equivalent flaw length is based on the influence of adjacent flaw tips on the stress intensity factor. These criteria provide the basis for the summation of individual flaws. Crack growth over a subsequent cycle is also included in the LEFM equivalent flaw length determination.

Uncertainty in sizing can also be incorporated into the screening criteria. This is done by adding the uncertainty on crack length sizing to the crack growth expected over the next cycle. However, the several significant conservatisms introduced in the methodology are considered to compensate for uncertainty in sizing.

Flaws are considered in the same plane if the perpendicular distance between the planes is 3.0 inches (twice the shroud thickness of 1.5") or less. Any flaws which lie at an angle to the horizontal plane should be separated into a circumferential and axial component. These components can then be used separately in the determination of limit load effective flaw lengths and LEFM equivalent flaw lengths.

The selection of indications for further investigation can be performed by evaluating the resulting limit load effective flaw lengths or LEFM equivalent flaw lengths. **Indications with flaw lengths greater than the allowable flaw sizes would require further characterization by NDE or more detailed analysis.** The procedure described here is conservative, since all of the indications are assumed through-wall and are being compared against the allowable through-wall flaw size.

This report describes the following steps:

- Determination of limit load effective flaw length including proximity criteria for adjacent flaws and LEFM equivalent flaw lengths including crack tip interaction.
- Determination of allowable flaw sizes based on both linear elastic fracture mechanics (LEFM) and limit load criteria.
- Screening criteria.

The report covers the limiting stresses for all the shroud welds (H1 through H7 welds). Therefore, the screening criteria developed here cover all shroud weld indications. A list of conservative assumptions used in this evaluation is summarized in Table 1-1.

NEDC 95-191 ATTACH 2.4
SHEET 7 OF 40

Table 1-1: Conservative Assumptions Included In Screening Evaluation

1. Postulated surface indications were assumed to be through-wall for analysis.
2. Future crack growth was included in effective and equivalent flaw lengths used for evaluation.
3. ASME Code primary pressure boundary safety margins were applied even though the shroud is not a primary pressure boundary.
4. ASME Code, Section XI proximity rules were applied for limit load effective flaw lengths, and the influence of adjacent flaw tips on the stress intensity factor was applied for the LEFM equivalent flaw length.
5. A proximity rule to account for perpendicular flaws was applied, although not required by Section XI for limit load.
6. A proximity rule which accounts for flaw tip interaction between adjacent flaws was used for LEFM.
7. Fracture toughness measured for similar materials having a higher fluence was used (fluence comparable to end-of-life prediction).
8. For welds H4, H5, and H6A, both LEFM and limit load analyses were applied, even though LEFM underestimates allowable flaw size, and is not required for austenitic materials.
9. The screening criteria are limited to one-fourth of the allowable circumferential flaw length in any arbitrary 90° sector for limit load criteria.
10. The limiting flaw length computed in each portion of the shroud is applied to all locations in that portion of the shroud.

2.0 LIMIT LOAD EFFECTIVE FLAW LENGTH

NEDC 95-191 ATTACH 2.4
SHEET 8 OF 40

The limit load effective flaw lengths are based on ASME Code, Section XI proximity criteria as presented in Subarticle IWA-3300. The procedure addresses both circumferential and axial flaws. Indications are considered to be in the same plane if the perpendicular distance between the planes is less than 3.0 inches. All flaws are considered to be through-wall. Therefore, indications on the inside and outside surface should be treated as if they are on the same surface. When two indications are close to each other, rules are established to combine them based on proximity. These rules apply only to the limit load evaluation. The crack tip interaction criteria for LEFM are described in Section 3.2.

Flaw length inspection uncertainty can be incorporated in the proximity rules by adding the uncertainty to crack growth, e.g., replace Δa by $(\Delta a + U)$ or $2\Delta a$ by $(2\Delta a + 2U)$.

2.1 Proximity Rules

The flaw combination methodology used here is similar to the ASME Code, Section XI proximity rules concerning neighboring indications. Under the rules, if two surface indications are in the same plane (perpendicular distance between flaw planes < 3.0 inches) and are within two times the depth of the deepest indication, then the two indications must be considered as one indication.

In Figure 2-1, two adjacent flaws L1 and L2 are separated by a ligament S. Crack growth would cause the tips to be closer. Assuming a conservative crack growth rate of 5×10^{-5} in/hr and 8000 hours of hot operation, the crack extension, Δa , at each tip is 0.6 inches for an 18 month fuel cycle (12,000 hours), and 0.8 inches for a 24 month fuel cycle (16,000 hours). Therefore, combining the crack growth and proximity criteria, the flaws are assumed to be close enough to be considered as one continuous flaw if the ligament is less than $(2 \times \Delta a + 2 \times$ shroud thickness). For a shroud thickness of 1.5 inches, this bounding ligament is 4.2 inches for an 18 month fuel cycle and 4.6 inches for a 24 month fuel cycle. Thus, if the ligament is less than $2\Delta a + 2t$, the effective length is $(L_1 + L_2 + S + 2\Delta a)$. Note that the addition of $2\Delta a$ is to include crack growth at the other (non-adjacent) end of each flaw (See Figure 2-2).

If the ligament is greater than $2\Delta a + 2t$, then the limit load effective flaw length is determined by adding the projected tip growth to each end of the flaw. For this example, $L_{1\text{eff}} = L_1 + 2\Delta a$, and $L_{2\text{eff}} = L_2 + 2\Delta a$.

SHEET 1 OF 40

A similar approach is used to combine flaws when a circumferential flaw is close to an axial flaw (See Figure 2-3). If the ligament between the flaws is less than $\Delta a + 2t$, then the limit load effective flaw length for the circumferential flaw is $L_{\text{eff}} = L_1 + S + \Delta a$ (the bounding ligament for these cases). If the ligament is greater than $\Delta a + 2t$, then the flaws are treated separately.

After the circumferential and axial flaws have been combined per the above criteria, a map of the limit load effective flaws in the shroud can be made, and the effective flaw length can be used for subsequent analysis.

To demonstrate the proximity criteria, three examples are shown in Table 2-1 and described below.

Table 2-1: Flaw Combinations Considered in Proximity Criteria

Case	Circumferential Flaw	Axial Flaw
A	Yes	No
B	Yes	Yes
C	No	Yes

2.1.1 Case A: Circumferential Flaw – No Axial Flaw

This case applies when two circumferential indications are considered. Figure 2-2a shows this condition. If the distance between the two surface flaw tips is less than $2\Delta a + 2t$, the indications must be combined such that the limit load effective length is (See Figure 2-2b):

$$L_{\text{eff}} = L_1 + S + L_2 + 2\Delta a$$

where: L₁ = length of first circumferential indication

L₂ = length of second circumferential indication

S = distance between two indications

Δa = estimated crack growth per tip for next operating period

NEDC 95-191 ATTACH 2.4

SHEET 10 OF 40

If the distance between the two tips is greater than $2\Delta a + 2t$, the limit load effective flaw lengths are (See Figure 2-2c):

$$L_{1\text{eff}} = L_1 + 2\Delta a$$

$$L_{2\text{eff}} = L_2 + 2\Delta a$$

2.1.2 Case B: Circumferential Flaw -- Axial Flaw

This case applies when both a circumferential and an axial flaw are being considered.

Figure 2-3a demonstrates this condition. For this case, only growth of the circumferential flaw is considered. If the distance between the circumferential indication tip and the axial indication is less than $\Delta a + 2t$, then the effective circumferential flaw length is (See Figure 2-3b):

$$L_{\text{eff}} = L_1 + S + \Delta a$$

where: L₁ = length of circumferential indication

S = distance between the circumferential tip and axial flaw,

and the limit load effective axial length is (Figure 2-3b):

$$L_{\text{eff}} = L_2 + 2\Delta a$$

where: L₂ = length of axial indication

If the distance between the circumferential indication tip and the axial indication is greater than $\Delta a + 2t$, then the flaws are not combined (See Figure 2-3c) and the effective lengths are:

$$L_{1\text{eff}} = L_1 + 2\Delta a \text{ (for circumferential flaw)}$$

$$L_{2\text{eff}} = L_2 + 2\Delta a \text{ (for axial flaw)}$$

2.1.3 Case C: No Circumferential Flaw -- Axial Flaw

NEDC 95-191 ATTACH 2.4
SHEET 11 OF 40

This case applies when only axial flaws are being considered. The effective length is determined in a manner similar to that used for Case A for circumferential flaws.

2.2 Application of Limit Load Effective Flaw Length Criteria

The application of the limit load effective length criteria is applied to two adjacent indications at a time. Figure 2-4 is a schematic which illustrates the process. For example, using the 0° azimuth as the starting location for a circumferential weld or plane, the general procedure would be as follows:

- Moving in the positive azimuthal direction, the first indication encountered is indication 1.
- The next indication is indication 2.
- Apply proximity rules to the pair of indications (indications 1 and 2). Combine the flaws if necessary ($L_1 + L_2 + S + 2\Delta a$). If the flaws are combined, the resulting flaw becomes indication 2.
- Continue along positive azimuthal direction until the next indication is encountered. This becomes indication 3.
- Apply proximity rules to indications 2 and 3. If indication 2 is a combined flaw, do not add an additional Δa , since it is included in the limit load effective flaw length previously determined.
- Continue proximity rule evaluation until all indications along the subject weld or plane have been considered.




Figure 2-1: ASME Code Proximity Criteria




NEDC 95-191 ATTACH 2.4
SHEET 13 OF 40

Figure 2-2: Application of Proximity Procedure to Neighboring Circumferential Flaws






Figure 2-3: Application of Proximity Procedure to Neighboring Axial and Circumferential Flaws


NEDC 95-191 ATTACH 2.4
SHEET 15 OF 40

Figure 2-4: Process for Determining Effective Flaw Length

3.0 STRUCTURAL ANALYSIS

NEDC 95-191 ATTACH 2.4
SHEET 16 OF 40

The preceding section of this report described the determination of limit load effective flaw lengths from the IVVI results. These limit load effective flaw lengths have to be compared to the allowable flaw lengths to assess the structural integrity of the shroud. This section describes the details and the results of the structural analysis performed to determine the allowable flaw lengths. The structural analysis consists of two steps: (1) the determination of axial and circumferential stress magnitudes in the shroud, and (2) the calculation of the allowable flaw lengths. Both the fracture mechanics and limit load methods are used in the calculation of allowable flaw lengths.

3.1 Applied Loads and Calculated Stresses

The applied loads on the shroud consist of differential pressure and dynamic (seismic). The dynamic loads consist of a horizontal shear force and an overturning bending moment. The shear force acts in a direction which does not influence crack growth significantly, so it is not considered. The bending moment stress at a shroud cross-section varies as a function of its vertical distance from the top of the shroud. Pressure on the crack face is not considered for two reasons: (1) It is overly conservative to consider the stress on a postulated through-wall flaw when the flaw is unlikely to be through-wall, and (2) the pressure stress on the crack face is negligible. Because of the inherent ductility of the material (which will be discussed in Section 3.2 of this report), residual stresses and other secondary stresses do not affect structural margin. Thus, they need not be considered in the analysis.

The magnitudes of the applied loads were obtained from the dynamic stress analysis (Reference 3-1) and system information report (Reference 3-2). The nominal shroud radius and thickness (Reference 3-3) were used to calculate the stresses from the applied loads. Stresses are calculated based on strength of materials formulas. Figure 3-1 shows the weld designation and relative locations in the shroud. Table 3-1 shows the calculated dynamic bending stress magnitudes for both the upset and faulted conditions. The appropriate pressure differences for the normal/upset and faulted conditions are shown in Table 3-2.

Table 3-1: Dynamic Bending Stresses at Shroud Welds

SHEET 17 OF 40

Weld Designation	Moment, (in-kip)		Stress, (ksi)	
	Upset	Faulted	Upset	Faulted
H1	7.60×10^3	1.52×10^4	0.18	0.37
H2	1.01×10^4	2.02×10^4	0.24	0.49
H3	1.04×10^4	2.08×10^4	0.28	0.57
H4	1.49×10^4	2.98×10^4	0.41	0.82
H5	2.95×10^4	5.90×10^4	0.81	1.62
H6A	3.71×10^4	7.42×10^4	1.02	2.03
H6B	3.83×10^4	7.66×10^4	1.05	2.10
H7	5.22×10^4	1.04×10^5	1.54	3.08

Table 3-2: Pressure Differences

Component	Pressure Differences (psi)	
	Normal/Upset Condition	Faulted Condition
Shroud Head and Upper Shroud	11.25	30.3
Core Plate	23.71	26.7
Lower Shroud	31.21	54.0

The structural analysis for the indications uses two methods; linear elastic fracture mechanics (LEFM) and limit load analysis. Both the limit load and the LEFM methods were used in determining the allowable flaw sizes in the shroud. Since the limit load is concerned with the gross failure of the section, the allowable flaw length based on this approach may be used for comparison with the sum of the limit load effective flaw lengths, determined in Section 2.2, of all the flaws at a cross-section. On the other hand, the LEFM approach considers the flaw tip fracture toughness and thus, the allowable flaw length based on this approach may be used for comparison with the LEFM equivalent flaw length, determined in Section 3.2.2, at a cross-section. The fluence levels at welds H1, H2, H6B, and H7 are such that no significant embrittlement effects are expected. Therefore, only the limit load approach was used at these welds. The technical approach for the two methods is described next.

3.2 LEFM Analysis

The shroud material (austenitic stainless steel) is inherently ductile and it can be argued that the structural integrity analysis can be performed entirely on the basis of limit load. In fact, J-R curve measurements (Figure 3-2) made on a core shroud sample taken from an overseas plant having higher fluence ($8 \times 10^{20} \text{ n/cm}^2$) than Cooper showed stable crack extension and ductile failure. The ASME Code recognizes this fact in using only limit load techniques in Section XI, Subsubarticle IWB-3640 analysis. Nevertheless, a conservative fracture mechanics evaluation was performed using an equivalent K_{Ic} corresponding to the material J_{Ic} .

3.2.1 Determination of K_{Ic}

The K_{Ic} for the overseas plant shroud was approximately $150 \text{ ksi} \sqrt{\text{in}}$. Use of this equivalence is extremely conservative since:

- i) The actual fluence for Cooper is lower than that for the overseas plant from which J-R curves were obtained.
- ii) The J-R curves show J_{max} values well above the J_{Ic} , confirming that there is load capability well beyond crack initiation (See Figure 3-2).

Also, for circumferential flaws K_{Ic} is divided by ASME Code safety factors: 2.8 for normal and upset condition stresses, and 1.4 for faulted condition stresses. K_{Ic} is divided by 3.0 and 1.5 respectively for axial flaws. For the analysis presented here, the LEFM analysis is confined to welds H4 to H6A. The fluence corresponding to welds at and below the core plate and above the top guide is an order of magnitude lower and the associated fracture toughness is comparable to that of the unirradiated material.

Therefore, for those locations only the limit load analysis is used.

3.2.2 LEFM Equivalent Flaw Length

A consideration that applies only to the fracture mechanics analysis is the question, "When is a flaw independent of an adjacent flaw?" The ASME Code proximity rule described in Section 2 considers how flaws can link up and become a single flaw as a result of proximity. However, even when two flaws are separated by a ligament that exceeds $2\Delta a + 2t$, they may not be considered totally independent of each other. That is, the flaw tip stress intensity factor may be affected by the presence of the adjacent flaw. This can be

accounted for by using the finite width correction factor for a flaw in a finite plate. For a through-wall flaw in an "infinite" plate, the stress intensity factor is:

NEDC 95-19 ATTACH 2.4

$$K = \sigma \sqrt{(\pi a)}$$

SHEET 19 OF 40

For a finite plate, the K value is higher as determined by the finite width correction factor, F (Reference 3-4). In this screening evaluation it is assumed that the plate is "infinite" if the correction factor F is less than 1.1.

As with the limit load proximity criteria, indications are considered to be in the same plane if the perpendicular distance between the planes is less than 3.0 inches. All flaws are considered to be through-wall. Therefore, indications on the inside and outside surface should be treated as if they are on the same surface. When two indications are close to each other, rules are established to combine them based on proximity of adjacent crack tips. These rules are described here and apply only to the LEFM evaluation. The proximity criteria for limit load are described in Section 2.0. Uncertainty in sizing may be incorporated into the LEFM flaw length by adding the uncertainty to each end of the flaw. Thus, Δa in the next paragraph discussion is changed to $(\Delta a + U)$.

As seen in Figure 3-3, if the width of the plate exceeds $2.5(L_1 + 2\Delta a)$ (or a/b less than 0.4), then there would be no interaction due to plate end edge effects. If this same condition is applied to two neighboring flaws, then there will be no interaction between the two indications if the tips are at least $0.75(L_1 + L_2 + 4\Delta a)$ apart. Thus, if the distance between indications is greater than $0.75(L_1 + L_2 + 4\Delta a)$, then they may be considered as two separate flaws. If however, they are closer, the LEFM equivalent flaw length is the sum of the two individual flaws including crack growth.

3.3 Limit Load Analysis

A through-wall circumferential flaw was assumed in this calculation. Limit load calculations were conducted using the approach outlined in Subsubarticle IWB-3640 and Appendix C of Section XI of the ASME Code. The flow stress was taken as $3S_m$. The S_m value for the shroud material (Type 304 stainless steel) is 16.9 ksi at the approximate normal operating temperature of 550°F.

Safety factors from the ASME Code (for circumferential flaws: 2.8 for normal and upset and 1.4 for emergency and faulted; for axial flaws: 3.0 for normal and upset and 1.5 for emergency and faulted) were used in the analysis.

NEDC 95-191 ATTACH 2.4

SHEET 20 OF 40

3.4 Shroud Thickness Considerations

A shroud thickness of 1.5 inches was used in developing the screening criteria. However, there are locations in the shroud with wall thickness greater than 1.5 inches. Therefore, it must be determined if the use of 1.5 inches is applicable to all other shroud locations.



The screening criteria based on the 1.5 inches thickness is considered applicable to locations of greater thickness, since stresses were determined based on the 1.5 inch thickness. This results in conservative stress values when applied to locations with thickness greater than 1.5 inches, such as the weld between the 1.5 inch shroud cylinder and 3 inch top guide support ring.

3.5 References

- 3-1. RA No. 145, "Seismic Response of RPV and Internals of Cooper Station," GE Design Analysis Unit, San Jose, CA, Completion date 12/23/69.
- 3-2. 257HA769 Rev. 3, Reactor Internal Pressure Differences - Data Book - Cooper," GE-NED, San Jose, CA.
- 3-3. **GE Drawings:**
 - a. 730E854, Rev. 12, "Shroud Purchased Part," GE-NED, San Jose, CA.
 - b. 919D690, Rev. 2, "Reactor Vessel Purchased Part," GE-APED, San Jose, CA.
- 3-4. Hiroshi Tada, Paul C. Paris, and George R. Irwin, "The Stress Analysis of Cracks Handbook - Second Edition," Paris Productions Incorporated, St. Louis, Missouri, 1985.

NEDC 95-191 ATTACH 2.4

SHEET 22 OF 40




NOT TO SCALE

Figure 3-1: Sketch Showing Typical Welds in the Core Shroud


NEDC 95-191 ATTACH 2.4

SHEET 23 OF 40



Per ASTM Standard E813

Figure 3-2: Comparison of J-R Curves Developed for Two Irradiated Stainless Steel Specimens




$$K = \sigma \sqrt{\pi a} \cdot F$$

$$K = \sigma \sqrt{\pi a}$$

a/b	F	(Reference 3-4)
0.0	1.0	
0.1	1.006	
0.2	1.0246	
0.3	1.0577	
0.4	1.1094	
0.5	1.1867	

NEDC 95-191 ATTACH 2.4

SHEET 24 OF 40



$$L1' = L1 + \Delta 2 - a$$

$$L2' = L2 + \Delta 2 - a$$

L1 and L2 are the lengths of the as-found indications.

Figure 3-3: Schematic Illustrating Flaw Interaction

4.0 ALLOWABLE THROUGH-WALL FLAWS

NEDC 95-191 ATTACH 2.4
SHEET 25 OF 40

Allowable through-wall flaw sizes were determined using both fracture mechanics and limit load techniques for both circumferential and axial flaws. It should be emphasized that the allowable through-wall flaws are based on many conservative assumptions and are intended for use only in the screening criteria. More detailed analysis can be performed to justify larger flaws (both through-wall or part-through when measured flaw depths are available). However, since the intent of the screening criteria is to determine when additional evaluation or NDE characterization is needed, a conservative bounding approach is utilized.

4.1 Allowable Through-Wall Circumferential Flaw Size

Both the LEFM and limit load methods were used to evaluate the allowable through-wall flaws. At welds H4 to H6A, LEFM and limit load analysis methods were used, and the limiting locations for through-wall cracking occurred at the H6A weld. For the limit load analysis, the governing case is the H7 weld location where the pressure and dynamic stresses are high.

4.1.1 LEFM Analysis

The total axial stress at weld H6A is 1.34 ksi for the upset condition and 2.91 ksi for the faulted condition. Using the ASME Code safety factors for fracture analysis (2.8 for normal and upset and 1.4 for faulted), the faulted condition is limiting.

To determine the allowable flaw size based on LEFM methods, the conservatively estimated irradiated material fracture toughness K_{Ic} value of 150 ksi $\sqrt{\text{in}}$ was used. Applying the ASME Code safety factors, allowable K_I values of ~ 54 ksi $\sqrt{\text{in}}$ (upset) and ~ 107 ksi $\sqrt{\text{in}}$ (faulted) were obtained. The allowable flaw size was calculated using the following equation:

$$K_I = G_m \sigma \sqrt{(\pi a)}$$

where G_m is a curvature correction factor as defined in (Reference 4-1), σ is the total axial stress, and 'a' is the half flaw length. The bending correction factor G_b is neglected because of the ductility of the material. The allowable through-wall circumferential flaw length ($2a$) was determined as ≈ 145 inches for H6A.

4.1.2 Limit Load Analysis

SHEET 26 OF 40

A through-wall circumferential flaw was assumed in this calculation. The limit load calculations were conducted using the approach outlined⁴ in Subsubarticle IWB-3640 and Appendix C of Section XI of the ASME Code. The flow stress was taken as $3S_m$. The S_m value for the shroud material is 16.9 ksi at the approximate normal operating temperature of 550°F.

The stresses and allowable flaw length for the limit load analysis are shown in the table below. The allowable flaw length is based on the limiting condition, which was faulted for welds H1-H7, and includes the ASME Code, Section XI safety factors.

Table 4-1: Stresses and Allowable Flaw Lengths at Shroud Welds

Weld	Axial Force Stress (ksi)		Bending Moment Stress (ksi)		Allowable Flaw Length (in)
	Upset	Faulted	Upset	Faulted	
H1-H2	0.35	0.94	0.18	0.37	423
H2	0.35	0.94	0.24	0.49	420
H3	0.33	0.88	0.28	0.57	393
H4	0.33	0.88	0.41	0.82	386
H5	0.33	0.88	0.81	1.62	368
H6A	0.33	0.88	1.02	2.03	360
H6B	0.64	1.23	1.05	2.10	349
H7	0.59	1.16	1.54	3.08	323

4.2 Allowable Axial Flaw Size

NEDC 95-191 ATTACH 2.4

SHEET 27 OF 40

4.2.1 LEFM Analysis

The allowable axial flaw size is governed entirely by the pressure hoop stress. As with the circumferential flaw case, the allowable axial flaw size was determined assuming a through-wall flaw. For a through-wall flaw of length $2a$ in the shroud, the applied stress intensity factor is given by:

$$K = M * \sigma_h * \sqrt{\pi a}$$

where M is the curvature correction factor given by:

$$M = [1 + 1.61a^2/(Rt)]^{0.5} \quad (\text{from Reference 4-2})$$

In the above expression, the allowable flaw length $2a$ can be determined by equating the calculated K to the fracture toughness of $150 \text{ ksi}\sqrt{\text{in}}$. The hoop stress for the faulted condition is 1.79 ksi ; the ASME safety factor of 1.5 is applied and the result is used in the previous equation.

The allowable flaw length was conservatively determined to be $2a = 85$ inches above the core plate.

4.2.2 Limit Load

An alternate approach to determining the allowable flaw size is to use limit load techniques. The allowable flaw length is given by the equation:

$$\sigma_h = \sigma_f / (M * SF)$$

where M is a curvature correction factor as defined above, $\sigma_f = 3S_m$ is the flow stress, SF is the safety factor (3.0 for upset conditions, 1.5 for faulted), and σ_h = the hoop stress corresponding to the ΔP of 30.3 psi (faulted) above the core plate and 31.21 psi (upset) below the core plate. The allowable flaw length based on the limit load analysis is 330 inches above the core plate (using the limiting shroud diameter at welds H1 and H2) and 167 inches below the core plate. Since the value above the core plate exceeds the LEFM value, the allowable axial through-wall flaw length is 85 inches between H3 and H6A.

4.3 References

- 4-1. Rooke, D.P. and Cartwright, D.J., "Compendium of Stress Intensity Factors," The Hillingdon Press (1976).
- 4-2. Ranganath, S., Mehta, H.S. and Norris, D.M., "Structural Evaluation of Flaws in Power Plant Piping," ASME PVP Volume No. 94 (1984).

5.0 SCREENING CRITERIA

NEDC 95-191 ATTACH 2.4

SHEET 29 OF 40

The determination of the allowable through-wall flaws has been described in Section 4. The objective was to use the allowable flaw size as the basis for the screening criteria. Since the screening rules represent the first step in the evaluation, they are by definition conservative. If the criteria are exceeded, the option of doing further detailed evaluation or performing additional NDE remains. The allowable through-wall flaws were:

- Circumferential Flaws

- H1: 423 inches (limit load)
- H2: 420 inches (limit load)
- H3: 393 inches (limit load)
- H4: 386 inches (limit load), 235 inches (LEFM)
- H5: 368 inches (limit load), 168 inches (LEFM)
- H6A: 360 inches (limit load), 145 inches (LEFM)
- H6B: 349 inches (limit load)
- H7: 323 inches (limit load)

- Axial Flaws

- H1-H2: 330 inches (limit load)
- H3-H6A: 85 inches (LEFM)
- H6B-H7: 167 inches (limit load)

A conservative approach in developing the screening rule is to include both the LEFM and limit load analysis. For circumferential flaws, LEFM provides the limit on LEFM equivalent single flaw length for H4 through H6A, while the limit load analysis provides the limit on effective cumulative flaw length. For axial flaws, the allowable flaw length is 330 inches between H1 and H2, 85 inches between H3 and H6A (LEFM), and 167 inches below the core plate (limit load).

For circumferential flaws at welds H4 through H6A, the limits are applied as follows. The fracture mechanics based limit for a single equivalent flaw length at H6A (for example), as determined in Section 3.2.2, is 145 inches. This in itself is not sufficient, since there could be several flaws (each less than 145 inches) in a circumferential plane that cumulatively add up to greater than 360 inches (the allowable circumferential flaw size based on limit

load analysis). Thus, the sum of the effective flaw lengths, as determined in Section 2.2, should be less than 360 inches.

While this fully assures the ASME Code margins, an additional conservative assumption is included in the screening. This states that the sum of the limit load effective flaw lengths cannot be more than $360/4 = 90$ inches in any 90 degree sector of the shroud. This is a conservative restriction that assures that long continuous flaws are not admissible.


The approach used here for the 90 inch limit for circumferential flaws is to assume a template with a moving window equal to a 90° sector. The sum of the limit load effective flaw lengths that appear in the window should be less than 90 inches. This is shown graphically in Figure 5-1. A similar restriction based on limit loads is not needed for axial flaws, since field experience has shown that they are typically associated only with circumferential welds and are unlikely to be aligned in the same plane.

The allowable flaw length of 90 inches for any 90 degree sector applies to weld H6A. Similarly, limit load allowable flaw lengths divided by four apply to welds H1 through H7.

When considering LEFM based evaluations, the crack interaction criteria described in Section 3.2 must be applied in comparing against the allowable lengths. For example, for adjacent flaws where the spacing, S, is less than $0.75(L_1 + L_2 + 4\Delta a)$, the length $L = L_1' + L_2'$ is used for comparison with the LEFM based allowable flaw length. The lengths L_1' and L_2' are as determined in Figure 3-3.

The criteria presented in this report are conservative in that continuous flaws (for limit load) were assumed. Additional analysis assuming the flaws are non-continuous (that is, distributed around the circumference of the shroud) or part-through wall will yield larger cumulative flaw lengths.

NEDC 95-191 ATTACH 2.4
SHEET 31 OF 40



Not to Scale

Figure 5-1: Schematic Illustrating Cumulative Limit Load Effective Flaw Criterion
for a 90° Sector

6.0 SUMMARY OF SCREENING CRITERIA

The screening criteria are schematically shown in Figure 6-1. The first step is to map the flaw indications observed by IVVI. Next the proximity rules are applied to the flaw map to develop limit load effective flaw lengths. The results of the limit load effective flaw lengths are also mapped.

For axial flaws, two neighboring flaws must be summed if $S < 0.75(L_1 + L_2 + 4\Delta a)$. If the longest resulting flaw is less than 85 inches, then the screening limit is met for axial flaws.

For circumferential flaws, all limit load effective flaw lengths (as determined by the methods outlined in Section 2.0) are summed in any 90° sector using a template. The next step is to compare the longest LEFM equivalent flaw to the LEFM based screening criteria for welds H4 to H6A.

NEDC 95-191 ATTACH 2.4

SHEET 33 OF 40




Figure 6-1: Schematic of Screening Criteria

7.0 COOPER FIELD HISTORY

Based on current available information at GE, the Cooper field history was tabulated.

Table 7-1 contains the list of known cracking incidences at Cooper. The relatively short list of cracking incidences is likely a reflection of the Cooper water chemistry quality.

Table 7-1. Cooper Field History

COMPONENT	DATE	DESCRIPTION
Instrument Line	1/76	Leak detected in 2-inch 304 S/S instrument line. Leak located 1/2-inch from safe end to pipe weld. 3/4-inch circumferential crack detected. Cause: IGSCC in weld HAZ.
Main Steam Line	10/76	UT indications in 26-inch main steam line carbon steel "D" loop flow restrictor spool. Indications 5/8-inch length, 3/16-inch width, 3/16-inch depth. Cause: Manufacturing defects.
Residual Heat Removal Drain Line	2/77	Failure in 1-inch RHR drain line. Cause: Fatigue.
Feedwater Sample Probe	2/77	Portions of 3/4-inch 316 S/S feedwater sample probe found broken off. Cause: Transgranular SCC associated with chlorides; cyclical vibration may have accelerated failure.
Control Rod Drive Spud	4/78	Failure of Alloy X-750 CRD spud finger. Cause: Mechanical overload.
Steam Jet Air Ejector System Elbow	11/77	Holes detected in 4-inch carbon steel elbow. Cause: Either pitting corrosion or erosion corrosion.
Position Indicator Tube	1975	Leak detected in 3/4-inch 304 S/S indicator tube. Cause: Leaching out of non-metallic inclusions.
Reactor Water Cleanup Flange	9/92	Leak detected in RWCU flange to tee weld. Cause: IGSCC in weld heat affected zone.
CRD Cap Screws	1991	Cracking initiated at the shank to head radius of the CRD cap screws. Cause: IGSCC assisted by crevice and notch conditions in the fillet region at the transition from the shank to the bolt head.
Shroud Head Bolts		Cracking in 21 Alloy 600 shroud head bolts to date. Cause: IGSCC in creviced region.

A.0 Cooper Materials/Chemistry Shroud Evaluation**NEDC 95-191 ATTACH 2.4****SHEET 35 OF 40****A.1 Water Chemistry**

For the first two cycles of hot operation, Cooper operated with relatively high primary water conductivity. As can be seen in Table 1, the cyclic conductivity mean values averaged 0.27 $\mu\text{S}/\text{cm}$. There was a dramatic conductivity improvement during the third cycle where the conductivity decreased to 0.142 $\mu\text{S}/\text{cm}$. Since the third cycle, conductivity values have improved and were excellent at approximately 0.10 $\mu\text{S}/\text{cm}$ during the last three operating cycles. Although Cooper is characterized by some of the best water chemistry in the BWR fleet (noting that Cycle 16 conductivity is somewhat higher), there were several documented early water chemistry transients experienced at Cooper (1):

1. August 29, 1974 -- Cooper reactor water conductivity reached 5 $\mu\text{S}/\text{cm}$ and pH decreased to 5.5 during shutdown due to a condensate demineralizer resin intrusion (Cycle 1).
2. December 8, 1974 -- Cooper reactor water conductivity reached 10 $\mu\text{S}/\text{cm}$ at power due to a condenser leak (Cycle 1).
3. January 27, 1975 -- Cooper reactor water conductivity reached 11.5 $\mu\text{S}/\text{cm}$ and pH decreased to 4.8 at power due to a RWCU resin intrusion (Cycle 1).
4. July 2, 1975 -- Cooper reactor water conductivity reached 12 $\mu\text{S}/\text{cm}$ at power due to a condenser tube leak (Cycle 1).
5. February 21, 1976 -- Cooper reactor water conductivity reached 4.3 $\mu\text{S}/\text{cm}$ and pH decreased to 4.9 at power due to a suspected resin intrusion. Chloride was also measured at 48 ppb (Cycle 1).
6. May 22, 1976 -- Cooper reactor water conductivity reached 4.9 $\mu\text{S}/\text{cm}$ and pH decreased to 4.9 at power due to a suspected resin intrusion. Chloride was also measured at 50 ppb (Cycle 1).

7. February 25, 1977 -- Cooper reactor water conductivity reached 1.1 $\mu\text{S}/\text{cm}$ and pH decreased to 5.6 at power due to a suspected resin intrusion. Chloride was also measured at 30 ppb (Cycle 2).

Because of the some higher early life conductivity and intrusion history, it is likely that intergranular stress corrosion cracking (IGSCC) initiation was accelerated in susceptible areas (both uncreviced and creviced) of the primary system, including the shroud. The effect of sulfate/conductivity on crack initiation in uncreviced material is presented in Figure 1. It is clear that an increase in sulfate/conductivity results in an acceleration in crack initiation as measured by the constant extension rate test (CERT). A similar type of initiation acceleration is expected for chloride ions.

The strong correlation between conductivity and IGSCC susceptibility in uncreviced sensitized stainless steels has also been examined in various other laboratory studies (2-4) and it is evident that a significant decrease in crack initiation time is expected with increased concentrations of certain deleterious anionic impurities, in particular sulfates and chlorides. For creviced BWR components the strong correlation of SCC susceptibility with actual BWR plant water chemistry history has been documented (5).

A.2 Shroud Evaluation

The recent cracking of shrouds at several BWRs has placed this stress corrosion concern at the highest levels. When Cooper is compared to 51 other BWRs relative to possible shroud performance, the following rankings and factors are noted:

1. First 5 cycle mean conductivity (0.188 $\mu\text{S}/\text{cm}$) - 41/51 highest. Shrouds in BWRs with lower 5 cycle mean conductivity have cracked.
2. Total mean conductivity (0.152 $\mu\text{S}/\text{cm}$) - 42/51 highest (based on June 1994 data). Shrouds in BWRs with lower total mean conductivity have cracked.
3. On-line years (14.6) - 13/51 highest (based on November 1993 data). Shrouds in BWRs with lower on-line years have cracked.

4. Estimated peak fluence (8.4E20) - 2/51 (based on December 1992 calculations). Shrouds in BWRs with significantly lower estimated peak fluences have cracked.
5. Shrouds fabricated out of Types 304L and 347 stainless steel and Cooper's shroud's material of construction, Type 304 stainless steel, have cracked. It should be noted that all Type 304 stainless steel shrouds inspected to date have revealed cracking.
6. Shrouds built by Rotterdam, Sun Ship, P. F. Avery and Cooper's shroud's manufacturer, Bingham Willamette, have cracked.

Based on the experience of shroud cracking in BWRs with relatively good water chemistry quality and at low fluence locations, independent of manufacturer, material of construction and relative age, future cracking in Cooper's shroud cannot be ruled out.

A.3 References

1. B. H. Dillman et al, "Monitoring of Chemical Contaminants in BWRs," EPRI NP-4134, July 1985.
2. R. B. Davis and M. E. Indig, "The Effect of Aqueous Impurities on the Stress Corrosion Cracking of Austenitic Stainless Steel in High Temperature Water," paper 128 presented at Corrosion 83, Anaheim, CA, NACE, April 1983.
3. L. G. Ljungberg, D. Cubicciotti and M. Trolle, "Effects of Impurities on the IGSCC of Stainless Steel in High Temperature Water," Corrosion, Vol. 44, No. 2, February 1988.
4. W. E. Ruther, W. K. Soppet and T. F. Kassner, "Effect of Temperature and Ionic Impurities at Very Low Concentrations on Stress Corrosion Cracking of Type 304 Stainless Steel," Corrosion, Vol. 44, No. 11, November 1988.
5. K. S. Brown and G. M. Gordon, "Effects of BWR Coolant Chemistry on the Propensity for IGSCC Initiation and Growth in Creviced Reactor Internals Components," paper presented at the Third Int. Symp. of Environmental Degradation of Materials in Nuclear Power Systems-Water Reactors, Traverse City, MI, August 1987, published in proceedings of same, TMS-AIME, Warrendale, PA, 1988.

Table 1. Cooper Water Chemistry History

SHEET 39 OF 40

<u>Cycle</u>	<u>Mean Value Conductivity μS/cm</u>	<u>Chloride ppb</u>	<u>Sulfate ppb</u>
1	0.204	31.72	
2	0.338	30.65	
3	0.142	31.04	
4	0.119	30.04	
5	0.135	30.07	
6	0.172	30.00	
7	0.210	30.00	
8	0.140	30.00	
9	0.126	30.00	
10	0.170	10.14	
11	0.149	7.41	
12	0.117	1.81	
13	0.093	0.88	1.99
14	0.094	1.70	3.00
15	0.096	1.98	2.60
16	0.123	3.77	4.71

Sulfate IGSCC Initiation Acceleration Sensitized Type 304 SS




Figure 1: Effect of Sulfate/Conductivity on Crack Initiation in Uncreviced Material