




**GULF STATES UTILITIES COMPANY**

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

July 30, 1984  
RBG-18371  
File Nos. G9.5, G9.25.1.1  
\*Corrected Copy

Mr. John T. Collins, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV, Office of Inspection and Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011



Dear Mr. Collins:

River Bend Station-Unit 1  
Docket No. 50-458  
Final Report/DR-139\*

Gulf States Utilities Company (GSU) has completed its evaluation of DR-139 concerning potentially defective springs in Models PSA-1 and PSA-3 mechanical shock arrestors supplied by Pacific Scientific. Physical testing at faulted and full load indicated that the springs with microcracks were sufficiently sound to provide their intended function. Nevertheless, the snubbers were rotated and requalified by Pacific Scientific to be suitable for their intended use. GSU has therefore determined that this condition is not reportable under 10CFR50.55(e).

Sincerely,

J. E. Booker  
Manager-Engineering,  
Nuclear Fuels & Licensing  
River Bend Nuclear Group

8408220504 840730  
PDR ADOCK 05000458  
S PDR

JEB/LAE/lp

cc: Director of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC Resident Inspector-Site

INPO

IE-27  
110