

Appendix

NOTICE OF VIOLATION

Detroit Edison Company

Docket No. 50-341

As a result of the inspection conducted on June 27-29 and July 10-12, 1984, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR, Appendix B, Criterion XVI, as implemented by Detroit Edison's Enrico Fermi Atomic Power Plant Unit 2 FSAR, Volume 9, Section 17.1.2, Paragraph q., and the Quality Assurance Manual, Enrico Fermi Power Plant Unit 2, Policy 17.0, Paragraph 17.0.1, require that appropriate and prompt corrective action be taken when conditions adverse to quality are identified.

Contrary to the above, Deviation Disposition Request No. C-12154, addressing shore barrier structure configuration deviations from design requirements, was improperly and inadequately dispositioned in that:


- a. The recommended FIELD PROPOSED DISPOSITION was "use as is" even though supporting data clearly showed that construction tolerances were significantly exceeded.
- b. The supporting data was misleading and contained errors of omission.
- c. The dispositioning was based on data which evidently was not analysed thoroughly.

This is a Severity Level IV violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

AUG 6 1984

Dated _____



R. L. Spessard, Director
Division of Reactor Safety

8408230142 840806
PDR ADOCK 05000341
Q PDR