

DMB

August 17, 1984

Docket No. 50-483

Union Electric Company
ATTN: Mr. Donald F. Schnell
Vice President - Nuclear
Post Office Box 149 - Mail Code 400
St. Louis, MO 63166

Gentlemen:

This confirms our plans discussed on August 17, 1984, with Mr. S. E. Miltenberger of your staff with Mr. W. L. Forney of this office to meet with you and members of your staff at 1:00 p.m. on August 20, 1984 at the Region III office.

The purpose of this meeting is to discuss proposed escalated enforcement action planned by the NRC as a result of the Callaway Plant being in Operational Mode 4 with both trains of the Containment Spray Systems inoperable in violation of Callaway Technical Specifications.

We will gladly discuss any questions you have regarding this meeting.

James G. Keppler
Regional Administrator

cc: W. H. Weber, Manager, Nuclear
Construction
S. E. Miltenberger, Plant Manager
R. L. Powers, Assistant Manager
Quality Assurance
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Region IV
K. Drey
Chris R. Rogers, P.E.
Utility Division, Missouri
Public Service Commission

8408230170 840817
PDR ADOCK 05000483
P PDR

IEOI
1/0

RIII
Pelke/ls
08/17/84

RIII
Forney

RIII
Warnick

RIII
Norelius

RIII
Davis

RIII
Keppler
8/17/84

fr