

AUG 17 1984

Docket Nos. 50-361
50-362

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

Attention: Kenneth P. Baskin
Vice President, Nuclear

Gentlemen:

Thank you for your letter dated August 1, 1984 from Mr. H. B. Ray,
Vice President and Site Manager, San Onofre addressing our concern related to
your assessment of the root cause of a violation as discussed in our letter
of July 25, 1984.

Although our July 25, 1984 letter was not specifically referenced, Mr. Ray's
letter adequately responds to our request.

Thank you for your cooperation in this matter. We will examine your
corrective actions during a subsequent inspection.

Sincerely,

// Signed //

Ross A. Scarano, Director
Division of Radiological Safety and
Safeguards Programs

bcc: RSB/Document Control Desk (RIDS)

IE01

Distributed by RV:
Mr. Martin, RV
State of CA

RV/jk

NORTH *BSM*

YUHAS *GP*

WENSLAWSKI *GP*

SCARANO *[Signature]*

~~MARTIN~~

8/16/84

8/17/84

8/17/84

8/17/84

~~8/ /84~~

8408230223 840817
PDR ADOCK 05000361
G PDR

RECEIVED
NRC

Southern California Edison Company

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

Aug 12 11:00 AM '84

HAROLD B. RAY
VICE PRESIDENT & SITE MANAGER
SAN ONOFRE

REGION V

TELEPHONE
714-361-8470

August 1, 1984

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator.

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
IE Inspection Reports 50-361/84-14 and 50-362/84-14
Review of NRC Observations
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, "Response to Notice of Violation," K. P. Baskin (SCE)
to J. B. Martin (NRC), dated June 25, 1984

Mr. R. A. Scarano's letter of May 25, 1984, issued the subject
IE Inspection Reports and forwarded a Notice of Violation resulting from the May 6
and 7, 1984, special inspection conducted by Mr. G. P. Yuhas. The referenced
letter provided our response to the Notice of Violation.

The purpose of this letter is to more fully respond to the inspector's
observations concerning activities associated with the event. We have
reviewed the observations in the context of Mr. Scarano's forwarding letter
with respect to generic corrective actions.

The May 5, 1984 Unusual Event, and observations identified in the subject
report, are of generic importance because they represent opportunities to
identify where management attention may result in significant improvements in
plant performance and compliance. Following a careful evaluation, actions
have been taken as described below. A number of these actions were already
underway and are also noted in the subject inspection reports or the reference
response.

FILE COPY

~~84-22-14-2267~~

84-22

Unit 3 has experienced a higher level of Reactor Coolant System radioactivity than Unit 2. As a result, we had identified a number of circumstances (e.g., minor leakage from the Radioactive Waste Gas System during system manipulations) where airborne radioactivity levels could become significant, relative to various action requirements. We had monitored these developments carefully and had initiated action to revise designs and modify operating and maintenance approaches. In the case of the May 5, 1984 Unusual Event, however, we had not adequately forecasted the circumstances which then existed such that the Shift Superintendent, and other personnel on shift, were promptly led to make the Unusual Event declaration.

Actions which were already underway or that have now been taken are described below.


1. Increasing alarm setpoints to more appropriate values allowed by the Technical Specifications, thereby eliminating unnecessary and distracting alarms was already being planned. We expedited our review of the effluent alarm setpoints and several monitor setpoints, including the wide range gas monitor 2 and 3 RE-7865, have now been raised to more appropriate values.
2. Training to ensure Operators are especially knowledgeable of effluent alarms to be expected during minor operating events and releases as a result of the increased level of Reactor Coolant System radioactivity is being provided. We have completed initial Operator training in this area and will include additional training on monitor alarm setpoints in the 1984-1985 Operator Requalification Program (ORP).
3. Significant resources were directed to maintaining the operability of effluent monitors and recorders to maximize the effluent assessment information available to the Operators. We increased our efforts to improve monitor availability and are also proceeding with the procurement of more reliable recorders.
4. Special Operator training classes devoted to full understanding of the release paths, effluent monitor performance, and special considerations such as the "streaming effect" in the common plenum are being provided. We have discussed the "streaming effect" in shift briefings and will include additional training on effluent pathways and monitor performance in 1984-1985 ORP.
5. Operator sensitivity and awareness of the effluent and radiation monitor readings during shift turnover and during unplanned releases is being enhanced. We have conducted shift briefings on the importance of these alarms. Operators are documenting any radiation monitors in alarm on shift turnover sheets and significant background radiation level changes will be noted on the common operator log, common operator turnover sheet, and brought to the Control Room Supervisor's attention.

6. Station emergency and operating procedures are being validated to ensure clarity in responding to abnormal conditions or monitor readings expected during these circumstances. We have revised several procedures to further clarify the conditions under which prompt declaration of an emergency is required.
7. Equipment and instrumentation is being reviewed to ensure against conflicting information, such as the plant computer and the corresponding radiation monitor having different alarm values. We are reviewing these problems and will complete an assessment by October 12, 1984.

Involvement of management is essential in controlling and anticipating plant performance, ensuring personnel sensitivity to system interactions, and in requiring alertness and attention to detail. This involvement is being promoted at San Onofre in a number of specific ways, and we believe it is producing positive and effective results. OK

If you require any additional information, please so advise.

Sincerely,



Enclosure

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2, and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

JUL 25 1984

docket file

Docket Nos. 50-361
50-362

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

Attention: Kenneth P. Baskin
Vice President, Nuclear

Gentlemen:

In view of the frequent reported releases of radioactive material from your facility, we conducted a special inspection of the airborne release that occurred on May 5, 1984. We transmitted a thorough report of our findings to you on May 25, 1984 and requested that in your response to the Notice of Violation you determine the root cause of the incident and your proposed corrective action.

In your response dated June 25, 1984, you stated that you believe the root cause was an isolated deficiency in the Radiation Monitor 2/3 RE 7808 alarm response procedure. We do not believe that this assessment is satisfactory. It fails to recognize several contributing factors as outlined in our inspector's exit interview and described in the inspection report; nor does it evidence any attempt on your part to look for other possible contributing problems. We feel strongly that introspective assessments of incidents are extremely important because identified causal weaknesses may be operative in other areas of plant operation.

This matter was discussed by our Regional Administrator, Mr. J. B. Martin with your Mr. Harold Ray on July 24, 1984. In that conversation, Mr. Lay agreed to reassess the May 5, 1984 incident and to submit the results of this reassessment to the Region V office of NRC. We request that you submit your reassessment within thirty days of the date of this letter.

Sincerely,

CC:
Mr. Martin; State of CA

bcc:
RSB/Document Control Desk (RIDS)
pink/green/docket file copies
resident Inspector
Joan Zollicoffer

orig signed
Ross A. Scarano, Director
Division of Radiological Safety
and Safeguards Programs

WJ
RV Yuhas:rc Wenslawski Scarano
07/25/84 07/25/84 07/15/84

TE
84-21