This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility: LaSalle Unit 2

Marseilles, IL 61341 Docket No: 50-374

Licensee Emergency Classification
General Emergency Site Area Emergency
Alert Unusual Event N/A X

Subject: CONTRACT DIVER INCIDENT (UPDATE)

The diver who experienced difficulties while working in the circulating water piping at LaSalle Unit 2 died early April 18, 1992, at a suburban Chicago hospital.

The diver had been working under water on the discharge side of the circulating water outlet valve. He was attempting to provide a better seal on the valve in preparation for condenser tube leak checks. The plant is in cold shutdown.

The diver experienced difficulties and was rescued from the piping by a backup diver. Cardiopulmonary resuscitation was administered to the diver, and he was taken to a Streator, Illinois, hospital. He was later flown to Lutheran General Hospital in Park Ridge, Illinois.

The State of Illinois and the Occupational Safety and Health Administration have been notified. The Cook County Medical Examiner's Office is investigating the incident and will conduct an inquest. The cause of the diver's difficulties has not been determined.

There has been area news media interest in the diver's death.

This updated information is current as of 10 a.m. on April 20, 1992.

RCK for A. Hsia B. Clayton (FTS) 388-5574

DISTRIBUTION:

REGIONS HEADQUARTERS OFFICES MAIL TO: DCS (Orig) MAIL TO: NMSS Region I Comm. Rogers OSP Region II DOT (Trans. Comm. Curtiss OPA-Region IV Only) Comm. Remick OCA Reg on V Comm. de Planque

EDO

Gen. Counsel *OCAA NRR Research

AEOD IRM -Enforcement ACRS

01G LSSA

FAX TO: The Chairman 2:34 INPO 2:50
NSAC 2:48 LIC 2:37 NRC OPS CTR 2:52
PDR (8/634-3343) 2:43 OIG 2:41
HQ Public Affairs 2:45

A. Byrdsong, NRR

*Denotes a Displaywriter/PC not an IBM 5520 Terminal

9204270015 920420 PDR I&E PNO-111-92-021 PDR IED7 1/0