

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Vermont Yankee Nuclear Power Station

DOCKET NUMBER (2)
0 5 0 0 0 2 7 1

PAGE (3)
1 OF 0 3

TITLE (4)
1984 Appendix J-Type B and C Testing

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0	6	1	6	8	4	8	4	8	4		0 0 0 0
				0	1	1		0	1	0	8 1 6 8 4
											0 5 0 0 0

OPERATING MODE (5) N

POWER LEVEL (10) 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)

<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.408(a)	<input type="checkbox"/> 60.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)
<input type="checkbox"/> 20.408(a)(1)(i)	<input type="checkbox"/> 60.36(a)(1)	<input type="checkbox"/> 60.73(a)(2)(v)	<input type="checkbox"/> 73.71(a)
<input type="checkbox"/> 20.408(a)(1)(ii)	<input type="checkbox"/> 60.36(a)(2)	<input type="checkbox"/> 60.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 305A)
<input type="checkbox"/> 20.408(a)(1)(iii)	<input checked="" type="checkbox"/> 60.73(a)(2)(i)	<input type="checkbox"/> 60.73(a)(2)(vii)(A)	10CFR50 App. J
<input type="checkbox"/> 20.408(a)(1)(iv)	<input type="checkbox"/> 60.73(a)(2)(ii)	<input type="checkbox"/> 60.73(a)(2)(vii)(B)	
<input type="checkbox"/> 20.408(a)(1)(v)	<input type="checkbox"/> 60.73(a)(2)(iii)	<input type="checkbox"/> 60.73(a)(2)(viii)	

LICENSEE CONTACT FOR THIS LER (12)

NAME: James P. Pelletier, Plant Manager

TELEPHONE NUMBER: AREA CODE 8 0 2, NUMBER 2 5 7 - 7 7 1 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
X	S B	V R	3, 4, 0	Y	X	B, B	V A	1, 8, 0	Y
X	A, A	V L	6, 3, 1	Y	B	S, J	V A	3, 9, 1	Y

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH: | DAY: | YEAR: |

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

While performing Type C Leak Rate Testing, MSIV-86B, CRD-412A, PCAC-V16-19-8, FDW-96A and CA-8°C were found to have seat leakage above that permitted by Tech. Spec. section 3.7.A.4. This resulted in the total Appendix J Type B and C limit of 14.75 lbm/Hr. being exceeded which does not meet Tech. Spec. section 3.7.A.3 requirements. (By procedure, VY uses the maximum pathway leakage in calculating total penetration leakage.)

Vermont Yankee has performed maintenance on all of the above valves and re-tested them to ensure that both total penetration and individual valve seat leakages are within Tech. Specs.

8408230534 840816
PDR ADOCK 05000271
S PDR

IE22
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Vermont Yankee	DOCKET NUMBER (2) 0500027184	LER NUMBER (8)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		84	011	010	2	03

TEXT (If more space is required, use additional NRC Form 266A's) (17)

While performing Type C Leak Rate Testing MSIV-86B, CRD-412A, PCAC V16-19-8, FDW-96A and CA-89C were found to have seat leakage above that permitted by Tech. Spec. section 3.7.A.4. This resulted in the total Appendix J Type B and C limit of 14.75 lbm/Hr being exceeded which does not meet Tech. Spec. section 3.7.A.3 requirements. (Note: By procedure, VY uses the maximum pathway leakage in calculating total penetration leakage.)

For MSIV-86B, CRD-412A, PCAC V16-19-8 and CA-89C, a second isolation valve in the applicable system was tested and met the acceptable criteria. For FDW-96A, containment was provided by the water seal on the inboard check valve and the plant's capability to maintain a pressure greater than P_a on the feedwater system.

Total penetration leakage based on the minimum pathway leakage equaled 9.83 lbm/Hr. Minimum pathway leakage in used to determine Appendix J Type A total containment leakage.

Vermont Yankee has performed maintenance on all of the above valves and re-tested them to ensure that both total penetration and individual valve seat leakages are within Tech. Specs.

Based on the above there were no adverse consequences to the health and safety of the public.

No similar events have been reported on MSIV-86B, CRD-412A, PCAC V16-19-8 or CA-89C in the last five years.

A similar event was reported on FDW-96A as LER 83-10.

LICENSEE EVENT REPORT (LER) FAILURE CONTINUATION

FACILITY NAME (1) Vermont Yankee	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1 8 4	LER NUMBER (6) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;">YEAR</td> <td style="width:15%;">SEQUENTIAL NUMBER</td> <td style="width:15%;">REVISION NUMBER</td> </tr> <tr> <td>8 4</td> <td>0 1 1</td> <td>0 1</td> </tr> </table>	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	8 4	0 1 1	0 1	PAGE (3) 0 3 OF 0 3
YEAR	SEQUENTIAL NUMBER	REVISION NUMBER							
8 4	0 1 1	0 1							

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS
X	LE	V C	3 3 9						



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157
GOVERNOR HUNT ROAD
VERNON, VERMONT 05354

August 16, 1984

VYV84-423


U. S. Nuclear Regulatory Commission
Document No. 50-271
Washington, D. C. 20555

REFERENCE: Operating License DPR-28
Docket No. 50-271
Reportable Occurrence No. LER 84-11, Revision 1

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 84-11, Revision 1.

Very truly yours,


James P. Pelletier
Plant Manager

RDP/ajg

cc: Regional Administrator
USNRC Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

IE27
11