

DMB

AUG 3 1984

Docket No. 50-254
Docket No. 50-265

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

This refers to the routine safety inspection conducted by Messrs. A. L. Madison, A. D. Morrongiello, J. C. Bjorgen, S. Hare, and F. Maura of this office on May 20 through June 23, 1984, of activities at Quad-Cities Nuclear Power Station, Units 1 and 2 authorized by NRC Operating Licenses No. DPR-29 and No. DPR-30 and to the discussion of our findings with Mr. N. J. Kalivianakis at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in noncompliance with NRC requirements, as specified in the enclosed Appendix. A written response is required.

As stated in the report the last two consecutive Type A tests at Quad-Cities Unit 2 have been failures and, pursuant to 10 CFR 50, Appendix J, Section III.A.6.(b), a Type A test shall be performed during each plant shutdown for refueling until two consecutive Type A tests meet the acceptance criteria of Appendix J. Accordingly, unless you request, and are granted, an exemption from this requirement by NRR, we expect you to conduct a Type A test during each refueling outage until two consecutive Type A tests satisfy the Appendix J acceptances criteria.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure(s) will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosure(s), and your response to this letter will be placed in the Public Document Room.

B408230549 B40803
PDR ADOCK 05000254
Q PDR

JE01
1/1

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.


Sincerely,

"Original Signed by C.E. Norelius"

C. E. Norelius, Director
Division of Reactor Projects

Enclosure: Inspection Reports
No. 50-254/84-08(DRP) and
No. 50-265/84-07(DRP)

cc w/encl:
D. L. Farrar, Director
of Nuclear Licensing
N. Kalivianakis, Plant
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Phyllis Dunton, Attorney
General's Office, Environmental
Control Division

RIII

Chrisotimos/sf
07/23/84

RIII
R.D.W. for
Maura
7-31-84

RIII
R.D.W. for
Guldmond
7-31-84

RIII
R.D.W. for
Shafer
7/31/84

RII
R.D.W. for
Harv
7-31-84

RIII
R.D.W. for
Norelius
8/1/84