

SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30303

JUL 10 1984



Report No. 50-261/84-21

Licensee: Carolina Power and Light Company
411 Fayetteville Street
Raleigh, NC 27602

Docket No. 50-261

License No. DPR-23

Facility Name: H. B. Robinson Steam and Electric Plant

Inspection Date: June 11-15, 1984

Inspector: C. C. Peery
A. Tillman, Physical Security Inspector

6-28-84
Date Signed

Approved by: D. R. McGuire
D. R. McGuire, Chief, Physical Security Section
Nuclear Materials Safety and Safeguards Branch
Division of Radiation Safety and Safeguards

6/28/84
Date Signed

SUMMARY

Scope: This routine, unannounced inspection entailed 31 inspector-hours on site (2 hours on backshift) inspecting: Implementation of approved Security Plan relative to plan changes and implementing procedures; Management Effectiveness - Security Program; Security Organization; Security Program Audit; Testing and Maintenance; Physical Barriers - Protected Areas; Physical Barriers - Vital Areas; Security System Power Supply; Compensatory Measures; Assessment Aids; Access Control (Personnel, Packages, and Vehicles); Detection Aids - Protected and Vital Areas; Alarm Station; and Communications.

Results: One violation was identified - Failure to maintain security related equipment in operable condition.

B408240010 B40710
PDR ADOCK 05000261
G PDR

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION.
UPON SEPARATION THIS
PAGE IS DECONTROLLED.

SAFEGUARDS INFORMATION