This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date. Facility: Commonwealth Edison Co. Licensee Emergency Classification: LaSalle County Nuclear Plant Notification of an Unusual Event Unit 2 Alert Marseilles, IL 61341 Site Area Emergency General Emergency Docket No: 50-374 Not Applicable Subject: INOPERABLE VALVE: SHUTDOWN GREATER THAN 48 HOURS At 4:15 a.m. (CDT), August 18, 1984, while the unit was in hot shutdown, the licensee declared an "unusual event" after a full flow test valve failed to completely close manually. The valve is located on the B Loop of the Residual Heat Removal (RHR) system. The valve first failed to completely close on August 17 while the licensee was performing an evolution with the suppression pool cooling mode of the B Loop of the RHR system. The valve was closed manually. Later, at 2 a.m. (CDT), August 18, a similar evolution was conducted and the valve again failed to completely close. This time, efforts to secure the valve manually were unsuccessful. The licensee declared the "unusual event" per its emergency classification procedure and proceeded to cold shutdown as required by technical specification. The inoperability of this valve affects primary containment isolation capability and makes inoperable the following modes of the B Loop of the RHR system: low pressure injection, shutdown cooling, and suppression pool cooling. The unusual event was terminated at 2:40 a.m. (CDT) when the unit was brought to cold shutdown. The unit will remain in cold shutdown pending repairs of the valve and other maintenance activities. It is expected to be shut down for about three days. The State of Illinois will be notified. Region III (Chicago) was first notified of the unusual event at 4:45 a.m. (CDT), August 18, 1984. This information is current as of 11 a.m. (CDT), August 20, 1984. CONTACT: rissotimos 8408240114 840820 PDR 1&E PNO-III-84-066 PDR DISTRIBUTION: H. St. 12:23 MNBB 12:25 Phillips 12:30 E/W 12:19 Willste 12:28 Chairman Palladino EDO IE NMSS Comm. Roberts PA OIA RES Comm. Asselstine MPA AEOD Comm. Bernthal Air Rights 12:20 ELD MAIL: Comm. Zech INPO 12:53 ADM: DMB

Applicable Resident Site 12:50

Regions [12:34, II]2:36, IV|2:40, V|2:38 Licensee (Corporate Office) 1:09

SECY

ACRS

PDR

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-III-84-66

Rev. 07/06/84

DOT: Trans Only

NSAC 12:5

Date August 20, 1984