



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4344

Gary J. Taylor
Vice President
Nuclear Operations

December 8, 1995
RC-95-0212

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. Stephen Dembek

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
TECHNICAL SPECIFICATION CHANGE REQUEST - TSP 950007
ECCS PUMP TESTING

South Carolina Electric & Gas Company (SCE&G), acting for itself and as agent for South Carolina Public Service Authority, hereby requests an amendment to the Virgil C. Summer Nuclear Station (VCSNS) Technical Specifications (TS). This change is being submitted pursuant to 10 CFR 50.90. The proposed change will follow the guidance located in the Westinghouse Standardized Technical Specifications (STS), NUREG 1431 (MERITS).

The sections affected by this change request are as follows:

- ▶ 4.1.2.2 (Boration Systems) - added new Surveillance Requirement.
- ▶ 3.1.2.3 (Charging Pump - Shutdown) -- Section 3/4.1.2.3 is being deleted.
- ▶ 3.1.2.4 (Charging Pumps - Operating) -- Section 3/4.1.2.4 is being deleted.
- ▶ 3.4.9.3 (Overpressure Protection Systems) -- Section 3.4.9.3 is being revised to assure only one charging pump is capable of RCS injection in the applicable modes.
- ▶ 4.4.9.3 (Overpressure Protection Systems) -- Section 4.4.9.3 is being revised to add a surveillance to demonstrate this assurance.
- ▶ 4.5.2.f (ECCS pump periodic testing under Specification 4.0.5) -- Section 4.5.2.f is being revised to delete specific pump testing acceptance criteria and reference acceptance criteria located in the plant IST Program.
- ▶ Bases Page B 3/4 1-3 -- Bases Page B 3/4 1-3 is being revised to correct an oversight from Amendment 26.
- ▶ Bases Page B 3/4 4-2 -- Bases Page B 3/4 4-2 is being revised to delete an inaccurate statement.
- ▶ Bases Page B 3/4 4-14a -- Bases Page B 3/4 4-14a is being revised to provide bases for the new Surveillance 4.4.9.3.3.



9512180069 951208
PDR ADOCK 05000395
P PDR

AD01

This Technical Specification Change Request (TSCR) is contained in the following attachments which document and support our request:

- Attachment I Description of Changes Chart
 Marked-up Technical Specification Pages
 Revised Technical Specification Pages
- Attachment II Description of Amendment Request and the Supporting
 Safety Evaluation
- Attachment III Description of Amendment Request and the Associated
 No Significant Hazards Evaluation


SCE&G requests the NRC review and approval of this TSCR by January 15, 1996, in order to support the planning and scheduling activities for the ninth refueling outage.

This proposed TSCR has been reviewed and approved by both the Plant Safety Review Committee and the Nuclear Safety Review Committee.

I declare that these statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

Should you have any questions, please call Mr. Philip Rose at (803) 345-4052 at your convenience.

Very truly yours,



Gary J. Taylor

PAR/GJT/dr
Attachments (3)

c: J. L. Skolds (w/o Attachments)
O. W. Dixon
R. R. Mahan (w/o Attachments)
R. J. White
S. D. Ebnetter
NRC Resident Inspector

J. B. Knotts Jr.
M. K. Batavia
K. R. Jackson
Central File System
RTS (TSP 950007)
File (813.20)

