



Northern States Power Company

Monticello Nuclear Generating Plant  
2807 West Hwy 75  
Monticello, Minnesota 55362-9637

December 11, 1995

10 CFR Part 50  
Section 50.90

U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

License Amendment Request Dated December 11, 1995  
Removal of Surveillance Requirement Concerning  
Periodic Replacement of Containment Purge and Vent Valve Seat Seal

Attached is a request for a change in the Technical Specifications, Appendix A of the Operating License for the Monticello Nuclear Generating Plant. This request is submitted in accordance with the provisions of 10 CFR Part 50, Section 50.90.

This proposed amendment changes section 4.7, Surveillance Requirements for Primary Containment Automatic Isolation Valves. The proposed change removes from the Monticello Technical Specifications surveillance requirement 4.7.D.4; replacement of the seat seals for the drywell and suppression chamber purge and vent valves every five years. The change is proposed as a cost beneficial licensing action in that the deletion of surveillance requirement 4.7.D.4 has the potential of improving safety by allowing licensee resources to be shifted from an activity that has a no effect on safety to those that more significantly enhance safety. It is estimated that a cost savings of approximately \$100,000 and a savings of 6 person-rem would be realized over the remaining life of the plant as a result of the proposed action.

Exhibit A contains a description of the proposed changes, the reasons for requesting the changes, a Safety Evaluation, a Determination of Significant Hazards Consideration, and an Environmental Assessment. Exhibit B contains the current Technical Specification pages marked up with the proposed changes. Exhibit C contains revised Monticello Technical Specification pages. Exhibit D contains a summary of the containment purge and vent valve leakage results.

Please contact Marvin Engen, Sr Licensing Engineer, (612-295-1291) if you require further information related to this request.

William J Hill  
Plant Manager  
Monticello Nuclear Generating Plant

9512180080 951211  
PDR ADOCK 05000263  
P PDR

ADDI

USNRC  
December 11, 1995  
Page :

NORTHERN STATES POWER COMPANY

c: Regional Administrator-III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
State of Minnesota  
Attn: Kris Sanda

Attachments: Affidavit to the US Nuclear Regulatory Commission  
Exhibit A - Evaluation of Proposed Changes to the Technical Specifications  
for Operating License DPR-22  
Exhibit B - Proposed Changes Marked Up on Existing Technical Specification  
Pages  
Exhibit C - Revised Monticello Technical Specification Pages  
Exhibit D - Measured Leakage of Monticello Primary Containment Purge and  
Vent Valves