

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Vogtle Unit 1

Docket No. 50-424
License No. CPPR-108

The following violation was identified during an inspection conducted on April 13 - May 14, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix B, Criterion V and the accepted QA program (PSAR Section 17), requires, in part, that activities affecting quality shall be prescribed by documented procedures and shall be accomplished in accordance with these procedures. Procedures shall include appropriate quantitative or qualitative acceptance criteria. Procedure GD-T-09, requires that electrical enclosures be sealed or wrapped during certain phases of construction to prevent airborne contamination.

Contrary to the above, activities affecting quality were not accomplished in accordance with the existing procedures and commitments in that on May 11, 1982, nine electrical control and instrumentation panels were not sealed or wrapped in order to prevent airborne contamination during welding, sanding and grinding operations in the surrounding area.

This is a Severity Level IV violation (Supplement II).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: JUN 14 1984