

Insert A to Page 3/4 3-9

NL-91/10

With the number of OPERABLE channels less than required by the minimum OPERABLE channels per trip system requirement for one trip system:

1. If placing the inoperable channel(s) in the tripped condition would cause an isolation, the inoperable channel(s) shall be restored to OPERABLE status within 6 hours or the ACTION required by Table 3.3.2-1 for the affected trip function shall be taken.

OR

2. If placing the inoperable channel(s) in the tripped condition would not cause an isolation, the inoperable channel(s) and/or that trip system shall be placed in the tripped condition within
 - a) 12 hours for trip functions common to RPS instrumentation#;
and
 - b) 24 hours for trip functions not common to RPS instrumentation#.