

**Idaho National Engineering Laboratory**

Operated by the U.S. Department of Energy

**Data Summaries of Licensee Event Reports  
of Selected Instrumentation and Control Components  
at U.S. Commercial Nuclear Power Plants  
January 1, 1976 to December 31, 1981**

Mike Trojovsky  
Sharon R. Brown

July 1984

Prepared for the

**U.S. Nuclear Regulatory Commission**

Under DOE Contract No. DE-AC07-76ID01570

8408240382 840731

PDR NUREG

CR-1740 R

PDR



Available from

GPO Sales Program  
Division of Technical Information and Document Control  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

and

National Technical Information Service  
Springfield, Virginia 22161

#### NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

NUREG/CR-1740  
EGG-2307  
Revision 1  
Distribution Categories: RG and 1S

**DATA SUMMARIES OF LICENSEE EVENT REPORTS OF  
SELECTED INSTRUMENTATION AND CONTROL  
COMPONENTS AT U.S. COMMERCIAL  
NUCLEAR POWER PLANTS  
JANUARY 1, 1976 TO DECEMBER 31, 1981**

Mike Trojovsky  
Sharon R. Brown

Published July 1984

EG&G Idaho, Inc.  
Idaho Falls, Idaho 83415

Prepared for the  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555  
Under DOE Contract No. DE-AC07-76ID01570  
FIN No. A6393

## ABSTRACT

This report describes a computer-based data file developed from Licensee Event Reports (LERs) of instrumentation and control (I&C) components in United States commercial nuclear power plants for the period January 1, 1976 to December 31, 1981. In addition to the creation of the file, summaries of data contained in the file were made to obtain data for risk assessment and statistical purposes. Gross constant fault (failure and command fault) rates were estimated for major components and channels that provide a direct reactor trip. Explanations, figures, and summary tables of the results are provided. This report updates and supersedes the original May 1981 edition of NUREG/CR-1740.

## SUMMARY

The Reliability and Statistics Branch of EG&G Idaho, Inc. reviewed Licensee Event Reports (LERs) to extract fault (failure and command fault) information, in support of the United States Nuclear Regulatory Commission's (USNRC's) effort to gather and analyze fault data concerning the reliability of nuclear power plants. LERs submitted by the utilities to the USNRC from January 1, 1976 through December 31, 1981, pertaining to electrical and electronic components in instrumentation and control (I&C) systems are the source of information used in this report. This report updates and supersedes the original May 1981 edition of NUREG/CR-1740, *Data Summaries of Licensee Event Reports of Selected Instrumentation and Control Components at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, in that three full years of data have been added to the data contained in the original document and the population data for the fault rate estimates have been derived from a recent study. Since the original document, six plants have achieved initial criticality thus bringing to 72 the number of plants evaluated in this report. For the six year period covered by this report, 20,027 LERs were manually screened and 4,698 were deemed as appropriate I&C events for this report.

In addition to updating the original data base, summaries of data contained in the file were made to obtain data for risk assessments and statistical purposes. Gross constant fault rates were estimated for major components and channels that provide

a direct reactor trip. Explanations, figures, and summary tables of the results are provided.

From the 4,698 applicable LERs, 5,092 one-line descriptions (containing 6,764 faults) were derived and entered into the I&C data base. Of the 6,764 faults, 6,180 (91%) were classified as actual failures. The remaining 584 were identified as being command faults. As in the earlier report, the component that had the highest percentage of the total number of component faults reported was the general switch (pressure, temperature, flow, and level switches). In the previous report, switches comprised 31% of the total number of faults reported; in this report they comprise 30%. Also, the fault cause that led to the most component faults was instrument drift. In both reports this fault cause contributed to 35% of the component faults reported.

In these and in other aspects, the additional three years of data analyzed in this report are in agreement with the previous study. No substantial differences in the occurrence of I&C faults in the two time periods were noticed.

The component faults and fault rates summarized in this report should be interpreted as tentative gross indicators of true fault trends and fault rates. Because subjective judgments had to be made regarding pertinence of recorded events, and because some component faults may not be recorded in the LERs, the individual analyst should confirm the applicability of the component faults and fault rates for their specific uses.

## FOREWORD

This report is one in a series summarizing the statistics of Licensee Event Reports (LERs) as submitted to the United States Nuclear Regulatory Commission (USNRC). The goal of the report is twofold: (a) to summarize the data for risk assessments and statistical analyses, and (b) to obtain gross constant fault (failure and command fault) rate estimates.

Owing to the subjective judgments that had to be made regarding population sizes and pertinence of recorded events, and to the fact that some component faults may not be recorded in the LERs, the component fault rates estimated in this report should be interpreted only as tentative gross indicators of the true fault rates. Furthermore, because LER reporting requirements can differ from plant to plant, comparisons of plant-to-plant fault rates should be interpreted with care; a higher fault rate may simply be the result of stricter reporting requirements. The analyst should confirm the applicability of the LER-derived fault rates for their specific uses. As more data are collected and more analyses are performed in the future, improved fault rate estimates will be produced.

Fault rates are only one of many kinds of information presented in this report. Tables and discussions classify important information on fault classifications according to fault modes, fault causes, and systems affected. Gross time trends are examined. Human errors are identified as are common cause faults and recurring faults. Each LER analyzed is presented in a useful, summarized form, and all evaluations are presented so that analysts can modify the authors' calculations or perform their own evaluations if so desired.

R. C. Robinson  
USNRC Project Manager  
February 1984

The previous reports in this series of data summaries of the Licensee Event Reports are:

1. W. H. Hubble and C. F. Miller, *Data Summaries of Licensee Event Reports of Control Rods and Drive Mechanisms at U.S. Commercial Nuclear Power Plants January 1, 1972 to April 30, 1978*, NUREG/CR-1331, February 1980.
2. J. P. Poloski and W. H. Sullivan, *Data Summaries of Licensee Event Reports of Diesel Generators at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, NUREG/CR-1362, March 1980.
3. D. W. Sams and M. Trojovsky, *Data Summaries of Licensee Event Reports of Primary Containment Penetrations at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, NUREG/CR-1730, September 1980.
4. C. F. Miller et al., *Data Summaries of Licensee Event Reports of Selected Instrumentation and Control Components at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, NUREG/CR-1740, May 1981.
5. M. Trojovsky, *Data Summaries of Licensee Event Reports of Pumps at U.S. Commercial Nuclear Power Plants January 1, 1972 to September 30, 1980*, NUREG/CR-1205, Revision 1, January 1982.
6. C. F. Miller et al., *Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1980*, NUREG/CR-1363, Revision 1, October 1982.

## ACKNOWLEDGMENTS

Sincere appreciation is expressed to the following persons for their assistance in the preparation of this report: Dr. Corwin L. Atwood for his development of a reactor trip system model applicable to the data available for computing LER fault rates. John C. Culley and Alan J. Smith for their technical assistance in computer graphics and data base management. Lee C. Cadwallader, Cindy D. Gentillon, and Judy A. Steverson for their helpful suggestions. Nila Hatton, Jan Isom, and the Technical Publication Composition Staff for their conscientious and timely efforts in the word processing and text composition of this report.



# CONTENTS

ABSTRACT .....	ii
SUMMARY .....	iii
FOREWORD .....	iv
ACKNOWLEDGMENTS .....	vi
NOMENCLATURE .....	xiv
Terms .....	xiv
Acronyms and Abbreviations .....	xv
INTRODUCTION .....	1
LER EVALUATION AND CODING METHODOLOGY .....	2
Scope .....	2
I&C Component Types .....	2
Parameter .....	3
Function .....	3
LER Selection .....	4
LER Classification .....	5
Fault/Failure .....	6
Fault Mode .....	6
Fault Cause .....	6
Event Classification (Age or Frequency of Use) .....	7
Type of Event .....	7
System .....	8
Event Date .....	8
Manufacturer .....	8
Activity Resulting in Discovery .....	8
LER Rate Estimations .....	8
Populations .....	9
Time .....	9
Faults .....	9
Computations .....	11
SUMMARY OF RESULTS .....	13
Engineering Data .....	13
Overview with Focus on Plants .....	13

NSSS Vendor .....	13
Plant-Specific Data .....	13
Overview with Focus on Components .....	13
Component .....	13
Fault Mode .....	13
Human Factors and Other Fault Causes .....	24
Fault Mode and Cause .....	24
Parameter .....	24
Function .....	24
System .....	24
Event Classification .....	36
Type of Event .....	36
Overview with Focus on Type of Event .....	36
Fault Mode .....	36
Fault Cause .....	36
Parameter .....	36
Function .....	36
System .....	36
Event Classification .....	36
LER Rates .....	36
REFERENCES .....	129
(NOTE: Appendixes D, F, H, and I to this report contain microfiche attached to the inside of the back cover).	
APPENDIX A—DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING .....	A-1
APPENDIX B—ONE-LINE LER CODING SCHEME .....	B-1
APPENDIX C—LER RATE ESTIMATION METHODS .....	C-1
APPENDIX D—INSTRUMENTATION AND CONTROL ONE-LINERS SORTED BY NSSS VENDOR .....	D-1
APPENDIX E—INSTRUMENTATION AND CONTROL ONE-LINERS SORTED BY HUMAN FACTORS .....	E-1
APPENDIX F—INSTRUMENTATION AND CONTROL ONE-LINERS SORTED BY SYSTEM .....	F-1
APPENDIX G—INSTRUMENTATION AND CONTROL ONE-LINERS SORTED BY TYPE OF EVENT .....	G-1
APPENDIX H—RESULTS OF COMPONENT LER RATE ESTIMATIONS .....	H-1
APPENDIX I—RESULTS OF CHANNEL LER RATE ESTIMATIONS .....	I-1

## FIGURES

1.	Simplified diagram showing I&C functional boundary .....	2
2.	Summary of I&C faults by NSSS .....	14
3.	Summary of I&C faults by plant .....	15
4.	Summary of I&C faults for Babcock & Wilcox plants .....	16
5.	Summary of I&C faults for Combustion Engineering plants .....	17
6.	Summary of I&C faults for Westinghouse plants .....	18
7.	Summary of I&C faults for General Electric plants .....	19
8.	Summary of I&C faults by component .....	22
9.	Summary of I&C faults by fault cause .....	25
10.	Summary of I&C faults by parameter .....	28
11.	Summary of I&C faults by function .....	30
12.	Summary of I&C faults by PWR systems .....	32
13.	Summary of I&C faults by BWR systems .....	33
14.	Summary of I&C faults by type of event .....	38
15a.	Scatter plot of operating LER rates for Babcock & Wilcox plant core flux sensors, inoperable, with command faults .....	100
15b.	Scatter plot of operating LER rates for Combustion Engineering plant core flux sensors, inoperable, with command faults .....	100
15c.	Scatter plot of operating LER rates for Westinghouse plant core flux sensors, inoperable, with command faults .....	101
15d.	Scatter plot of operating LER rates for General Electric plant core flux sensors, inoperable, with command faults .....	101
15e.	Scatter plot summarizing operating LER rates of core flux sensors, inoperable, with command faults .....	102
16a.	Scatter plot of operating LER rates for Babcock & Wilcox plant temperature sensors, inoperable, with command faults .....	102
16b.	Scatter plot of operating LER rates for Combustion Engineering plant temperature sensors, inoperable, with command faults .....	103
16c.	Scatter plot of operating LER rates for Westinghouse plant temperature sensors, inoperable, with command faults .....	103

16d.	Scatter plot summarizing operating LER rates of temperature sensors, inoperable, with command faults .....	104
17a.	Scatter plot of operating LER rates for Babcock & Wilcox plant flow and pressure transmitters, inoperable, with command faults .....	104
17b.	Scatter plot of operating LER rates for Combustion Engineering plant flow, level, and pressure transmitters, inoperable, with command faults .....	105
17c.	Scatter plot of operating LER rates for Westinghouse plant flow, level, and pressure transmitters, inoperable, with command faults .....	105
17d.	Scatter plot of operating LER rates for General Electric plant flow transmitters, inoperable, with command faults .....	106
17e.	Scatter plot summarizing operating LER rates of flow, level, and pressure transmitters, inoperable, with command faults .....	106
18a.	Scatter plot of operating LER rates for Babcock & Wilcox plant flow, pressure, temperature, and core flux conditioning systems, inoperable, with command faults .....	107
18b.	Scatter plot of operating LER rates for Combustion Engineering plant flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults .....	107
18c.	Scatter plot of operating LER rates for Westinghouse plant flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults .....	108
18d.	Scatter plot of operating LER rates for General Electric plant flow and core flux conditioning systems, inoperable, with command faults .....	108
18e.	Scatter plot summarizing operating LER rates of flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults .....	109
19a.	Scatter plot of operating LER rates for Babcock & Wilcox plant flow, pressure, temperature, and core flux bistables, inoperable, with command faults .....	109
19b.	Scatter plot of operating LER rates for Combustion Engineering plant flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults .....	110
19c.	Scatter plot of operating LER rates for Westinghouse plant flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults .....	110
19d.	Scatter plot of operating LER rates for General Electric plant flow and core flux bistables, inoperable, with command faults .....	111
19e.	Scatter plot summarizing operating LER rates of flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults .....	111
20a.	Scatter plot of operating LER rates for Babcock & Wilcox plant pressure switches, inoperable, with command faults .....	112
20b.	Scatter plot of operating LER rates for Westinghouse plant pressure switches, inoperable, with command faults .....	112

20c.	Scatter plot of operating LER rates for General Electric plant pressure/vacuum and level switches, inoperable, with command faults .....	113
20d.	Scatter plot summarizing operating LER rates of level, pressure, and pressure/vacuum switches, inoperable, with command faults .....	113
21a.	Scatter plot of operating LER rates for General Electric plant radiation monitors, inoperable, with command faults .....	114
21b.	Scatter plot summarizing operating LER rates of radiation monitors, inoperable, with command faults .....	114
22a.	Scatter plot of operating LER rates for Babcock & Wilcox plant core flux channels, inoperable, with command faults .....	115
22b.	Scatter plot of operating LER rates for Combustion Engineering plant core flux channels, inoperable, with command faults .....	115
22c.	Scatter plot of operating LER rates for Westinghouse plant core flux channels, inoperable, with command faults .....	116
22d.	Scatter plot of operating LER rates for General Electric plant core flux channels, inoperable, with command faults .....	116
22e.	Scatter plot summarizing operating LER rates of core flux channels, inoperable, with command faults .....	117
23a.	Scatter plot of operating LER rates for Babcock & Wilcox plant temperature channels, inoperable, with command faults .....	117
23b.	Scatter plot of operating LER rates for Combustion Engineering plant temperature channels, inoperable, with command faults .....	118
23c.	Scatter plot of operating LER rates for Westinghouse plant temperature channels, inoperable, with command faults .....	118
23d.	Scatter plot summarizing operating LER rates of temperature channels, inoperable, with command faults .....	119
24a.	Scatter plot of operating LER rates for Babcock & Wilcox plant flow channels, inoperable, with command faults .....	119
24b.	Scatter plot of operating LER rates for Combustion Engineering plant flow channels, inoperable, with command faults .....	120
24c.	Scatter plot of operating LER rates for Westinghouse plant flow channels, inoperable, with command faults .....	120
24d.	Scatter plot of operating LER rates for General Electric plant flow channels, inoperable, with command faults .....	121
24e.	Scatter plot summarizing operating LER rates of flow channels, inoperable, with command faults .....	121

25a.	Scatter plot of operating LER rates for Combustion Engineering plant level channels (analog), inoperable, with command faults .....	122
25b.	Scatter plot of operating LER rates for Westinghouse plant level channels (analog), inoperable, with command faults .....	122
25c.	Scatter plot summarizing operating LER rates of level channels (analog), inoperable, with command faults .....	123
26a.	Scatter plot of operating LER rates for Babcock & Wilcox plant pressure channels (analog), inoperable, with command faults .....	123
26b.	Scatter plot of operating LER rates for Combustion Engineering plant pressure channels (analog), inoperable, with command faults .....	124
26c.	Scatter plot of operating LER rates for Westinghouse plant pressure channels (analog), inoperable, with command faults .....	124
26d.	Scatter plot summarizing operating LER rates of pressure channels (analog), inoperable, with command faults .....	125
27a.	Scatter plot of operating LER rates for General Electric plant level channels (digital), inoperable, with command faults .....	125
27b.	Scatter plot summarizing operating LER rates of level channels (digital), inoperable, with command faults .....	126
28a.	Scatter plot of operating LER rates for Babcock & Wilcox plant pressure channels (digital), inoperable, with command faults .....	126
28b.	Scatter plot of operating LER rates for Westinghouse plant pressure channels (digital), inoperable, with command faults .....	127
28c.	Scatter plot of operating LER rates for General Electric plant pressure/vacuum channels (digital), inoperable, with command faults .....	127
28d.	Scatter plot summarizing operating LER rates of pressure and pressure/vacuum channels (digital), inoperable, with command faults .....	128

## TABLES

1.	I&C reactor trip populations for fault rates .....	10
2.	Accounting of I&C LERs .....	13
3.	Summary of I&C failures and command faults by plant and year .....	20
4.	Summary of I&C faults by component and fault mode .....	23
5.	Summary of I&C faults by component and fault cause .....	26
6.	Summary of I&C faults by component, fault cause, and fault mode .....	27
7.	Summary of I&C faults by component and parameter .....	29

8. Summary of I&C faults by component and function .....	31
9. Summary of I&C faults by component and system .....	34
10. Summary of I&C faults by component and event classification .....	37
11. Summary of I&C faults by component and type of event .....	39
12. Summary of I&C faults by type of event and fault mode .....	41
13. Summary of I&C faults by fault cause and type of event .....	42
14. Summary of I&C faults by type of event and parameter .....	43
15. Summary of I&C faults by type of event and function .....	44
16. Summary of I&C faults by type of event and system .....	45
17. Summary of I&C faults by type of event and event classification .....	46
18. Summary of I&C LER rate estimations for components that provide a direct reactor trip .....	47
19. Summary of I&C LER rate estimations for instrument channels that provide a direct reactor trip .....	48
20. Summary of input data for LER rate estimations for components .....	49
21. Summary of input data for LER rate estimations for channels .....	74
B-1. General plant information .....	B-5
B-2. Codes used in one-line descriptions .....	B-12
B-3. Manufacturers referenced in I&C LERs .....	B-14

## NOMENCLATURE

This section contains terms, acronyms, and abbreviations.

### Terms

1. **Component**—The largest entity of hardware for which data are most generally collected and expected to be available (e.g., pump with motor, valve with operator, amplifier, pressure transmitter). It is generally an off-the-shelf item procured by the system designer as a basic building block for their system. It would be distinguished from seals, bearings, nuts, bolts, and other piece parts from which the component is manufactured.
2. **System**—A collection of components arranged so as to provide a desired function (e.g., Containment Spray System, Residual Heat Removal System, High Pressure Coolant Injection System).
3. **Fault**—As used in the context of this report, fault refers to failures and command faults. The terms failure or command fault will be used when referring to one or the other.
4. **Failure**—A subset of a fault that represents an irreversible state of a component such that it must be repaired in order for it to perform its design function. Failures are sometimes classified as primary or secondary failures. A primary failure is the so-called *random failure* found in the literature. It results from no external cause. A secondary failure results when the component is subject to conditions that exceed its design envelope (e.g., excessive voltage, pressure, shock, vibration, temperature.) However, in classifying failures for this report, no distinction has been made between these two classifications.
5. **Command Fault**—A subset of a fault that represents an event in which the component did not function as required, not because of a failure in the component, but because of inputs or lack of inputs to the component as supplied by personnel, other components, or the environment external to the component. This is a reversible state of the component that can be corrected once the faulty input is corrected. No component repair is required.
6. **Common Cause Failure**—Two or more redundant components failing together or having the potential to fail within a relatively short period of time because of a single causal event. Multiple common cause failures are usually secondary failures.
7. **Fault Cause**—The identified cause and sequence of events that prevented the component from performing its intended function.
8. **Fault Mode**—The manner in which a component ceases to perform its intended function.
9. **Demand Failure Rate**—The probability (per demand) that a component will not operate when required to start, change state, or function.
10. **Operating Failure Rate**—The probability (per hour) of failure for those operating components required to operate or function for a period of time.
11. **Standby Failure Rate**—The probability (per hour) of failure for those components that are normally dormant or in a standby state until tested or required to operate or function for a period of time.



12. **Instrument Channel**—That portion of the circuitry that encompasses the sensor and all electrical and electronic components up to and including the comparator (or bistable). The comparator is a device that produces an abrupt change in output when the input exceeds a predetermined voltage or current reference level.

## Acronyms and Abbreviations

A/C	Air Conditioning
A/M	Automatic/Manual
AC	Alternating Current
ACC	Accumulator
ACT	Actuating
ACTUAT	Actuation
ADJST, ADJUST	Adjustment
ADMIN	Administration
ADS	Automatic Depressurization System
AFW	Auxiliary Feedwater
AFWP	Auxiliary Feedwater Pump
AMP	Amplifier
ANNUN, ANNUNC	Annunciator
APD	Air Particulate Detector, Axial Power Distribution
APDMS	Axial Power Distribution Monitoring System
API	Absolute Position Indication
APRM	Average Power Range Monitor
ARM	Area Radiation Monitor
ASI	Axial Shape Index
ASSOC	Associated
ATM	Atmosphere
ATWS	Anticipated Transient Without Scram
AUTO	Automatic
AUX	Auxiliary
AVE, AVG	Average
AXL	Axial
B, BAB & WIL, B&W	Babcock & Wilcox
B/S	Bistable
B/U	Backup
BATT	Battery
BFR	Binomial Failure Rate
BIT	Boron Injection Tank
BLDG	Building
BRD	Board
BRG	Bearing
BRKR	Breaker
BST	Bleed Storage Tank
BWR	Boiling Water Reactor
BWST	Borated Water Storage Tank
BYPSD	Bypassed
C, CE, COMB ENG	Combustion Engineering
C, CIRC, CKT	Circuit
C C COMD	Common Cause Command Fault
CAC	Containment Atmospheric Control

CAL	Calibrate, Calibration
CAM	Constant Air Monitor, Containment Atmosphere Monitor
CAMS	Containment Atmosphere Monitoring System
CAP	Capacitor
CBL	Cable
CC	Component Cooling
CCW	Component Cooling Water
CEA	Control Element Assembly
CEAC	Control Element Assembly Calculator
CEDM	Control Element Drive Mechanism
CEDS	Control Element Drive System
CFCU	Containment Fan Cooling Unit
CHNGD	Changed
CHRGR	Charger
CIS	Containment Isolation Signal
CKTBRK	Circuit Breaker
CMFLPD	Core Maximum Fraction of Limiting Power Density
CNDNSR, COND	Condenser
CNDNSTN	Condensation
CNSRVTV	Conservative
CNSTRCTN, CONSTR	Construction
CNTCTR	Contractor
CNTNMNT, CONT	Containment
CNTRL	Control
CNTRLLR	Controller
CNVRTR	Converter
COIN	Coincident
COLSS	Core Operating Limits Supervisory System
COM CAUSE	Common Cause
COMPON	Component
COMPUT MOD COND & FEED	Computation Module Condensate & Feed
CONDIT	Conditioner
CONDUCT	Conduction
CPC	Core Protection Calculator
CR	Control Rod, Control Room
CRA	Control Rod Assembly
CRD	Control Rod Drive, Card
CRDM	Control Rod Drive Mechanism
CS	Condensate System
CSI	Containment Spray Injection
CST	Condensate Storage Tank
CURR	Current
CV	Containment Vessel
CVCS	Chemical Volume Control System
CVR	Cover
D/G	Diesel Generator
DBA	Design Basis Accident
DC	Direct Current
DDPS	Digital Data Processing System
DECRS	Decrease
DEH	Digital Electric Hydraulic
DEMIN	Demineralizer

DET	Detector
DH	Decay Heat
DHR	Decay Heat Removal
DIR	Direct
DNBR	Departure from Nucleate Boiling Ratio
DP, D/P	Differential Pressure
DPIS	Differential Pressure Isolation Switch
DRPI	Digital Rod Position Indication
DRWR	Drawer
DSTRBD	Disturbed
DT, D/T	Differential Temperature
DW	Drywell
DWED	Drywell Equipment Drain
DWFD	Drywell Floor Drain
DWG	Drawing
ECCS	Emergency Core Cooling System
EDG	Emergency Diesel Generator
EFF, EFFLNT	Effluent
EFW	Emergency Feedwater
EGM	Electronic Governor Motor
EGTS	Emergency Gas Treatment System
EHC	Electro-Hydraulic Control
ELECT MALF	Electrical Malfunction
EM	Electromagnetic
EMERG	Emergency
EMRV, ERV	Electromagnetic Relief Valve
EOL	End of Life
EPR	Electric Pressure Regulator
EQUIP	Equipment
ERCW	Essential Raw Cooling Water
ESF	Engineered Safety Features
ESFAS	Engineered Safety Features Actuation System
ESW	Emergency Service Water
ETS	Environmental Technical Specifications
EWST	Elevated Water Storage Tank
EXHST	Exhaust
FAB CON QC	Fabrication/Construction/Quality Control
FLTR	Filter
FR	Front
FSAR	Final Safety Analysis Report
FW	Feedwater
G, GE, GEN ELEC	General Electric
GEN CONTR	General Control/Indication/Alarm
GENER	General
GM	Geiger-Mueller
GSLO	Gland Seal Leak Off
H/X	Heat Exchanger
HCU	Hydraulic Control Unit
HP	High Pressure
HPCI	High Pressure Coolant Injection
HPI	High Pressure Injection

HPSI	High Pressure Safety Injection
HT	High Temperature
HV	High Voltage
HVPS	High Voltage Power Supply
I&C	Instrumentation and Control
I/O	Input/Output
IA	Instrument Air
ILRT	Integrated Leak Rate Test
INADV	Inadvertent
INCRS	Increase
IND	Indicator, Indicate
INST, INSTR	Instrument
INSTLD	Installed
INSUF	Insufficient
INT	Integrated (circuit)
INTEG. INTGRTR	Integrator
IRM	Intermediate Range Monitor
IRPI	Individual Rod Position Indication
ISOL	Isolation
LED	Light Emitting Diode
LER	Licensee Event Report
LIQ	Liquid
LIS	Level Indicating Switch
LK SENS LN	Leaking or Blocked Instrument Sensing Lines
LL	Low Level
LP	Low Pressure
LPCI	Low Pressure Coolant Injection
LPCS	Low Pressure Core Spray
LPD	Local Power Density
LPRM	Local Power Range Monitor
LPSI	Low Pressure Safety Injection
LVL	Level
LVR	Lever
LW	Liquid Waste
MAG AMP	Magnetic Amplifier
MAIN, MAINT	Maintenance
MCC	Motor Control Center
MDAFP	Motor Driven Auxiliary Feedwater Pump
MECH MALF	Mechanical Malfunction
MFG	Manufacturing
MFR	Manufacturer
MG	Motor Generator
MIN	Minimum
MPR	Mechanical Pressure Regulator
MS	Main Steam
MSIV	Main Steam Isolation Valve
MSL	Main Steam Line
MSP	Maintenance Surveillance Procedure
MSR	Moisture Separator Reheater
MTR	Meter

NAOH	Sodium Hydroxide
NI	Nuclear Instrument
NIS	Nuclear Instrumentation System
NOR OPER	Normal Plant Operation
NRC	Nuclear Regulatory Commission
NRML	Normal
NSIC	Nuclear Safety Information Center
NSSS	Nuclear Steam Supply System
OH	Overheated
OOA	Out of Alignment, Out of Adjustment
OOC	Out Of Calibration
OOS	Out Of Service
OOT	Out of Tolerance
OP	Optical
OPER	Operation
OPPS	Overpressurization Protection System
OTDT	Over-Temperature Delta-T
PCIS	Primary Containment Isolation System
PDIS	Pressure Differential Indicating Switch
PENET, PENETR	Penetration
PER MAIN	Personnel Maintenance
PER OPER	Personnel Operation
PER TEST	Personnel Testing
PI	Pressure Indicator
PLCEA	Part Length Control Element Assembly
PORV	Power Operated Relief Valve
POS	Position
PPS	Plant Protection System
PR	Power Range
PRESS	Pressure
PRMSSV	Permissive
PROC	Procedure
PROT, PRTCTN	Protection
PROTECT	Protector
PS	Pressure Switch, Power Supply
PT	Pressure Transmitter
PWR	Pressurized Water Reactor, Power
PZR	Pressurizer
QA	Quality Assurance
QC	Quality Control
R C C COMD	Recurring Common Cause Command Fault
R COM CAUS	Recurring Common Cause Failure
RADW	Radwaste
RB	Reactor Building
RBM	Rod Block Monitor
RC	Reactor Coolant
RCIC	Reactor Core Isolation Cooling
RCP	Reactor Coolant Pump
RCS/PCS	Reactor Coolant System/Primary Coolant System
REAC CONT	Reactor Control

REC	Recorder
REC COMD	Recurring Command Fault
REC REVIEW	Records Review
REC'D	Received
RECAL	Recalibrate
RED CAPAB	Reduced Capability
REF	Reference
REG	Regulated
REM	Remote
REQ	Required
RHR	Residual Heat Removal
RIP	Reactor Instrument Penetration
RMS	Radiation Monitoring System
RPC	Reactor Protection Channel
RPI	Rod Position Indication
RPS	Reactor Protection System
RPV	Reactor Pressure Vessel
RRP	Reactor Recirculation Pump
RSCS	Rod Sequence Control System
RSDP	Remote Shutdown Panel
RSPT	Reed Switch Position Transmitter
RTD	Resistance Temperature Detector
RTGB	Reactor Turbine General Board
RWCU	Reactor Water Cleanup
RWM	Rod Worth Minimizer
RWST	Refueling Water Storage Tank
RWT	Refueling Water Tank
RX	Reactor
S/U	Startup
SAM	Safety Actuation Monitor
SBLC	Standby Liquid Control
SBV(S)	Shield Building Ventilation (System)
SD, S/D	Shutdown
SERV WTR	Service Water
SFAS	Safety Features Actuation System
SFRCS	Steam and Feedwater Rupture Control System
SG, S/G	Steam Generator
SGIS	Steam Generator Isolation System
SGLIC	Steam Generator Level Instrument Channel
SGTS	Standby Gas Treatment System
SI	Safety Injection
SIAS	Safety Injection Actuation System
SIG	Signal
SIT	Safety Injection Tank
SJAE	Steam Jet Air Ejector
SJWCP	Skid Jacket Water Cooling Pump
SLBIC	Steam Line Break Isolation Control
SRM	Source Range Monitor
SSPS	Solid State Protection System
STAT	Station
STM	Steam
SUP	Supply
SUPP	Suppression

SW	Service Water, Switch
SYS	System
T	Temperature
T.S.	Technical Specification
TC, T/C	Thermocouple
TDAFWP	Turbine Driven Auxiliary Feedwater Pump
TDS	Temperature Differential Switch
TE	Temperature Element
TECH	Technician
TEMP	Temperature
THROTL, THRCTL	Throttle
TIP	Traversing Incore Probe
TM/LP	Thermal Margin/Low Pressure
TORQ	Torque
TRANSM, TX	Transmitter
TRP	Trip
TURB	Turbine
U/L	Upper/Lower
UNSP	Unspecified
USNRC	United States Nuclear Regulatory Commission
VAC, VCUUM	Vacuum
VAR	Variation, Variable
VENTILATN	Ventilation
VIAS	Ventilation Isolation Actuation Signal
VIB	Vibration
VLTG	Voltage
VLV	Valve
W, WESTING	Westinghouse
WRNI	Wide Range Nuclear Instrument
WST	Waste
WTR	Water
XDCR	Transducer
XFMR	Transformer
XMISSION	Transmission
XMITTER, XMTR	Transmitter
XSTR	Transistor

# DATA SUMMARIES OF LICENSEE EVENT REPORTS OF SELECTED INSTRUMENTATION AND CONTROL COMPONENTS AT U.S. COMMERCIAL NUCLEAR POWER PLANTS JANUARY 1, 1976 TO DECEMBER 31, 1981

## INTRODUCTION

Licensee Event Reports (LERs) submitted between January 1, 1976 and December 31, 1981 that pertain to electrical and electronic components in instrumentation and control (I&C) systems have been evaluated and are presented herein, in support of the United States Nuclear Regulatory Commission's (USNRC's) continuing effort to gather and analyze fault (failure and command fault) data for active and passive components in nuclear power plants. This report updates and supersedes NUREG/CR-1740<sup>1</sup> in that three full years of additional data have been included and the population data for the fault rate estimates have been derived from a recent study.<sup>2</sup>

As in the original report, the data reported in the LERs were qualitatively evaluated and pertinent information (e.g., fault mode, fault cause, and event date) contained in each LER describing an I&C event was coded into a one-line description of the event. Each one-line description was then stored in a computer-based data file for future use. Data in this computerized file can be searched, sorted, collated, retrieved, updated, and displayed by almost any item of information contained in the original LER. For example, plant, Nuclear Steam Supply System (NSSS) vendor, event date, fault mode, and fault cause data can all be accessed and manipulated by the analyst. This feature makes the one-line LER data base useful for obtaining various LER summary statistics for use in analyses of component and fault events.

Various fault rates (herein called *LER rates*) were estimated for selected I&C components and channels for each operating U.S. commercial nuclear power plant, with the exception of three plants that were considered atypical for this report. These estimates were averaged to obtain corresponding component and channel LER rates for the four NSSS vendors considered. Finally, specific plant fault data were averaged to obtain various LER

rates for pressurized water reactors (PWRs), boiling water reactors (BWRs), and the aggregate of both reactor types.

LER rates are useful for probabilistic analyses such as gross risk and reliability evaluations. However, when using the LER rates, the analyst should apply them with caution. LER rates reported herein are estimates based on the component faults reported in the LER system. This is important since these faults do not necessarily comprise all faults for any given component and, hence, may not represent the component's actual fault rate. There are various reasons why all faults may not be reported. For example, plant status (at power, cold shutdown, and refueling) at the time of failure and the failure's impact on the system or subsystem are two factors that can influence whether or not a fault is reported. The estimation of exposure time during which faults can occur is another source of variation in the LER rates. This time depends on the number of selected components in the facility and the operating time of each component. Appendix A contains a further discussion on the variations in LER reporting.

The body of this report has two major parts. First, the LER analysis is described. Included are the assumptions, definitions, and limitations used in carrying out the analysis. Next, a summary of the data according to various encoded characteristics is provided. In Appendix A, some of the causes for the variations in LER reporting are explained. Appendix B describes the LER coding scheme. Appendix C discusses the methods used to estimate the LER fault rates. Appendixes D through G contain sorts of the one-line descriptions by NSSS vendor, human factors, system, and type of event, respectively. Appendixes H and I contain LER rate estimations for components and channels, respectively.



# LER EVALUATION AND CODING METHODOLOGY

## Scope

In the context of this report, instrumentation provides data or signals of plant process variables (e.g., pressure and temperature) that are sensed and interpreted by control systems. Plant systems then respond to the output from the I&C systems. Nuclear power plants have an abundance of electrical and electronic equipment that are part of the I&C systems. The discussion that follows describes what were considered to be I&C components for the purpose of this report.

**I&C Component Types.** The electrical and electronic components that are considered to perform an I&C function are shown in Figure 1. The nineteen I&C component types identified for use are listed below (see also COMP in Appendix B):

1. Amplifier/buffer/isolation amplifier
2. Cable/receptacle/junction box/terminal
3. Controller
4. Comparator (bistable)
5. Converter/conditioner
6. General switch (e.g., temperature, flow, pressure, and level switches)
7. Hand switch
8. Computation module
9. Indicator/meter/annunciator
10. Computer
11. Limit switch
12. Monitor
13. Power supply
14. Recorder




Figure 1. Simplified diagram showing I&C functional boundary.

15. Relay/solenoid
16. Sensor
17. Timer
18. Transformer
19. Transmitter.

Most of the components listed above are self-explanatory when considered in relation to Figure 1. Only these electrical and electronic equipment are considered in this report. Sensors include resistance temperature detectors (RTDs), and various types of core flux detectors (power range, wide range, and source range). In some cases, *other/unknown* was used for the component type. This occurred when LERs described events that were within the scope of Figure 1, but which provided insufficient detail to classify the components involved. For example, two source range channels were inoperable for an hour. The cause of failure could not be located.

Figure 1 shows that certain types of actuation relays, sequencers, and other I&C generic components fall outside the scope of this report. In general, relays, sequencers, and circuit breakers associated with a nuclear power plants' electrical distribution system were not considered for this report; however, an analysis of these components is under way and will be published as another report in this series. Another class of I&C generic components not considered for this report were those that fell within the bounds of components treated in other LER summary reports. An example of the last category are limit and torque switches associated with the *operation* of a valve operator. These switches were considered in NUREG/CR-1363 Revision 1,<sup>3</sup> *Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1980*, and consequently LERs dealing specifically with such switches are not included in this report. Components of the nineteen types had to be within a system that provides signals of plant process variables to selected control systems or be within the selected control systems to be considered within the scope of this report. For a rationale of control systems not selected for this report, see the LER selection section.

For the purposes of this report, the concept of a *channel* (i.e., an arrangement of I&C components forming a higher level component) is employed. An

instrument channel is defined as that portion of the circuitry that encompasses the sensor and all electrical and electronic components up to and including the comparator (bistable). Therefore, the channel generates a signal when the variable sensed exceeds a limit. A typical channel is shown within the dotted boundary in Figure 1. While the concept of a channel is general and a channel can perform any of the several functions discussed in detail below, it is within the context of the reactor trip function that the channel is primarily used in this report.

**Parameter.** In order to analyze an instrument channel it is necessary to categorize it by the parameter it monitors. The monitored parameters identified for this report are listed below:

1. Liquid level
2. Nuclear (core flux)
3. Flow
4. Temperature
5. Radiation (area)
6. Pressure/vacuum
7. Position
8. Other/unknown.

These parameters are self-explanatory, except the *other/unknown* parameter. Most of the events categorized as *other/unknown* were unknown because the LER failed to identify the parameter, or more than one parameter was identified. A few events, however, did involve other parameters such as frequency and voltage. There were not enough of these events to warrant separately classifying them.

**Function.** The I&C systems and the constituent components are also classified by the function they perform. I&C systems within nuclear power plants basically fall into four functional categories: reactor protection, reactor control, process control, and radiation monitoring.<sup>4</sup> This report considers the most important of these functions to be reactor protection. The Institute of Electrical and Electronic Engineers defines the protection system as:

"For purposes of these criteria, the nuclear power generating station protection system

encompasses all electrical and mechanical devices and circuitry (from sensors to actuation device input terminals) involved in generating those signals associated with the protective function. These signals include those that actuate reactor trip and that, in the event of a serious reactor accident, actuate engineered safeguards such as containment isolation, core spray, safety injection, pressure reduction, and air cleaning."<sup>5</sup>

Based on this definition, the list of functional categories was expanded from 4 to 5 for this report to encompass the following:

1. Reactor trip (scram)
2. Engineered safety features actuation
3. Reactor control
4. General control/indication/alarm
5. Radiation detection.

The first two functions are subsets of the protection system function.

All of the events described herein are categorized by one of these five functions. For example, any event that described the fault of a component within an instrument channel, when that instrument channel was identified as providing a direct reactor trip signal, was categorized as reactor trip.

If a faulted component was in a channel that provided a signal to actuate a component (e.g., a pump) in an engineered safety features (ESF) system, the event was considered to provide an ESF actuation function.

**NOTE:** Some ESF systems, when actuated, supply a signal back to the reactor-trip logic. This indirect trip signal will scram the reactor if, for some reason, the direct trip signal failed to do so. I&C components involved in indirect scrams were considered outside the scope of this report.

Those components that affected the control of the reactor, in terms of control rod position, were considered to provide reactor control functions. Reactor control encompasses rod block monitors, rod position indication, axial power monitors, and in general, any component or instrument channel that supplies a signal that aids in positioning the control rods so as to maintain the desired reactor power.

Faults of components designed to monitor radiation, such as air-particle detectors and rad-waste monitors were categorized as radiation detection. One exception to this is the radiation detectors in BWR plants that sense radiation in the steam lines. Faults involving these detectors were categorized as reactor trip because a main steam high-radiation condition requires a direct reactor trip.

Although seemingly straightforward, the task of assigning a function to each event required some subjective judgments. For example, the failure of a bistable in a PWR temperature channel supplying a reactor trip function would be assigned a reactor trip function. However, the failure of a meter that is receiving input from this same channel is not assigned a reactor trip function, but is considered *general control/indication/alarm*. Any one channel may, in fact, provide a reactor trip and/or a signal to actuate an ESF system component while, at the same time, providing indication or alarm functions (general control). Also, the information contained in the LERs is not always sufficient to permit one to make clear functional distinctions. In addition, plant FSARs (Final Safety Analysis Reports) are not always clear as to what functions a particular instrument channel is capable of providing. The four components, indicator, meter, annunciator, and recorder, were generally viewed as providing a general control function.

To review the discussion of I&C components, the concept of an instrument channel, parameters, and functions, and how these items relate to one another, refer again to Figure 1. Only components within the heavy line are considered I&C components for this report. Similarly, basic instrument channel components are shown within the dashed line. Figure 1 is very simplistic and is provided only to aid the reader in visualizing those concepts discussed thus far.

**LER Selection.** The LERs for the first edition of this report, covering January 1, 1976 through December 31, 1978, were obtained from the USNRC in the form of two computer sorts. The first sort contained LERs that were coded INSTRU in the component field and involved I&C component faults. The second sort was a text search of the LER file narratives for words such as channel, transmitter, sensor, bistable, and amplifier, excluding those LERs obtained in the first sort. These two sorts yielded 2,587 LERs for consideration. An additional sort, from the pump data summary,<sup>6</sup> produced 54 LERs that were reviewed for radiation

monitor sample pumps. After an audit, conducted during the original I&C study, it was concluded that at least 90% of the LERs involving I&C events had been considered.

In order to ensure completeness of the LERs pertaining to I&C for this report, the entire computerized USNRC LER file was obtained for the period January 1, 1976 through December 31, 1981. This file contained 17,386 additional LERs that were individually screened to identify all relevant I&C events. This method for obtaining LERs provides additional assurance that all of the I&C LERs are considered. Therefore, the total number of LERs reviewed for this report was 20,027. However, not all of these LERs were used for this analysis with many having been excluded for one or more of the following reasons:

1. The LERs pertained to other electrical and electronic components outside the scope of this report.
2. The LERs contained informational items rather than component faults. An example of an informational item is a LER stating that "a calibration check was not performed on or before the date required."
3. The LERs were submitted by three plants considered atypical. These plants are Fort St. Vrain (gas-cooled), Humboldt Bay (BWR/1, 63 megawatts), and LaCrosse (the only plant with Allis-Chalmers as the NSSS vendor). Also, Indian Point 1 differs from the 72 plants evaluated in this report, because it was shutdown and defueled prior to January of 1976. Consideration was given to Dresden 1, but any events after October 31, 1978 are not considered because of the extended shutdown that started on October 31, 1978, and which was still in effect on December 31, 1981. LERs submitted by Three Mile Island 1 and 2 prior to the March 28, 1979 accident are considered in this report. Events from either plant after that date are excluded, as Three Mile Island 2 is still shutdown, and Three Mile Island 1 is shutdown due to a restraining order.
4. The LERs were submitted prior to the date of initial criticality for the respective plant.
5. The LERs described faults of components and/or instrument systems considered to be of lesser importance in terms of reactor safety. Chemical monitors such as pH monitors, oxygen and hydrogen analyzers, and systems such as *other instrument systems not required for safety*, were excluded.
6. The LERs contained a faulted I&C component that fell within the bounds of major components treated in other LER summary reports; major components include valves, pumps, control rod drive mechanisms, or diesel generators. For example, limit and torque switches on valves were excluded. These components typically interface with the moveable mechanical parts of a valve such as stems and hydraulic control linkages. Information on these types of switches can be obtained from the data summary report<sup>3</sup> on valves and valve operators. Similarly, the other data summary reports<sup>6,7,8</sup> contain data on those I&C components included within their bounds.
7. The LERs described faults of components that monitored parameters outside the reactor building or primary containment. Component faults involving seismic and meteorological monitors were, therefore, excluded.

## LER Classification

The purpose of this report is to provide reliability data, quantitative and qualitative, on selected electrical/electronic components that are part of the I&C systems in commercial nuclear power plants. A computerized data base of component/system operational experiences categorized by standard reliability characteristics was developed to provide an efficient and accurate way of retrieving and sorting the various reliability data. The various fields that are explained and discussed in this section are listed below.

1. NSSS vendor
2. Plant
3. LER control number
4. Fault mode
5. Fault cause

6. Event classification (Age or Frequency of Use)
7. Type of event
8. System
9. Event date
10. Manufacturer
11. Activity resulting in discovery.

The USNRC LER system contains a centralized source of component/system operational experiences of off-normal events in the nuclear industry. The USNRC LER file, however, is not a reliability data base. Therefore, direct transcription of these LERs for reliability purposes is not usually possible. At times, there is some correlation between the component code, component subcode, cause, and system that is coded in an LER and also what is needed in the I&C reliability data base. For these cases, a direct transcription was made. However, the descriptive text of the LER provided the bulk of the information needed for the data base. This text also provided the mechanism to check for errors in any coded portions of the original LER that were used in the data base.

Although most LERs contain only a single report involving one event (a failure or a command fault), some LERs contained multiple reports, each involving either single or multiple events. For the case where multiple reports existed in the LER, an appropriate one-line data record was created in the data base for each report contained in the LER. For the case where the LER described multiple faults involving like components, information was encoded into the one-line data record to account for the number of events.

A detailed explanation of the coding scheme is given in Appendix B. A discussion of the assumptions and definitions used to encode certain fields within the one-line data record is provided below. The issue of the difference between faults and failures is presented first in order to provide a context for interpreting these fields. Three fields in each one-line data record contain items that are used for identification purposes: NSSS vendor, plant, and LER control number. These items need no explanation other than that provided in Appendix B.

**Fault/Failure.** As defined in the "Nomenclature" section, a fault refers to failures and command faults. A failure implies that a component must be repaired or replaced in order for it to perform as designed. A command fault is an event in which the component of interest does not fail, but is in the wrong state because of external inputs or lack of inputs. An instrument channel failing to provide a trip signal because a technician left a test switch in the wrong position is an example of a command fault.

**Fault Mode.** Initially, a cursory evaluation of the applicable LERs was conducted to ensure that the fault modes defined in this report would encompass the bulk of the LERs. Because of the lack of detailed information in most of the LER fault descriptions, only two fault modes are defined. The fault modes are:

1. Reduced capability
2. Inoperable.

The reduced capability fault mode describes an event in which the I&C component is operational, but does not perform its function within defined limits. Reduced capability implies calibration or adjustment is needed. Instrument drift, out-of-calibration, and intermittent (spurious) conditions are examples of events that are coded reduced capability.

The fault mode, inoperable, is used to describe failure events involving actual failure, meaning component repair or replacement was needed. Command faults, such as a closed sensing-line valve, which prevented a transmitter from measuring a parameter (e.g., pressure and flow), also fall into the inoperable fault mode.

**Fault Cause.** The fault causes used in our report are those stated in the respective LERs, and should be self-explanatory (see Appendix B). The intent is to encode the cause most directly responsible for the event; not necessarily the root cause. Most fault causes were identified by screening the cause description text of the LER. The LER contains a coded fault cause (entered by the utility), but this did not always agree with the cause description contained in the text. When the text and the code disagreed, the fault cause stated in the text was entered in the one-line data record. For example,

if the LER cause field indicated *component failure* when the text stated that instrument drift was the problem, instrument drift was encoded as the cause of failure. It should be noted that for command faults, causes such as *sticking or piece part fault* describe problems with components providing inputs to the faulted I&C component.

**Event Classification (Age or Frequency of Use).**

Each I&C component fault was reviewed to determine if the fault was related to the frequency of use (starts, stops, openings, and closings) of the component or, simply, the age of the component. As the standby time or running time increases, the cumulative chance of an age-related fault increases. The cumulative chance of a frequency-of-use-related fault increases as the number of demands or cycles of the component increases. The number of demands or cycles is not necessarily a linearly-increasing function of time.

Knowing a relationship between age-related and frequency-related faults can aid in establishing or evaluating a testing policy. If frequency-related faults predominate for a particular component, increased testing (which would place more demands on the component) may not be appropriate. Conversely, if age-related faults predominate, increased testing would be appropriate, because as the time interval between tests decreases, so does the chance of a component being unavailable. As an example of how such distinctions were made, a component that faulted because of electronic or electrical piece part deterioration was considered an age-related fault, while a component fault that resulted from a broken linkage arm or handswitch was considered a frequency-of-use-related fault.

All reports involving personnel error were classified as frequency, because it was felt that the probability of these events increased as the number of personnel interactions with the component increased. When a LER did not provide adequate fault cause information to enable the analyst to determine the event classification, unknown was used to classify these events.

The original LERs do not contain a coded field indicating whether a fault is age- or frequency-related, nor is the reporting organization required to provide such an assessment in the text of the LER. Therefore, the code that appears in the one-line summaries is the result of a subjective review of the available information; other analysts may draw different conclusions.

**Type of Event.** Seven types of events are of special interest for risk/reliability consideration:

1. Recurring failure
2. Common cause failure
3. Recurring common cause failure
4. Command fault
5. Recurring command fault
6. Common cause command fault
7. Recurring common cause command fault.

The events not coded as one of these specified types are considered to be *random* failures. In the context of this report, random failures refers to occurrences that do not meet the definitions of the other type of events.

NOTE: In the original version of this report (NUREG/CR-1740, May 1981), only six type of event categories were used (including random). More specifically, no categories were provided for common cause command faults and recurring common cause command faults. One-liners from the 1976 to 1978 time period were screened for this report to provide the added level of detail.

For an event to be considered *recurring*, one plant had to submit more than one LER that identified a failure of the same component or similar components by the same failure cause. In addition, if an individual LER reported that a component had experienced previous failures, the event was coded recurring.

*Common cause* events consist not only of events describing two or more components failing simultaneously, but also include single events where the potential for two or more failures exists. The latter are considered common cause candidates. The common cause candidates were identified, along with the other common cause failures, not only for use in this report but as part of a data gathering effort to provide input into the binomial failure rate (BFR) common cause model.<sup>9</sup> The justification for considering single failures in the BFR model is explained by Atwood. If there was any doubt as to whether an event was common cause or not common cause, then the event was coded as common

cause. If the same common cause event was reported more than once at one plant, this event was coded as *recurring common cause*.

As pointed out earlier, a *command fault* is an event where there is no actual physical failure of the component, but the component is in the wrong state because of factors external to the component. External factors such as failure of a component that interfaces with the faulted component or human error, account for most command faults. A transmitter that is assumed to be monitoring pressure but is inoperable because of a closed sensing-line valve, is considered a command fault event. The transmitter is not *failed* but is *commanded* to be inoperable because of the closed valve. However, if there were any doubts as to whether the fault was a command fault or failure, then the fault was considered a failure. *Recurring command faults* describe events that combine both the criteria for recurring and the concept of command faults. *Common cause command faults* occur when two or more components are affected by a single command fault. An example is "two instrument channels being deenergized at once due to personnel error." When the fault was both recurring and a common cause command fault, the fault was identified as a *recurring common cause command fault*.

**System.** When coding the applicable system, the system receiving the output from the instrument was the system encoded. For example, an instrument that monitors containment pressure often provides input to the reactor trip system. In this case Reactor Trip would be encoded into the system field. In general, most of the LERs reported events that involved the reactor trip system or the Engineered Safety Features Actuation System (ESFAS). It was felt that the ESFAS encompassed too broad a spectrum of systems. Therefore, if it could be determined that the instrument provided input to control systems of specific safety systems, such as High Pressure Coolant Injection (HPCI) or Automatic Depressurization then that specific system was encoded into the system field. If an instrument monitored a variable (temperature or pressure) of a system and the output from that instrument was only used in controlling or monitoring that same system, then the monitored system was encoded into the system field.

**Event Date.** The event date in the one-line data record corresponds to the event date reported in the LER. The LER event date, however, is not

necessarily the date on which the fault occurred. There are instances when a component is discovered faulted and has obviously been faulted for a considerable time. The LER event date actually corresponds to the date the fault was discovered. The event date was assumed to correspond to the date of component fault. Such an assumption, however, does not significantly impact any of the results presented in this report.

**Manufacturer.** The LERs provide a coded field for the manufacturer of a faulted component. However, the manufacturer code in the LER is sometimes missing and sometimes not appropriate for the component coded in the data base. On occasion, the manufacturer given in the LER was not the instruments' manufacturer. References were made in the LER as to the instruments' subcomponent (e.g., seal, resistor, or bellows) or to the failed component that was responsible for the instruments' command fault (e.g., power supply or a leaking valve in a sensing line). Due to these reporting variations no attempt was made to further evaluate the manufacturers reported. However, the codes are available in the data base should a more detailed study of the LERs be undertaken.

**Activity Resulting in Discovery.** Each one-line data record contains a code that indicates the activity taking place that led to the discovery of the event. In some instances, the activity was the cause of the event. Although the original LER contains a specific field for this information, the text of the LER is primarily relied on to obtain this information.

## LER Rate Estimations

Owing to the limited availability of component populations, LER rates are estimated for only those I&C components identified as being part of an instrument channel that performs a reactor trip function. These components are assumed to be in an operational state (energized) at all times, regardless of the status of the reactor; therefore, LER rates in this report are operating fault rates in units of faults per hour. The data necessary to estimate the LER rates are (a) the reactor trip instrument channel and constituent component populations that provide a trip function, (b) the exposure time, and (c) the number of component failures and command faults. These data were obtained for each plant from various sources. The

following discussion presents the assumptions and sources used to arrive at the values for each of these data needs.

**Populations.** A comprehensive source of data from which to obtain all I&C component populations within each plant was not found. However, most of the plants' individual FSARs or the NSSS Vendor Standard Technical Specifications<sup>10-13</sup> gave a listing of reactor trip functions along with the number of sensors and/or channels that provide inputs to each reactor trip function and information that enabled determination of what type of instrument channel, analog or digital, was being used to supply each reactor trip function. From this information, denominators for LER rates for the following five categories of related equipment could be calculated:

1. Sensing devices for analog type channels
  - a. Nuclear core flux
  - b. Temperature detectors
  - c. Flow, level, and pressure transmitters
2. Conditioning systems (a conglomeration of computation modules, summation amplifiers, power supplies, etc.) that receive output from the sensing devices and develop this output for input to comparators or bistables to achieve a desired trip function
3. Comparators and bistables that receive output from the conditioning systems in turn provide inputs to logic matrices, which in turn shutdown the reactor plant
4. Pressure/vacuum and level switches that make up a digital channel
5. Main steam line radiation monitors found in BWR plants.

Components with a reactor trip function fall into instrument channels, as indicated in Table 1. This table shows which type of components and channels are found in reactor trip instrumentation populations for each NSSS vendor. Also shown,

analog radiation channels consist of the single component, radiation monitors, and digital channels contain a single component, switches.

In order to obtain counts for I&C components and channels providing a direct reactor trip function the FSAR information collated by Atwood<sup>2</sup> was used. Counting sensors, conditioning systems, and bistables is straightforward based on Atwood's work. In most cases, the number of channels and conditioning systems is the same. A channel may, however, have more than one conditioning system in cases where several conditioning systems feed each other. In particular, for Babcock & Wilcox plants, reactor outlet temperature and pressure/temperature conditioning systems are combined in considering temperature channels. Most Westinghouse temperature channels are a combination of overpower/ $\Delta T$ , T-average/ $\Delta T$ , and overtemperature/ $\Delta T$  conditioning systems.

**Time.** The exposure time used in estimating the LER rates was the total calendar hours from January 1, 1976, or from the date of initial criticality, whichever is later, to December 31, 1981. All plants that achieved initial criticality before 1976 have an exposure time of 52,608 hours, while plants that achieved initial criticality after 1976 had their exposure time calculated from their respective date of initial criticality to December 31, 1981. Calendar hours are based on a 24-hour day and a 365-day year, which is 8,760 hours in an average year. The additional hours in 1976 and 1980 (leap years) were included where applicable. The dates for plant initial criticality were obtained from the USNRC's "Gray Book."<sup>14</sup>

**Faults.** The number of failures and command faults is contained in the one-line data file. Sorts of this file provided the fault data needed for the various estimates. LER rates using both failures and failures plus command faults were estimated if population data were available. The rates that are computed are based on the 1,886 events that occurred in I&C components and channels identified as providing a direct reactor trip.

In estimating the LER rates for this report, each failure or command fault was assumed to be an individual random event when, in fact, some of the events are suspected to be common cause. It is beyond the scope of this report, however, to treat the common cause events differently when performing LER rate estimates.



**Table 1. I&C reactor trip populations for fault rates<sup>a</sup>**

Components	Channels							
	Analog						Digital	
	Flux	Temperature	Flow	Level	Pressure	Radiation	Level	Pressure
Core Flux Sensors	B	—	—	—	—	—	—	—
	C	—	—	—	—	—	—	—
	W	—	—	—	—	—	—	—
	G	—	—	—	—	—	—	—
Temperature Sensors	—	B	—	—	—	—	—	—
	—	C	—	—	—	—	—	—
	—	W	—	—	—	—	—	—
	—	—	—	—	—	—	—	—
Transmitters	—	—	B	—	B	—	—	—
	—	—	C	C	C	—	—	—
	—	—	W	W	W	—	—	—
	—	—	G	—	—	—	—	—
Conditioning Systems	B	B	B	—	B	—	—	—
	C	C	C	C	C	—	—	—
	W	W	W	W	W	—	—	—
	G	—	G	—	—	—	—	—
Bistables	B	B	B	—	B	—	—	—
	C	C	C	C	C	—	—	—
	W	W	W	W	W	—	—	—
	G	—	G	—	—	—	—	—
Switches	—	—	—	—	—	—	—	B
	—	—	—	—	—	—	—	W
	—	—	—	—	—	—	G	G <sup>b</sup>
	—	—	—	—	—	—	—	—
Radiation Monitors	—	—	—	—	—	—	—	—
	—	—	—	—	—	—	—	—
	—	—	—	—	—	—	—	—
	—	—	—	—	—	G	—	—

a. B = Babcock & Wilcox; C = Combustion Engineering; W = Westinghouse; G = General Electric. The presence of B, C, W, or G indicates that one or more of the corresponding plants has the specified type of reactor trip channel and component.

b. Pressure/vacuum switches.

LER rates were estimated for the following components.

1. Nuclear core flux sensors
2. Temperature sensors
3. Flow, level, and pressure transmitters
4. Signal conditioning systems for flux, temperature, flow, level, and pressure
5. Flux, temperature, flow, level, and pressure comparators and bistables
6. Pressure/vacuum and level switches
7. Radiation monitors.

Also the major components of the analog systems (detectors/sensors, transmitters, conditioning systems, and bistables) were combined, depending upon the parameter they were monitoring, to form an instrument channel. In digital systems, switches were considered a channel.

LER rates were estimated for the following instrument channels.

1. Analog Channels
  - a. Nuclear core flux
  - b. Temperature
  - c. Flow
  - d. Level
  - e. Pressure
2. Digital Channels
  - a. Level switches
  - b. Pressure/vacuum switches.

There was no need to estimate a radiation channel fault rate since a radiation channel consists of the single component, radiation monitor, and a LER rate was estimated for radiation monitors.

In assigning faults for the various parameter-based fault rates some subjectivity was involved in determining in which parameter-based channel the

fault occurred. In most cases a sensor monitoring a particular parameter provides a signal to a conditioning system which in turn provides a signal to a comparator or bistable. However, there are conditioning systems that receive signals from more than one sensor, each sensor monitoring a different parameter. This same conditioning system, may in turn, provide a signal to other conditioning systems or to a comparator or bistable. This case creates a problem in that a fault in this type of conditioning system could be placed in either parameter-based channel that is providing input to the conditioning system. These types of conditioning systems have been identified and an example is shown below, along with the parameter assigned for the purposes of calculating the parameter-based channel fault rates.<sup>a</sup>

Conditioning Systems and Associated Bistables	Parameter Assigned For LER Rate Calculations
<b><i>Babcock &amp; Wilcox Plants</i></b>	
Power to Flow	Flow
Pressure/temperature	Temperature
<b><i>Combustion Engineering Plants</i></b>	
Thermal Margin/low pressure or DNBR	Temperature
<b><i>Westinghouse Plants</i></b>	
Overpower/ $\Delta T$	Temperature
Overtemperature/ $\Delta T$ (Pressurizer provides an input)	Temperature

**Computations.** The computational formulas used to estimate the LER rates are discussed in Appendix C. LER rates for the components and instrument channels were grouped as follows:

1. An LER rate for each licensed operating plant

a. The parameter coded in the one-liner was not used because it was generally an *other/unknown* parameter.

2. An LER rate for each NSSS vendor
3. An LER rate for PWRs and BWRs
4. An overall LER rate based on aggregating the fault data of each licensed operating plant.

In each of the above cases, if no population data were available for a particular fault rate calculation, then the applicable plant, NSSS vendor, or reactor type (PWR or BWR) would be omitted from the calculation.

Chi-square confidence bounds were derived for each fault rate estimate. These confidence bounds apply only when all the components that are combined in an estimate have exactly the same fault rate. When components have different fault rates (e.g., because of individual component variations and different plant environments), the confidence interval describes only the average fault rate, not the individual component fault rates. The main use of these bounds is for comparisons. Narrow bounds apply to estimates that are based on more information (i.e., for a fixed fault rate, more faults and longer exposure times lead to narrow bounds).

## SUMMARY OF RESULTS

Table 2 presents an accounting of the number of LERs used in this report. Of the 6,764 faults in the data file, 6,180 (91%) were classified as actual failures. The remaining 584 were identified as being command faults.

**Table 2. Accounting of I&C LERs**

LERs	Numbers
Total screened	20,027
Total excluded after screening	15,329
Total coded	4,698
Total one-line data records created from the 4,698 LERs (315 LERs contained multiple reports resulting in 394 additional records)	5,092
Number of events contained in the 5,092 one-line data records (732 records contained multiple events resulting in 1,672 additional events)	6,764

### Engineering Data

The main coding fields are presented with emphasis on plants, components, and the type of event. Presented in this engineering data summary are discussions, figures (bar graphs), and tables summarizing pertinent information contained in the data base. In order to provide easier comparisons between variables and faults, the horizontal bar graphs are arranged in increasing order from top to bottom, while vertical bar graphs are arranged in descending order from left to right. Percentages of the total number of faults associated with each variable can be found on each bar graph.

The component faults and fault rates summarized in this report should be interpreted as only tentative gross indicators of true fault trends and fault rates. Because subjective judgments had to be made regarding pertinence of recorded events, and because some component faults may not be

recorded in the LERs, the individual analyst should confirm the applicability of the component faults and fault rates for their specific uses.

### Overview with Focus on Plants

**NSSS Vendor.** Figure 2 is a graph of the 6,764 faults by NSSS vendor. It is evident from Figure 2 that the General Electric (BWR) plants account for the majority (51%) of I&C faults. Refer to Appendix D for one-line sorts by NSSS vendor.

**NOTE:** This engineering data consists of raw fault counts, not adjusted for the number of plants or I&C components associated with each vendor.

**Plant-Specific Data.** Figure 3 presents individual plant faults for all 72 plants in a highly comparative form, while Figures 4 through 7 present the same information, in descending order, grouped by plants within the four NSSS vendors.

Table 3 is grouped by NSSS vendor and presents the 6,180 failures and 584 command faults for each plant by year. Also provided are the calendar hours for each plant so that one may normalize selected data if desired. The dashes, as for Crystal River 3 in 1976, indicate that the plant had not achieved initial criticality.

**Overview with Focus on Components.** In the following sections, breakdowns of the number of faults according to the main coding fields (fault mode and cause, parameter, function, system, event classification, and type of event) and according to the components within these fields are presented.

**Component.** Figure 8 is a graph of the 6,764 faults by component. The seven major components (sensor, transmitter, amplifier, power supply, converter/conditioner, computation module, and comparator/bistable) considered to be in a typical analog type channel totaled 2,282 (34%) of the total 6,764 faults. The single major component of digital type channels, the general switch, accounted for 2,004 (30%) of the total 6,764 faults.

**Fault Mode.** Table 4 presents component fault data by fault mode. The general switch stands out as the component with the largest number of faults. Of the 2,004 general switch faults, 1,533 (77%) and 471 (24%) involved reduced capability and inoperable fault modes, respectively.

LEGEND  
Total 6764  
▨ FAULTS




Figure 2. Summary of I&C faults by NISS.

SSSN





Figure 3. Summary of I&C faults by plant.






Figure 5. Summary of I&C faults for Combustion Engineering plants.






Figure 6. Summary of I&C faults for Westinghouse plants.




Figure 7. Summary of I&C faults for General Electric plants.


Table 3. Summary of I&C failures and command faults by plant and year

Plant Code	Plant Name	1976			1977			1978			1979			1980			1981			Total		
		Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours <sup>a</sup>
<b>BABCOCK &amp; WILCOX</b>																						
AR1	Arkansas Nuclear One 1	2	0	8,784	8	0	8,760	1	0	8,760	1	0	8,760	0	0	8,784	0	1	8,760	12	1	52,608
CR3	Crystal River 3	--	--	--	20	0	8,448	16	0	8,760	27	3	8,760	14	3	8,784	42	9	8,760	119	15	43,512
DB1	Davis-Besse 1	--	--	--	20	1	3,408	54	0	8,760	55	0	8,760	31	7	8,784	28	3	8,760	188	11	38,472
OE1	Oconee 1	1	0	8,784	5	0	8,760	15	8	8,760	12	0	8,760	3	1	8,784	5	0	8,760	41	9	52,608
OE2	Oconee 2	0	0	8,784	4	0	8,760	5	0	8,760	6	0	8,760	1	0	8,784	2	0	8,760	18	0	52,608
OE3	Oconee 3	0	0	8,784	3	1	8,760	9	0	8,760	7	0	8,760	2	1	8,784	3	0	8,760	24	2	52,608
RS1	Rancho Seco 1	4	0	8,784	3	0	8,760	1	0	8,760	1	0	8,760	4	1	8,784	10	1	8,760	23	2	52,608
TI1	Three Mile Island 1	7	2	8,784	1	0	8,760	2	0	8,760	0	0	2,064	--	--	--	--	--	--	10	2	28,368
TI2	Three Mile Island 2	--	--	--	--	--	--	9	0	6,696	2	0	2,064	--	--	--	--	--	--	11	0	8,760
Total Faults		14	2	52,704	64	2	64,416	112	8	76,776	111	3	65,448	55	13	61,488	90	14	61,320	446	42	382,152
<b>COMBUSTION ENGINEERING</b>																						
AR2	Arkansas Nuclear One 2	--	--	--	--	--	3	0	576	36	4	8,760	45	2	8,784	48	2	8,760	132	8	26,952	
CC1	Calvert Cliffs 1	8	1	8,784	32	0	8,760	10	1	8,760	21	0	8,760	18	1	8,784	25	6	8,760	114	9	52,608
CC2	Calvert Cliffs 2	3	0	768	19	0	8,760	13	0	8,760	30	3	8,760	29	1	8,784	21	3	8,760	115	7	44,592
FC1	Fort Calhoun 1	14	0	8,784	15	0	8,760	22	0	8,760	4	1	8,760	13	2	8,784	7	0	8,760	75	3	52,608
MY1	Maize Yankee	8	0	8,784	2	0	8,760	8	0	8,760	17	3	8,760	4	0	8,784	9	2	8,760	48	5	52,608
MI2	Millstone 2	11	0	8,784	13	0	8,760	11	0	8,760	20	0	8,760	8	2	8,784	9	3	8,760	72	5	52,608
PA1	Palisades	10	0	8,784	9	0	8,760	5	0	8,760	2	0	8,760	10	3	8,784	8	0	8,760	44	3	52,608
SL1	St. Lucie 1	2	3	6,096	7	1	8,760	13	1	8,760	16	0	8,760	33	5	8,784	22	1	8,760	93	11	49,920
Total Faults		56	4	50,784	97	1	61,320	85	2	61,968	146	11	70,080	160	16	70,272	149	17	70,080	693	51	384,504
<b>WESTINGHOUSE</b>																						
BV1	Beaver Valley 1	2	4	5,664	37	1	8,760	11	1	8,760	5	1	8,760	28	3	8,784	31	4	8,760	114	14	49,488
DC1	Cook 1	17	1	8,784	14	0	8,760	35	0	8,760	28	8	8,760	8	1	8,784	13	6	8,760	115	16	52,608
DC2	Cook 2	--	--	--	--	--	66	0	7,128	26	0	8,760	21	1	8,784	19	6	8,760	132	7	33,432	
JF1	Farley 1	--	--	--	17	0	3,480	26	1	8,760	32	6	8,760	29	5	8,784	15	5	8,760	119	17	38,544
JF2	Farley 2	--	--	--	--	--	--	--	--	--	--	--	--	--	15	6	5,784	15	6	5,784	6	5,784
RG1	Gona	5	0	8,784	0	0	8,760	0	0	8,760	1	0	8,760	3	0	8,784	4	1	8,760	13	1	52,608
HN1	Haddam Neck	4	0	8,784	6	0	8,760	1	0	8,760	2	0	8,760	3	0	8,784	2	0	8,760	18	0	52,608
IP2	Indian Point 2	8	0	8,784	5	0	8,760	12	0	8,760	2	0	8,760	2	2	8,784	3	1	8,760	32	3	52,608
IP3	Indian Point 3	15	0	6,480	7	0	8,760	7	0	8,760	4	0	8,760	5	0	8,784	0	0	8,760	38	0	50,304
KE1	Kewaunee	10	0	8,784	11	0	8,760	12	0	8,760	11	0	8,760	10	2	8,784	10	0	8,760	64	2	52,608
MG1	McGuire 1	--	--	--	--	--	--	--	--	--	--	--	--	--	24	3	3,504	24	3	3,504	3	3,504
NA1	North Anna 1	--	--	--	--	--	23	0	6,504	47	4	8,760	21	9	8,784	21	3	8,760	112	16	32,808	
NA2	North Anna 2	--	--	--	--	--	--	--	--	--	--	--	56	3	4,872	35	3	8,760	91	6	13,632	
PT1	Point Beach 1	4	0	8,784	1	0	8,760	3	0	8,760	3	1	8,760	0	0	8,784	4	0	8,760	15	1	52,608
PT2	Point Beach 2	2	0	3,784	0	0	8,760	5	4	8,760	1	0	8,760	3	1	8,784	2	0	8,760	13	5	52,608
PR1	Prairie Island 1	8	0	8,784	3	0	8,760	4	1	8,760	3	2	8,760	5	2	8,784	4	0	8,760	27	5	52,608
PR2	Prairie Island 2	6	0	8,784	7	2	8,760	6	0	8,760	3	0	8,760	3	0	8,784	12	0	8,760	37	2	52,608
RO2	Robinson 2	3	0	8,784	0	0	8,760	3	0	8,760	1	2	8,760	12	3	8,784	5	0	8,760	24	5	52,608
SA1	Salem 1	3	0	504	20	1	8,760	17	0	8,760	24	3	8,760	37	3	8,784	37	3	8,760	138	10	44,128
SA2	Salem 2	--	--	--	--	--	--	--	--	--	--	--	1	0	3,504	59	4	8,760	60	4	12,264	
SO1	San Onofre 1	5	0	8,784	0	0	8,760	1	0	8,760	5	0	8,760	3	3	8,784	8	2	8,760	22	5	52,608
SE1	Sequoyah 1	--	--	--	--	--	--	--	--	--	--	--	25	13	4,320	60	11	8,760	85	24	13,080	
SE2	Sequoyah 2	--	--	--	--	--	--	--	--	--	--	--	--	--	3	2	1,368	3	2	1,368	3	1,368
SU1	Surry 1	3	2	8,784	4	0	8,760	4	0	8,760	11	2	8,760	10	10	8,784	20	17	8,760	52	31	52,608
SU2	Surry 2	6	0	8,784	2	0	8,760	2	1	8,760	1	0	8,760	12	6	8,784	8	9	8,760	31	16	52,608

Table 3. (continued)

Plant Code	Plant Name	1976			1977			1978			1979			1980			1981			Total		
		Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours	Failures	Command Faults	Hours <sup>a</sup>
WESTINGHOUSE (continued)																						
TR1	Trojan	3	2	8,784	17	1	8,760	6	0	8,760	4	0	8,760	2	1	8,784	6	3	8,760	38	7	52,608
TU3	Turkey Point 3	2	0	8,784	6	0	8,760	2	0	8,760	4	0	8,760	5	1	8,784	0	2	8,760	19	3	52,608
TU4	Turkey Point 4	2	0	8,784	3	0	8,760	0	0	8,760	1	0	8,760	2	0	8,784	1	0	8,760	9	0	52,608
YR1	Yankee-Rowe 1	0	0	8,784	18	0	8,760	13	4	8,760	12	1	8,760	4	1	8,784	21	0	8,760	68	6	52,608
Z11	Zion 1	22	0	8,784	32	0	8,760	34	0	8,760	35	0	8,760	30	3	8,784	22	2	8,760	175	5	52,608
Z12	Zion 2	26	0	8,784	18	0	8,760	20	0	8,760	22	0	8,760	16	0	8,784	23	2	8,760	125	2	52,608
Total Faults		156	9	179,544	228	5	196,200	313	12	215,112	288	30	219,000	356	73	232,296	487	95	255,936	1,828	224	1,298,088
GENERAL ELECTRIC																						
BP1	Big Rock Point 1	2	0	8,784	4	0	8,760	7	0	8,760	5	0	8,760	17	0	8,784	8	0	8,760	38	0	52,608
BF1	Browns Ferry 1	2	1	8,784	6	2	8,760	11	0	8,760	8	0	8,760	21	4	8,784	4	0	8,760	91	12	52,608
BF2	Browns Ferry 2	6	1	8,784	2	3	8,760	11	0	8,760	15	0	8,760	47	1	8,784	34	8	8,760	115	13	52,608
BF3	Browns Ferry 3	9	1	3,504	3	0	8,760	51	0	8,760	13	0	8,760	40	2	8,784	22	2	8,760	138	5	47,328
BR1	Brunswick 1	3	0	2,040	56	0	8,760	26	0	8,760	62	2	8,760	58	2	8,784	45	8	8,760	250	12	45,864
BR2	Brunswick 2	94	2	8,784	47	0	8,760	28	0	8,760	40	0	8,760	68	0	8,784	71	3	8,760	348	12	52,608
CO1	Cooper Station	14	0	8,784	20	3	8,760	10	0	8,760	5	1	8,760	9	2	8,784	8	1	8,760	66	7	52,608
DA1	Duane Arnold	28	6	8,784	52	0	8,760	12	7	8,760	18	0	8,760	24	3	8,784	16	5	8,760	150	21	52,608
DR1	Dresden 1	2	2	8,784	18	0	8,760	4	0	7,296	—	—	—	—	—	—	—	—	—	24	2	24,840
DR2	Dresden 2	13	0	8,784	22	1	8,760	16	2	8,760	19	0	8,760	16	0	8,784	20	5	8,760	106	9	52,608
DR3	Dresden 3	2	0	8,784	25	1	8,760	20	3	8,760	15	0	8,760	20	0	8,784	23	0	8,760	105	4	52,608
FP1	Fitzpatrick	30	0	8,784	31	1	8,760	23	8	8,760	44	1	8,760	164	21	8,784	44	3	8,760	336	34	52,608
EN1	Hatch 1	29	1	8,784	15	1	8,760	23	0	8,760	14	0	8,760	39	5	8,784	51	12	8,760	171	19	52,608
EN2	Hatch 2	—	—	—	—	—	—	22	5	4,344	48	9	8,760	140	7	8,784	121	18	8,760	331	39	30,648
M11	Millstone 1	19	0	8,784	13	0	8,760	11	0	8,760	17	1	8,760	7	2	8,784	24	2	8,760	91	5	52,608
MO1	Monticello	3	0	8,784	10	0	8,760	8	0	8,760	5	0	8,760	9	2	8,784	4	4	8,760	39	6	52,608
NM1	Nine Mile Point 1	21	0	8,784	30	0	8,760	43	0	8,760	4	0	8,760	6	2	8,784	21	2	8,760	125	4	52,608
OC1	Oyster Creek 1	7	3	8,784	12	0	8,760	15	0	8,760	8	3	8,760	52	4	8,784	44	3	8,760	138	13	52,608
PB2	Peach Bottom 2	26	1	8,784	41	3	8,760	10	1	8,760	14	7	8,760	15	0	8,784	12	6	8,760	118	18	52,608
PB3	Peach Bottom 3	18	0	8,784	21	1	8,760	7	0	8,760	12	1	8,760	9	1	8,784	12	1	8,760	79	4	52,608
PI1	Pilgrim 1	14	0	8,784	16	0	8,760	19	0	8,760	14	0	8,760	15	2	8,784	20	2	8,760	98	4	52,608
QC1	Quad-Cities 1	2	0	8,784	13	0	8,760	18	0	8,760	13	3	8,760	7	2	8,784	13	0	8,760	66	5	52,608
QC2	Quad-Cities 2	10	1	8,784	12	0	8,760	19	0	8,760	32	0	8,760	6	6	8,784	17	1	8,760	96	8	52,608
VY1	Vermont Yankee 1	18	0	8,784	27	0	8,760	11	6	8,760	11	5	8,760	16	0	8,784	11	0	8,760	94	11	52,608
Total Faults		372	19	190,008	496	17	201,480	425	32	204,360	436	33	201,480	805	76	202,032	679	90	201,480	3,213	267	1,200,840

a. Hours are total calendar hours from January 1, 1976 or from the date of initial criticality, whichever is later, to December 31, 1981.

Total 6754 **LEGEND**  
 FAULTS




Figure 8. Summary of I&C faults by component.

**Table 4. Summary of I&C faults by component and fault mode**

Component	Fault Mode		Total Faults
	Reduced Capability	Inoperable	
Amplifier/buffer/isolation amplifier <sup>a</sup>	63	75	138
Cable/receptacle/junction box/terminal <sup>a</sup>	43	183	226
Controller	23	49	72
Comparator (bistable) <sup>a</sup>	216	111	327
Converter/conditioner <sup>a</sup>	74	24	98
General switch <sup>a</sup>	1,533	471	2,004
Hand switch	4	31	35
Computation module <sup>a</sup>	80	144	224
Indicator/meter/annunciator	144	159	303
Computer	4	41	45
Limit switch	34	36	70
Monitor <sup>a</sup>	226	753	979
Power supply <sup>a</sup>	15	212	227
Recorder	21	96	117
Relay/solenoid <sup>a</sup>	61	214	275
Sensor <sup>a</sup>	187	237	424
Timer	10	17	27
Transformer <sup>a</sup>	1	10	11
Transmitter <sup>a</sup>	497	347	844
Other/unspecified <sup>a</sup>	140	178	318
Total Faults	3,376	3,388	6,764

a. This component was analyzed for the LER rates.

Sensing devices (monitors, sensors, transmitters, and general switches) account for 4,251 (63%) of the total faults. Sensing devices comprise 2,443 (72%) of the 3,376 faults coded reduced capability and 1,808 (53%) of the 3,388 coded inoperable. The general switch is the highest contributor to the reduced capability fault mode with 1,533 (45%) of the faults, while the monitor is the highest contributor to the inoperable fault mode with 753 (22%) of the faults.

**Human Factors and Other Fault Causes.** Figure 9 is a graph of faults by fault cause. It is evident from Figure 9 that drift accounted for a major portion (2,349 or 35%) of the faults, while piece part faults are next with 1,090 (16%) of the total faults. There were 930 (14%) faults coded with unknown fault causes.

All faults related to personnel, design, fabrication, construction, quality control, and procedures were considered to fall into a general category of causes called human factors. Human factors account for 1,171 (17%) of all the faults in this report. Of the 1,171 human factor faults, personnel errors during operation, maintenance, and testing account for 596 (51%), while design, fabrication, construction, quality control, and procedural errors account for the remaining 49%. Personnel maintenance is the largest single contributor to human factor faults at 31%, with procedural problems second with 22%. Refer to Appendix E for one-line sorts by human factors.

Table 5 summarizes component faults by fault cause. The general switch stands out with 1,325 (56%) of component drift problems, as well as the monitor with 307 (28%) of piece part faults.

**Fault Mode and Cause.** Table 6 presents component faults by fault cause and mode. Drift faults with the reduced capability mode comprise the majority (2,274 or 67%) of the total reduced capability mode, while inoperable piece part faults comprise the majority (1,033 or 30%) of the total inoperable mode. The general switch contributes 1,308 (58%) faults to the reduced capability drift category, while the monitor contributes 295 (29%) faults to the inoperable piece part failure category.

**Parameter.** Figure 10 summarizes the number of faults by parameter, while Table 7 presents the faults by component and parameter. The numbers here appear to reflect the distribution of com-

ponents used to monitor the various parameters. For example, the component *monitor* in Table 7 has 967 (96%) of its faults under the parameter *radiation*. This is to be expected because the general purpose of a monitor, as used in this report, is to measure radiation.

**Function.** Figure 11 summarizes the number of faults by function. The two functions comprising the reactor protection system (reactor trip and ESF actuation) account for 52% (28% and 24%, respectively) of all faults.

Table 8 presents the number of faults by component and function. Transmitter and general switch faults comprise the majority of the reactor trip function faults at 20% and 18%, respectively. General switch faults comprise 58% of the ESF actuation function faults, with transmitter faults a distant second at 15%. Faults involving indicators, meters, annunciators, recorders, controllers, and computers, which provide a general indication and control function, comprise 469 (28%) of the general control function faults.

**System.** Faults for PWR and BWR systems are presented graphically in Figures 12 and 13. It should be noted that certain systems are applicable to only one reactor type. For example, the Automatic Depressurization System (ADS) is only applicable to BWR reactors.

As explained in the LER classification section, the focus in assigning system codes is on the system receiving the output from the instrumentation. Thus, any component or channel fault that resulted in the loss of a direct reactor trip signal was considered to be in the reactor (RX) trip system, regardless of what plant system the component or channel was monitoring. Where a component or channel could be identified as providing an ESF actuation function or some general control function, the system provided in the LER was coded. For example, if an LER stated, "Channel A failed to provide a signal to isolate the containment," the system coded for this LER was *containment*. If the LER did not provide system information, but from the text of the LER it could be determined that the faulted component or channel did provide an ESF actuation signal when required, *other ESF* was coded for the system.

Table 9 presents faults by component and combined PWR and BWR systems. The reactor trip

Total 6764

LEGEND  
▨ FAULTS




Figure 9. Summary of I&C faults by fault cause.



**Table 5. Summary of I&C faults by component and fault cause**

Component	Fault Cause															Total Faults
	Unknown	Personnel Operation	Personnel Maintenance	Personnel Testing	Design Error	Fabrication/Construction/Quality Control	Defective Procedures	Extreme Environment	Mechanical Malfunction	Electrical Malfunction	Leaking or Blocked Instrument Sensing Lines	Dirty/Binding/Sticking	Piece Part Fault	Drift		
Amplifier/buffer/isolation amplifier	34	8	0	0	0	0	9	1	0	10	0	1	42	33	138	
Cable/receptacle/junction box/terminal	32	6	35	0	2	3	45	5	6	33	0	25	34	0	226	
Controller	23	1	5	0	1	0	2	0	0	3	3	2	25	7	72	
Comparator (bistable)	30	13	15	7	10	0	37	3	0	10	0	5	47	150	327	
Converter/conditioner	13	0	3	0	1	2	6	0	1	3	0	0	8	61	98	
General switch	103	40	98	8	26	23	45	40	57	19	17	125	78	1,325	2,004	
Hand switch	5	4	3	3	2	0	2	0	4	3	0	3	6	0	35	
Computation module	60	5	9	0	10	0	2	6	0	6	0	2	66	58	224	
Indicator/meter/annunciator	92	5	13	2	18	3	10	7	11	13	5	14	36	74	303	
Computer	6	2	1	0	2	0	0	0	0	11	0	2	20	1	45	
Limit switch	11	1	1	0	1	19	0	0	14	2	0	7	7	7	70	
Monitor	66	54	66	7	19	16	31	108	85	74	22	24	307	100	979	
Power supply	75	1	8	2	1	0	8	1	2	22	0	5	96	6	227	
Recorder	14	2	4	0	3	0	1	0	11	2	1	11	64	4	117	
Relay/solenoid	48	2	7	1	18	16	1	22	22	12	0	34	55	37	275	
Sensor	138	9	26	3	6	18	14	18	8	27	8	9	66	74	424	
Timer	7	1	0	0	0	0	0	1	2	0	0	7	2	7	27	
Transformer	0	0	0	0	0	0	0	0	0	1	0	1	8	1	11	
Transmitter	75	12	38	10	47	9	32	59	21	10	77	8	95	351	844	
Other/unspecified	98	0	35	12	12	26	16	2	11	10	6	1	28	53	318	
<b>Total Faults</b>	<b>930</b>	<b>174</b>	<b>367</b>	<b>55</b>	<b>179</b>	<b>135</b>	<b>261</b>	<b>273</b>	<b>255</b>	<b>271</b>	<b>139</b>	<b>286</b>	<b>1,090</b>	<b>2,349</b>	<b>6,764</b>	



Total 6764

LEGEND  
[Cross-hatched box] FAULTS




Figure 10. Summary of I&C faults by parameter.

**Table 7. Summary of I&C faults by component and parameter**

Component	Parameter								Total Faults
	Liquid Level	Core Flux	Flow	Temperature	Radiation	Pressure/ Vacuum	Position	Other/ Unknown	
Amplifier/buffer/ isolation amplifier	6	60	8	20	0	11	27	6	138
Cable/receptacle/ junction box/ terminal	6	111	4	18	1	14	49	23	226
Controller	5	1	28	8	0	9	6	15	72
Comparator (bistable)	56	88	33	20	2	114	0	14	327
Converter/ conditioner	6	2	15	5	0	2	59	9	98
General switch	385	2	179	139	1	1,103	34	161	2,004
Hand switch	0	6	3	4	1	2	1	18	35
Computation module	2	62	53	38	1	15	15	38	224
Indicator/meter/ annunciator	60	22	30	21	2	35	116	17	303
Computer	0	6	3	0	0	0	17	19	45
Limit switch	0	0	0	0	0	3	59	8	70
Monitor	1	2	3	2	967	1	2	1	979
Power supply	13	67	23	13	2	30	35	44	227
Recorder	8	3	9	39	16	12	1	29	117
Relay/solenoid	8	9	18	3	1	13	32	191	275
Sensor	11	151	33	104	6	22	83	14	424
Timer	0	0	0	0	0	3	3	21	27
Transformer	0	0	0	0	1	5	2	3	11
Transmitter	375	0	236	15	0	215	1	2	844
Other/unspecified	24	70	31	16	5	18	54	100	318
<b>Total Faults</b>	<b>966</b>	<b>662</b>	<b>709</b>	<b>465</b>	<b>1,006</b>	<b>1,627</b>	<b>596</b>	<b>733</b>	<b>6,764</b>

Total 6764  
LEGEND  
☒ FAULTS




Figure 11. Summary of I&C faults by function.

**Table 8. Summary of I&C faults by component and function**

Component	Function					Total Faults
	Reactor Trip	ESF Actuation	Reactor Control	General Control	Radiation Detection	
Amplifier/buffer/isolation amplifier <sup>a</sup>	94	4	16	24	0	138
Cable/receptacle/junction box/terminal <sup>a</sup>	121	21	41	43	0	226
Controller	1	7	1	63	0	72
Comparator (bistable) <sup>a</sup>	191	96	6	32	2	327
Converter/conditioner <sup>a</sup>	17	8	45	28	0	98
General switch <sup>a</sup>	337	957	319	390	1	2,004
Hand switch	11	4	4	15	1	35
Computation module <sup>a</sup>	140	40	16	27	1	224
Indicator/meter/annunciator	8	6	31	258	0	303
Computer	0	0	3	42	0	45
Limit switch	39	2	1	28	0	70
Monitor <sup>a</sup>	71	2	1	12	893	979
Power supply <sup>a</sup>	96	55	29	45	2	227
Recorder	0	0	1	106	10	117
Relay/solenoid <sup>a</sup>	95	101	17	61	1	275
Sensor <sup>a</sup>	173	81	41	123	6	424
Timer	0	4	5	18	0	27
Transformer <sup>a</sup>	1	4	2	3	1	11
Transmitter <sup>a</sup>	371	250	1	222	0	844
Other/unspecified <sup>a</sup>	129	16	35	133	5	318
<b>Total Faults</b>	<b>1,895</b>	<b>1,658</b>	<b>615</b>	<b>1,673</b>	<b>923</b>	<b>6,764</b>

a. This component was analyzed for the LER rates.

Total 3284  
 LEGEND  
 ▨ FAULTS




Figure 12. Summary of I&C faults by PWR systems.

Total 3480    LEGEND  
   FAULTS




Figure 13. Summary of I&C faults by BWR systems.



**Table 9. Summary of I&C faults by component and system**

Component	System													Total Faults
	ADS <sup>a</sup>	Condensate and Feed	Containment	CSI	CVCS <sup>b</sup>	HPCI	LPCI	LPCS <sup>a</sup>	RCIC <sup>a</sup>	Reactor Trip	Service Water	Other ESF	All Others	
Amplifier/buffer/ isolation amplifier	0	1	2	0	0	1	0	0	0	94	0	8	32	138
Cable/receptacle/ junction box/ terminal	0	5	1	0	0	1	9	0	4	122	2	12	70	226
Controller	0	2	1	1	0	8	3	0	11	1	1	19	25	72
Comparator (bistable)	1	2	11	4	0	8	0	0	3	194	0	97	7	327
Converter/ conditioner	0	0	2	0	0	1	0	0	1	17	0	8	69	98
General switch	20	24	135	23	1	158	92	67	142	337	11	501	493	2,004
Hand switch	0	1	4	0	0	0	0	0	3	12	0	9	6	35
Computation module	0	9	2	0	0	2	1	1	1	142	0	40	35	224
Indicator/meter/ annunciator	2	11	23	3	1	2	10	0	3	37	2	37	172	303
Computer	0	0	0	0	0	0	0	0	0	0	0	0	45	45
Limit switch	0	0	16	0	0	0	1	0	1	39	1	1	11	70
Monitor	0	0	21	0	0	0	0	0	4	71	0	57	826	979
Power supply	3	8	8	3	0	7	2	2	5	96	0	34	59	227
Recorder	9	0	20	1	5	0	2	0	0	0	0	7	82	117
Relay/solenoid	17	6	13	1	0	7	7	1	4	94	0	68	57	275

Table 9. (continued)

Component	System												Total Faults	
	ADS <sup>a</sup>	Condensate and Feed	Containment	CSI	CVCS <sup>b</sup>	HPCI	LPCI	LPCS <sup>a</sup>	RCIC <sup>a</sup>	Reactor Trip	Service Water	Other ESF		All Others
Sensor	1	5	12	0	5	4	3	0	4	173	0	68	149	424
Timer	3	1	0	0	0	0	0	0	0	0	1	8	14	27
Transformer	0	0	0	0	0	0	0	0	0	1	0	5	5	11
Transmitter	15	15	62	3	8	5	11	0	3	370	12	196	144	844
Other/unspecified	2	6	6	1	1	3	2	0	4	130	0	72	91	318
Total Faults	64	87	339	40	21	207	143	71	193	1,930	30	1,247	2,392	6,764

a. System applicable only to BWR plants.

b. System applicable only to PWR plants.

system comprises the majority (29%) of the faults, with transmitter and general switch faults making up 19% and 17% of this system, respectively.

Appendix F presents the one-line data descriptions by system and reactor type.

**Event Classification.** Table 10 presents the number of faults for each component by event classification. Frequency implies demand-related faults while age implies time-related faults. Frequency accounts for 24% of the total number of faults, while age accounts for 52%. General switch and monitor faults each account for 19% of demand-related faults, while the general switch accounts for 42% of time-related faults.

**Type of Event.** The number of faults for each type of event are presented in Figure 14. Recurring faults (the sum of recurring command faults, recurring common cause command faults, recurring common cause failures, and recurring failures) account for 3,065 (45%) of the total faults. Recurring failures comprise 84% of recurring faults. This is primarily because drift affects nearly all instrumentation on a repeated basis.

Table 11 summarizes the faults by component and type of event. The general switch accounts for 40% and 25% of the recurring and random failures, respectively.

Appendix G presents the one-line descriptions of all types of events. Using the information in this appendix, the analyst can identify the specific kinds of problems that are occurring and also which plants are experiencing these problems.

For the rest of the text, the term recurring will only refer to the recurring failures category, unless otherwise stated.

**Overview with Focus on Type of Event.** Because the type of event classification provides insight for both the causes of faults and how faults relate to each other, breakdowns of the number of faults according to the main coding fields (fault mode and cause, parameter, function, system, and event classification) and according to the type of event within these fields are presented.

**Fault Mode.** Table 12 summarizes faults by type of event and fault mode. For both recurring and random failures, 52% are reduced capability.

Reduced capability contains 43% random failures and 40% recurring failures. Of events in the inoperable fault mode category, 40% are random failures and 37% are recurring failures.

**Fault Cause.** Table 13 summarizes faults by fault cause and type of event. Drift failures involved 45% of the recurring and 41% of the random failures. Piece part failures occurred in 22% and 15% of recurring and random events, respectively.

**Parameter.** Table 14 summarizes faults by type of event and parameter. Recurring failures involved 52% of the radiation faults, while 50% of the temperature faults involved random failures. Random and recurring failures made up 59% and 23% of the other/known parameter.

**Function.** Table 15 summarizes faults by type of event and function. Recurring failures involved 53% of the radiation detection faults. 47% of the general control and 46% of the reactor trip faults involved random failures.

**System.** Table 16 summarizes faults by type of event and system. 63% of the condensate and feed system failures were random, while 56% of the low pressure core spray (LPCS) system failures were recurring.

**Event Classification.** Table 17 summarizes faults by type of event and event classification. Common cause failures comprise 23% of the failures in the frequency event classification; 51% of the age related faults were recurring failures; and random failures occurred in 58% of the unknown event classification faults.

## LER Rates

Appendixes H and I contain the LER rate estimates. These appendixes provide operating<sup>a</sup> LER rate estimates for selected components and instrument channels, respectively, which provide a direct reactor trip. Each appendix contains:

---

a. It should be noted that the term *operating* is used frequently with the status of a reactor plant (operating or shutdown). The use of the word *operating* in the context of *operating fault rate* merely implies that the component the fault rate applies to is assumed to be operational or in an energized state (i.e., versus being in a standby state). I&C components are assumed to be operating at all times, even when the reactor is shutdown.

**Table 10. Summary of I&C faults by component and event classification**

Component	Event Classification			Total Faults
	Frequency	Age	Unknown	
Amplifier/buffer/isolation amplifier	22	67	49	138
Cable/receptacle/junction box/terminal	115	47	64	226
Controller	13	15	44	72
Comparator (bistable)	83	189	55	327
Converter/conditioner	18	63	17	98
General switch	312	1,495	197	2,004
Hand switch	18	8	9	35
Computation module	28	106	90	224
Indicator/meter/annunciator	71	122	110	303
Computer	16	14	15	45
Limit switch	27	26	17	70
Monitor	314	418	247	979
Power supply	42	67	118	227
Recorder	18	62	37	117
Relay/solenoid	97	101	77	275
Sensor	110	171	143	424
Timer	7	11	9	27
Transformer	2	9	0	11
Transmitter	207	470	167	844
Other/unspecified	131	65	122	318
Total Faults	1,651	3,526	1,587	6,764

Total 6764

LEGEND  
⊠ FAULTS




Figure 14. Summary of I&C faults by type of event.

Table 11. Summary of I&C faults by component and type of event

Component	Type of Event								Total Faults
	Random Failure	Recurring Failure	Common Cause Failure	Recurring Common Cause Failure	Command Fault	Recurring Command Fault	Common Cause Command Fault	Recurring Common Cause Command Fault	
Amplifier/buffer/isolation amplifier	76	41	3	18	0	0	0	0	138
Cable/receptacle/junction box/terminal	91	26	65	37	2	0	5	0	226
Controller	50	15	2	0	0	0	5	0	72
Comparator (bistable)	169	67	30	27	8	1	17	8	327
Converter/conditioner	34	48	2	12	0	0	2	0	98
General switch	711	1,040	73	52	21	10	76	21	2,004
Hand switch	21	5	0	0	2	0	7	0	35
Computation module	128	77	8	4	1	1	3	2	224
Indicator/meter/annunciator	158	81	23	8	4	1	16	12	303
Computer	16	24	0	0	3	0	2	0	45

Table 11. (continued)

Component	Type of Event								Total Faults
	Random Failure	Recurring Failure	Common Cause Failure	Recurring Common Cause Failure	Command Fault	Recurring Command Fault	Common Cause Command Fault	Recurring Common Cause Command Fault	
Limit switch	32	14	14	7	0	0	3	0	70
Monitor	240	508	56	57	18	7	33	60	979
Power supply	123	73	5	0	3	1	22	0	227
Recorder	44	65	2	0	2	0	3	1	117
Relay/solenoid	119	99	14	23	2	0	18	0	275
Sensor	244	90	23	9	10	4	41	3	424
Timer	8	17	0	0	1	0	1	0	27
Transformer	5	5	0	0	0	0	0	1	11
Transmitter	416	237	51	62	23	3	25	27	844
Other/unspecified	146	44	84	2	3	6	31	2	318
Total Faults	2,831	2,576	455	318	103	34	310	137	6,764

40

**Table 12. Summary of I&C faults by type of event and fault mode**

Type of Event	Fault Mode		Total Faults
	Reduced Capability	Inoperable	
Random Failure	1,464	1,367	2,831
Recurring Failure	1,336	1,240	2,576
Common Cause Failure	189	266	455
Recurring Common Cause Failure	149	169	318
Command Fault	31	72	103
Recurring Command Fault	18	16	34
Common Cause Command Fault	131	179	310
Recurring Common Cause Command Fault	58	79	137
<b>Total Faults</b>	<b>3,376</b>	<b>3,388</b>	<b>6,764</b>

1. Individual plant data that were used to determine the LER rate estimates (populations, faults, and operating hours) and individual plant LER rate estimates
2. A Final Statistics section that provides a LER rate estimate for each NSSS vendor, an average estimate for PWRs, and an overall average estimate for PWRs and BWRs combined.

For each component type or channel, these two items are provided for both of the fault modes, reduced capability and inoperable, both with and without command faults.

Along with the LER rates, the Final Statistics sections give the upper 95% confidence limit and lower 5% confidence limit expressed as factors of the LER rate point estimate. To obtain the upper 95% confidence limit, multiply the given LER rate point estimate by the upper multiple associated with this estimate. To obtain the corresponding lower 5% confidence limit, divide the LER rate estimate by the lower divisor associated with this point estimate. In other words:

multiply X.X times Y.YE-YY to obtain upper 95% confidence limit

and

divide Z.Z into Y.YE-YY for lower 5% confidence limit

where

X.X = upper 95% confidence multiplier

Y.YE-YY = LER rate point estimate and

Z.Z = lower 5% confidence divisor.

Tables 18 and 19 provide a summary of I&C LER rate estimates (Appendixes H and I) obtained in this report, for selected components and instrument channels, respectively. The upper and lower bounds were determined as indicated above and are provided in these tables; Appendixes H and I, however, contain the multipliers. LER rate estimates without command faults are shown in parentheses. This summary indicates that the small number of command faults had little or no effect on the LER rate



Table 13. Summary of I&C faults by fault cause and type of event

Fault Cause	Type of Event								Total Faults
	Random Failure	Recurring Failure	Common Cause Failure	Recurring Common Cause Failure	Command Fault	Recurring Command Fault	Common Cause Command Fault	Recurring Common Cause Command Fault	
Unknown	694	188	11	0	14	9	13	1	930
Personnel operation	15	1	19	16	11	5	53	54	174
Personnel maintenance	43	18	111	38	18	5	107	27	367
Personnel testing	0	2	9	3	10	0	20	11	55
Design error	26	20	41	47	5	0	23	17	179
Fabrication/ construction/ quality control	21	4	53	24	4	0	22	7	135
Defective procedures	27	2	122	56	6	1	39	8	261
Extreme environment	43	133	20	54	9	4	8	2	273
Mechanical malfunction	101	135	9	2	8	0	0	0	255
Electrical malfunction	136	108	8	5	4	0	9	1	271
Leaking or blocked instrument sensing lines	48	67	13	5	3	0	3	0	139
Dirty, binding, or sticking	99	175	0	0	3	4	5	0	286
Piece part fault	427	571	27	40	7	5	4	9	1,090
Drift	1,151	1,152	12	28	1	1	4	0	2,349
Total Faults	2,831	2,576	455	318	103	34	310	137	6,764

42

Table 14. Summary of I&C faults by type of event and parameter

Type of Event	Parameter								Total Faults
	Liquid Level	Core Flux	Flow	Temperature	Radiation	Pressure/Vacuum	Position	Other/Unknown	
Random Failure	424	294	333	231	255	607	255	432	2,831
Recurring Failure	345	132	236	166	520	778	232	167	2,576
Common Cause Failure	41	107	49	21	57	78	31	71	455
Recurring Common Cause Failure	62	56	29	4	57	49	57	4	318
Command Fault	16	10	23	9	18	18	4	5	103
Recurring Command Fault	8	6	1	0	6	5	2	6	34
Common Cause Command Fault	47	46	24	29	32	73	15	44	310
Recurring Common Cause Command Fault	23	11	14	5	61	19	0	4	137
Total Faults	966	662	709	465	1,006	1,627	596	733	6,764

**Table 15. Summary of I&C faults by type of event and function**

Type of Event	Function					Total Faults
	Reactor Trip	ESF Actuation	Reactor Control	General Control	Radiation Detection	
Random Failure	875	666	271	794	225	2,831
Recurring Failure	569	694	285	541	487	2,576
Common Cause Failure	219	85	16	91	44	455
Recurring Common Cause Failure	89	86	28	60	55	318
Command Fault	18	23	4	40	18	103
Recurring Command Fault	4	12	0	13	5	34
Common Cause Command Fault	97	76	7	99	31	310
Recurring Common Cause Command Fault	24	16	4	35	58	137
Total Faults	1,895	1,658	615	1,673	923	6,764

**Table 16. Summary of I&C faults by type of event and system**

Type of Event	System												Total Faults	
	ADS <sup>a</sup>	Condensate and Feed	Containment	CSI	CVCS <sup>b</sup>	HPCI	LPCI	LPCS <sup>a</sup>	RCIC <sup>a</sup>	Reactor Trip	Service Water	Other ESF		All Others
Random Failure	24	55	138	16	13	69	58	20	65	893	12	549	919	2,831
Recurring Failure	32	11	127	22	4	93	70	40	102	579	15	445	1,036	2,576
Common Cause Failure	1	8	16	2	1	15	6	2	7	223	2	94	78	455
Recurring Common Cause Failure	0	0	15	0	2	7	1	4	11	91	0	66	121	318
Command Fault	2	4	4	0	0	1	2	2	0	19	1	24	44	103
Recurring Command Fault	0	0	4	0	0	1	0	0	0	4	0	9	16	34
Common Cause Command Fault	4	6	24	0	1	20	6	2	8	97	0	52	90	310
Recurring Common Cause Command Fault	1	3	11	0	0	1	0	1	0	24	0	8	88	137
<b>Total Faults</b>	<b>64</b>	<b>87</b>	<b>339</b>	<b>40</b>	<b>21</b>	<b>207</b>	<b>142</b>	<b>71</b>	<b>193</b>	<b>1,930</b>	<b>30</b>	<b>1,247</b>	<b>2,392</b>	<b>6,764</b>

a. System applicable only to BWR plants.

b. System applicable only to PWR plants.

**Table 17. Summary of I&C faults by type of event and event classification**

Type of Event	Event Classification			Total Faults
	Frequency	Age	Unknown	
Random Failure	282	1,622	927	2,831
Recurring Failure	273	1,786	517	2,576
Common Cause Failure	378	26	51	455
Recurring Common Cause Failure	226	53	39	318
Command Fault	66	15	22	103
Recurring Command Fault	13	12	9	34
Common Cause Command Fault	288	9	13	310
Recurring Common Cause Command Fault	125	3	9	137
<b>Total Faults</b>	<b>1,651</b>	<b>3,526</b>	<b>1,587</b>	<b>6,764</b>

estimates. WASH-1400<sup>15</sup> failure rates for "Instrumentation—General," which are comparable to the instrument channel LER rates in this report, are provided (see note on Table 19). The plant-specific data used for the LER rate estimates are provided in Tables 20 and 21.<sup>2</sup> These tables allow the reader to modify the data and corresponding fault rates if known differences exist.

Scatter plots of plant LER rates by vendor and plant are provided in Figures 15a through 28d. These scatter plots present the LER rates for selected components and instrument channels that failed or experienced command faults making the channel inoperable.

These plots illustrate plant-to-plant variability in LER rate estimates within a vendor. An arrow for a lower confidence bound and the comment *lower bound = 0* indicate that the associated point estimate has no recorded faults and has been obtained from Equations C-6 through C-8. The arrows are employed to indicate a zero lower bound since it is impossible to actually show zero on the logarithmic scales used in the following figures. The LER

rate plotted for a plant that reported no faults is the 50% point estimate for that plant (see Appendix C for calculation methodology).

The primary purpose for plotting the bounds is for comparisons. In examining these scatter plots, note that the point estimate of the operating fault rate increases with an increasing number of faults, and the width of the confidence interval decreases. Conversely, a small number of faults will lead to a smaller point estimate with a larger confidence interval (assuming the time is constant). This is because the width of the confidence bounds on a logarithmic scale is sensitive to changes in the number of faults.

The fault data are plotted by increasing fault rates. Scales vary between plots because the scale is automatically adjusted by the fault values associated with the plant having the highest fault rate. Outliers are not necessarily indicators of exceptionally good or bad performers. That is, the plots should not be interpreted at face value without considering some of the underlying causes for LER variations (see Appendix A).

Table 18. Summary of I&C LER rate estimations for components that provide a direct reactor trip

	Babcock & Wilcox			Combustion Engineering			Westinghouse			PWRs			General Electric (BWRs)			Overall		
	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB
Core Flux Sensors																		
Reduced Capability	1.6E-06 (9.8E-07)	3.3E-07 7.4E-08 <sup>b</sup>	1.7E-08 c )	1.4E-06 (1.4E-06)	5.9E-07 3.9E-07	2.0E-07 2.0E-07)	1.1E-06 (5.7E-07)	6.6E-07 4.6E-07	3.7E-07 2.2E-07)	9.0E-07 (7.3E-07)	6.0E-07 4.4E-07	3.8E-07 2.4E-07)	1.5E-07 (1.5E-07)	9.9E-08 9.9E-08	6.2E-08 6.2E-08)	2.1E-07 (2.0E-07)	1.6E-07 1.4E-07)	1.1E-07 1.0E-07)
Inoperable	1.6E-06 (1.6E-06)	3.3E-07 3.3E-07	1.7E-08 1.7E-08)	9.3E-07 (9.3E-07)	3.0E-07 3.0E-07	5.4E-08 5.4E-08)	2.6E-06 (2.2E-06)	2.0E-06 1.6E-06	1.4E-06 1.1E-06)	1.8E-06 (1.3E-06)	1.4E-06 1.1E-06	1.0E-06 7.9E-07)	1.8E-07 (1.7E-07)	1.3E-07 1.2E-07)	8.7E-08 8.0E-08)	3.5E-07 (3.3E-07)	2.9E-07 2.5E-07)	2.2E-07 1.9E-07)
Temperature Sensors																		
Reduced Capability	3.1E-06 (3.1E-06)	6.5E-07 6.5E-07	3.3E-08 3.3E-08)	2.7E-06 (2.7E-06)	1.6E-06 1.6E-06	8.4E-07 8.4E-07)	6.9E-07 (6.9E-07)	2.2E-07 2.2E-07)	3.9E-08 3.9E-08)	1.2E-06 (1.2E-06)	7.4E-07 7.4E-07)	4.4E-07 4.4E-07)	d			1.2E-06 (1.2E-06)	7.4E-07 7.4E-07)	4.4E-07 4.4E-07)
Inoperable	4.0E-06 (4.0E-06)	1.3E-06 2.3E-07)	2.3E-07 2.3E-07)	4.2E-06 (4.2E-06)	2.8E-06 2.8E-06)	1.8E-06 1.8E-06)	1.9E-06 (1.9E-06)	1.1E-06 1.1E-06)	6.1E-07 6.1E-07)	2.4E-06 (2.4E-06)	1.7E-06 1.7E-06)	1.2E-06 1.2E-06)	d			2.4E-06 (2.4E-06)	1.7E-06 1.7E-06)	1.2E-06 1.2E-06)
Transmitters																		
Reduced Capability	7.5E-06 (7.5E-06)	5.2E-06 3.5E-06)	3.5E-06 3.5E-06)	2.6E-06 (2.1E-06)	1.7E-06 1.4E-06)	1.1E-06 9.3E-07)	4.3E-06 (4.2E-06)	3.9E-06 3.8E-06)	3.5E-06 3.5E-06)	3.9E-06 (3.7E-06)	3.5E-06 3.4E-06)	3.2E-06 3.1E-06)	7.4E-07 (7.4E-07)	5.6E-08 <sup>b</sup> 5.6E-08 <sup>b</sup>	c )	3.6E-06 (3.5E-06)	3.3E-06 3.2E-06)	3.0E-06 2.9E-06)
Inoperable	3.4E-06 (3.1E-06)	2.0E-06 1.7E-06)	1.1E-06 8.5E-07)	1.9E-06 (1.8E-06)	1.1E-06 1.1E-06)	6.5E-07 6.5E-07)	2.8E-06 (2.4E-06)	2.3E-06 2.0E-06)	1.9E-06 1.7E-06)	2.4E-06 (2.2E-06)	2.0E-06 1.8E-06)	1.7E-06 1.5E-06)	7.4E-07 (7.4E-07)	5.6E-08 <sup>b</sup> 5.6E-08 <sup>b</sup>	c )	2.3E-06 (2.0E-06)	1.9E-06 1.7E-06)	1.6E-06 1.4E-06)
Conditioning Systems																		
Reduced Capability	5.5E-06 (4.6E-06)	3.9E-06 3.2E-06)	2.8E-06 2.4E-06)	3.1E-06 (3.1E-06)	2.2E-06 2.2E-06)	1.6E-06 1.6E-06)	1.3E-06 (1.1E-06)	9.3E-07 8.8E-07)	7.2E-07 6.8E-07)	1.7E-06 (1.6E-06)	1.4E-06 1.3E-06)	1.2E-06 1.1E-06)	3.6E-06 (3.6E-06)	3.0E-06 3.0E-06)	2.5E-06 2.5E-06)	2.0E-06 (1.9E-06)	1.8E-06 1.7E-06)	1.6E-06 1.5E-06)
Inoperable	1.7E-06 (1.7E-06)	9.2E-07 9.2E-07)	4.4E-07 4.4E-07)	8.9E-06 (8.6E-06)	7.3E-06 7.2E-06)	6.1E-06 6.0E-06)	2.6E-06 (2.5E-06)	2.2E-06 2.1E-06)	1.8E-06 1.8E-06)	3.2E-06 (3.0E-06)	2.9E-06 2.7E-06)	2.6E-06 2.5E-06)	6.1E-06 (5.9E-06)	5.1E-06 4.9E-06)	4.3E-06 4.1E-06)	3.7E-06 (3.5E-06)	3.4E-06 3.2E-06)	3.1E-06 2.9E-06)
Isolables																		
Reduced Capability	2.2E-06 (6.1E-07)	1.3E-06 1.3E-07)	7.2E-07 6.7E-09)	2.5E-06 (2.7E-06)	1.6E-06 1.9E-06)	1.3E-06 1.3E-06)	9.4E-07 (8.6E-07)	7.2E-07 6.6E-07)	5.5E-07 5.1E-07)	1.2E-06 (9.5E-07)	9.8E-07 7.9E-07)	8.2E-07 6.6E-07)	2.7E-06 (2.7E-06)	2.1E-06 2.1E-06)	1.6E-06 1.6E-06)	1.4E-06 (1.3E-06)	1.2E-06 1.1E-06)	1.0E-06 9.2E-07)
Inoperable	1.0E-06 (1.0E-06)	3.9E-07 3.9E-07)	1.1E-07 1.1E-07)	1.5E-06 (1.5E-06)	8.9E-07 8.9E-07)	4.9E-07 4.9E-07)	7.5E-07 (6.0E-07)	5.8E-07 4.3E-07)	4.5E-07 3.1E-07)	7.9E-07 6.5E-07)	6.1E-07 5.0E-07)	4.7E-07 3.8E-07)	3.9E-07 (3.9E-07)	1.5E-07 1.5E-07)	4.1E-08 4.1E-08)	6.8E-07 (5.6E-07)	5.2E-07 4.3E-07)	4.0E-07 3.3E-07)
Switches																		
Reduced Capability	7.8E-06 (7.8E-06)	3.9E-06 3.9E-06)	1.7E-06 1.7E-06)	d	d	d	1.6E-06 (1.6E-06)	5.2E-07 5.2E-07)	9.3E-08 9.3E-08)	2.7E-06 (2.7E-06)	1.5E-06 1.5E-06)	7.5E-07 7.5E-07)	9.5E-06 (8.8E-06)	8.6E-06 8.0E-06)	7.8E-06 7.3E-06)	8.3E-06 (7.8E-06)	7.5E-06 7.1E-06)	6.8E-06 6.5E-06)
Inoperable	3.1E-06 (3.1E-06)	6.5E-07 6.5E-07)	3.3E-08 3.3E-08)	d	d	d	7.8E-07 (7.8E-07)	5.9E-08 <sup>b</sup> 5.9E-08 <sup>b</sup>	c )	8.9E-07 (8.9E-07)	1.9E-07 1.9E-07)	9.7E-09 9.7E-09)	1.4E-06 (1.3E-06)	1.1E-06 1.0E-06)	7.9E-07 7.1E-07)	1.3E-06 (1.2E-06)	1.0E-06 8.9E-07)	7.7E-07 6.4E-07)
Radiation Monitors																		
Reduced Capability	d	d	d	d	d	d	d	d	d	d	d	d	1.2E-05 (1.2E-05)	9.6E-06 9.1E-06)	7.4E-06 7.0E-06)	1.2E-05 (1.2E-05)	9.6E-06 9.1E-06)	7.4E-06 7.0E-06)
Inoperable	d	d	d	d	d	d	d	d	d	d	d	d	8.4E-06 (7.8E-06)	6.0E-06 5.6E-06)	4.3E-06 4.0E-06)	8.4E-06 (7.8E-06)	6.0E-06 5.6E-06)	4.3E-06 4.0E-06)

a. Numbers in parentheses are LER rates without common faults.

b. Denotes 50% point estimate when no faults are recorded.

c. Denotes no lower bound.

d. Not applicable—no populations or faults.

CF = Core Flux, F = Flow, L = Level, LB = Lower Bound, P = Pressure, P/V = Pressure/Vacuum, T = Temperature, UB = Upper Bound

**Table 19. Summary of I&C LER rate estimations for instrument channels that provide a direct reactor trip**

	Babcock & Wilcox			Combustion Engineering			Westinghouse			PWRs			General Electric (BWRs)			Overall		
	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB	UB	Estimate	LB
<b>Analog Channels</b>																		
<b>Core Flux</b>																		
Reduced Capability	2.6E-05	2.0E-05	1.4E-05	8.4E-06	5.6E-06	3.5E-06	4.6E-06	3.5E-06	2.5E-06	6.8E-06	5.7E-06	4.8E-06	7.1E-06	5.9E-06	4.9E-06	6.4E-06	5.8E-06	5.3E-06
Inoperable	5.2E-06	2.0E-06	5.4E-07	2.5E-05	1.9E-05	1.5E-05	3.1E-05	9.1E-06	7.6E-06	1.1E-05	1.0E-05	8.3E-06	8.2E-06	6.8E-06	5.7E-06	9.0E-06	8.2E-06	7.5E-06
<b>Temperature</b>																		
Reduced Capability	3.1E-06	6.5E-07	3.3E-08	2.0E-05	1.3E-05	8.7E-06	8.8E-06	6.8E-06	4.9E-06	8.8E-06	6.8E-06	5.2E-06	b	b	b	8.8E-06	6.8E-06	5.2E-06
Inoperable	7.8E-06	3.9E-06	1.7E-06	3.6E-05	2.8E-05	2.2E-05	1.6E-05	1.2E-05	9.2E-06	1.7E-05	1.4E-05	1.2E-05	b	b	b	1.7E-05	1.4E-05	1.2E-05
<b>Flow</b>																		
Reduced Capability	1.5E-05	1.0E-05	6.3E-06	1.7E-05	1.1E-05	6.9E-06	5.3E-06	4.4E-06	3.7E-06	6.4E-06	5.3E-06	4.4E-06	6.8E-06	4.0E-06	2.1E-06	6.2E-06	5.2E-06	4.3E-06
Inoperable	9.4E-06	5.2E-06	2.6E-06	1.3E-05	7.7E-06	4.3E-06	5.4E-06	4.5E-06	3.8E-06	5.8E-06	4.8E-06	4.0E-06	3.4E-06	1.3E-06	3.5E-07	5.4E-06	4.5E-06	3.8E-06
<b>Level</b>																		
Reduced Capability	b	b	b	1.4E-05	8.5E-06	5.0E-06	7.8E-06	6.5E-06	5.4E-06	8.0E-06	6.7E-06	5.6E-06	b	b	b	8.0E-06	6.7E-06	5.6E-06
Inoperable	b	b	b	6.0E-06	2.6E-06	9.0E-07	5.6E-06	4.7E-06	3.9E-06	5.4E-06	4.5E-06	3.8E-06	b	b	b	5.4E-06	4.5E-06	3.8E-06
<b>Pressure</b>																		
Reduced Capability	1.8E-05	1.2E-05	8.0E-06	6.3E-06	4.2E-06	2.8E-06	1.4E-05	1.1E-05	8.5E-06	9.8E-06	8.2E-06	6.8E-06	b	b	b	9.8E-06	8.2E-06	6.8E-06
Inoperable	7.8E-06	3.9E-06	1.7E-06	6.6E-06	4.7E-06	3.1E-06	6.6E-06	4.7E-06	3.1E-06	6.0E-06	4.6E-06	3.5E-06	b	b	b	6.0E-06	4.6E-06	3.5E-06
<b>Digital Channels</b>																		
<b>Level</b>																		
Reduced Capability	b	b	b	b	b	b	b	b	b	b	b	b	1.0E-05	8.3E-06	6.9E-06	1.0E-05	8.3E-06	6.9E-06
Inoperable	b	b	b	b	b	b	b	b	b	b	b	b	3.8E-06	2.7E-06	1.9E-06	3.8E-06	2.7E-06	1.9E-06
<b>Pressure</b>																		
Reduced Capability	7.8E-06	3.9E-06	1.7E-06	b	b	b	1.6E-06	5.2E-07	9.3E-08	2.7E-06	1.5E-06	7.5E-07	9.6E-06	8.7E-06	7.9E-06	8.0E-06	7.3E-06	6.6E-06
Inoperable	3.1E-06	6.5E-07	3.3E-08	b	b	b	7.8E-07	5.9E-08 <sup>c</sup>	d	8.9E-07	1.9E-07	9.7E-09	8.0E-07	4.7E-07	2.6E-07	7.0E-07	4.1E-07	2.3E-07

a. Numbers in parentheses are LER rates without command faults.

b. Not applicable—no population or faults.

c. Denotes 50% point estimate—seen no faults are recorded.

d. Denotes no lower bound.

Note: WASH-1400 failure rates for instrumentation—General (includes transmitter, amplifier, and output device).

Failure to operate  $1 \times 10^{-6}/hr$  (comparable to fault mode Inoperable)

Shift in calibration  $3 \times 10^{-5}/hr$  (comparable to fault mode Reduced Capability).

UB = Upper Bound, LB = Lower Bound.

Table 20. Summary of input data for LER rate estimations for components

Babcock & Wilcox Plants



Analog  
 Digital

				Fault Modes			
				Reduced Capability		Inoperable	
Component				Command Faults	Failures	Command Faults	Failures
				Component Population	Hours Per Component		
Arkansas 1	AR1		Core Flux Sensors	8	52608		
			Temperature Sensors	4	52608		
			Transmitters	12	52608		
			Conditioning Systems	20	52508	1	
			Comparators/Bistables	20	52608		
	<input checked="" type="checkbox"/>	Switches	4	52608		1	
Crystal River 3	CR3		Core Flux Sensors	8	43512	1	
			Temperature Sensors	4	43512		
			Transmitters	12	43512		12
			Conditioning Systems	20	43512	4	3
			Comparators/Bistables	20	43512		
	<input checked="" type="checkbox"/>	Switches	4	43512		1	
Davis-Besse 1	DB1		Core Flux Sensors	8	38472		
			Temperature Sensors	4	38472		
			Transmitters	12	38472		
			Conditioning Systems	20	38472		
			Comparators/Bistables	20	38472		
	<input checked="" type="checkbox"/>	Switches	4	38472			3



Table 20. (continued)

Babcock & Wilcox Plants (continued)

 Analog  
 Digital




				Fault Modes			
				Reduced Capability		Inoperable	
Component				Command Faults	Failures	Command Faults	Failures
				Component Population	Hours Per Component		
Oconee 1	OE1	Core Flux Sensors	8	52608			
		Temperature Sensors	4	52608			
		Transmitters	12	52608		1	
		Conditioning Systems	20	52608		13	
		Comparators/Bistables	20	52608	8		
	 Switches	4	52608		3		1
Oconee 2	OE2	Core Flux Sensors	8	52608			
		Temperature Sensors	4	52608			
		Transmitters	12	52608		2	
		Conditioning Systems	20	52608			
		Comparators/Bistables	20	52608			
	 Switches	4	52608		1		1
Oconee 3	OE3	Core Flux Sensors	8	52608			
		Temperature Sensors	4	52608		1	
		Transmitters	12	52608		1	1
		Conditioning Systems	20	52608		8	
		Comparators/Bistables	20	52608		1	
	 Switches	4	52608				1

Table 20. (continued)



Babcock & Wilcox Plants (continued)

Analog  
 Digital

Plant	System	Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Rancho Seco 1	RS1	Core Flux Sensors	8	52608				
		Temperature Sensors	4	52608				
		Transmitters	12	52608		6		2
		Conditioning Systems	20	52608		1		
		Comparators/Bistables	20	52608	1			
	Switches	4	52608					
Three Mile Is. 1	TI1	Core Flux Sensors	8	28368				
		Temperature Sensors	4	28368				
		Transmitters	12	28368		2		1
		Conditioning Systems	20	28368				2
		Comparators/Bistables	20	28368				
	Switches	4	28368					
Three Mile Is. 2	TI2	Core Flux Sensors	8	8760				1
		Temperature Sensors	4	8760				
		Transmitters	12	8760				
		Conditioning Systems	20	8760				
		Comparators/Bistables	20	8760				
	Switches	4	8760					

Table 20. (continued)



Combustion Engineering Plants<sup>d</sup>

 Analog  
 Digital

				Fault Modes			
				Reduced Capability		Inoperable	
Component <sup>e</sup>				Command Faults	Failures	Command Faults	Failures
				Component Population	Hours Per Component		
Arkansas 2	AR2		Core Flux Sensors	12	26952		
			Temperature Sensors	16	26952		
			Transmitters	28	26952		
			Conditioning Systems	32	26952		2
			Comparators/Bistables	36	26952		4
Calvert Cliffs 1	CC1		Core Flux Sensors	20	52608		
			Temperature Sensors	16	52608		6
			Transmitters	32	52608		2
			Conditioning Systems	32	52608		9
			Comparators/Bistables	32	52608		3
Calvert Cliffs 2	CC2		Core Flux Sensors	20	44592		1
			Temperature Sensors	16	44592		6
			Transmitters	32	44592		
			Conditioning Systems	32	44592		7
			Comparators/Bistables	32	44592		1
						1	20

Table 20. (continued)



Combustion Engineering Plants<sup>a</sup> (continued)

 Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
		Component Population	Hours Per Component					
Fort Calhoun 1	FC1	Core Flux Sensors	20	52608				
		Temperature Sensors	16	52608				2
		Transmitters	32	52608		1		1
		Conditioning Systems	32	52608		3	1	15
		Comparators/Bistables	32	52608		1		3
Millstone 2	MI2	Core Flux Sensors	20	52608		2		
		Temperature Sensors	16	52608		1		
		Transmitters	32	52608		5		3
		Conditioning Systems	32	52608		1		18
		Comparators/Bistables	32	52608	2	9		
Maine Yankee	MY1	Core Flux Sensors	16	52608				1
		Temperature Sensors	6	52608				2
		Transmitters	44	52608		1		2
		Conditioning Systems	32	52608		3		16
		Comparators/Bistables	36	52608	1			1

Table 20. (continued)

Combustion Engineering Plants<sup>a</sup> (continued)

 Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Palisades	PA1	Core Flux Sensors	10	52608				
		Temperature Sensors	16	52608				
		Transmitters	28	52608		1		3
		Conditioning Systems	26	52608		2		
		Comparators/Bistables	26	52608		5		
St. Lucie 1	SL1	Core Flux Sensors	20	49920				
		Temperature Sensors	16	49920		3		
		Transmitters	32	49920		1		3
		Conditioning Systems	32	49920				
		Comparators/Bistables	32	49920		6		6

Table 20. (continued)

Westinghouse Plants

Analog  
 Digital

				Fault Modes				
				Reduced Capability		inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Beaver Valley 1	BV1	<input type="checkbox"/>	Core Flux Sensors	12	49488		1	
		<input type="checkbox"/>	Temperature Sensors	6	49488		1	
		<input type="checkbox"/>	Transmitters	36	49488		1	5
		<input type="checkbox"/>	Conditioning Systems	47	49488		4	15
		<input type="checkbox"/>	Comparators/Bistables	50	49488		3	
	<input checked="" type="checkbox"/>	Switches	3	49488				
Cook 1	DC1	<input type="checkbox"/>	Core Flux Sensors	12	52608			8
		<input type="checkbox"/>	Temperature Sensors	8	52608			3
		<input type="checkbox"/>	Transmitters	47	52608		11	9
		<input type="checkbox"/>	Conditioning Systems	59	52608		3	7
		<input type="checkbox"/>	Comparators/Bistables	59	52608	1	1	4
	<input checked="" type="checkbox"/>	Switches	3	52608				
Cook 2	DC2	<input type="checkbox"/>	Core Flux Sensors	12	33432			2
		<input type="checkbox"/>	Temperature Sensors	8	33432			1
		<input type="checkbox"/>	Transmitters	47	33432		6	7
		<input type="checkbox"/>	Conditioning Systems	59	33432		1	2
		<input type="checkbox"/>	Comparators/Bistables	59	33432		2	3
	<input checked="" type="checkbox"/>	Switches	3	33432				



Table 20. (continued)

Westinghouse Plants (continued)

		Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Haddam Neck	HN1	Core Flux Sensors	8	52608				1
		Temperature Sensors	8	52608				
		Transmitters	18	52608		1		2
		Conditioning Systems	24	52608		1		
		Comparators/Bistables	23	52608		2		
	Switches	4	52608					
Indian Point 2	IP2	Core Flux Sensors	12	52608			1	
		Temperature Sensors	8	52608				1
		Transmitters	47	52608		1		1
		Conditioning Systems	59	52608		3		1
		Comparators/Bistables	58	52608				
	Switches	3	52608					
Indian Point 3	IP3	Core Flux Sensors	12	50304				1
		Temperature Sensors	8	50304				1
		Transmitters	47	50304				2
		Conditioning Systems	59	50304		7		1
		Comparators/Bistables	58	50304		1		
	Switches	3	50304					

Table 20. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital



















				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Farley 1	JF1	 Core Flux Sensors	12	38544		1	2	
		 Temperature Sensors	6	38544				
		 Transmitters	36	38544		1	1	2
		 Conditioning Systems	47	38544		5		7
		 Comparators/Bistables	50	38544	2	6	1	2
	 Switches	3	38544					
Farley 2	JF2	 Core Flux Sensors	12	5734				
		 Temperature Sensors	6	5734				
		 Transmitters	36	5734		2	2	
		 Conditioning Systems	47	5734				1
		 Comparators/Bistables	50	5734				2
	 Switches	3	5734					
Kewaunee	KE1	 Core Flux Sensors	12	52608			1	
		 Temperature Sensors	8	52608				
		 Transmitters	27	52608		27		5
		 Conditioning Systems	43	52608				
		 Comparators/Bistables	46	52608		3		
	 Switches	3	52608					





Table 20. (continued)

Westinghouse Plants (continued)

		Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
McGuire 1	MG1	Core Flux Sensors	12	3504				
		Temperature Sensors	8	3504				
		Transmitters	47	3504			1	2
		Conditioning Systems	59	3504		1	1	4
		Comparators/Bistables	59	3504				
		Switches	3	3504				
North Anna 1	NA1	Core Flux Sensors	12	32808		2		1
		Temperature Sensors	6	32808				1
		Transmitters	36	32808	6	10	1	2
		Conditioning Systems	47	32808	2	2	1	8
		Comparators/Bistables	50	32808	1			
		Switches	3	32808		1		
North Anna 2	NA2	Core Flux Sensors	12	13632		1		
		Temperature Sensors	6	13632				1
		Transmitters	36	13632		7		
		Conditioning Systems	47	13632	1	5		5
		Comparators/Bistables	50	13632		3		1
		Switches	3	13632				

Table 20. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital




				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Prairie Island 1	PR1	Core Flux Sensors	12	52608	2	2	1	3
		Temperature Sensors	8	52608				
		Transmitters	27	52608				
		Conditioning Systems	43	52608				
		Comparators/Bistables	46	52608				
	 Switches	3	52608					
Prairie Island 2	PR2	Core Flux Sensors	12	52608		4		1
		Temperature Sensors	8	52608				
		Transmitters	27	52608				
		Conditioning Systems	43	52608				
		Comparators/Bistables	46	52608				
	 Switches	3	52608					
Point Beach 1	PT1	Core Flux Sensors	12	52608				2
		Temperature Sensors	8	52608				
		Transmitters	27	52608				
		Conditioning Systems	43	52608				
		Comparators/Bistables	46	52608				
	 Switches	3	52608					

Table 20. (continued)



Westinghouse Plants (continued)

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Point Beach 2	PT2	Core Flux Sensors	12	52608				1
		Temperature Sensors	8	52608				
		Transmitters	27	52608		1		
		Conditioning Systems	43	52608				2
		Comparators/Bistables	46	52608		1		
		Switches	3	52608				
Ginna	RG1	Core Flux Sensors	12	52608				
		Temperature Sensors	8	52608				
		Transmitters	27	52608		1		
		Conditioning Systems	43	52608				2
		Comparators/Bistables	46	52608				
		Switches	3	52608				
Robinson 2	RO2	Core Flux Sensors	12	52608	1		1	1
		Temperature Sensors	6	52608				1
		Transmitters	36	52608				
		Conditioning Systems	47	52608			2	1
		Comparators/Bistables	50	52608				1
		Switches	3	52608				

Table 20. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital




				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Salem 1	SA1	Core Flux Sensors	12	44328				
		Temperature Sensors	8	44328				
		Transmitters	47	44328		6	1	9
		Conditioning Systems	59	44328		4	1	19
		Comparators/Bistables	59	44328		1		4
		Switches	3	44328				
Salem 2	SA2	Core Flux Sensors	12	12254				1
		Temperature Sensors	8	12254				
		Transmitters	47	12254		2		9
		Conditioning Systems	59	12254				3
		Comparators/Bistables	59	12254				
		Switches	3	12254				
Sequoyah 1	SE1	Core Flux Sensors	12	13080				
		Temperature Sensors	8	13080				
		Transmitters	47	13080		4	6	10
		Conditioning Systems	59	13080		1	1	1
		Comparators/Bistables	59	13080		2	2	2
		Switches	3	13080				

Table 20. (continued)

Westinghouse Plants (continued)

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Sequoyah 2	SE2	<input type="checkbox"/>	Core Flux Sensors	12	1368			
		<input type="checkbox"/>	Temperature Sensors	8	1368			
		<input type="checkbox"/>	Transmitters	47	1368			
		<input type="checkbox"/>	Conditioning Systems	59	1368			1
		<input type="checkbox"/>	Comparators/Bistables	59	1368			1
		<input checked="" type="checkbox"/>	Switches	3	1368			
San Onofre 1	SO1	<input type="checkbox"/>	Core Flux Sensors	8	52608			
		<input type="checkbox"/>	Temperature Sensors	6	52608			
		<input type="checkbox"/>	Transmitters	15	52608			1
		<input type="checkbox"/>	Conditioning Systems	21	52608			4
		<input type="checkbox"/>	Comparators/Bistables	21	52608		6	
		<input checked="" type="checkbox"/>	Switches	4	52608			
Surry 1	SU1	<input type="checkbox"/>	Core Flux Sensors	12	52608			
		<input type="checkbox"/>	Temperature Sensors	6	52608			
		<input type="checkbox"/>	Transmitters	36	52608		8	
		<input type="checkbox"/>	Conditioning Systems	47	52608			1
		<input type="checkbox"/>	Comparators/Bistables	50	52608			2
		<input checked="" type="checkbox"/>	Switches	3	52608			

Table 20. (continued)

Westinghouse Plants (continued)

Analog  
 Digital

		Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
Plant	Unit				Command Faults	Failures	Command Faults	Failures
Surry 2	SU2	Core Flux Sensors	12	52608				
		Temperature Sensors	6	52608		1		
		Transmitters	36	52608		2		1
		Conditioning Systems	47	52608		2		2
		Comparators/Bistables	50	52608		1		2
			Switches	3	52608			
Trojan	TR1	Core Flux Sensors	12	52608			2	2
		Temperature Sensors	8	52608				
		Transmitters	47	52608		11		1
		Conditioning Systems	59	52608			1	1
		Comparators/Bistables	67	52608		1		
			Switches	3	52608		1	
Turkey Point 3	TU3	Core Flux Sensors	12	52608				
		Temperature Sensors	6	52608				
		Transmitters	36	52608				
		Conditioning Systems	47	52608				
		Comparators/Bistables	50	52608		3	2	3
			Switches	3	52608			

Table 20. (continued)

Westinghouse Plants (continued)

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Turkey Point 4	TU4	Core Flux Sensors	12	52608				
		Temperature Sensors	6	52608				
		Transmitters	36	52608				
		Conditioning Systems	47	52608				
		Comparators/Bistables	50	52608				1
	<input checked="" type="checkbox"/>	Switches	3	52608				
Yankee-Rowe 1	YR1	Core Flux Sensors	12	52608				
		Temperature Sensors <sup>b</sup>						
		Transmitters <sup>b</sup>						
		Conditioning Systems	3	52608				
	Comparators/Bistables	3	52608					
<input checked="" type="checkbox"/>	Switches <sup>b</sup>							
Zion 1	Z11	Core Flux Sensors	12	52608				
		Temperature Sensors	8	52608				
		Transmitters	47	52608		33		12
		Conditioning Systems	59	52608		7		11
		Comparators/Bistables	59	52608		2		
	<input checked="" type="checkbox"/>	Switches	3	52608				

Table 20. (continued)

Westinghouse Plants (continued)



Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Zion 2	Z12	Core Flux Sensors	12	52608				2
		Temperature Sensors	8	52608				
		Transmitters	47	52608		26		6
		Conditioning Systems	59	52608		4		12
		Comparators/Bistables	59	52608		1		2
			Switches	3	52608			



Table 20. (continued)

General Electric Plants

 Analog  
 Digital









				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Browns Ferry 1	BF1		Core Flux Sensors	188	52608			
			Transmitters	4	52608			
			Radiation Monitors	4	52608		1	
			Conditioning Systems	20	52608			
			Comparators/Bistables	18	52608			
			Switches	28	52608		16	1 3
Browns Ferry 2	BF2		Core Flux Sensors	188	52608			
			Transmitters	4	52608			
			Radiation Monitors	4	52608		4	3
			Conditioning Systems	20	52608			4
			Comparators/Bistables	18	52608			
			Switches	28	52608	7	21	4
Browns Ferry 3	BF3		Core Flux Sensors	188	47328			
			Transmitters	4	47328			
			Radiation Monitors	4	47328		1	
			Conditioning Systems	20	47328		1	45
			Comparators/Bistables	18	47328			
			Switches	28	47328		24	2 2

Table 20. (continued)

General Electric Plants (continued)

 Analog  
 Digital






				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Big Rock Point 1	BP1	Core Flux Sensors Transmitters <sup>b</sup>	8	52608				
		Radiation Monitors <sup>b</sup>						
		Conditioning Systems Comparators/Bistables	8	52608				1
		Switches	8	52608				
		Switches	16	52608		1		
Brunswick 1	BR1	Core Flux Sensors Transmitters	140	45864		1		2
		Radiation Monitors	4	45864				2
		Conditioning Systems	4	45864		11		2
		Comparators/Bistables	20	45864		3		2
		Comparators/Bistables	18	45864		9		
		Switches	24	45864		8		2
Brunswick 2	BR2	Core Flux Sensors Transmitters	140	52608		1		1
		Radiation Monitors	4	52608				2
		Conditioning Systems	4	52608		3		
		Comparators/Bistables	20	52608		1	4	10
		Comparators/Bistables	18	52608				
		Switches	28	52608		33		

Table 20. (continued)

General Electric Plants (continued)

 Analog  
 Digital






				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Cooper Station	CO1	Core Flux Sensors	140	52608		1		1
		Transmitters	4	52608				
		Radiation Monitors	4	52608		1		
		Conditioning Systems	20	52608		3		2
		Comparators/Bistables	18	52608				
	 Switches	24	52608			4		3
Duane Arnold	DA1	Core Flux Sensors	98	52608		1		1
		Transmitters	4	52608				
		Radiation Monitors	4	52608				1
		Conditioning Systems	18	52608		4		4
		Comparators/Bistables	16	52608		2		
	 Switches	24	52608					
Dresden 1	DR1	Core Flux Sensors	9	24840		1		
		Transmitters <sup>b</sup>						
		Radiation Monitors <sup>b</sup>	9	24840		12		1
		Conditioning Systems	9	24840		3		
	Comparators/Bistables	9	24840					
 Switches	12	24840						

Table 20. (continued)

General Electric Plants (continued)

 Analog  
 Digital






				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Dresden 2	DR2	Core Flux Sensors	180	52608		1		
		Transmitters	4	52608				
		Radiation Monitors	4	52608		4		2
		Conditioning Systems	20	52608		8		6
		Comparators/Bistables	18	52608		3		1
	 Switches	28	52608	2	15		2	
Dresden 3	DR3	Core Flux Sensors	180	52608			1	1
		Transmitters	4	52608				
		Radiation Monitors	4	52608		1		2
		Conditioning Systems	20	52608		16		4
		Comparators/Bistables	18	52608		4		
	 Switches	28	52608		8		1	
Hatch 1	EN1	Core Flux Sensors	140	52608				1
		Transmitters	4	52608				
		Radiation Monitors	4	52608	1			2
		Conditioning Systems	20	52608				
		Comparators/Bistables	18	52608		1		
	 Switches	24	52608		9			

Table 20. (continued)



General Electric Plants (continued)

 Analog  
 Digital

Plant	Unit	Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Hatch 2	EN2	Core Flux Sensors	140	30648				4
		Transmitters	4	30648				
		Radiation Monitors	4	30648	1	1		
		Conditioning Systems	20	30648		1		1
		Comparators/Bistables	18	30648		6		
		Switches	24	30648		18	1	4
Fitzpatrick	FP1	Core Flux Sensors	140	52608		3	1	4
		Transmitters	4	52608				
		Radiation Monitors	4	52608		1		2
		Conditioning Systems	20	52608		13	1	24
		Comparators/Bistables	18	52608		1		
		Switches	24	52608	6	12		5
Millstone 1	MI1	Core Flux Sensors	136	52608		2		
		Transmitters	4	52608				
		Radiation Monitors	4	52608		3		1
		Conditioning Systems	20	52608		1		
		Comparators/Bistables	18	52608		1		
		Switches	24	52608	1	16		

Table 20. (continued)

General Electric Plants (continued)

 Analog  
 Digital





















				Fault Modes				
				Reduced Capability		Inoperable		
Component				Command Faults	Failures	Command Faults	Failures	
				Component Population	Hours Per Component			
Monticello	MO1		Core Flux Sensors	112	52608			
			Transmitters	4	52608			
			Radiation Monitors	4	52608			
			Conditioning Systems	20	52608			
			Comparators/Bistables	18	52608		4	2
			Switches	28	52608			1
Nine Mile Point 1	NM1		Core Flux Sensors	128	52608			4
			Transmitters <sup>b</sup>	4	52608			1
			Radiation Monitors	4	52608		1	
			Conditioning Systems	18	52608		5	
			Comparators/Bistables	16	52608			
			Switches	24	52608		5	
Oyster Creek 1	OC1		Core Flux Sensors	128	52608		6	
			Transmitters <sup>b</sup>	4	52608		2	
			Radiation Monitors	4	52608			
			Conditioning Systems	18	52608			5
			Comparators/Bistables	16	52608			
			Switches	24	52608		7	1

Table 20. (continued)

General Electric Plants (continued)

 Analog  
 Digital




				Fault Modes				
				Reduced Capability		Inoperable		
		Component	Component Population	Hours Per Component	Command Faults	Failures	Command Faults	Failures
Peach Bottom 2	PB2	Core Flux Sensors	188	52608				1
		Transmitters	4	52608				
		Radiation Monitors	4	52608		3	2	3
		Conditioning Systems	20	52608		1		
		Comparators/Bistables	18	52608		3		
		Switches	28	52608		3		1
Peach Bottom 3	PB3	Core Flux Sensors	188	52608				
		Transmitters	4	52608				
		Radiation Monitors	4	52608		4		3
		Conditioning Systems	20	52608		2		1
		Comparators/Bistables	18	52608		2		
		Switches	28	52608	1	2		1
Pilgrim 1	PI1	Core Flux Sensors	136	52608				1
		Transmitters	4	52608				
		Radiation Monitors	4	52608				
		Conditioning Systems	20	52608				1
		Comparators/Bistables	18	52608				
		Switches	28	52608		9		

Table 20. (continued)

General Electric Plants (continued)

		Component	Component Population	Hours Per Component	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Quad-Cities 1	QC1	Core Flux Sensors	180	52608				
		Transmitters	4	52608				
		Radiation Monitors	4	52608				
		Conditioning Systems	20	52608				
		Comparators/Bistables	18	52608				
		Switches	28	52608		18		1
Quad-Cities 2	QC2	Core Flux Sensors	180	52608				
		Transmitters	4	52608				
		Radiation Monitors	4	52608		1		1
		Conditioning Systems	20	52608				
		Comparators/Bistables	18	52608				
		Switches	28	52608		15		
Vermont Yankee 1	VY1	Core Flux Sensors	94	52608				
		Transmitters	4	52608				
		Radiation Monitors	4	52608				
		Conditioning Systems	18	52608		1		
		Comparators/Bistables	18	52608				
		Switches	24	52608		2		

a. Switches or digital type channels found not to be incorporated in reactor trip systems for these plants.

b. Population unknown.

Note. Components affected by the footnotes above are omitted from the LER rate calculations.



Table 21. Summary of input data for LER rate estimations for channels



Babcock & Wilcox Plants<sup>a</sup>

Analog  
 Digital

Plant	Channel	Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Arkansas 1	AR1	Core Flux Temperature	4	52608	1			
			4	52608				
		Flow Pressure	4	52608				
			4	52608				
		Pressure	4	52608		1		
Crystal River 3	CR3	Core Flux Temperature	4	43512	5	3		1
			4	43512				
		Flow Pressure	4	43512		4		1
			4	43512		8		1
		Pressure	4	43512		1		
Davis-Besse 1	DB1	Core Flux Temperature	4	38472				1
			4	38472				4
		Flow Pressure	4	38472				4
			4	38472			1	1
		Pressure	4	38472				

Table 21. (continued)



Babcock & Wilcox Plants<sup>a</sup>(continued)

 Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Oconee 1	OE1	Core Flux Temperature	4	52608	4	13		
		Flow Pressure	4	52608	4	1		1
		Pressure	4	52608		3		
		Pressure	4	52608				
Oconee 2	OE2	Core Flux Temperature	4	52608				
		Flow Pressure	4	52608		2		
		Pressure	4	52608		1		1
		Pressure	4	52608				
Oconee 3	OE3	Core Flux Temperature	4	52608		4		1
		Flow Pressure	4	52608		5		
		Pressure	4	52608		1	1	
		Pressure	4	52608				

Table 21. (continued)

Babcock & Wilcox Plants<sup>a</sup>(continued)

 Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Rancho Seco 1	RS1	Core Flux Temperature	4	52608	1			
		Temperature	4	52608				
		Flow Pressure	4	52608		1		1
		Pressure	4	52608		5		1
Three Mile Is. 1	T11	Core Flux Temperature	4	28368				1
		Temperature	4	28368				
		Flow Pressure	4	28368			2	1
		Pressure	4	28368				1
Three Mile Is. 2	T12	Core Flux Temperature	4	8760				1
		Temperature	4	8760				
		Flow Pressure	4	8760				
		Pressure	4	8760				

Table 21. (continued)

Combustion Engineering Plants<sup>b</sup>

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
Parameter				Command Faults	Failures	Command Faults	Failures	
				Channel Population	Hours Per Channel			
Arkansas 2	AR2	Core Flux Temperature	4	26952			1	
			4	26952			4	
		Flow <sup>c</sup>						
		Level Pressure	4 16	26952 26952				1
Calvert Cliffs 1	CC1	Core Flux Temperature	8	52608		4	8	
			4	52608		3	7	
		Flow	4	52608		7		1
		Level Pressure	4 12	52608 52608		2 5		4
Calvert Cliffs 2	CC2	Core Flux Temperature	8	44572		4	10	
			4	44572		6	14	
		Flow	4	44572				1
		Level Pressure	4 12	44572 44572		3	1	2

Table 21. (continued)

Combustion Engineering Plants<sup>b</sup> (continued)

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Fort Calhoun 1	FC1	Core Flux	8	52608		1	1	11
		Temperature	4	52608		1		4
		Flow	4	52608		2		
		Level Pressure	4	52608		1		2
			12	52608				4
Millstone 2	M12	Core Flux	8	52608	1	4		11
		Temperature	4	52608		1		6
		Flow	4	52608		6		3
		Level Pressure	4	52608		4		
			12	52608	1	3		1
Maine Yankee	MY1	Core Flux	8	52608				7
		Temperature	4	52608		3		7
		Flow	4	52608				3
		Level Pressure	4	52608				2
			12	52608	1	1		3

Analog  
 Digital

Table 21. (continued)

Combustion Engineering Plants<sup>b</sup> (continued)

Analog  
 Digital

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Palisades	PA1	Core Flux Temperature	6	52608		2		
			4	52608		1		
		Flow	4	52608		1		3
		Level Pressure	4	52608		2		
			8	52608		2		
St. Lucie 1	SL1	Core Flux Temperature	8	49920				3
			4	49920		3		1
		Flow	4	49920				
		Level Pressure	4	49920		4		
			12	49920		3		6

Table 21. (continued)



Westinghouse Plants

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Beaver Valley 1	BV1	<input type="checkbox"/> Core Flux	8	49488		2		8
		<input type="checkbox"/> Temperature	3	49488		4	3	4
		<input type="checkbox"/> Flow	15	49488		4	1	4
		<input type="checkbox"/> Level	12	49488				3
		<input type="checkbox"/> Pressure	3	49488				1
	<input checked="" type="checkbox"/>	Pressure	3	49488				
Cook 1	DC1	<input type="checkbox"/> Core Flux	8	52608				13
		<input type="checkbox"/> Temperature	4	52608		2		5
		<input type="checkbox"/> Flow	20	52608	1	3		2
		<input type="checkbox"/> Level	15	52608		5		11
		<input type="checkbox"/> Pressure	4	52608		5		
	<input checked="" type="checkbox"/>	Pressure	3	52608				
Cook 2	DC2	<input type="checkbox"/> Core Flux	8	33432		1		3
		<input type="checkbox"/> Temperature	4	33432				2
		<input type="checkbox"/> Flow	20	33432		1		5
		<input type="checkbox"/> Level	15	33432		3		3
		<input type="checkbox"/> Pressure	4	33432		4		2
	<input checked="" type="checkbox"/>	Pressure	3	33432				

Table 21. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Haddam Neck	HN1	Core Flux	6	52608		2		1
		Temperature	4	52608				
		Flow	8	52608		1		2
		Level	3	52608		1		
		Pressure	3	52608				
			Pressure	4	52608			
Indian Point 2	IP2	Core Flux	8	52608		2	1	
		Temperature	4	52608		1		1
		Flow	20	52608				
		Level	15	52608		1		2
		Pressure	4	52608				
			Pressure	3	52608			
Indian Point 3	IP3	Core Flux	8	50304		1		2
		Temperature	4	50304		6		1
		Flow	20	50304				1
		Level	15	50304				1
		Pressure	4	50304		1		
			Pressure	3	50304			





Table 21. (continued)

Westinghouse Plants (continued)

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Farley 1	JF1	Core Flux	8	38544		4	2	1
		Temperature	3	38544		2		5
		Flow	15	38544		4	1	1
		Level	12	38544		2		2
		Pressure	3	38544	2	1	1	2
			Pressure	3	38544			
Farley 2	JF2	Core Flux	8	5784				
		Temperature	3	5784				2
		Flow	15	5784			2	1
		Level	12	5784		2		
		Pressure	3	5784				
			Pressure	3	5784			
Kewaunee	KE1	Core Flux	8	52608				1
		Temperature	4	52608		1		
		Flow	10	52608		8		2
		Level	9	52608		8		3
		Pressure	4	52608		13		
			Pressure	3	52608			

Table 21. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital




		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
McGuire 1	MG1	Core Flux	8	3504			1	1
		Temperature	4	3504				3
		Flow	20	3504				2
		Level	15	3504		1	1	
		Pressure	4	3504				
		Pressure	3	3504				
North Anna 1	N/1	Core Flux	8	32808	1	2		3
		Temperature	3	32808	1			4
		Flow	15	32808		4		2
		Level	12	32808	7	6	2	3
		Pressure	3	32808		2		1
		Pressure	3	32808		1		
North Anna 2	NA2	Core Flux	8	13632	1	5		4
		Temperature	3	13632		2		1
		Flow	15	13632		4		1
		Level	12	13632		1		
		Pressure	3	13632		5		1
		Pressure	3	13632				

Table 21. (continued)

Westinghouse Plants (continued)

				Fault Modes							
				Reduced Capability		Inoperable					
				Command Faults	Failures	Command Faults	Failures				
		Parameter	Channel Population	Hours Per Channel							
Prairie Island 1	PR1	Core Flux	8	52608	2	2	3	4			
		Temperature	4	52608					1		
		Flow	10	52608						1	
		Level	9	52608							2
		Pressure	4	52608							
Pressure	3	52608									
Prairie Island 2	PR2	Core Flux	8	52608		4		3			
		Temperature	4	52608					1		
		Flow	10	52608						4	
		Level	9	52608							1
		Pressure	4	52608							
Pressure	3	52608									
Point Beach 1	PT1	Core Flux	8	52608				3			
		Temperature	4	52608					1		
		Flow	10	52608						2	
		Level	9	52608							
		Pressure	4	52608							
Pressure	3	52608									



Table 21. (continued)

Westinghouse Plants (continued)

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Point Beach 2	PT2	Core Flux	8	52608		1		3
		Temperature	4	52608				
		Flow	10	52608				
		Level	9	52608		1		
		Pressure	4	52608			1	
			Pressure	3	52608			
Girna	RG1	Core Flux	8	52608				2
		Temperature	4	52608				
		Flow	10	52608				
		Level	9	52608				
		Pressure	4	52608		1		
			Pressure	3	52608			
Robinson 2	RO2	Core Flux	8	52608	1		3	1
		Temperature	3	52608				1
		Flow	15	52608				
		Level	12	52608				2
		Pressure	3	52608				
			Pressure	3	52608			

Table 21. (continued)

Westinghouse Plants (continued)

 Analog  
 Digital




				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Salem 1	SA1	Core Flux	8	44328		1		11
		Temperature	4	44328		2		2
		Flow	20	44328		5	1	10
		Level	15	44328		3		8
		Pressure	4	44328			1	1
			Pressure	3	44328			
Salem 2	SA2	Core Flux	8	12264				1
		Temperature	4	12264				
		Flow	20	12264				11
		Level	15	12264		1		
		Pressure	4	12264		1		1
			Pressure	3	12264			
Sequoyah 1	SE1	Core Flux	8	13080		1	1	
		Temperature	4	13080			2	
		Flow	20	13080		2		3
		Level	15	13080		2	3	10
		Pressure	4	13080		2	3	
			Pressure	3	13080			

Table 21. (continued)

Westinghouse Plants (continued)

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
					Command Faults	Failures	Command Faults	Failures
Sequoyah 2	SE2	Core Flux	8	1368			1	
		Temperature	4	1368				1
		Flow	20	1368				
		Level	15	1368				
		Pressure	4	1368				
		Pressure	3	1368				
San Onofre 1	SO1	Core Flux	6	52608				1
		Temperature	3	52608				6
		Flow	6	52608				
		Level	3	52608				
		Pressure	3	52608		6		
		Pressure	4	52608				
Surry 1	SU1	Core Flux	8	52608				1
		Temperature	3	52608				1
		Flow	15	52608		6		1
		Level	12	52608		2		1
		Pressure	3	52608				
		Pressure	3	52608				

Table 21. (continued)

Westinghouse Plants (continued)

Analog  
 Digital

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Surry 2	SU2	Core Flux	8	52608		2		1
		Temperature	3	52608		2		1
		Flow	15	52608				1
		Level	12	52608		2		1
		Pressure	3	52608				1
		Pressure	3	52608				
Trojan	TR1	Core Flux	8	52608			3	2
		Temperature	4	52608				
		Flow	20	52608	1	1		
		Level	15	52608		8		1
		Pressure	4	52608		3		1
		Pressure	3	52608		1		
Turkey Point 3	TU3	Core Flux	8	52608			2	1
		Temperature	3	52608		2		
		Flow	15	52608				2
		Level	12	52608		1		
		Pressure	3	52608				
		Pressure	3	52608				

Table 21. (continued)

Westinghouse Plants (continued)

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
				Command Faults	Failures	Command Faults	Failures	
Turkey Point 4	TU4	Core Flux	8	52608				
		Temperature	3	52608				1
		Flow	15	52608				
		Level	12	52608				
		Pressure	3	52608				
		Pressure	3	52608				
Yankee-Rowe 1	YR1	Core Flux	3	52608				
		Temperature <sup>d</sup>						
		Flow <sup>d</sup>						
		Level <sup>d</sup>						
		Pressure <sup>d</sup>						
		Pressure <sup>d</sup>						
Zion 1	Z11	Core Flux	8	52608		4		1
		Temperature	4	52608		2		8
		Flow	20	52608		20		10
		Level	15	52608		15		3
		Pressure	4	52608		1		1
		Pressure	3	52608				



Table 21. (continued)



Westinghouse Plants (continued)

Analog  
 Digital

		Parameter	Channel Population	Hours Per Channel	Fault Modes			
					Reduced Capability		Inoperable	
				Command Faults	Failures	Command Faults	Failures	
Zion 2	Z12	Core Flux	8	52608				3
		Temperature	4	52608				3
		Flow	20	52608		12		7
		Level	15	52608		19		7
	Pressure	4	52608				2	
		Pressure	3	52608				

Table 21. (continued)

General Electric Plants

 Analog  
 Digital













				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Browns Ferry 1	BF1	 Core Flux	18	52608				
		 Flow	2	52608				
		 Level	8	52608		3		3
		 Pressure	20	52608		13	1	
Browns Ferry 2	BF2	 Core Flux	18	52608				3
		 Flow	2	52608				1
		 Level	8	52608	7	2		3
		 Pressure	20	52608		19		1
Browns Ferry 3	BF3	 Core Flux	18	47328		1		45
		 Flow	2	47328				
		 Level	8	47328		2	2	2
		 Pressure	20	47328		22		

Table 21. (continued)

General Electric Plants (continued)

				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Big Rock Point 1	BP1							
		Core Flux	8	52608				1
		Flow <sup>e</sup>						
		Level	4	52608				
		Pressure	12	52608		1		
Brunswick 1	BR1							
		Core Flux	18	45864		13		4
		Flow	2	45864				
		Level	8	45864		7		2
		Pressure	16	45864		1		
Brunswick 2	BR2							
		Core Flux	18	52608		2	4	11
		Flow	2	52608				
		Level	8	52608		17		
		Pressure	20	52608		16		



 Analog  
 Digital

Table 21. (continued)

General Electric Plants (continued)



Plant	Parameter	Channel Population	Hours Per Channel	Fault Modes			
				Reduced Capability		Inoperable	
				Command Faults	Failures	Command Faults	Failures
Cooper Station	Core Flux	18	52608		4		3
	Flow	2	52608				
	Level	8	52608				2
	Pressure	16	52608		4		1
Duane Arnold	Core Flux	16	52608			7	4
	Flow	2	52608				1
	Level	8	52608				
	Pressure	16	52608				
Drasden 1	Core Flux	9	24840			16	1
	Flow <sup>e</sup>						
	Level <sup>f</sup>						
	Pressure	12	24840				

□ Analog

▨ Digital

Table 21. (continued)



General Electric Plants (continued)

 Analog  
 Digital

			Fault Modes					
			Reduced Capability		Inoperable			
Plant	System	Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Dresden 2	DR2	Core Flux	18	52608		6		7
		Flow	2	52608		6		
		Level	8	52608		4		
		Pressure	20	52608	2	11		2
Dresden 3	DR3	Core Flux	18	52608		20	1	4
		Flow	2	52608				1
		Level	8	52608		4		
		Pressure	20	52608		4		1
Hatch 1	EN1	Core Flux	18	52608		1		1
		Flow	2	52608				
		Level	8	52608		4		
		Pressure	16	52608		5		

Table 21. (continued)

General Electric Plants (continued)

 Analog  
 Digital













				Fault Modes					
				Reduced Capability		Inoperable			
Parameter				Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Hatch 2	EN2		Core Flux	18	30648		7		5
			Flow	2	30648				
			Level	8	30648		3	1	4
			Pressure	16	30648		15		
Fitzpatrick	FP1		Core Flux	18	52608		16	2	28
			Flow	2	52608		1		
			Level	8	52608	6	2		3
			Pressure	16	52608		10		2
Millstone 1	MI1		Core Flux	18	52608		4		
			Flow	2	52608				
			Level	8	52608				
			Pressure	16	52608	1	16		



Table 21. (continued)

General Electric Plants (continued)

			Fault Modes					
			Reduced Capability		Inoperable			
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Monticello	MO1	Core Flux	18	52608		4		2
		Flow	2	52608				
		Level	8	52608				1
		Pressure	20	52609				
Nine Mile Point 1	NM1	Core Flux	16	52608		6		4
		Flow	2	52608				
		Level	8	52608		4		
		Pressure	16	52608		1		
Oyster Creek 1	OC1	Core Flux	16	52608		6		5
		Flow	2	52608				
		Level	8	52608		5		
		Pressure	16	52608		2		1

Table 21. (continued)

General Electric Plants (continued)

 Analog  
 Digital















				Fault Modes				
				Reduced Capability		Inoperable		
Parameter				Command Faults	Failures	Command Faults	Failures	
				Channel Population	Hours Per Channel			
Peach Bottom 2	PB2		Core Flux	18	52608		4	1
			Flow	2	52608			
			Level	8	52608			1
			Pressure	20	52608		3	
Peach Bottom: 3	PB3		Core Flux	18	52608		3	1
			Flow	2	52608		1	
			Level	8	52608			
			Pressure	20	52608	1	2	1
Pilgrim 1	PI1		Core Flux	18	52608			2
			Flow	2	52608			
			Level	8	52608		2	
			Pressure	20	52608		7	



Table 21. (continued)

General Electric Plants (continued)

 Analog  
 Digital













				Fault Modes				
				Reduced Capability		Inoperable		
		Parameter	Channel Population	Hours Per Channel	Command Faults	Failures	Command Faults	Failures
Quad-Cities 1	QC1	 Core Flux	18	52608				
		 Flow	2	52608				
		 Level	8	52608		4		1
		 Pressure	20	52608		14		
Quad-Cities 2	QC2	 Core Flux	18	52608				
		 Flow	2	52608				
		 Level	8	52608				
		 Pressure	20	52608		15		
Vermont Yankee 1	VY1	 Core Flux	16	52608				
		 Flow	2	52608		1		
		 Level	8	52608				
		 Pressure	16	52608		2		

Table 21. (continued)

---

- 
- a. Level found not to be incorporated in reactor trip systems for these plants.
  - b. Digital type channels found not to be incorporated in reactor trip systems for these plants.
  - c. RCP proximity devices used and considered atypical.
  - d. Population unknown.
  - e. Flow found not to be incorporated in reactor trip systems for these plants.
  - f. The steam dome level switches found at DR1 were considered atypical and populations for these switches were unknown.

Note. Channels affected by the footnotes above are omitted from the LEK rate calculations.

---




Figure 15a. Scatter plot of operating LER rates for Babcock & Wilcox plant core flux sensors, inoperable, with command faults.




Figure 15b. Scatter plot of operating LER rates for Combustion Engineering plant core flux sensors, inoperable, with command faults.




Figure 15d. Scatter plot of operating LER rates for General Electric plant core flux sensors, inoperable, with command faults.




Figure 15c. Scatter plot of operating LER rates for Westinghouse plant core flux sensors, inoperable, with command faults.




Figure 15e. Scatter plot summarizing operating LER rates of core flux sensors, inoperable, with command faults.




Figure 16a. Scatter plot of operating LER rates for Babcock & Wilcox plant temperature sensors, inoperable, with command faults.




Figure 16b. Scatter plot of operating LER rates for Combustion Engineering plant temperature sensors, inoperable, with command faults.




Figure 16c. Scatter plot of operating LER rates for Westinghouse plant temperature sensors, inoperable, with command faults.




Figure 16d. Scatter plot summarizing operating LER rates of temperature sensors, inoperable, with command faults.




Figure 17a. Scatter plot of operating LER rates for Babcock & Wilcox plant flow and pressure transmitters, inoperable, with command faults.




Figure 17b. Scatter plot of operating LER rates for Combustion Engineering plant flow, level, and pressure transmitters, inoperable, with command faults.




Figure 17c. Scatter plot of operating LER rates for Westinghouse plant flow, level, and pressure transmitters, inoperable, with command faults.






Figure 17d. Scatter plot of operating LER rates for General Electric plant flow transmitters, inoperable, with command faults.




Figure 17e. Scatter plot summarizing operating LER rates of flow, level, and pressure transmitters, inoperable, with command faults.




Figure 18a. Scatter plot of operating LER rates for Babcock & Wilcox plant flow, pressure, temperature, and core flux conditioning systems, inoperable, with command faults.




Figure 18b. Scatter plot of operating LER rates for Combustion Engineering plant flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults.




Figure 18d. Scatter plot of operating LER rates for General Electric plant flow and core flux conditioning systems, inoperable, with command faults.




Figure 18c. Scatter plot of operating LER rates for Westinghouse plant flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults.




Figure 18e. Scatter plot summarizing operating LER rates of flow, level, pressure, temperature, and core flux conditioning systems, inoperable, with command faults.




Figure 19a. Scatter plot of operating LER rates for Babcock & Wilcox plant flow, pressure, temperature, and core flux bistables, inoperable, with command faults.




Figure 19b. Scatter plot of operating LER rates for Combustion Engineering plant flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults.




Figure 19c. Scatter plot of operating LER rates for Westinghouse plant flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults.




Figure 19d. Scatter plot of operating LER rates for General Electric plant flow and core flux bistables, inoperable, with command faults.




Figure 19e. Scatter plot summarizing operating LER rates of flow, level, pressure, temperature, and core flux bistables, inoperable, with command faults.




Figure 20b. Scatter plot of operating LER rates for Westinghouse plant pressure switches, inoperable, with command faults.




Figure 20a. Scatter plot of operating LER rates for Babcock & Wilcox plant pressure switches, inoperable, with command faults.




Figure 20c. Scatter plot of operating LER rates for General Electric plant pressure/vacuum and level switches, inoperable, with command faults.




Figure 20d. Scatter plot summarizing operating LER rates of level, pressure, and pressure/vacuum switches, inoperable, with command faults.






Figure 21b. Scatter plot summarizing operating LER rates of radiation monitors, inoperable, with command faults.




Figure 21a. Scatter plot of operating LER rates for General Electric plant radiation monitors, inoperable, with command faults.




Figure 22a. Scatter plot of operating LER rates for Babcock & Wilcox plant core flux channels, inoperable, with command faults.




Figure 22b. Scatter plot of operating LER rates for Combustion Engineering plant core flux channels, inoperable, with command faults.




Figure 22c. Scatter plot of operating LER rates for Westinghouse plant core flux channels, inoperable, with command faults.




Figure 22d. Scatter plot of operating LER rates for General Electric plant core flux channels, inoperable, with command faults.




Figure 22e. Scatter plot summarizing operating LER rates of core flux channels, inoperable, with command faults.




Figure 23a. Scatter plot of operating LER rates for Babcock & Wilcox plant temperature channels, inoperable, with command faults.




Figure 23b. Scatter plot of operating LER rates for Combustion Engineering plant temperature channels, inoperable, with command faults.




Figure 23c. Scatter plot of operating LER rates for Westinghouse plant temperature channels, inoperable, with command faults.




Figure 23d. Scatter plot summarizing operating LER rates of temperature channels, inoperable, with command faults.




Figure 24a. Scatter plot of operating LER rates for Babcock & Wilcox plant flow channels, inoperable, with command faults.




Figure 24b. Scatter plot of operating LER rates for Combustion Engineering plant flow channels, inoperable, with command faults.




Figure 24c. Scatter plot of operating LER rates for Westinghouse plant flow channels, inoperable, with command faults.




Figure 24c. Scatter plot summarizing operating LER rates of flow channels, inoperable, with command faults.




Figure 24d. Scatter plot of operating LER rates for General Electric plant flow channels, inoperable, with command faults.






Figure 25a. Scatter plot of operating LER rates for Combustion Engineering plant level channels (analog), inoperable, with command faults.




Figure 25b. Scatter plot of operating LER rates for Westinghouse plant level channels (analog), inoperable, with command faults.




Figure 25c. Scatter plot summarizing operating LER rates of level channels (analog), inoperable, with command faults.




Figure 26a. Scatter plot of operating LER rates for Babcock & Wilcox plant pressure channels (analog), inoperable, with command faults.




Figure 26b. Scatter plot of operating LER rates for Combustion Engineering plant pressure channels (analog), inoperable, with command faults.




Figure 26c. Scatter plot of operating LER rates for Westinghouse plant pressure channels (analog), inoperable, with command faults.




Figure 26d. Scatter plot summarizing operating LER rates of pressure channels (analog), inoperable, with command faults.




Figure 27a. Scatter plot of operating LER rates for General Electric plant level channels (digital), inoperable, with command faults.




Figure 27b. Scatter plot summarizing operating LER rates of level channels (digital), inoperable, with command faults.




Figure 28a. Scatter plot of operating LER rates for Babcock & Wilcox plant pressure channels (digital), inoperable, with command faults.




Figure 28b. Scatter plot of operating LER rates for Westinghouse plant pressure channels (digital), inoperable, with command faults.




Figure 28c. Scatter plot of operating LER rates for General Electric plant pressure/vacuum channels (digital), inoperable, with command faults.




Figure 28d. Scatter plot summarizing operating LER rates of pressure and pressure/vacuum channels (digital), inoperable, with command faults.

## REFERENCES

1. C. F. Miller et al., *Data Summaries of Licensee Event Reports of Selected Instrumentation and Control Components at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, NUREG/CR-1740, May 1981.
2. C. L. Atwood, *Common Cause Fault Rates for Instrumentation and Control Assemblies: Estimates Based on Licensee Event Reports at U.S. Commercial Nuclear Power Plants 1976-1981*, NUREG/CR-3289, May 1983.
3. C. F. Miller et al., *Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1980*, NUREG/CR-1363, Revision 1, October 1982.
4. Topical Report, *Characteristics of Instrumentation and Control System Failures in Light Water Reactors*, EPRI NP-443, August 1977, p. 7.
5. The Institute of Electrical and Electronics Engineers, Inc., IEEE Standard 380-1975, *Definitions of Terms Used in IEEE Standards on Nuclear Power Generating Systems*.
6. M. Trojovsky, *Data Summaries of Licensee Event Reports of Pumps at U.S. Commercial Nuclear Power Plants January 1, 1972 to September 30, 1980*, NUREG/CR-1205, Revision 1, January 1982.
7. W. H. Hubbie and C. F. Miller, *Data Summaries of Licensee Event Reports of Control Rods and Drive Mechanisms at U.S. Commercial Nuclear Power Plants January 1, 1972 to April 30, 1978*, NUREG/CR-1331, February 1980.
8. J. P. Poloski and W. H. Sullivan, *Data Summaries of Licensee Event Reports of Diesel Generators at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1978*, NUREG/CR-1362, March 1980.
9. C. L. Atwood, *Estimators for the Binomial Failure Rate Common Cause Model*, NUREG/CR-1401, April 1980.
10. Standard Technical Specifications for Babcock & Wilcox Pressurized Water Reactors, Section 3/4.3.1, *Reactor Protection Instrumentation*, NUREG-0103, Revision 3, July 1979.
11. Standard Technical Specifications for Combustion Engineering Pressurized Water Reactors, Section 3/4.3.1, *Reactor Protection Instrumentation*, NUREG-0212, Revision of March 15, 1977.
12. Standard Technical Specifications for General Electric Boiling Water Reactors, Section 3/4.3.1, *Reactor Protection Instrumentation*, NUREG-0123, Revision 1, April 1978.
13. Standard Technical Specifications for Westinghouse Pressurized Water Reactors, Section 3/4.3.1, *Reactor Protection Instrumentation*, NUREG-0452, Revision 2, July 1979.
14. *Operating Units Status Report*, 6, 3, NUREG-0020, March 1982.
15. *Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Reactor Plants*, Appendixes III and IV, WASH-1400, NUREG-75/014, October 1975, Table III-4-2, p. III-47-48.



**APPENDIX A**

**DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING**

## APPENDIX A

### DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING

There are generally two criteria used by the utilities to determine reporting requirements for faults; these are: (a) technical specifications for each individual plant and (b) the LER reporting guide, Regulatory Guide 1.16.<sup>A-1</sup> The technical specifications for plants licensed prior to January 1, 1976, were independently written by individual plants without any planned uniformity among plants. All plants licensed after this date use standardized technical specifications that helped to create more uniform reporting. Three plants (Calvert Cliffs 1, Yankee-Rowe 1, and Brunswick 2) that received operating licenses prior to 1976 converted to standard technical specifications in 1977. In addition to technical specification standardization there have been changes in the rules that govern LER reporting since 1976. These updated rules and the standardized technical specifications are expected to result in more uniform LER reporting after January 1, 1976. But pre-1976 LER data, as well as LER data reported by plants which are not subject to standard technical specifications, will show considerable variation.

The above *mechanical* causes for LER reporting variations are explicable and expected. However, there are additional reporting variations. Differences in interpretation of the rules for submit-

ting LER reports cause some variation. Also, variation is caused by the difficulty in determining the extent of safety and nonsafety systems and therefore, by the questions of what faults are or are not required to be reported. Finally, variation can be caused by the degree of importance assigned to the LER reports by management of the individual utilities. Such variation in both the quantity and quality of LERs submitted by similar plants may appear where one would expect a more uniform reporting.

The one thing that seems to have most hindered the development of uniform reporting is the lack of agreement about the purpose of a LER. Many persons feel that LERs are intended to highlight problem areas within the safety systems. Some feel that the LERs ought to be used to highlight generic problem areas. Many of these same people do not feel that these uses are compatible with the need to determine fault rate information. These differing viewpoints may be an additional reason for the variations in the quality and quantity of LERs received by the United States Nuclear Regulatory Commission. For further discussion of the causes of variations in LER reporting, see Reference A-2.

### References

- A-1. U.S. Nuclear Regulatory Commission, *Reporting of Operating Information—Appendix A Technical Specification*, U.S. Nuclear Regulatory Commission, Regulatory Guide 1.16 Rev. 4, August 1975.
- A-2. Gerald L. Boner and Harvey W. Hanners, *Enhancement of Onsite Emergency Diesel Generator Reliability*, University of Dayton Research Institute, NUREG/CR-0660, 1979, pp. I-4,5, IV-5,6, V-10, and V-13.

APPENDIX B  
ONE-LINE LER CODING SCHEME

## CONTENTS

ONE-LINE LER CODING SCHEME .....	B-4
NSSS Vendor (NSSS) .....	B-4
Plant (PLANT) .....	B-4
Control Number (CONTROL NUMBER) .....	B-4
Event Date (EVENT DATE) .....	B-4
Component (COMP) .....	B-4
Parameter and Function (PROCESS) .....	B-9
System (SYSTEM) .....	B-9
Fault Mode and Cause (MODE & CAUSE) .....	B-10
Activity Resulting in Discovery (ACTIVITY) .....	B-10
Type of Event (TYPE) .....	B-10
Event Classification (CLASS) .....	B-10
Number of Faults (FAIL #) .....	B-11
Fault Mode Description (FAULT MODE DESCRIPTION) .....	B-11
Fault Cause Description (FAULT CAUSE DESCRIPTION) .....	B-11
Additional Information .....	B-11
Manufacturer .....	B-11
Flagging .....	B-11
Report Type .....	B-11
Plant Report Number .....	B-11
References .....	B-20

## TABLES

B-1. General plant information .....	B-5
B-2. Codes used in one-line descriptions .....	B-12
B-3. Manufacturers referenced in I&C LERs .....	B-14

## APPENDIX B

### ONE-LINE LER CODING SCHEME

In order to extract as much pertinent information as possible from the information provided in the original LER, and, at the same time, try to restrict the information to one line of computer output per LER, the following coding scheme was developed.

In general, the order of the discussion that follows is the order in which the various fields appear in the one-line descriptions of the I&C events. The headings used for the corresponding fields in the one-line descriptions are contained in parentheses following the topic headings used below.

#### NSSS Vendor (NSSS)

The NSSS field indicates the vendor associated with the plant submitting the LER report. A 1-character field is used to store and display the vendor code. This field can be used as a sort key. The following list gives the code and corresponding NSSS vendor.

Code	NSSS Vendor
B	Babcock & Wilcox
C	Combustion Engineering
W	Westinghouse
G	General Electric

#### Plant (PLANT)

A 3-character field was used to identify the commercial power plant responsible for submitting each LER. Table B-1 provides a list of the plants and codes and also supplies other plant information.<sup>B-1</sup> The PLANT field can be used as a sort key.

#### Control Number (CONTROL NUMBER)

To identify each one-line LER within the data file, and to provide a cross-reference with the actual LER submitted to the USNRC, the unique six-digit control number assigned to the report by the

USNRC was entered into the CONTROL NUMBER field. LERs describing 1981 events but received after December 31, 1981 were assigned a number by the Nuclear Safety Information Center (NSIC). There were some instances of several different events being listed in the narrative summary of a single LER. To accommodate this situation, an alphabetic character was added to the six-digit number in order to separately identify each report. Thus, traceability back to the original LER number was maintained, yet each report remained unique. When a single LER reported more than one instance of the same event (e.g., two bistables failed to trip) in the summary description, an asterisk (\*) was placed after the control number to flag the coded one-line description as containing multiple events. The corresponding number of events was then entered into the FAIL # field so that each event could be accounted for. The CONTROL NUMBER field can be used as a sort field, but it is primarily intended for data record identification within the data file.

#### Event Date (EVENT DATE)

A six-digit field was used to record the date of the event: two digits each, for the month, day, and year. The EVENT DATE corresponds to the event date listed in the LER for each event. The month, day, or year can be used as sort keys.

#### Component (COMP)

This field lists the types of I&C components identified in the LERs. Some related types are combined under one code, as shown in the following list. This field can be used as a sort key.

Code	Component
AM	Amplifier/buffer/isolation amplifier
CA	Cable/receptacle/junction box/terminal
CL	Controller
CM	Comparator (bistable)
CN	Converter/conditioner
GS	General switch
HS	Hand switch

**Table B-1. General plant information**

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Date of Initial Criticality	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
<b>BABCOCK &amp; WILCOX</b>							
AR1	Arkansas Nuclear One 1 (50-313)	850	08/06/74	12/19/74	AR	Bechtel	Bechtel
CR3	Crystal River 3 (30-302)	825	01/14/77	03/13/77	FL	Gilbert Associates	J. A. Jones Construction
DB1	Davis-Besse 1 (50-346)	906	08/12/77	07/31/78	OH	Bechtel	Bechtel
OE1	Oconee 1 (50-269)	887	04/19/73	07/15/73	SC	Duke & Bechtel	Duke Power
OE2	Oconee 2 (50-270)	887	11/11/73	09/09/74	SC	Duke & Bechtel	Duke Power
OE3	Oconee 3 (50-287)	887	09/05/74	12/16/74	SC	Duke & Bechtel	Duke Power
RS1	Rancho Seco 1 (50-312)	918	09/16/74	04/17/75	CA	Bechtel	Bechtel
TI1	Three Mile Island 1 <sup>a</sup> (50-289)	819	06/05/74	09/02/74	PA	Gilbert Associates	United Engineers & Constructors
TI2	Three Mile Island 2 <sup>a</sup> (50-320)	906	03/28/78	12/30/78	PA	Burns & Roe	United Engineers & Constructors
<b>COMBUSTION ENGINEERING</b>							
AR2	Arkansas Nuclear One 2 (50-368)	912	12/05/78	03/26/80	AR	Bechtel	Bechtel
CC1	Calvert Cliffs 1 (50-317)	845	10/07/74	05/08/75	MD	Bechtel	Bechtel
CC2	Calvert Cliffs 2 (50-318)	845	11/30/76	04/01/77	MD	Bechtel	Bechtel
FC1	Fort Calhoun 1 (50-285)	478	08/06/73	06/20/74	NB	Gibbs, Hill, Durham & Richardson, Inc.	Gibbs, Hill, Durham & Richardson, Inc.
MI2	Millstone 2 (50-336)	870	10/17/75	12/26/75	CT	Bechtel	Bechtel
MY1	Maine Yankee (50-309)	825	10/23/72	12/28/72	ME	Stone & Webster	Stone & Webster
PA1	Palisades (50-255)	805	05/24/71	12/31/71	MI	Bechtel	Bechtel
SL1	St. Lucie 1 (50-335)	830	04/22/76	12/21/76	FL	Ebasco	Ebasco

**Table B-1. (continued)**

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Date of Initial Criticality	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
WESTINGHOUSE							
BV1	Beaver Valley 1 (50-334)	835	05/10/76	10/01/76	PA	Stone & Webster	Stone & Webster
DC1	Cook 1 (50-315)	1030	01/18/75	08/27/75	MI	American Electric Power Service Corporation	American Electric Power Service Corporation
DC2	Cook 2 (50-316)	1100	03/10/78	07/01/78	MI	American Electric Power Service Corporation	J. A. Jones Construction
HN1	Haddam Neck (50-213)	582	07/24/67	01/01/68	CT	Stone & Webster	Stone & Webster
IP2	Indian Point 2 (50-247)	873	05/22/73	08/01/74	NY	United Engineers & Constructors, Inc.	Westinghouse Development Corporation
IP3	Indian Point 3 (50-286)	965	04/06/76	08/30/76	NY	United Engineers & Constructors, Inc.	Westinghouse Development Corporation
JF1	Farley 1 (50-348)	829	08/09/77	12/01/77	AL	Southern Services, Inc.	Bechtel
JF2	Farley 2 (50-364)	829	05/05/81	07/30/81	AL	Southern Services, Inc.	Bechtel
KE1	Kewaunee (50-305)	535	03/07/74	06/16/74	WI	Pioneer Services & Engineering	Pioneer Services & Engineering
MG1	McGuire 1 (50-369)	1180	08/08/81	12/01/81	NC	Duke Power	Duke Power
NA1	North Anna 1 (50-338)	907	04/05/78	06/06/78	VA	Stone & Webster	Stone & Webster
NA2	North Anna 2 (50-339)	907	06/12/80	12/14/80	VA	Stone & Webster	Stone & Webster
PR1	Prairie Island 1 (50-282)	530	12/01/73	12/16/73	MN	Fluor Pioneer, Inc.	Northern States Power Company
PR2	Prairie Island 2 (50-306)	530	12/17/74	12/21/74	MN	Fluor Pioneer, Inc.	Northern States Power Company
PT1	Point Beach 1 (50-266)	497	11/02/70	12/21/70	WI	Bechtel	Bechtel
PT2	Point Beach 2 (50-301)	497	05/30/72	10/01/72	WI	Bechtel	Bechtel
RG1	Ginna (50-244)	470	11/08/69	07/01/70	NY	Gilbert Associates	Bechtel

**Table B-1. (continued)**

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Date of Initial Criticality	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
WESTINGHOUSE (continued)							
RO2	Robinson 2 (50-261)	700	09/20/70	03/07/71	SC	Ebasco	Ebasco
SA1	Salem 1 (50-272)	1090	12/11/76	06/30/77	NJ	Public Services & Gas Co.	United Engineers & Constructors, Inc.
SA2	Salem 2 (50-311)	1115	08/08/80	10/13/81	NJ	Public Services & Gas Co.	United Engineers & Constructors, Inc.
SE1	Sequoyah 1 (50-327)	1148	07/05/80	07/01/81	TN	Tennessee Valley Authority	Tennessee Valley Authority
SE2	Sequoyah 2 (50-328)	1148	11/05/81	06/01/82	TN	Tennessee Valley Authority	Tennessee Valley Authority
SO1	San Onofre 1 (50-206)	436	06/14/67	01/01/68	CA	Bechtel	Bechtel
SU1	Surry 1 (50-280)	788	07/01/72	12/22/72	VA	Stone & Webster	Stone & Webster
SU2	Surry 2 (50-281)	788	03/07/73	05/01/73	VA	Stone & Webster	Stone & Webster
TR1	Trojan (50-344)	1130	12/15/75	05/20/76	OR	Bechtel	Bechtel
TU3	Turkey Point 3 (50-250)	693	10/20/72	12/14/72	FL	Bechtel	Bechtel
TU4	Turkey Point 4 (50-251)	693	06/11/73	09/07/73	FL	Bechtel	Bechtel
YR1	Yankee-Rowe 1 (50-029)	175	08/19/60	07/01/61	MA	Stone & Webster	Stone & Webster
ZI1	Zion 1 (50-295)	1040	06/19/73	12/31/73	IL	Sargent & Lundy	Commonwealth Edison
ZI2	Zion 2 (50-304)	1040	12/24/73	09/17/74	IL	Sargent & Lundy	Commonwealth Edison
GENERAL ELECTRIC							
BF1	Browns Ferry 1 (50-259)	1065	08/17/73	08/01/74	AL	Tennessee Valley Authority	Tennessee Valley Authority
BF2	Browns Ferry 2 (50-260)	1065	07/20/74	03/01/75	AL	Tennessee Valley Authority	Tennessee Valley Authority
BF3	Browns Ferry 3 (50-296)	1065	08/08/76	03/01/77	AL	Tennessee Valley Authority	Tennessee Valley Authority



**Table B-1. (continued)**

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Date of Initial Criticality	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
GENERAL ELECTRIC (continued)							
BP1	Big Rock Point 1 (50-155)	72	09/27/62	03/29/63	MI	Bechtel	Bechtel
BR1	Brunswick 1 (50-325)	821	10/08/76	03/18/77	NC	United Engineers & Constructors	Brown & Root
BR2	Brunswick 2 (50-324)	821	03/20/75	11/03/75	NC	United Engineers & Constructors	Brown & Root
CO1	Cooper Station (50-298)	778	02/21/74	07/01/74	NB	Burns & Roe	Burns & Roe
DA1	Duane Arnold (50-331)	538	03/23/74	02/01/75	IA	Bechtel	Bechtel
DR1	Dresden 1 <sup>b</sup> (50-010)	200	10/15/59	07/04/60	IL	Bechtel	Bechtel
DR2	Dresden 2 (50-237)	794	01/07/70	06/09/70	IL	Sargent & Lundy	United Engineers & Constructors
DR3	Dresden 3 (50-249)	794	01/31/71	11/16/71	IL	Sargent & Lundy	United Engineers & Constructors
EN1	Hatch 1 (50-321)	777	09/12/74	12/31/75	GA	Bechtel	Georgia Power Co.
EN2	Hatch 2 (50-356)	784	07/04/78	09/05/79	GA	Bechtel	Georgia Power Co.
FP1	Fitzpatrick (50-333)	821	11/17/74	07/28/75	NY	Stone & Webster	Stone & Webster
M11	Millstone 1 (50-245)	660	10/26/70	03/01/71	CT	Ebasco	Ebasco
MO1	Monticello (50-263)	545	12/10/70	06/30/71	MN	Bechtel	Bechtel
NM1	Nine Mile Point 1 (50-220)	620	09/05/69	12/01/69	NY	Niagara Mohawk Power Corporation	Stone & Webster
OC1	Oyster Creek 1 (50-219)	650	05/03/69	12/01/69	NJ	Burns & Roe	Burns & Roe
PB2	Peach Bottom 2 (50-277)	1065	09/16/73	07/05/74	PA	Bechtel	Bechtel
PB3	Peach Bottom 3 (50-278)	1065	08/07/74	12/23/74	PA	Bechtel	Bechtel
P11	Pilgrim 1 (50-293)	655	06/16/72	12/01/72	MA	Bechtel	Bechtel

**Table B-1. (continued)**

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Date of Initial Criticality	Date of Commercial Operation	Location (State)	Architect/Engineer	Constructor
GENERAL ELECTRIC (continued)							
QC1	Quad-Cities 1 (50-254)	789	10/18/71	02/18/73	IL	Sargent & Lundy	United Engineers & Constructors, Inc.
QC2	Quad-Cities 2 (50-265)	789	04/26/72	03/10/73	IL	Sargent & Lundy	United Engineers & Constructors, Inc.
VY1	Vermont Yankee 1 (50-271)	514	03/24/72	11/30/72	VT	Ebasco	Ebasco

a. Plant shutdown since 03/28/79.

b. Plant shutdown since 10/31/78.

Code	Component	Code	Parameter
IM	Computation module	L	Liquid level
IN	Indicator/meter/annunciator	N	Nuclear (core flux)
LM	Computer	F	Flow
LS	Limit switch	T	Temperature
MO	Monitor	R	Radiation
PS	Power supply	P	Pressure/vacuum
RC	Recorder	D	Position
RE	Relay/solenoid	X	Other/unknown
SE	Sensor		
TI	Timer		
TR	Transformer		
TX	Transmitter		
ZZ	Other/unspecified		

**Parameter and Function (PROCESS)**

The PROCESS field is a 2-character field. The first character indicates which plant parameter is being measured or monitored, while the second character indicates what type of function the faulted component was providing the plant. Each character can be used as a sort key. The following lists the parameter and function codes and descriptions.

Code	Function
T	Reactor trip
S	Engineered safety features actuation
C	Reactor control
G	General control/indication/alarm
R	Radiation detection

**System (SYSTEM)**

A 2-character field is used to indicate the system that was being monitored or controlled by the faulted I&C component. This field can be used as a sort key. The following is a list of system codes and descriptions.

Code	System
SA	Automatic depressurization (BWRs only)
IC	Containment (includes penetration and isolation control)
SD	Low pressure core spray (LPCS) (BWRs only)
SF	Containment spray injection (CS <sup>2</sup> )
AG	Chemical volume control (CVCS) (PWRs only)
SH	High pressure coolant injection (HPCI)
SL	Low pressure coolant injection (LPCI)
SQ	Reactor core isolation cooling (RCIC) (BWRs only)
AS	Service water
CT	Condensate and feed
PX	Reactor trip
NN	All others
SN	Other ESF (parent system not identified)

### Fault Mode and Cause (MODE & CAUSE)

A 3-character field indicates the fault code. A 1-character subordinate field indicates the fault mode and a 2-character subordinate field indicates the fault cause. The following scheme was used to encode the various fault modes and causes identified in the LERs. Either field can be used as sort keys.

Code	Fault Mode
A	Reduced capability
B	Inoperable

Code	Fault Cause
00	Unknown
01	Personnel operation
02	Personnel maintenance
03	Personnel testing
04	Design error
05	Fabrication/construction/quality control
06	Defective procedures
07	Extreme environment
08	Mechanical malfunction
09	Electrical malfunction
11	Leaking or blocked instrument sensing lines

Code	Fault Cause
12	Dirty, binding, or sticking
13	Piece part fault
14	Drift

### Activity Resulting in Discovery (ACTIVITY)

A 1-character code was used to indicate the activity taking place that caused or led to the discovery of the event. Any activity not specifically identified was considered to be *during normal operation*. This field can be used as a sort key. The coding scheme for this field is as follows.

Code	Activity
N	During normal plant operation (other than listed below)
M	During maintenance
R	During records review
T	During testing

### Type of Event (TYPE)

A 1-character field indicates the type of event identified in the LER. A blank in this field implies a random event. This field can be used as a sort key. The following scheme was used to identify the event types.

Code	Type of Event
B	Recurring common cause failure
C	Common cause failure
R	Recurring failure
S	Command fault
T	Recurring command fault
U	Common cause command fault
V	Recurring common cause command fault
Blank	Random failure

### Event Classification (CLASS)

A 1-character field was used to classify the events as age-related or frequency-of-use-related. A *D* in this field was used for frequency-of-use-related events, and a *T* was used for age-related events. If no determination could be made, a *U* was inserted in this field. This field can be used as a sort key.

## Number of Faults (FAIL #)

The FAIL # field, mentioned in the "Control Number" paragraph, was used to store a count of the number of events per one-line LER description. A blank in this field implies that the value of this field is one. Should there be more than one event per LER, the corresponding number of events is entered in this field.

## Fault Mode Description (FAULT MODE DESCRIPTION)

The LER narrative summary of the fault mode was condensed into a 50-character alphanumeric field. This field provides a short, concise description of the fault mode. It is not a sort field.

## Fault Cause Description (FAULT CAUSE DESCRIPTION)

A 41-character alphanumeric field was used for a narrative description of the fault cause. If no cause was reported, this field provided additional space for a description of the LER. It is not a sort field.

In order to provide as much information as possible in both the MODE and CAUSE DESCRIPTIONS, many words are abbreviated and many acronyms are used. Most of these acronyms can be found in the "Nomenclature" section at the beginning of this report.

Table B-2 provides most of the codes used in the one-line descriptions and is presented as a summary of the preceding discussion. One of these coding sheets will precede each sort of one-line descriptions in this report so that the reader need not continually refer to this appendix.

## Additional Information

Although not presented in the one-line descriptions, because of space limitations, additional information pertaining to manufacturer and various other items of interest is available. A discussion of the additional information fields follows.

**Manufacturer.** A 4-character alphanumeric field was used to identify the manufacturer given in the

LER. If no manufacturer was given in the LER, ZZZZ was used in the Manufacturer field. The codes used for the various manufacturers were taken from Exhibit J of the *Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File*.<sup>B-2</sup> Table B-3 lists the manufacturer codes that were found in the LERs used for this report. The Manufacturer field can be used as a sort key.

One should be cautious in using this manufacturer information because the manufacturer code is sometimes missing and sometimes not appropriate for the component coded in the data base.

**Flagging.** The Flagging field was used to distinguish whether the faulted component caused an accident or failed to mitigate an accident. The letter **A** was used to identify those I&C components that caused an accident (e.g., loss-of-coolant flow) upon failure, and **B** was used to identify those I&C components that failed to mitigate an accident upon failure. The letter **C** was used when the faulted I&C component neither caused nor failed to mitigate an accident, but could have caused or failed to mitigate an accident. The letter **C** was also used to identify an LER that requires some additional attention in future reports. The Flagging Field is a sort field.

**Report Type.** The Report Type was taken directly from the LER. The letter **A** was used to indicate two-week reports, **B** was used to indicate 30-day reports, and **C** was used to indicate other types of reports. Report Type is a sort field.

**Plant Report Number.** In addition to a plant docket number, each plant assigns a number to each LER that it submits. This number is assigned sequentially within each calendar year to every LER submitted by the plant. At the end of the calendar year the plant LER number will start again with 001 for the next year. A 3-character field was used to indicate the plant LER number associated with a particular plant. Plant Report Number can be used as a sort key, although it is primarily intended for data record identification within the data file.

Manufacturer, Flagging, Report Type, and Plant Report Number are not found in the one-line description sorts. Also, the Flagging, Report Type, and Plant Report Number fields are only found, where applicable, as additional information in the data base for LERs that have an event date later than December 31, 1978.

Table B-2. Codes used in one-line descriptions

FAULT MODE			CODES USED IN LER ONE-LINE DESCRIPTIONS		ACTIVITY RESULTING IN DISCOVERY	
CODE	DESCRIPTION	CODE	DESCRIPTION	CODE	DESCRIPTION	
A	REDUCED CAPABILITY	00	UNKNOWN	N	DURING NORMAL PLANT OPERATION (I.E. OTHER THAN LISTED BELOW)	
B	INOPERABLE	01	PERSONNEL OPERATION	M	DURING MAINTENANCE	
-----			02	PERSONNEL MAINTENANCE	R	DURING RECORDS REVIEW
FUNCTION			03	PERSONNEL TESTING	T	DURING TESTING
CODE	DESCRIPTION	04	DESIGN ERROR			
T	REACTOR TRIP	05	FABRICATION/CONSTRUCTION/QUALITY CONTROL			
E	ENGINEERED SAFETY FEATURES ACTUATION	06	DEFECTIVE PROCEDURES			
R	REACTOR CONTROL	07	EXTREME ENVIRONMENT			
G	GENERAL CONTROL/INDICATION/ALARM	08	MECHANICAL MALFUNCTION			
R	RADIATION DETECTION	09	ELECTRICAL MALFUNCTION			
-----			11	LEAKING OR BLOCKED INSTRUMENT SENSING LINES		
PARAMETER			12	DIRTY, BINDING, OR STICKING		
CODE	DESCRIPTION	13	PIECE PART FAULT			
L	LIQUID LEVEL	14	DRIFT			
N	NUCLEAR (CORE FLUX)	-----				
F	FLOW	COMPONENT		NSSS VENDOR		
T	TEMPERATURE	CODE	DESCRIPTION	CODE	DESCRIPTION	
R	RADIATION	AM	AMPLIFIER/BUFFER/ISOLATION AMPLIFIER	B	BABCOCK & WILCOX	
P	PRESSURE/VACUUM	CA	CABLE/RECEPTACLE/JUNCTION BOX/TERMINAL	C	COMBUSTION ENGINEERING	
D	POSITION	CL	CONTROLLER	M	WESTINGHOUSE	
X	OTHER/UNKNOWN	CM	COMPARATOR (BISTABLE)	G	GENERAL ELECTRIC	
-----			CN	CONVERTER/CONDITIONER		
TYPE OF EVENT			GS	GENERAL SWITCH		
CODE	DESCRIPTION	HS	HAND SWITCH			
B	RECURRING COMMON CAUSE FAILURE	IM	COMPUTATION MODULE			
C	COMMON CAUSE FAILURE	IN	INDICATOR/METER/ANNUNCIATOR			
R	RECURRING FAILURE	LM	COMPUTER			
S	COMMAND FAULT	LS	LIMIT SWITCH			
T	RECURRING COMMAND FAULT	MO	MONITOR			
U	COMMON CAUSE COMMAND FAULT	PS	POWER SUPPLY			
V	RECURRING COMMON CAUSE COMMAND FAULT	RC	RECORDER			
BLANK	RANDOM FAILURE	RE	RELAY/SOLENOID			
			SE	SENSOR		
			TI	TIMER		
			TR	TRANSFORMER		
			TX	TRANSMITTER		
			ZZ	OTHER/UNSPECIFIED		
			-----			
			EVENT CLASSIFICATION			
			CODE DESCRIPTION			
			D - FREQUENCY			
			T - AGE			
			U - UNKNOWN			

B-12

Table B-2. (continued)

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
SA	AUTOMATIC DEPRESSURIZATION (BWR'S ONLY)
TC	CONTAINMENT (INCLUDES PENETRATION & ISOLATION CONTROL)
SD	LOW PRESSURE CORE SPRAY (LPCS) (BWR'S ONLY)
SP	CONTAINMENT SPRAY INJECTION (CSI)
AG	CHEMICAL VOLUME CONTROL (CVC) (PWR'S ONLY)
SH	HIGH PRESSURE COOLANT INJECTION (HPCI)
SL	LOW PRESSURE COOLANT INJECTION (LPCI)
SO	REACTOR CORE ISOLATION COOLING (RCIC) (BWR'S ONLY)
AS	SERVICE WATER
CT	CONDENSATE AND FEED
PX	REACTOR TRIP
NN	ALL OTHERS
SN	OTHER ESIPARENT SYSTEM NOT IDENTIFIED)

**Table B-3. Manufacturers referenced in I&C LERs**

Code	Manufacturer
A015	A.P.V. Company, Inc.
A055	Adams & Westlake
A109	AGASTAT Relay Co.
A123	Airpac Electronics
A160	Allen-Bradley Co.
A200	Aloyco, Inc.
A370	Ampere Electronic Corp.
A380	AMPHENOL
A382	Amp Special Industries
A415	Anderson, Greenwood & Co.
A435	API Instr Co.
A485	Armstrong Mach
A499	ASCO
A501	Ashcroft Gauge
A533	Athena Control
A535	Atkomatic Valve Co., Inc.
A552	Atlas Valve
A580	Atomics International
A587	AUL Instruments
A610	Automatic Switch Company (ASCO)
A611	Automatic Timing and Control Inc.
A640	Automation Industries Inc.
A645	Automation Products, Inc.
B005	B-W Contr'or
B015	Babcock & Wilcox Company
B030	Babcock-Persta
B040	Bailey Instrument Co., Inc.
B045	Bailey Meter Company
B066	Barber-Colman Co.
B067	Barber Mfg. Company
B069	Barksdale Company
B070	Barksdale Valve Company
B080	Barton Instrument Co., Division of ITT
B093	Basler Electric Company
B130	Bechtel Corp.
B135	Beckman Instruments, Inc.
B165	Bell and Howell
B185	Belmont Smelting & Refining Works, Inc.
B222	Bertan Association Inc
B250	BIF
B350	Borg-Warner Corp.
B369	Bostrom-Bergen Metal Products
B371	Bourns Co.
B415	Bristol
B440	Brooks Instrument Company
B445	Brooks Rotameter
B450	Brown & Root Inc.
B481	Browning Co.

Table B-3. (continued)

Code	Manufacturer
B485	Bruce GM Diesel, Inc.
B515	Buffalo Forge Company
B572	Burns Engineering
C028	Cajon Co.
C075	Cannon Electric-ITT
C138	Carolina Power & Light Company
C268	Chemelex Corp.
C305	Chemtree Corp.
C345	Clare, C. P.
C360	Clark Controller
C415	Climet Instruments Co.
C470	Colt Industries, Inc.
C490	Combustion Engineering, Inc.
C515	CONAX Corp.
C518	Conde' Milking Machine Company
C520	Condec Corp.
C521	Conde Pump Company
C560	Consolidated Controls Corp.
C568	Consolidated Valve Corp.
C626	Controlotron
C635	Copes-Vulcan, Inc.
C649	Couch
C650	Cosmodyne
C680	Crane-Flowatics Div.
C685	Crawford Fitting Co.
C720	Crouse-Hinds
C753	Custom Component Switches, Inc.
C770	Cutler-Hammer
D012	Daniel Industries, Inc.
D055	De Laval Turbine, Inc.
D093	Deleval Condenser, Inc.
D142	Devar Connecticut
D149	Dialco
D150	Diamond Power Specialty Corp.
D232	Dragon Valve, Inc.
D243	Dresser Industrial Valve & Inst. Div.
D282	DWYER
E020	Eagle Signal
E095	Edwards Valves Div.
E146	Electro-Mechanics
E158	Electro-Mechano
E259	Engdahl Enterprises
E328	ESSEX Wire Corp.
F010	Fairbanks Morse
F013	Fairchild Products Hiller, Fairchild Hiller Products



Table B-3. (continued)

Code	Manufacturer
F020	Fansteel, Inc.
F030	Farr Co.
F080	Fenwall Electronics Co.
F081	Fenwall, Inc.
F120	Fischer & Porter Co.
F127	Fisher Flow Control Div (Rockwell Inter)
F128	Flow Technology Inc.
F130	Fisher Controls Co.
F166	Flowmatics
F180	Foxboro Co., The
G030	Gamma Process Co., Inc.
G039	Gates Rubber Co.
G046	Gast Manufacturing Corporation
G048	Gelman Instrument Co.
G050	Gems, Inc.
G051	Gedney Electric
G063	General Atomic Co.
G080	General Electric Co.
G100	General Motors
G112	General Precision Inc.
G166	Glen Controls Inc.
G175	Gordon, Claud S. Co.
G190	Goulds Manufacturing
G200	Goulds Pumps Inc.
G202	GPE Controls
G223	Grayhill
G272	GTE Sylvania Inc.
G290	GA Electronic Systems Div.
G305	Gulf General Atomic, Inc. (see G063)
H015	Hagan Controls
H020	Hagan/Computer Systems
H021	Hagan Corporation
H025	Hamilton Manufacturing Co.
H041	Hankison Corp.
H065	Harshaw Chemical Co.
H120	Hayden Mfg. Co.
H138	Heise Bourdon Tube Co.
H165	Hewlett Packard Co.
H260	Honeywell Corporation
I010	IBM Corp.
I075	Ingersoll-Rand Co.
I130	International Instruments, Inc.
I149	International Telephone & Telegraph Corp.
I202	ITE Imperial Corporation
I204	ITT-Barton
I207	ITT Grinnell

Table B-3. (continued)

Code	Manufacturer
J073	Johnson Controls Inc.
J090	Johnson Service Co.
K085	Kerotest Manufacturing Corp.
K130	Kinematics, Inc.
L010	L N D, Inc.
L045	Lambda Electronics
L130	Leeds & Northrup Co.
L180	Leybold-Heraeus Inc.
L185	LFE Corp.
L200	Limitorque Corp.
L206	Licon Division (Illinois Tool Works Inc.)
M035	Magnetics, Inc.
M040	Magnetrol, Inc.
M095	Marotta Value Corp.
M120	Masoneilan International, Inc.
M170	McDonnell & Miller ITT
M175	McGraw Edison
M225	Meltron Corp.
M235	Mercoide Corp.
M270	Metal Bellows
M282	Meter Devices Co.
M285	Metra Instruments
M302	Micro Switch
M314	Mid-West Instrument
M325	Milton-Roy Co.
M371	Modulash Corp.
M422	Moore Industries
M455	Motorola
N007	NAMCO Controls
N010	Nash Engineering Co., The
N015	National ACME Co.
N049	National Semi Conductor
N080	Nelson Electric
N114	Newport Laboratories
N120	NGK Insulator
N150	Nooter Corp.
N191	Nortec
N235	Nuclear Containment Systems, Inc.
N305	Nuclear Measurements Corp. (NMC)
N310	Nuclear Pacific, Inc.
N330	Nuclear Research Corp.
O080	Oster Manufacturing Co.

Table B-3. (continued)

Code	Manufacturer
P015	Pacific Electric Mfg.
P070	Parker Hannifin Corp.
P129	Penn Controls Inc.
P175	Permutit Co., The
P200	Philco Ford Corp.
P235	Pioneer Aluminum Inc.
P297	Potter & Brumfield
P314	Power-Mate
P323	Power Designs Inc.
P387	Pressure Switch Co.
R070	Radiological Systems
R078	Ramapo Instrument Co.
R120	RCA Electronic Components
R139	Rees Instruments LTD.
R140	Reactor Controls Inc.
R165	Reliance Electric Company
R278	Riley Co., The
R290	Robertshaw Controls Co.
R335	Rochester Instrument Systems, Inc.
R340	Rockwell Manufacturing Co.
R344	Rockwell-International
R362	Roots-Connersville Blower
R369	Rosemount, Inc.
R370	Rosemount Engineering Company
R378	Rofork Inc.
R389	Rowan Controller
R390	Rowe Industries Div.
S054	Scam Instrument Corp.
S075	Schutte and Koerting Co.
S093	Schwitzer
S185	Sigma Instruments, Inc.
S190	Signal Engineering Mfg.
S202	Simplex Wire and Cable Co.
S204	Simmonds Precision
S205	Singer Co., The
S245	Sola Electric Co.
S257	Sorensen
S258	Sorgel Electric Co.
S260	Sostman, H. E. Company
S345	Square D Co.
S371	Stallings & Lanley
S379	Static Products
S382	Static-O-Ring
S392	Stearns-Roger Fabricators Inc.
S395	Steel Fabricating Co.
S420	Stone & Webster Engineering Corp.
S525	Systems Engineering Laboratories, Inc.

Table B-3. (continued)

Code	Manufacturer
T020	Target Rock Corporation
T039	Taylor Instrument Companies
T040	Taylor Instrument Process Control Div.
T078	Technipower Inc.
T083	Teledyne Corporation
T100	Teledyne-Geotech
T115	Teleflex, Inc.
T120	Tempo Instrument, Inc.
T147	Terry Steam Turbine Company
T155	Texas Instruments Inc.
T161	TGM Detectors, Inc.
T185	Thermon Mfg.
T215	Times Wire and Cable
T248	Topay Electronics
T250	Torngren Co.
T260	Tracer Lab
T287	Transmation, Inc.
T300	TRAPELO
U010	U.S. Gage Company
U075	United Electric Controls Company
V033	Valmont Industries
V065	Varian Data Machines
V085	Velan Valve Corp.
V110	Vickery Simms, Inc.
V115	Victoreen Instrument Div.
V125	Viking Pump Co.
V132	Vitro Engineering Division
V135	Vogt, Henry Machine Co.
W030	Walworth Co.
W120	Westinghouse Electric Corporation
W121	Westinghouse Electric Company (Elev Div)
W128	West Steel
W130	Westronics, Inc.
W165	Whitey Co.
W209	Wilmar Electronics Inc.
W290	Woodward Governor Co.
W305	Worcester Controls Corp.
X001	Xerox Data System
Y005	Yarnall-Waring Co.
Y010	Yarway Corp.
ZZZZ	Unknown

## References

- B-1. *Operating Units Status Report, 6, 3*, NUREG-0020, March 1982.
- B-2. *Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File*, NUREG-0161, July 1977.

APPENDIX C  
LER RATE ESTIMATION METHODS

## APPENDIX C

### LER RATE ESTIMATION METHODS

To estimate the LER fault rates for components, the following well-known statistical methods were used for Type-I censored data with replacement.<sup>C-1</sup>

The general methods for estimating rates on an hourly basis and on a demand basis are

$$\hat{\lambda}(\text{hourly}) = \frac{N}{T} \quad (\text{C-1})$$

$$\hat{\lambda}(\text{demand}) = \frac{N}{D} \quad (\text{C-2})$$

where

$\hat{\lambda}$  = estimated fault rate

$N$  = number of reported component faults

$T$  = total time accrued by all components

$D$  = total number of demands on all components.

The general computational formulas, Equations (C-1) and (C-2), may be applied to particular situations. The fault rate for a component in a particular plant is estimated by setting

$$N = N_i$$

$$T = T_i$$

$$D = D_i$$

where

$N_i$  = number of component faults in plant  $i$

$T_i$  = total accrued hours of all like components in plant  $i$

$D_i$  = total accrued number of demands on all like components in plant  $i$ .

In a similar manner, fault rates may be estimated for components manufactured by a particular vendor, for components in a particular plant type (PWR or BWR), or for components present in all plants.

Confidence limits for hourly fault rates were based on the assumption that the underlying component fault distributions are exponential; therefore, the resulting LER data are representable by a Poisson process. In demand evaluations,  $N$  is binomially distributed. However, since the probability of fault is small and the number of demands is large, the Poisson distribution may be used to approximate this variable. The generalized formulas for estimating 100(1 -  $\alpha$ )% confidence limits on the fault rates are

$$\frac{\chi_{\alpha/2}^2(2N)}{2T} \leq \lambda(\text{hourly}) \leq \frac{\chi_{1-\alpha/2}^2(2N+2)}{2T} \quad (\text{C-3})$$

and

$$\frac{\chi_{\alpha/2}^2(2N)}{2D} \leq \lambda(\text{demand}) \leq \frac{\chi_{1-\alpha/2}^2(2N+2)}{2D} \quad (\text{C-4})$$

where

$\chi_a^2(b)$  = chi-square variate at cumulative probability,  $a$ , with,  $b$ , degrees of freedom.

In these equations,  $\alpha$  is the fraction left out in the intervals. For example, for 90% confidence limits  $\alpha$  is 0.10,  $\alpha/2$  is 0.05, and the upper limit uses the 95th percentile.

If  $D$  is small, then the Poisson approximation of the binomial distribution is not adequate, and 100(1- $\alpha$ )% confidence limits for the demand fault rate are

$$\begin{aligned} \frac{NF_L}{D - N + 1 + NF_L} &\leq \lambda(\text{demand}) \\ &\leq \frac{(N + 1) F_U}{D - N + (N + 1) F_U} \end{aligned} \quad (\text{C-5})$$

where

$$F_L = F_{\alpha/2}(2N, 2D - 2N + 2),$$

$$F_U = F_{1-\alpha/2}(2N + 2, 2D - 2N), \text{ and}$$

$F_{a(b,c)}$  = F variate at cumulative probability,  $a$ , with,  $b$ , and,  $c$ , degrees of freedom.

As before, for 90% confidence limits the 0.05 and 0.95 quantities are used ( $\alpha = 0.10$ ).

In this work, hourly rate confidence limits were always based on Equation (C-3). Demand rate confidence limits were based on Equation (C-4) if  $D - N \geq 100$ , and on Equation (C-5) otherwise.

The lower limits in Equations (C-3), (C-4), and (C-5) are not defined in cases where no faults are observed ( $N = 0$ ). Zero is the appropriate lower limit in these cases. However, Equations (C-1) and (C-2) also give zero as the point estimates when  $N = 0$ . More realistic point estimates for such cases are

$$\hat{\lambda} = \frac{\chi^2_{0.50}(2N+1)}{2T} \quad (C-6)$$

$$\hat{\lambda} = \frac{\chi^2_{0.50}(2N+1)}{2D} \quad (C-7)$$

and

$$\hat{\lambda} = \frac{(2N+1)F_M}{2D-2N+1+(2N+1)F_M} \quad (C-8)$$

where

$$F_M = F_{0.50}(2N+1, 2D-2N+1)$$

and the F and  $\chi^2$  distribution percentile and degree of freedom notations are as defined above.

Equation (C-6) applies for hourly rates while Equation (C-7) is used with the upper bound from Equation (C-4), and Equation (C-8) is used with Equation (C-5). Equations (C-6) and (C-7) are applicable to faults occurring according to a Poisson distribution regardless of the number of faults observed. A similar comment applies to Equation (C-8) and the binomial distribution. Typical estimates from Equation (C-6) are in the following table for comparison with Equation (C-1). Equation (C-6) has been used in other fault data studies, such as Reference C-2.

$N$	$\hat{\lambda}$
30	30.15/T
20	20.15/T
10	10.15/T
5	5.15/T
2	2.18/T
1	1.19/T
0	0.23/T

The estimates of Equations (C-6) through (C-8) can be obtained in two ways. The first is to consider shrinking the confidence intervals of Equations (C-3), (C-4), and (C-5) to the case where  $\alpha = 1.00$  and both  $\alpha/2$  and  $1-\alpha/2$  are 0.5. Because of the differing degrees of freedom, the intervals do not shrink to a single point. The equations use an average for the differing degrees of freedom. Because the estimates use 50th percentiles, they are related to medians.

The second way of considering Equations (C-6) through (C-8) uses the medians directly. In a Bayesian context,  $\lambda$  is regarded as a random variable. With Poisson sampling and a noninformative conjugate prior distribution, the posterior distribution for the occurrence rate has a gamma distribution with parameters<sup>C-3</sup>

$$(\alpha, \beta) = (N + 1/2, 1/T) \quad (C-9)$$

Because the gamma distribution with parameters  $(N, 2)$  is identical to the chi-square distribution with  $2N$  degrees of freedom,<sup>C-4</sup> Equation (C-6) can be shown to be the median of the distribution described by Equation (C-9). Using a similar relation between beta and F distributions, Equation (C-8) can be derived as the median of the posterior fault rate distribution obtained in sampling from a binomial distribution with a noninformative conjugate prior.

In summary, Equations (C-6), (C-7), and (C-8) describe median point estimates for the fault rate. They can be used when  $N = 0$ , and are more conservative in that case than the point estimates given in Equations (C-1) and (C-2). In this work, they are



used with, respectively, the upper confidence limits in Equations (C-3), (C-4), and (C-5) whenever no faults are observed.

In estimating the above confidence limits, all components in the sample were assumed to have

exactly the same true fault rate. No effort was made to account for possible variations arising from the mixture of populations having different true fault rates. For further discussion of the assumptions and limitations of these confidence limits, see References C-1 and C-5.

## References

- C-1. L. J. Bain, *Statistical Analysis of Reliability and Life-Testing Models*, New York: Marcel Dekker, Inc., 1978, p. 157.
- C-2. *NPRDS 1978 Annual Reports of Cumulative System and Component Reliability*, NUREG/CR-0942, Southwest Research Institute, September, 1979.
- C-3. G. E. P. Box and G. C. Tiao, *Bayesian Inference in Statistical Analysis*, Addison-Wesley, Reading, MA, 1973.
- C-4. N. R. Mann, R. E. Shafer, and N. D. Singpurwalla, *Methods for Statistical Analysis of Reliability and Life Data*, New York: John Wiley and Sons, Inc., 1974.
- C-5. N. L. Johnson and S. Kotz, *Discrete Distributions*, New York: John Wiley and Sons, Inc., 1969, pp. 58-59 and 96.

**APPENDIX D**

**INSTRUMENTATION AND CONTROL ONE-LINERS  
SORTED BY NSSS VENDOR**

CODES USED IN LER ONE-LINE DESCRIPTIONS

<u>FAULT MODE</u>		<u>FAULT CAUSE</u>	<u>ACTIVITY RESULTING IN DISCOVERY</u>
<u>CODE</u>	<u>DESCRIPTION</u>	<u>CODE</u>	<u>DESCRIPTION</u>
A	REDUCED CAPABILITY	00	UNKNOWN
B	INOPERABLE	01	PERSONNEL OPERATION
-----		02	PERSONNEL MAINTENANCE
<u>FUNCTION</u>		03	PERSONNEL TESTING
<u>CODE</u>	<u>DESCRIPTION</u>	04	DESIGN ERROR
I	REACTOR TRIP	05	FABRICATION/CONSTRUCTION/QUALITY CONTROL
E	ENGINEERED SAFETY FEATURES ACTUATION	06	DEFECTIVE PROCEDURES
R	REACTOR CONTROL	07	EXTREME ENVIRONMENT
G	GENERAL CONTROL/INDICATION/ALARM	08	MECHANICAL MALFUNCTION
R	RADIATION DETECTION	09	ELECTRICAL MALFUNCTION
-----		11	LEAKING OR BLOCKED INSTRUMENT SENSING LINES
<u>PARAMETER</u>		12	DIRTY, BINDING, OR STICKING
<u>CODE</u>	<u>DESCRIPTION</u>	13	PIECE PART FAULT
L	LIQUID LEVEL	14	DRIFT
N	NUCLEAR (CORE FLUX)	-----	
F	FLOW	<u>COMPONENT</u>	
T	TEMPERATURE	<u>CODE</u>	<u>DESCRIPTION</u>
R	RADIATION	AM	AMPLIFIER/BUFFER/ISOLATION AMPLIFIER
P	PRESSURE/VACUUM	CA	CABLE/RECEPTACLE/JUNCTION BOX/TERMINAL
D	POSITION	CL	CONTROLLER
X	OTHER/UNKNOWN	CM	COMPARATOR (BISTABLE)
-----		CH	CONVERTER/CONDITIONER
<u>TYPE OF EVENT</u>		CS	GENERAL SWITCH
<u>CODE</u>	<u>DESCRIPTION</u>	HS	HAND SWITCH
B	RECURRING COMMON CAUSE FAILURE	IM	COMPUTATION MODULE
C	COMMON CAUSE FAILURE	IN	INDICATOR/METER/ANNUNCIATOR
R	RECURRING FAILURE	CM	COMPUTER
C	COMMAND FAULT	LS	LIMIT SWITCH
R	RECURRING COMMAND FAULT	MD	MONITOR
C	COMMON CAUSE COMMAND FAULT	PS	POWER SUPPLY
R	RECURRING COMMON CAUSE COMMAND FAULT	RC	RECORDER
BLANK	RANDOM FAILURE	RE	RELAY/SOLENOID
		SE	SENSOR
		TI	TIMER
		TR	TRANSFORMER
		TX	TRANSMITTER
		ZZ	OTHER/UNSPECIFIED
		-----	
		<u>NSSS VENDOR</u>	
		<u>CODE</u>	<u>DESCRIPTION</u>
		D	BABCOCK & WILCOX
		C	COMBUSTION ENGINEERING
		W	WESTINGHOUSE
		G	GENERAL ELECTRIC
		-----	
		<u>EVENT CLASSIFICATION</u>	
		<u>CODE</u>	<u>DESCRIPTION</u>
		D	FREQUENCY
		T	AGE
		U	UNKNOWN

SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
SA	AUTOMATIC DEPRESSURIZATION (BWR'S ONLY)
SC	CONTAINMENT (INCLUDES PENETRATION & ISOLATION CONTROL)
SD	LOW PRESSURE CORING SPRAY (LPCS) (BWR'S ONLY)
SE	CONTAINMENT SPRAY INJECTION (CSI)
AG	CHEMICAL VOLUME CONTROL (CVCS) (PWR'S ONLY)
SH	HIGH PRESSURE COOLANT INJECTION (HPCI)
SL	LOW PRESSURE COOLANT INJECTION (LPCI)
SR	REACTOR CORE ISOLATION COOLING (RCIC) (BWR'S ONLY)
SW	SERVICE WATER
CC	CONDENSATE AND FEED
RR	REACTOR TRIP
NO	ALL OTHERS
SN	OTHER ESP (PARENT SYSTEM NOT IDENTIFIED)

INSTRUMENTATION AND CONTROL ONE-LINERS SORTED BY N555 VENDOR

N555	PLAN T	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION	
B	ARI	013962	010576	PS	DC	NN	B13	N	R	T			DURING NORMAL OP., CONTROL ROD GROUP 6 TRIPPED	APP. CAUSE IS FAILURE OF GROUP 6 PS	
B	ARI	014496	032376	GS	PT	PX	A14	T	F				RX BUILDING PRESSURE SWITCH FAILED TO TRIP	INSTRUMENT DRIFT	
B	ARI	016955*	011077	GS	PG	SN	B07	N	C	U	4	4	SLBIC ALARM ACTUATION IN CONTROL ROOM	ALL 4 SENSING LINES FROZE ACTUATING PS	
B	ARI	017234A	021977	TX	FG	AG	B13	T	R	D			FLOW TRANSMITTER ON HPI SYSTEM (LOOP A) FAILED	BELLOWS FAILED DUE TO OVERPRESSURIZATION	
B	ARI	017234B	021977	TX	FG	AG	B13	T	R	D			FLOW TRANSMITTER ON HPI SYSTEM (LOOP A) FAILED	BELLOWS FAILED DUE TO FATIGUE	
B	ARI	017234C	021977	TX	FG	AG	A14	T	T		2		FLOW TRANSMITTERS ON HPI SYS (LOOP B) OUT OF CAL.	NORMAL DRIFT	
B	ARI	021416	042678	RE	XG	NN	B09	T	D				EMERGENCY SUPPLY FANS FAILED TO START AUTOMATICAL.	GROUND AT ACTUATING SOLENOID	
B	ARI	026910	081379	RE	XT	PX	B13	N	U				TURBINE LOCKOUT FAILED	LOOSE TERMINALS AND BROKEN LUG ON RELAY	
B	ARI	038482	080481	ZZ	NT	PX	A02	M	U				B RPS SCALD DIFF IN AMP GAIN SETTING ERRONEOUS	WRNG POTENTIOMETER ADJUSTD IN PREVIOUS CAL	
B	CR3	017175	020177	IN	TG	NN	B13	T	R	U			RC REMOTE TEMPERATURE INDICATOR FOUND TO BE IN ERR	METER MOVEMENT FAILED-REPLACED & CALIBRAT	
B	CR3	017169	020477	ZZ	PG	NN	B01	N	D				LOW RANGE OVERPRESSURE PROTECTION CIRCUIT NOT ARME	PERSONNEL ERROR-FAILED TO FOLLOW PROCEDURE	
B	CR3	018406	040677	CA	DC	NN	B13	N	U				INOPERABLE POSITION INDICATOR FOR ROD 5 GROUP 8	AMPHENOL CONNECTOR FAULTY PIN CONNECTION	
B	CR3	018232	060777	MO	RR	NN	B07	N	R	D			RMA-6 VAC PUMP INOPERABLE ON THREE DIFFERENT DCASN	THRM COND CAUSED TRIP, USING TEMP FAN	
B	CR3	018384	062977	IN	DG	NN	B13	N	R	T			ABSOLUTE POSITION INDICATOR DECLARED INOPERABLE	FAILURE OF ABSOLUTE POSITION INDICATOR TU	
B	CR3	018391	070277	PS	DC	NN	B09	T	U				ROD 3 GROUP 6 API FOR ALL REG RODS WAS LOST	15 VOLT POWER SUPPLY SPIKE-CAUSE UNKNOWN	
B	CR3	018555	071277	TX	LG	SN	A14	N	T				A AND B LEVEL CHANNELS OF BWST DISAGREED	CALIBRATION SHIFT OF LEVEL IND TRANSMITTE	
B	CR3	019011	082277	IN	DG	NN	B00	N	U				API FOR ROD 6 GROUP 7 FAILED AND DECLARED INOPERAB	CAUSE UNKNOWN-SELF CORRECTED	
B	CR3	019009*	090277	TX	FT	PX	A14	R	T		4	4	4 RCS FLOW INSTRUMENTS OUT OF CALIBRATION	CALIBRATION DRIFT OF D/P TRANSMITTERS	
B	CR3	019002	091877	MO	RR	NN	B13	N	R	T			RB PURGE MONITOR RM-A1 DECLARED INOPERABLE	VACUUM PUMP FAILED	
B	CR3	019304*	092077	IN	DG	NN	B13	N	R	T		4	4	API FOR ROD 1 GROUP 8 FAILED	MIS-ALIGNMENT OF API TUBE
B	CR3	019639	110777	MO	RR	NN	B13	N	R	D			RM-A6 VAC PUMP INOPERABLE, CSD LOSS OF LK DET SYS	WORN & DISTORTED CARBON VANES, 2ND OCCURNC	
B	CR3	019885	120877	MO	RR	NN	B00	T	U				DHV FOR ECCS PUMP WOULD NOT CONTROL FLOW AT 3000 G	CALIBRATION SHIFT OF FLOW SWITCH	
B	CR3	020753*	020378	GS	PS	SN	A14	N	T		2		CONTROL COMPLEX RETURN DUCT RAD MONITOR OP UNSATIS	CAUSE UNKNOWN-COULD NOT DUPLICATE	
B	CR3	021164	040878	MO	RR	NN	A00	N	U				B STEAMLINE RUPTURE MATRIX ACTUATED	DEAD BAND SHIFT OF PRESSURE SWITCHES	
B	CR3	021209	042878	MO	RR	NN	B13	N	R	T			FUEL POOL AREA RAD MONITOR SPIKING HIGH INTERMITTE	CAUSE UNKNOWN-STILL UNDER INVESTIGATION	
B	CR3	021777	060378	MO	RR	NN	B13	T	R	T			MOTOR OL RELAYS FOR RAD MON RM-2 FOUND DEFECTIVE	MOTOR OVERLOAD RELAYS WERE RENEWED	
B	CR3	022041	080178	SE	NS	SN	B13	N	T				AUX BLDG MONITOR FAILED TO RESPOND	FAILED SURGE CAPACITOR IN CONTROL RELAY	
B	CR3	022710	091578	IN	DG	NN	B06	T	D				STARTUP RATE AND COUNT RATE FOR N12 OSCILLATING	FAILED SOURCE RANGE DETECTOR (NI-2)	
B	CR3	022708	092078	MO	RR	NN	A14	N	R	T			RELATIVE POSITION INDICATOR INOPERABLE (RMA-7 ROD-8)	PROCEDURE-REACTIMETER TERMINATION TO RPI	
B	CR3	023422	100578	RE	XS	IC	B08	T	D				RX BUILDING AIR SAMPLE MONITOR INOPERABLE (RMA 6)	FLOW CONTROLLER OUT OF ADJUSTMENT	
B	CR3	023168	111378	MO	RR	NN	B13	N	R	T			M RELAY IN ACTUATION CH CABINET 2A WAS STICKING	IMPROPER RELAY ALIGNMENT, CABLE STRESS	
B	CR3	023167	111578	MO	RR	NN	B01	T	D				VACUUM PUMP FOR RAD MON RMA-1 SEIZED	CAUSE NOT MENTIONED, REPAIRED BY NORM MAIN	
B	CR3	023165	112178	GS	DC	NN	A12	T	R	T			CONTAINMENT ATMOS RAD MONITOR IN PURGE MODE (RMA-1)	PERSONNEL ERROR-WRONG MODE OF OPERATION	
B	CR3	023420	121378	RE	XC	IC	B12	T	R	T			API FOR ROD 4 GROUP 3 NOT OBSERVED AS ROD MOVED	STICKING REED SWITCH	
B	CR3	02421*	121378	GS	DC	NN	A12	T	R	T	2		RB3-GP-2 LIGHT DID NOT LIGHT WHEN CIRCUIT TESTED	RELAY L IN ES CABINET STUCK, CLEANED	
B	CR3	023418	122478	MO	RR	NN	B13	N	R	T			2 API FOR ROD 5 GROUP 6 FLUCTUATING (OCCURRED TWICE)	STICKING REED SWITCHES	
B	CR3	025353	011979	RE	XS	SN	B12	T	R	T			SAMPLE PUMP FOR RAD MON RMA-6 FAILED	WORN AND DISTORTED CARBON VANES	
B	CR3	025357	021479	RE	XS	IC	B12	T	R	D			RELAY AR IN CABINET 5C FAILED	DIRTY CONTACTS	
B	CR3	025351	022079	SE	TS	SL	B00	N	U				RELAY FAILED	BURR ON RELAY SHAFT	
B	CR3	025350	022379	RC	XG	AG	B13	N	T				RTD DH-2-TE FOR DH-39-TI, DH COOLER OUTLET TEMP, //	FAILED, NO CAUSE GIVEN	
B	CR3	025345	022379	IN	PG	CT	A07	N	D				TRACE RECORDER HTRT-5 FOR CON BORIC ACID FLOW-PATH	//FOUND INOPERABLE, FAILED DRIVE WHEEL	
B	CR3	025628	031879	MO	RR	NN	B13	N	R	U			MOTOR DRIVEN AUX FEED PUMP DISCH PRESS GAUGE FOUND	// GUC, INOPERABLE DAMPING SNUBBER	
B	CR3	025629	032179	SE	DG	NN	A12	N	T				RX BLDG IODINE RAD MON RMA-6 FOUND INUP	FAILED PRINTED CIRCUIT BOARD	
B	CR3	025630	032179	IN	PG	CT	B00	T	U				POSITION INDICATION FOR ROD 8 GROUP 6 WAS LOST	REED SWITCH FOUND STICKING	
B	CR3	025632	032779	RC	XG	AG	B13	N	T				MOTOR DRIVEN AUX FEED PUMP DISCH PRESS GAUGE FAIL	NO CAUSE GIVEN	
B	CR3	025634	033079	RC	XG	AG	B00	N	U				TRACE RECORDER HTRT-5 FOR CON BORIC ACID FLOW-PATH	//FOUND INOPERABLE, FAILED DRIVE CURD	
B	CR3	025934	040479	MO	RR	NN	A02	M	V	D			HEAT TRACE RECORDER HTRT-1 PERFORMED ERRATICALLY	CAUSE UNKNOWN	
B	CR3	025935	040479	MO	RR	NN	A00	N	S	D			DISCOVERED SENSOR FOR RX BLDG RAD MON MIS-POSITION	NOT POSITIONED CORRECTLY AFTER MAINTENAN.	
B	CR3	025991A	050979	AM	NT	PX	A14	T	T				BKR FOR RX BLDG RAD MON FOUND OPEN	NO CAUSE FOUND	
B	CR3	025991A	050979	AM	NT	PX	A14	T	T				NUCLEAR SOURCE RANGE INS NI-1 FOUND OOC	COUNT-RATE AMP HAD DRIFTED	

D-5

The remainder of Appendix D is provided on microfiche.

**APPENDIX E**

**INSTRUMENTATION AND CONTROL ONE-LINERS  
SORTED BY HUMAN FACTORS**

## CONTENTS

Personnel Operation .....	E-001
Personnel Maintenance .....	E-004
Personnel Testing .....	E-010
Design Error .....	E-011
Fabrication/Construction/Quality Control .....	E-014
Defective Procedures .....	E-016





























DESIGN ERROR

PLANT	CONTROL NUMBER	EVENT DATE	AREA	DESCRIPTION	STATUS	CAUSE	CLASS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
B	CR3	038102	071881	IN FG NN A04 N V D					EMERG FW ULTRASONIC FLD IND OUT OF ZERO CHECK LO//	LMT. UNABLE TO CONSISTENTLY IND ZERO FLOW
B	CR3	172159	120881	IN FG CT A04 M V D					EMERGENCY FW ULTRASONIC FLD IND FW-313-FI DRIFTED	DESIGN ERROR
B	DB1	023594*	121578	MO RR NN 804 T B D			10	SER. MTR. OUT RAD MONITOR REB432 INOPER. ON 10 DAYS	DESIGN ERROR-FLOW SWITCH STICKS IF D/P LU	
B	DB1	026808	010479	MO RR NN 804 T B D				REB432 ON SERVICE WATER HEADER HAD NO FLOW	SYSTEM OP INSUFFICIENT DUE TO DESIGN	
B	DB1	026594	070779	GS PG CT 804 T B D				PSL-49298 AFW PUMP 1-2 SUCTION BEFORE STRAINER SW/	7/FAILED. WRONG MATERIAL USED IN DIAPHRAM	
B	DB1	027423*	110979	CM XG CT A04 R U D			2	SFRCS CH 1&2 FOUND TO HAVE SETPOINTS LESS CONSER//	VATIVE THAN REQUIRED. DESIGN CALCULATION	
B	DB1	030262	012280	ZZ XG NN 804 T V D				NI-7 IND ON CMPTR GRP 38 RCG BELOW HEAT BALNC PWR	DESIGN ERROR EXTRMLY TIGHT 100% CAL BAND	
B	DB1	030434	021780	TX LS SN 804 N B D				SFAS CHNL 3 BWST HIGH LVL IND DECLRD INOP	COLD WEATHER FROZE XMITR LT1525C SENS LIN	
B	DB1	030457A	022680	TX LS SN 804 N B D				SFAS CHNL 3 BWST HIGH LVL IND DECLRD INOP	INADEQUATE DESIGN OF FREEZE PROTECTION	
B	DB1	030457B	022980	TX LS SN 804 N B D				SFAS CHNL 3 BWST HIGH LVL IND DECLRD INOP	INADEQUATE DESIGN OF FREEZE PROTECTION	
B	DB1	031472	060680	IN LG NN A04 T U D				SPENT FUEL POOL LVL BELOW TECH SPEC	IMPROPER ALARM SETPOINT	
B	DB1	033357	120380	ZZ XG NN 804 T V D				SHRT CKT LOST Y3 THUS RPS-3 & SFAS-3 INOP	DESIGN ERROR ALLIGATOR CLIPS TOO SMALL	
C	AR2	031785	070880	IN XG NN 804 N S D				"B" SG HI PRETRIP/TRIP ON CHANNEL "C" PPS	DEFECT B/S CRD (PPS "C" SG-2 HI LVL CARD)	
C	CL2	014901	051176	IN XG NN 804 N S D				CH A RPS VOPT RESETTING AUTOMATICALLY	ELECTRICAL NOISE FROM ANNUNCIATOR	
C	CL2	027797B	112779	ZZ PG SN 804 N C D				CH ZG PZR PRESS XMITTR TAKEN OOS TO REPAIR CON//	DUIT. CONDUIT TO CLOSE TO PIPE HANGER	
C	FC1	014509	032776	IN NI PX 804 N R U				BCH 19-301A ADD-SUB MODULE WENT INTO OSCILLATION	CIRCUIT MODIFIED PER LATER LER	
C	FC1	014510	040576	IN NI PX 804 N R U				CH 8 APD POS LIMIT HIGH	BCH 19-301A ADD-SUB MODULE OSCILLATING	
C	FC1	014558	041376	IN NI PX 804 N R U				CH A APD POS LIMIT HIGH	BCH 19-301A MOD OSCILLATING, RANDOM NOISE	
C	FC1	014361	101177	GS LG SN 804 T T				STRWT RECIRC LEVEL SW A/LC-383 FAILED TO TRIP	WRONG SWITCH FOR APPLICATION	
C	MY2	044015*	011476	IN TT PX 804 R C U			4	4 OF 4 TM/LP TRIP NON-CONSERVATIVE FOR ALL CONDITI	DESIGN WIRING ERROR INPUT TO CEA FUNC GEN	
C	MI2	033801	040380	CM PT PX A04 N U D			2	A-RPS LO SG PRESS BTPS REMVL B/S CARD HIGH SETPOINT	HI SENSIVTY TO CHANGE IN INPUT RESISTANCE	
C	MI2	033062*	102380	CA NT PX 804 T B D				0-RPS HI PWR, LOCAL PWR DENSITY & TM/LP TRPS INOP	REVERSED UPPER & LOWER DET SIG CABLES	
C	MY1	027009	091079	MO RR NN A04 R U D				LIQUID RAD WASTE RAD MONITOR DID NOT RESPOND PROP	INSTALLED CHECK SOURCE TO SMALL	
C	MY1	037085	050981	GS LS SK 804 T D				RWST LEVEL SWITCH INTERLOCK FOR RAS FOUND FAILED	MATERIAL INCOMPATIBILITY	
C	SL1	014849	050476	IN DC NN 804 T S D				DATA PROCESSOR MALFUNCT. CAUSN LOSS OF CEA PULSE	CONT. PROGRAM SKIPPED 160K OF WORDS	
C	SL1	014850	051276	ZZ DC SN 804 N S D				POWER DEPEND. INSERTION LIMIT CHANGN IN NGNCONSERV	DIR. AS POWER INCREASED; ERROR IN WIRING D-	
C	SL1	021114	032678	PS PS SN 804 N T				1 CHAN. OF S/G LO PRESS FOR MAIN STEAM ISO. FAILED	POWER SUPPLY FAILED--REQUESTD DESIGN CHANG	
C	SL1	023394	120478	LA DG NN 804 N R D				DDPS MALFUNCTIONED	ERROR IN INSTALLED PROGRAM	
C	SL1	027298*	092179	CM LT PX A04 R C D			4	S/G LVL INSTRUMENTATION HAD A 2% NON-CONSERVATIVE	//ERROR. INCORRECT LEVEL SPAN USED	
C	SL1	033148	102480	IN DG NN 804 N C D				PRIMARY DDPS COMPUTER FAILD LOST PULSE COUNTG CEA/	/ POS IND. PROGRAM SOFTWARE ERROR	
C	SL1	172200	121081	SE NG NN 804 T U D				IN-CORE DETECTOR ALARM SET POINTS INCORRECT	COMPUTER SOFTWARE USED WRONG FLUX INPUTS	
M	DC1	172094A	121081	IN TG NN 804 N V D			2	2 RCS HOT LEG TEMP INDICATIONS RDG LOW	DESIGN ERROR IN MODIFICATION	
M	DC1	172094B	121081	IN PG NN 804 N V D				2 RCS WIDE RANGE PRESS INDICATN RDG LOW	DESIGN ERROR IN MODIFICATION	
M	DC2	021426A	051578	RE XG NN A04 T R D			2	H2 SKIMMER FANS STARTING; TIMES FOUND EXCESSIVE	WRONG STARTING RELAY RANGE, 2HV-CEQ2, Q1	
M	DC2	021426B	062078	RE XG NN A04 T R D				H2 SKIMMER FANS STARTING TIMES FOUND EXCESSIVE	WRONG STARTING RELAY RANGE, 2HV-CEQ2, Q1	
M	DC2	037005	041681	CM PT PX 804 R U D				TURB IMPULSE CHAMBR PRESS B/S SETPT IN ERROR	ERROR IN ENGR. DOC & T.S. TABLE	
M	DC2	172093A	121081	IN TG NN 804 N V D			2	2 RCS HOT LEG TEMP INDICATION RDG LOW	DESIGN ERROR IN MODIFICATION	
M	DC2	172093B	121081	IN PG NN 804 N V D				2 RCS WIDE RANGE PRESS INDICATION RDG LOW	DESIGN ERROR IN MODIFICATION	
M	JF1	022635*	092078	HS NT PX 804 T U			2	LOSS OF H.V. TO BOTH SOURCE RANGE NLS CHANNELS	SWITCH WIRING DESIGN	
M	JF2	038186	071781	TX FT PX 804 N U D				STM FLD XMITR FT-474 INOP BREAK IN XMITR VENT PIPE	OVERSIZED VLV USED IN SENS G LINE	
M	HG1	038414*	082281	IN FG CT 804 N C D			4	AUX FEED FLOW GAUGES IN CONTROL ROOM DIDNT AGREE//	WITH LOCAL GAUGES. WRONG SCALE USED	
M	NA1	032277A	080780	TX LT PX A04 N V D				PZR PROTCTN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSING DRIFT	
M	NA1	032275B	080880	TX LT PX A04 N V D				PZR PROTCTN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSG DRIFT	
M	NA1	032275C	080980	TX LT PX A04 N V D				PZR PROTCTN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSG DRIFT	
M	NA1	038751	092281	SE DG NN 804 N C D				IRPI FOR ROD 3-8, BANK D FOUND GREATER THAN 12 STE-	-PS BELOW DEMAND. TEMP CHANGE IN COIL	
M	PR2	018818	081977	IN XG SN 804 T S D				AUX BLDG VENT "NOT READY" MON LITES DID NOT ENERGZ	OPENING FAN BRKR DEGNRGZS LITE-DESIGN ERR	
M	RO2	023183	120578	RE XT PX A04 R U U				RPS RELAY RT-38 POTENTIAL GENERIC PROBLEM GE-BFD	THERMAL DETERIORATION/RELAY STICKING	
M	SAL	028007*	112179	MO RR TC 804 N U D			2	RADIATION MONITORS MADE INOPERABLE	OVERLOAD FROM TEMP EQUIPMENT TRIPPED BKR	
M	SAL	166702A	052181	ZZ LG IC 804 N U D				PARTIAL BLACKOUT CAUSED LOSS OF CNTNMT SUMP LEVEL	DESIGN ERROR IN D/G BREAKER	
M	SAL	166709B	052181	ZZ LG IC 804 N U D				PARTIAL BLACKOUT CAUSED LOSS OF CNTNMT SUMP LEVEL	DESIGN ERROR IN D/G BREAKER	

DESIGN ERROR

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROB	CAUSE	MODE	ACTIVITY	CLASS	FAIL	FAULT NODE DESCRIPTION	FAULT CAUSE DESCRIPTION
W	SE1	032343	081380	TX PG	NN	B04	N	B	D	REMOTE S/D MONITORING CHNL L-68-312C FOUND INOP	WTR IN LP SENSING LINE OF TRANSMITTER
W	SE1	032876A	100480	TX LG	NN	B04	N	V	D	PZR RELIEF TANK LI-68-312C INOP	XMITTR DRY LEG FULL OF WATER
W	SE1	032876B	101180	TX LG	NN	B04	N	V	D	PZR RELIEF TANK LI-68-312C INOP	XMITTR DRY LEG FULL OF WATER
W	SE1	032975*	101480	GV FT	NN	B04	N	U	D	2 ERCW NON O-FLO-90-134/141 INOP SPURIOUS HI SPIKES	PS-3-138A/B CHATTER PRODUCED ELEC PROBLEM
W	SE1	033603*	120980	CM FT	PX	A04	R	C	D	2 DP AT STM FLO XMITTR LESS THAN EXPECTED	STM/FW FLO MISMATCH B/S SETTING LESS CNSRVT
W	SE1	033727A	122580	TX PG	NN	B04	N	B	D	SG-3 "A" STEAMLINE PRESSURE CHANNEL FAILED HIGH	UNPROTECTED SENSING LINES FROZE
W	SE1	033727B	122580	TX PG	NN	B04	N	B	D	SG-3 "A" FLOW CHANNEL FAILED HIGH	UNPROTECTED SENSING LINES FROZE
W	SE1	033727C	122580	TX FG	NN	B04	N	B	D	3 SG-1,2,4 "B" FEEDWATER FLOW CHANNELS FAILED LOW	UNPROTECTED SENSING LINES FROZE
W	SE1	036220A	010581	TX FT	PX	B04	N	B	D	FEEDWATER FLOW CHANNEL F-3-35B(S/G #3) FAILED LOW	INADEQUATELY PROTECTED SENSING LINE FROZE
W	SE1	036075	011281	TX LS	SN	B04	N	B	D	RMST LEVEL CHANNEL L-63-53 FAILED	SENSING LINE FROZE INSULATION INSUF
W	SE1	036220B	011281	TX FT	PX	B04	N	B	D	FEEDWATER FLOW CHANNEL F-3-90B(S/G #1) FAILED LOW	INADEQUATELY PROTECTED SENSING LINE FROZE
W	SE1	036799A	032381	TX LT	PX	B04	N	B	D	3 PZR LEVEL CH 1-L-68-339, 325C & 1-L-326C FAILED	MODIFICATION TO CONDENSATE RESERVOIR
W	SE1	036799B	040281	TX LT	PX	B04	N	B	D	PZR LEVEL CH 1-L-68-339 DECLARED INOPERABLE	MODIFICATION TO CONDENSATE RESERVOIR
W	SE1	036799C	041781	TX LT	PX	B04	N	B	D	2 PZR LEVEL CH 1-L-68-325C & 326C DECLARED INOP	MODIFICATION TO CONDENSATE RESERVOIR
W	SE1	031075	050680	ZZ XG	NN	B04	N	U	D	INCORE FLUX THIMBLE BENT OUTWARD DEGRADIN OF PRIM/	7ARY COOLANT BDRY. DESIGN ERROR
W	TU3	017101*	010477	RE XT	PX	B04	T	C	D	4 IE CIRCULAR---ALL BFD RELAYS TESTD IN CKT. TRAINA	DEFECTIVE RELAYS, COILS OVERHEAT
W	TU4	014877	021476	IN LG	SN	A04	T	C	D	REF. WATER ST. INK 1 PERCENT LOW THAN ALLOWD T.S.	LEVEL GAGE IS WIDE RANGE; INSTALL NARROW R
W	TU4	017100*	010877	RE XT	PX	B04	T	C	D	2 ALL BFD RELAYS TESTD; 2 FOUND IN CKT. TRAIN A RT465	DEFECT RELAY; VARNISHD CLOTH OUTER COVER
W	YR1	023411	122878	MO RR	NN	B04	N	R	D	LD FLOW ALARM ON MAIN COOLNT APD; MOTOR FAILURE	EXCESS CURRENT DUE TO LO VOLTAGE
W	YR1	027502	110979	RE XS	SN	B04	T	C	D	SI ACCUMULATOR TIME DELAY RELAY FOUND OOC	DESIGN DEFICIENCY OF CAPACITOR IN PS
W	YR1	032987	101280	TX LT	PX	A04	M	U	D	LOW LEVEL SCRAM SETPOINTS BELOW TECH SPEC LIMITS	HARD TO VENT XMITR DUE TO LINE CONFIGRTH
W	Z11	016381*	101976	TX LS	SN	A04	T	C	D	6 ACCUM. LEVEL XMITRS SETPOINTS OFF 16 OF 3 WERE HI	INADEQUACY OF PRESENT XMITRS FOR GIVN RANG
W	Z12	038618A	091481	ZZ XG	CT	B04	T	C	D	2 FLAW DETECTED IN CONTROL CIRCUITS FOR 2B C 2C AFWP	DESIGN ERROR
W	BF2	014662*	041276	RE DC	NN	B04	T	C	D	3 FIVE REED RELAY FAILURES DISCOVERED	FAILED CONTACTS ON REED RELAYS/DESIGN ER.
W	BR1	019085A	091577	SE LG	NN	A04	N	R	D	TORUS LEVEL INST CAC-LT-2601 FOUND TO BE DRIFTING	MOISTURE IN DRY REFERENCE LEGS
G	BR1	019085B	091777	SE LG	NN	A04	N	R	D	TORUS LEVEL INST CAC-LT-2601 FOUND TO BE DRIFTING	MOISTURE IN DRY REFERENCE LEGS
G	BR1	020615*	020978	MO RR	NN	B04	T	R	D	2 CONT RADIATION MONITORS CAC-AQH-1260, 1262 FAILED	MOISTURE IN SENSING LINES
G	BR1	031410B	052680	SE NT	P7	A04	T	R	D	SRM C COUNT RATE DION'T DECR WHEN DET OUT OF CORE	PULSE HEIGHT DISCRIMINATOR OUT OF ADJUST
G	BR1	033699	122880	IN DC	NN	B04	N	B	D	ROD WORTH MINIMIZER INOP	COMPUTER RMM SOFTWARE DESIGN PROBLEMS
G	BR1	169949	100481	TX LG	NN	A04	N	B	D	IND XMITR 2CAC-LT-3342 OUT OF CALIBRATION	CHNG IN TRCKL FLOW TO WET REFRCN LEG XMITR
G	BR1	171928A	120581	TX LG	NN	A04	T	B	D	SUPPRESSION CHAMBER WTR LVL TX 1-CAC-LT-2602 RFAD-	-5" LOW. TRICKLE FLOW DESIGN ERROR
G	BR1	171928B	120881	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LVL TX 1-CAC-LT-2602 READ-	-3" LOW. TRICKLE FLOW DESIGN ERROR
G	BR1	171928C	121081	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LVL TX 1-CAC-LT-2602 READ-	-2.5" LOW. TRICKLE FLOW DESIGN ERROR
G	BR2	014652	020876	GS T6	SH	A04	N	R	D	HPCI ISOLATED ON STEAM LEAK DETECTION	TOO CONSERVATIVE REQUIREMENT
G	BR2	014944*	061276	GS LT	PX	A04	T	C	D	3 RX LOW WATER LEVEL SW 2-B21-LIS-M024 A,B,298 ACT L	CIRCUIT DESIGN USED HIGH LEVEL SWITCHES
G	BR2	017601*	022177	GS TG	SH	B04	N	R	D	3 HPCI ISOLATED ON SIGNAL FROM E41-DTS-N601A	COLD REACTOR INLET AIR
G	BR2	026629A	073179	TX LG	NN	B04	N	B	D	CAC-LT-3342 HAD IMPROPER CALIBRATION RANGE DUE TO	ELEVATION OF TRANSMITTER. DESIGN
G	BR2	026629B	073179	TX LG	NN	B04	N	B	D	2 CAC-LT-2601&2602 DISCOVERED OOC. PLAT RUNS IN //	SENSING LINES TRAPPS AIR
G	BR2	038491A	081781	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LVL IND READING OOC	EXACT CAUSE NOT STATED MODIF REQUESTED
G	BR2	038491B	082081	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LVL IND READING OOC	EXACT CAUSE NOT STATED MODIF REQUESTED
G	BR2	038491C	082381	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LVL IND READING OOC	EXACT CAUSE NOT STATED MODIF REQUESTED
G	BR2	038692	090981	TX LG	NN	A04	N	B	D	SUP CHNBR WTR LVL RECORDER 2-CAC-LT-2602 ROG OOC	CHANGE IN TRICKLE FLO TO XMITR WET REF LEG
G	BR2	038913	100481	TX LG	NN	A04	N	B	D	SUP CHNBR WTR LVL IND 2-CAC-LT-3342 ROG OOC	CHANGE IN TRICKLE FLO TO XMITR WET REF LEG
G	BR2	039366	112881	TX LG	NN	A04	N	B	D	SUPPRESSION CHAMBER WTR LI-2601-3 IND BELOW ACTUAL	CHANGE IN TRICKLE FLO TO XMITR WET REF LEG
G	CO1	022737	081478	RE XS	SD	B04	T	R	D	CORE SPRAY TOR #CS-TDR-K16B FAILED TO OPERATE	DESIGN ERROR, INOPERABLE DUE TO INACTIVITY
G	CO1	027469	100179	GS FG	NN	A04	T	C	D	MS-DPIS-119B FOUND OOC(INS ISO & CONTROL)	"SET" IN NEW INST AFTER INSTALLATION
G	CO1	032236B	041481	CM XC	NN	B04	T	C	D	IN SCRAM 2 SCRAM DSCHRG HEADER CMS CHNL UP IMPROPR	BONDING IN TRANSDUCER
G	DAL	016917	010777	MO RR	NN	B04	T	B	D	RR 4379B WAS FOUND DOWNSCALE ON PARTICULATE CHANNE	CONDENSATE IN DETECTOR-DESIGN ERROR
G	DAI	017310	021377	GS PG	NN	B04	T	U	D	RECIRC RISER D/P SWITCH DPIS 4644 NEEDLE STICKING	NEEDLE STICKING ON ADJUSTMENT LOCKSCREW
G	DAI	033570	120780	RC XG	SN	A04	N	V	D	D/W PRESS & TORUS WTR LVL RECORDER PR/LR-4384 INOP	POUR CABNT VENT/HI TEMP CAUSE PS OUT VARY









DEFECTIVE PROCEDURES

UNCLAS	PLANT	CONTROL NUMBER	EVENT DATE	CONTR	PROGRAM	STATUS	MODE	CAUSE	ACTIVITY	CLAS	FAIL #		FAULT MODE DESCRIPTION		FAULT CAUSE DESCRIPTION	
													FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION		
B	CR3	022710	091578	IN	DG	NN	B06	T	D				RELATIVE POSITION INDICATOR INOPERABLE (GP-7 ROD-8)	PROCEDURE-REACTIMETER TERMINATION TO RPI		
B	CR3	032855A	102880	MD	RR	IC	A06	N	D				RAD MON-AL NOT CORRECTLY SAMP RX BLDG ATMOS DUE TO//	MAINI PROC W/ DET REMOV/REPLAC. DFCT PROC		
B	DB1	019378	101177	PS	NT	PX	B06	N	S	D			RFS CHANNEL 1 ACCIDENTALLY DEENERGIZED DURING TEST	ERROR IN MAINTENANCE WORK ORDER		
B	DB1	030077	010780	SE	DC	NN	B06	N	B	D			CNTRL ROD 5-11 API INOP CAUSE DFCTV REED SW CAUSED	//BY EXCESSV TEMP. DEFECTIVE PROCEDURE		
B	DB1	030432	021080	SE	DC	NN	B06	N	B	D			CNTRL ROD 5-11 API INOP DFCTV REED SW CAUSED BY //	HIGH TEMP. MAJOR CAUSE DFCTV PROCEDURES		
B	DB1	030867	033080	SE	DG	NN	B06	N	B	D			CNTRL ROD 5-11 API INOP DFCTV REED SW DUE TO HIGH//	//TEMP. MAJOR CAUSE DFCTV PROCEDURES		
B	DB1	031416	052880	ZZ	XG	SH	B06	T	C	D			TEST CHNCTN CAUSED ON ISOL VLV TO CLOSE, ON PMP 1-//	// TO STOP. PROCEDURAL INADEQUACY		
B	DB1	031471	060980	SE	NC	NN	B06	T	C	D			NI-2 NOT COMPLETELY CONNECTD TO NIMBINS EQUIP	LACK OF WRITTEN PROCEDURE ON CRCT HOOKUP		
B	DB1	038238	071781	SE	XG	CT	A06	R	U	D			AFW PUMP OSCHRG VLV SPEED OOC (HIGH)	SPEED ELEMENT PROBE NOT ADJSTD/PROC INADQ		
B	DF1	025840B	121578	AM	NT	PX	A06	R	B	D			NI POWER INDICATIONS DISCOVERED OUT OF CALIBRATION	DEFECTIVE PROCEDURES		
B	DF1	025840C	122678	AM	NT	PX	A06	R	B	D			NI POWER INDICATIONS DISCOVERED OUT OF CALIBRATION	DEFECTIVE PROCEDURES		
B	DF1	019485	030877	CM	PS	SN	A06	T	U				SHUTDOWN BYPASS TRIP 1726 VICE LESS THAN 1720	TEST PROCEDURE TOLERANCE EXCEEDS TS TOLER		
B	DF1	019884	122881	TX	PT	PX	B06	N	U	D			NI-2 LEFT VALVED OUT AFTER REPAIR TO TEST TEE	INCORRECT/INCOMPLETE VALVE CHECKLIST		
B	DF1	018772	072677	MO	RR	SN	B06	N	R	D			RADIATION MONITOR RM-A2 OOSR.B. SAMPLE NOT TAKEN	FAILED TO ENSURE O-RING IN PLACE		
B	DF1	023486	123078	CA	NT	PX	B06	N	R	D			UPPER AND LOWER NI LEADS SWAPPED	LEADS INITIALLY INSTALLED BACKWARDS		
C	AR2	036443	022481	ZZ	LT	PX	A06	R	C	D			PPS "A" SG HT LVL TRP SETPT LESS CNSRVTV THAN T.S.	DEFICIENCY IN SURVEILLANCE PROCEDURE		
C	AR2	037634	061081	MD	RR	NN	A06	N	C	D			CNTRL RM VENT RAD MON ZRITS-8750-1 HI ALRM SETPT//	ERRONEOUS. PROCEDURE TO BE MODIFIED		
C	AR2	171777*	112481	CM	XT	PX	B06	T	C	D			PENELTY FACTORS NOT CONSIDERD IN SETTING DNBR SE-	-T POINTS. PROCEDURAL DISCREPANCY		
C	CC1	019201	092777	ZZ	DC	NN	B06	N	B	D			CHI DECLARED INOP DUE TO METRASCOPE BEING INOP.	INCORRECT SIZE POTENTIOMETER SPEC. BY TM		
C	CC2	036931	040781	MD	RR	NN	B06	N	B	D			APD CABLE TO JUNCTN BOX CNNECTR FAILED	CONDUCTOR STRESS FORMED DURING REPAIR		
C	FC1	016667	121476	TX	TT	PX	A06	T	D				B CH COLD LEG TEMP HIGH	CALIBRATION PROCEDURE IN ERROR		
C	FC1	031386	052280	MD	RR	NN	A06	N	C	D			STACK IODINE PROCESS MON RMO-60 CAL W/ OUT OF DAT//	7E PROCEDURE. WRNG PROC USED BY HP TECH		
C	FC1	019425	121377	ZZ	XG	NN	B06	T	D				SUMP RECIRC ACTUATE SIGNAL DID NOT OCCUR	SRAS BYPASSED PER PROCEDURE		
C	FC1	022887	111578	MD	RR	NN	A06	N	D				SFP VENT PART & GAS SETPOINTS EXCEED T.S.	INCORRECT PROCEDURE DID NOT LIST TS LIMIT		
C	FC1	021323	041478	CM	FT	PX	A06	T	C	D			CH A LO PRI FLOW WAS 94.6 PCT, TS REQ MIN 95 PCT	CALIB PROCED REQS CHK THAT AFFECTS TRIP		
C	PA1	031640*	051080	GS	PS	IC	A06	R	C	D			PS-1801 THRU 1804 SET AT LOWER SETPT THAN T.S.	DEFECTIVE PROCEDURE		
C	PA1	031954	071080	IN	XG	NN	A06	N	U	D			NI-C3 NOT DCLRD OPERABLE PRIOR TO RX S/U	ADMIN CNTRL MECHANISM (EOR) NOT CLEARED		
C	PA1	032156	071980	IN	FG	SN	B06	N	U	D			HSPI FLD TO LOOP 28 (FT-0313) INOP	INSTRMNT EQUALZG VLV NOT CLOSU AFTER CAL		
C	SL1	017871	030577	CM	FT	PX	A06	T	S	D			SETPOINT OF BISTABLE TRIP FOR S/G PRESS LT. TS LMT	SETPOINT NOT CHECKED DUE TO ERROR IN PROC		
C	SL1	020513*	020378	SE	TV	PX	A06	T	C	D			RTD RESPONSE TIMES GT. 5SEC. VALUE SET BY VENDOR	RTD'S MOUNTD IN INST. WELLS--NOT ACC'D FOR		
W	BV1	018724*	072877	ZZ	XT	PX	B06	T	C	D			NINE PROTECTION CIRCUITS FOUND INOPERABLE	INCORRECT PROCEDURE DAMAGED DIODES		
W	BV1	022397	022178	CM	FG	NN	A06	R	R	D			LOOP 18 COLD LEG LOOP STOP VLV INTER SETPOINT LOW	DEFECTIVE PROCEDURE		
W	BV1	036045*	010881	SE	TS	SH	A06	T	U	D			RWST RECIRC LINE FROZEN	HEAT TRACE CKT THERMOSTATS IN OFF POS		
W	BV1	037353*	052881	MD	RR	NN	A06	M	C	D			GASEOUS WASTE PROCESS VENT EFF MON PLACD ON MAINT//	/CLEARANCE. MISSG PROCEDURE STEP IN MSP		
W	BV1	038232	071981	GS	XS	SH	A06	M	U	D			B SSPS INOP DUE TO ERRATIC RX TRP & SI SIGNALS	WIRING CHANGE TO OUTPUT RELAY SELECTOR SW		
W	DC1	017145	020777	HS	NT	PX	B06	T	D				POWER WAS LOST TO BOTH SOURCE RANGE CHANNELS	PROCEDURE FOR TEST WAS DEFECTIVE (N-31632		
W	IP2	019237	083177	IN	DG	NN	A06	N	D				ROD N-5 INDICATED POSITION 13 STEPS HIGH	WRONG CALIBRATION CURVE USED		
W	IP2	020743*	022378	TX	PG	SN	A06	N	U				NRC NOTIFICATION OF ACCUM LEVEL XMTS CAL PROCEDURE	MODEL 1151DP XMTS CALIBRATED WRONG		
W	JF1	026249*	062379	SE	NT	PX	B06	T	U	D			BOTH SOURCE RANGE CHANNELS UNRELIABLY DEENERGIZ	//ED DURING TEST. DEFECTIVE PROCEDURE		
W	JF1	172222A	121581	MD	RR	NN	A06	M	V	D			CNTNMNT PURGE VLV NOT CLOSU WHEN RAD MON R24A INOP	PROCEDURAL INADEQUACY		
W	JF1	172222B	121781	MD	RR	NN	A06	M	V	D			CNTNMNT PURGE VLV NOT CLOSU WHEN RAD MON R24A INOP	PROCEDURAL INADEQUACY		
W	KE1	015227	050176	RE	XT	PX	A06	R	R	D			MGT REVIEW OF PROC UV TRIPS LESS CONSERVATIVE	BUS 1-1A TRIP SAME AS T-S. NO TOLERANCE		
W	KE1	020424*	020678	TX	PT	PX	A06	R	C	D			PCR PRESS READINGS HIGH	PROCEDURE NOT INCLUDING HEAD CORRECTION		
W	NA1	021151	041378	CM	PG	SN	A06	T	U	D			PC-455B RESET PT AT 1998.5 VICE 1990	ERROR IN CALIBRATION PROCEDURE		
W	NA1	022571	092778	TX	FT	PX	A06	T	D				RX COOLANT LO-LO FLOW TRIP NON-CONSERVATIVE	XMTS CAL PROCEDURE W/O ELEVATION COMPENSA		
W	PR1	026267*	052579	PS	NT	PX	B06	N	U	D			BOTH NIS CHANNELS DEENERGIZED AS SAME TIME	PROCEDURE DIDNT STATE HOW MANY		
W	PR1	039115	102981	TX	PT	PX	A06	N	C	D			RZR PRESSURE TX 1-PT-431 OBSERVED TO BE 30 PSI LO	APPARENTLY DEFECTIVE PROCEDURES		
W	RG1	031256*	050680	GS	PG	NN	A06	T	D				DC PWR SW OF LO TEMP OPSS OFF W/NO RCS VENT OPEN	DEFECTIVE PROCEDURES		
W	RG1	036825B	040281	MO	RR	NN	B06	N	U	D			RAD MONITOR R-10A NOT PLACED IN SERVICE AFTER FAI-	-LURE OF R-11 & 12. DEFECTIVE PROCEDURES		
W	RO2	027652	073179	HS	PG	SN	B06	R	U	D			ON 111279 DISCOVERED THAT A SAFEGUARD TEST SW IN//	B SL HI DP TRAIN LEFT IN TEST. PROCEDURAL		



DEFECTIVE PROCEDURES

N U M B E R	P L A N T	C O N T R O L N U M B E R	E V E N T D A T E	C O M P	P R O C E D U R E	S Y S T E M	M O D E	A C T I V I T Y	T Y P E	C L A S S	F A I L #	F A U L T M O D E D E S C R I P T I O N	F A U L T C A U S E D E S C R I P T I O N
C	FP1	171670	040181	AM	FT	PX	A06	N	C	D		DURING SHUTDOWN DP IN SINGLE LOOP CORE FLW TOO HIGH	IMPROPER AMP GAIN SETTING
C	FP1	171673	082181	MO	RR	NN	B06	N	U	D		ISOL VLVs FOR CONT ATM GAS AND PARTIC MO CLSD 22HR	PROC ERR NOT TO OPEN ISOLATION VALVES
C	FP1	038979	100781	GS	LS	SN	A06	N	U	D		CST LVL SW 23-LIS-75B DAMAGED NEEDED REPAIR	SCREW CAUGHT & DAMAGED WIRE INSULATION
C	MI1	032046	080380	MO	RR	NN	B06	N	U	D		AIR EJCTR OFF-GAS SYS RAD MON INOP SAMP LIN MAN //	STOP VLV CLOSED. VLV NOT ON LINE-UP LIST
C	MO1	021562*	060678	CM	NT	PX	A06	T	C	T	4	4 OF 6 APRM SCRAM SETTINGS 3 TO 4% LOW	BIASED DISTRIB OF LPRMS WITHIN APRM PAGES
C	MO1	022186*	080578	CM	NT	PX	B06	T	B	U	2	1 APRM SETTING 4 TO 5% LOW, 1 BYPASSED	LRG PWR SHAPE CHNG DEFECT PROCEDURES
C	NM1	038144A	063081	MO	RR	SO	A06	T	C	D	3	3 EMERGENCY COND VENT MONITORS FOUND OUT OF CAL	POSSIBLY DUE TO IMPROPER CALIBRATION PROC
C	NM1	038144B	063081	MO	RR	SO	B06	T	C	D		EMER CONDENSER MONITOR #122 FOUND OOC HIGH BY	75 MR/HR. IMPROPER CALIBRATION PROCEDURE
C	OC1	021929*	071478	GS	LT	PX	A06	T	C	D	4	FOUR RX WTR SWTCHS USED FOR SCRAM INI LESS CONSV	THAN IS-DEFICIENCIES IN TEST PROCEDURE
C	OC1	027014	082279	CM	NC	SN	A06	R	U	D		ROD BLOCK TRIP FROM SOURCE RANGE TRIP FOUND OOC LO	TRIP SETPOINT TO CLOSE TO TECH SPEC
C	OC1	033850B	091680	ZZ	DC	NN	A06	M	U	D		GREEN-GREEN RPI REMAINED LIT WHEN W/DREW ROD 10-23	PROC IN BYPS OF 2 CNTRL ROD INTERLOCKS
C	P82	025882	090379	CL	IG	NN	A06	N	U	D		TEMP OF SOLUTION IN SBLCS FOUND OUT OF SPEC	TEMP CONTROLLER SETPOINT SET WRONG
C	QC2	015157	062876	MO	RR	NN	B06	N	S	D		REFUEL FLOOR RAD MON 28 WAS FOUND OUT OF SER GT 24	PROCEDURE INADEQUACY-OUTG RPT QOS 1700-1

**APPENDIX F**  
**INSTRUMENTATION AND CONTROL ONE-LINERS**  
**SORTED BY SYSTEM**

## CONTENTS

PWR Systems .....	F-001
Containment (Includes Penetration and Isolation Control) .....	F-001
Containment Spray Injection .....	F-003
Chemical Volume Control .....	F-004
High Pressure Coolant Injection .....	F-005
Low Pressure Coolant Injection .....	F-006
Service Water .....	F-007
Condensate and Feed .....	F-008
Reactor Trip .....	F-010
All Others .....	F-030
Other ESF (Parent System not Identified) .....	F-051
BWR Systems .....	F-061
Automatic Depressurization .....	F-061
Containment (Includes Penetration and Isolation Control) .....	F-063
Low Pressure Core Spray .....	F-067
Containment Spray Injection .....	F-069
High Pressure Coolant Injection .....	F-070
Low Pressure Coolant Injection .....	F-073
Reactor Core Isolation Cooling .....	F-076
Service Water .....	F-079
Condensate and Feed .....	F-080
Reactor Trip .....	F-081
All Others .....	F-091
Other ESF (Parent System not Identified) .....	F-106



SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
SA	AUTOMATIC DEPRESSURIZATION (BWR'S ONLY)
SC	CONTAINMENT (INCLUDES PENETRATION & ISOLATION CONTROL)
SD	LOW PRESSURE CORE SPRAY (LPCS) (BWR'S ONLY)
SE	CONTAINMENT SPRAY INJECTION (CSI)
SG	CHEMICAL VOLUME CONTROL (CVCS) (PWR'S ONLY)
SH	HIGH PRESSURE COOLANT INJECTION (HPCI)
SI	LOW PRESSURE COOLANT INJECTION (LPCI)
SO	REACTOR CORE ISOLATION COOLING (RCIC) (BWR'S ONLY)
SM	SERVICE WATER
SCM	CONDENSATE AND FEED
ST	REACTOR TRIP
NO	ALL OTHERS
SN	OTHER ESF/PARENT SYSTEM NOT IDENTIFIED



PWR -- CONTAINMENT (INCLUDES PENETRATION AND ISOLATION CONTROL)

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
B	CR3	023422	100578	RE	XS	IC	B08	T	D			M RELAY IN ACTUATION CH CABINET 2A WAS STICKING	IMPROPER RELAY ALIGNMENT, CABLE STRESS
B	CR3	023420	121378	RE	XC	IC	B12	T	R	D		PB3-GP-2 LIGHT DID NOT LIGHT WHEN CIRCUIT TESTED	RELAY L IN ES CABINET; STUCK, CLEANED
B	CR3	025357	021479	RE	XS	IC	B12	T	R	D		RELAY FAILED	BURR ON RELAY SHAFT
B	CR3	032855A	102880	MO	RR	IC	A06	N	T	D		RAD MON-A1 NOT CORRECTLY SAMP RX BLDG ATMOS DUE TO//	MAINT PROC W/ DET REMOV/REPLAC. DFCT PROC
B	CR3	032855B	102980	MO	RR	IC	A02	N	V	D		RAD MON-A1 NOT CORRECTLY SAMP RX BLDG ATMOS	VALVE MISALIGNMENT PERSONNEL MAINTENANCE
B	CR3	036096	011981	IN	DG	IC	B00	N	U			POSITION INDICATOR FOR CNTNMNT ISO VLV CAV-2 FAIL-	-ED. NO CAUSE FOUND
B	CR3	036510	030181	RE	XS	IC	B12	T	R	U		RX BLDG ISO CH B GROUP 2 RELAY FAILED	BURR FOUND ON RELAY SHAFT
B	CR3	171804A	122181	RE	XS	IC	B13	T	R	U		RELAY 63Z 3D/RB-3(FOR CNTNMNT ISO VLV CFV-27) INOP	COILS & PLUNGER REPLACED
B	CR3	171804B	122181	RE	XS	IC	B13	T	R	U		RELAYS 63Z 4D/RB-1 & 2E/RD-3 FOR CNTNMNT ISO VLV-	-FAILED. COILS AND PLUNGERS REPLACED
B	DE1	025338A	020579	TX	PS	IC	A14	N	T			ES CHANNEL A RX BLDG NARROW RANGE PRESS TRANSMIT//	/ER FOUND OOC. INSTRUMENT DRIFT
B	DE2	025175A	011879	TX	PS	IC	A14	T	R	T		ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	INSTRUMENT DRIFT
B	DE2	025175B	012379	TX	PS	IC	A14	T	R	T		ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	INSTRUMENT DRIFT
B	DE2	025175C	012979	TX	PS	IC	A13	T	R	T		ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	AMPLIFIER REPLACED
B	DE2	025338B	020579	TX	PS	IC	A14	N	T			CHANNEL C RX BLDG NARROW RANGE PRESS TRANSMIT//	FOUND OOC. INSTRUMENT DRIFT
B	T12	021608	051278	GS	PS	IC	A14	N	T			SETTING OF BS-PS-3260 GT. TECH SPECS	INSTRUMENT DRIFT DURN SURVEILLNCE TIME
C	AR2	031377	050780	SE	DS	IC	B08	M	C	D		POSITION SWITCH MISALIGNED	SCREW BACKED OUT LEAVING SW MISALIGNED
C	CC2	027392	100579	IN	PG	IC	B13	T	T			CONTAINMENT PRESSURE SENSOR VOLTAGE METER FAILED	AGING OF METER MOVEMENT WINDINGS
C	CC2	171060	101781	GS	LS	IC	B12	N	T			CONT SUMP LVL ALARM WAS INOPERABLE	PROBABLY DIRT IN LEVEL SWITCH
C	FC1	032471*	080480	MO	RR	IC	A03	N	V	D		STACK PRICLT RMO-61 SETPT SELECTR SW IN WRONG POS	PERS ERR SW NOT RETURN TO POS AFTER TEST
C	PA1	031640*	051080	GS	PS	IC	A06	R	C	D		PS-1801 THRU 1804 SET AT LOWER SETPT THAN T.S.	DEFECTIVE PROCEDURE
C	PA1	032486	081180	MO	RR	IC	A07	N	C	T		CV-04378/388 LIGHTS NOT LIT, PWR SUP FUSES BLOWN	MOISTURE IN JUNCTN BOX CAUSED GROUND
C	PA1	039053	100681	MO	RR	IC	B13	T	U			RAD MON RIA 2316 FAILED	BELEIVED TO BE CABLE CONNECTORS
C	SL1	027971	112379	MO	RR	IC	B13	T	R	T		RB CIS CHANNEL WOULD NOT TRIP ON HIGH RADIATION	FAILED MV/I CONVERTER
C	SL1	030988	032480	AM	TG	IC	B00	N	U			68Z HEATER FOR SBVS DISCOVERED INOP	DFCTV THERMOCOUPLE AMPLIFIER IN CNTRL CKT
C	SL1	036801	031981	MO	RR	IC	913	N	R	U		HIGH CNTNMT RAD MON CH "B" FOR CNTNMNT ISO FAILED	MODULE POWER SUPPLIES FAILED
C	SL1	038527B	081881	CM	PS	IC	A14	T	I			CH "A" CNTNMNT PRESSURE SET POINT FOR CNTNMNT ISO-	-FOUND OOC. INSTRUMENT DRIFT
C	SL1	172032	122281	CM	RR	IC	A14	N	T			CNTNMNT ISOL CHNL MC HI RAD B/S OOC NON-CONSRVTVLY	INSTRUMENT DRIFT
W	BV1	037636A	060181	TX	LS	IC	B00	N	U			"A" CHEMICAL ADDITION TANK LT-QS-101A FAILED LOW	UNKNOWN REASONS
W	BV1	037636B	071081	TX	LS	IC	B00	N	U			"A" CHEMICAL ADDITION TANK LT-QS-101A FAILED LOW	XMTX ELECTRONIC ADJUST LOOP PWR SUP REPLC
W	UC1	171681	112381	MO	RR	IC	A02	M	U	D		CONT RAD BYPASS VLVS WERE FOUND OPEN	MAINTENANCE PERSONNEL ERROR
W	JF1	027854	120279	CM	PS	IC	B00	N	U			CNTNMNT PRESS HI-162 TRIP STATUS LIGHTS FOR ONE //	CHANNEL FOUND ENERGIZED. FAIL COMPARTOR
W	JF1	027914	122079	CA	PS	IC	B12	T	T			CNTNMNT PRESS CHANNEL (PT950) FOUND INOPERABLE	FILM BUILDUP ON CONNECTION
W	KE1	038264	080781	TX	PS	IC	A14	T	T			CNTNMNT PRESSURE TRANSMITTER FOUND OOC LOW	INSTRUMENT DRIFT
W	NA1	025854	041279	PS	PS	IC	B14	T	T			HI-HI CONTAINMENT PRESSURE TRIP FOUND OOC HIGH	EXCESSIVE INST DRIFT IN POWER SUPPLY
W	NA1	027089	080979	CM	PS	IC	B13	N	R	D		CONTAINMENT HI-HI PRESS CH II BECAME INOPERABLE	CARD COMPONENT W-39-1-J WAS HEAT SENSITIV
W	NA1	027087	081479	CM	PS	IC	B13	N	R	U		CNTNMNT INTERMEDIATE HI HI PRESS CH II BISTABLE //	FAILED IN TRIP POS. FAILED CAPACITOR
W	NA1	027086	091179	CM	PS	IC	B13	N	R	U		CNTNMNT HI-HI PRESS CH I BISTABLE FAILED	BAD SIGNAL COMPARTOR CARD
W	NA1	027258	091879	SE	FS	IC	B07	N	C	D		CNTNMNT SUMP FLOW INTEGRATOR FTO-DA115 FAILED	PIECE OF RUBBER GLOVE FOUND IN INTERNALS
W	NA1	031045	120779	PS	LS	IC	B13	N	U			CASING COOLING TNK LVL IND LI-RS103A OOC	DFCTV ZENER DIODE IN LOOP'S PWR SUP CARD
W	NA1	030111	011180	TX	LS	IC	A02	M	B	D		CASING COOLG TNK LT-RS103A REMOVD NOV-RS100A INOP	CNSTRCTN PERS REMOVD LT FOR DESIGN CHANGE
W	NA1	030333	012980	TX	LS	IC	B02	N	B	D		"B" CASING COOLING SUBSYS INOP LT-RS103B DISCHNCTD	//FOR DESIGN CHANGE. CNSTRCTN PERS ERROR
W	NA1	033433	120780	CM	PS	IC	B00	N	U			CNTNMNT HI-HI PRESS ALARM REC'D	SIG COMPARTOR CRD FAILED OUT (LOW)
W	NA2	033020	102580	IM	FS	IC	B12	N	T			CONT SUMP FLO INTEGRTR FTO-DA215 STOP TOTALZNG FLO	FOREIGN MAT'L IN INTEGRATOR MECHANISM
W	NA2	033338	112780	CL	PG	IC	B00	N	U			CONTAINMENT PRESSURE CHNL III FAILED HIGH	DEFECTIVE CARD IN THE CIRCUIT
W	NA2	033622A	122080	TX	LS	IC	B02	N	B	D		3 RWST LVL XMITTERS LT-QS-2008,C,D FROZEN	IMPROP ADJUST HEAT TRACING CKT SETPT POTS
W	NA2	033622B	122080	TX	LS	IC	B07	N	B	T		3 RWST LVL XMITTERS LT-QS-2008,C,D FROZEN	COLD OUTSIDE TEMPERATURES
W	NA2	036120	012181	PS	PS	IC	B13	N	R	U		CNTNMNT PRESSURE PROTECTION CH III FAILED LOW	FAILED POWER SUPPLY CARD
W	NA2	036242	012681	PS	PS	IC	B13	N	R	U		CNTNMNT PRESSURE, CH III, FAILED HIGH	FAILED POWER SUPPLY CARD
W	PR1	030697	031180	GS	PS	IC	A14	T	T			#11 CNTNMNT VAC BRKR ISOL VLV OPENED OOT (HIGH)	DRIFT IN O/P SWITCH
W	SA1	025074	011679	MO	RR	IC	B06	T	U	D		RMS CHANNEL NOT RESET AT RMS(IR11A)	PROCEDURE DIDNT STIPULATE RESETTING

F-6

The remainder of Appendix F is provided on microfiche.

**APPENDIX G**  
**INSTRUMENTATION AND CONTROL ONE-LINERS**  
**SORTED BY TYPE OF EVENT**

## CONTENTS

Recurring Common Cause Failure .....	G-001
Common Cause Failure .....	G-005
Recurring Failure .....	G-009
Command Fault .....	G-049
Recurring Command Fault .....	G-051
Common Cause Command Fault .....	G-052
Recurring Common Cause Command Fault .....	G-057
Random Failure .....	G-059



SYSTEM IDENTIFICATION CODES

<u>CODE</u>	<u>DESCRIPTION</u>
SA	- AUTOMATIC DEPRESSURIZATION (BWR'S ONLY)
CD	- CONTAINMENT (INCLUDES PENETRATION & ISOLATION CONTROL)
LD	- LOW PRESSURE CORE SPRAY (LPCS) (BWR'S ONLY)
CS	- CONTAINMENT SPRAY INJECTION (CSI)
AG	- CHEMICAL VOLUME CONTROL (CVCS) (PWR'S ONLY)
HP	- HIGH PRESSURE COOLANT INJECTION (HPCI)
LP	- LOW PRESSURE COOLANT INJECTION (LPCI)
RC	- REACTOR CORE ISOLATION COOLING (RCIC) (BWR'S ONLY)
SW	- SERVICE WATER
CF	- CONDENSATE AND FEED
TR	- REACTOR TRIP
AO	- ALL OTHERS
SN	- OTHER ESP (PARENT SYSTEM NOT IDENTIFIED)









RECURRING COMMON CAUSE FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	CODE	ALARM	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	PI1 016078	090876	MO	RR	NN	813	N	B	T			RBVPRN SAMPLE PUMP OVERLOADING POWER SUPPLY	PUMP BINDING MODEL 2065-V2 GE FRAME 56
	PI1 016077	090976	MO	RR	NN	813	N	B	T			MS-PRN SAMPL PUMP BLOWING POWER SUPPLY FUSE	PUMP BINDING GAST MFG. MODEL 2065-V2
	PI1 016177	101176	MO	RR	NN	813	N	B	T			MS-PRN PUMP BLEW FUSES IMPLEMENTING PLNT DESGN CHANGE	MS-PRN PUMP BINDS GAST MFG MODEL 2065-V2
	PI1 018324	061777	MO	RR	NN	813	N	B	T			MS-PRN SAMPL PUMP BLOWING FUSES GAST MFG	PUMP BINDS MODEL 2065-V2 GE FRAME 56
G	PI1 018326	062077	MO	RR	NN	813	N	B	T			MS-PRN SAMPLE PUMP INOPERATIVE	SAMPLE PUMP BINDS
G	PI1 020247	123077	MO	RR	NN	813	N	B	T			MS-PRN SAMPLE PUMP INOPERATIVE	MS-PRN PUMP BINDS OVERLDNG POWR SUPPLY
G	QC1 028067A	112879	GS	LT	PX	A04	T	B	D			FOUND LEVEL INSTRUMENTATION SETPOINT TOO LOW	CALIBRATION BASED ON WRONG REF LEG TEMP
G	QC1 028067B	112879	GS	LS	SN	A04	T	B	D			FOUND LEVEL INSTRUMENT SETPOINT TOO LOW	CALIBRATION BASED ON WRONG REF LEG TEMP
G	QC2 022817*	100478	MO	RR	NN	813	N	B	U	2		2A RX VENT & REFLNG FLR RAD MONS SPURIOUSLY SPIKNG	FAULTY PWR SUPPLY COMMON TO BOTH MONITORS
G	VY1 017953A	052477	MO	RR	NN	807	N	B	O			LIGHTNING STRIKE MADE STACK GAS I MONITR INOPERABL	LIGHTNIN CAUSD A LOG CRM BOARD FAILURE
G	VY1 017953B	052477	MO	RR	NN	807	N	B	O			STACK GAS II FAILED TO START IN STNDRY	LIGHTNING CAUSD CONTRL PWR FUSES TO BLOW
G	VY1 018703A	080177	MO	RR	NN	807	N	B	O			SG I MONITOR WOULDNT START WHEN DEMANDED TO	FAIL & LOG RATE METER CKT. BOARD TO FAIL
G	VY1 018703B	080177	MO	RR	NN	807	N	B	O			SG I MONITOR WOULDNT START WHEN DEMANDED TO	UNIT II PUMP CONT PWR FUSES BLEW
G	VY1 021767	061978	MO	RR	NN	807	N	B	O			ELEC STORM SG II S/D; SG I FAILED DUE TO LIGHTNING	HIGH VOLT PWR SUPPLY & LOG COUNT RATE BRD
G	VY1 027704*	111079	TX	LS	IC	811	N	B	T	2		CH A & B LI 16-19-46A/B; TORUS LEVEL, FAILED HIGH	PACKING LEAK







COMMON CAUSE FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	OPER	RECORDING	STATUS	MODE	CAUSE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION		
G	DA1 019965*	112877	CA	NT	PX	A01	T	C	D	4	NONCONSERV ERRORS INDUCED IN APRM CH A,B,C & D	PERSONNEL-REVERSED INPUT/OUTPUT OF RECORD	
G	DA1 032033	071880	CA	DS	SN	A01	N	T	C	D	4	8" RBM FAILED "INOP" CAUSING CONTROL ROD BLOCK	PIN CNNECTR LOOSE INADVRT CNTCT W/ PERS
G	DR2 020869*	032778	MO	RT	PX	A06	N	T	C	D	4	MSL HIGH RAD ISOLATION SETPOINT SET HIGH	TYPOGRAPHICAL ERROR IN PROCEDURE
G	DR2 025904A	051979	CA	NT	PX	B02	N	T	C	D	4	IRM 17 FAILED DOWNSCALE DUE TO A FAILED CONNECTOR	APPARENTLY DAMAGED DURING REFUELING
G	DR3 020871	032778	MO	RT	PX	A03	N	T	C	D	4	MSL HIGH RAD SCRAM ISOL MONITOR SETPOINT HIGH	PERSONNEL ERROR-SETPOINT ADJUSTED HIGH
G	DR3 021510*	052178	GS	FS	SN	A14	T	C	T	3	MSL HI-FLOW ISOL DPIS 261-2C,2N,2S EXCEEDED LIMITS	INSTRUMENT DRIFT	
G	EN1 015559*	070276	GS	PG	SD	B05	T	C	C	2	CORE SPRAY D/P SW E21-M004A & B OPERATED IMPROPERL	FABRICATION-WIRING ERROR	
G	EN2 022676*	101178	CM	HT	PX	A06	T	C	U	6	HIGH FLUX SCRAM SETPOINTS SET VERY HIGH	PROCEDURE DID NOT LIST STARTUP SETTING	
G	EN2 030834	041580	WE	XS	SL	B05	T	C	U	2	8" RHR LPCI PHP WOULDNT START ON LOCA SIG TO ST/	7ART RELAY 2E11-K121B, MISWIRED RELAY	
G	EN2 032217*	072680	GS	LS	PX	B00	N	T	C	2	SCRAM DSCHRG VLV HI LVL SW 2C11-N013A/D INOPERABLE	CRUSHED FLOATS CAUSE UNKNOWN	
G	FP1 014483	040576	GS	PT	PX	B02	T	C	U	19	REACTOR HIGH PRESS SW 2-3-550 FAILED TO ACTUATE	INCORRECT ADJUSTMENT OF MECHANICAL STOP	
G	FP1 018051*	062677	WE	NT	PX	B02	T	C	D	19	LOSS OF 19% APRM SCRAM FUNCTION	CONTRACTOR CUT 19 OF 31 LPRM STRINGS	
G	FP1 020928*	040178	WE	NT	PX	B05	T	C	D	4	LPRM-36-45 DET A & B, LPRM-12-21 DET B & C NOT OP	DETECTOR WIRING INCORRECT	
G	FP1 026924	090579	CA	LS	SN	B02	T	C	D	2	SW FOR INST 02-3-LIS-720 DIDNT PICKUP RELAY	WIRING ERROR MADE IN JUNE	
G	FP1 163896*	010681	GS	LS	SN	B07	T	C	D	2	CONDENSATE STORAGE TANK LEVEL SW'S 23-LS- 48 & 75B	--FOUND OOC. MOISTURE CAUSED DRIFT	
G	FP1 171670	040181	AM	FT	PX	A06	N	T	C	D	4	DURING SHUTDOWN OP IN SINGLE LOOP CORE FLW TOO HIGH	IMPROPER AMP GAIN SETTING
G	M11 171788	111081	MO	RT	PX	B02	N	T	C	D	4	MSL RADIATION MONITOR ALARMED DOWNSCALE(CHANNEL B)	CABLES ACCIDENTLY BUMPED
G	M01 021562*	060678	CM	HT	PX	A06	T	C	D	4	4 OF 6 APRM SCRAM SETTINGS 3 TO 4% LOW	BIASED DISTRIB OF LPRMS WITHIN APRM PAGES	
G	NM1 021439*	052678	SE	NT	PX	B02	T	C	D	8	LPRM DET A&B TO APRM 11 & 15 CROSS CONNECTED	GE-NA-100 DETECTORS CROSS-CONNECTED	
G	NM1 022698*	102078	ZZ	FS	SN	A08	T	C	D	8	ALL 8 MN STM HIGH FLOW SETPOINTS NON-CONSERVATIVE	HEISE TEST GAUGE INACCURATE LOOSE SCREW	
G	NM1 038144A	063081	MO	RR	SQ	A06	T	C	D	3	3 EMERGENCY COND VENT MONITORS FOUND OUT OF CAL	POSSIBLY DUE TO IMPROPER CALIBRATION PROC	
G	NM1 038144B	063081	MO	RR	SQ	B06	T	C	D	3	EMER CONDENSER MONITOR #122 FOUND OOC HIGH BY	75 MR/MR. IMPROPER CALIBRATION PROCEDURE	
G	OC1 017753*	050477	WE	FS	SN	B02	T	C	D	2	MN STM HI FLO SENSRS RE22 & RE22H WOULD NOT ACTAT	SPNG ELE IN HG BULBS FUSED-GND BY MAINIEN	
G	OC1 021929*	071478	WE	FS	PX	A06	T	C	D	4	FOUR RX WTR SWITCHS USED FOR SCRAM INJ LESS CONSV	THAN IS-DEFICIENCIES IN TEST PROCEDURE	
G	OC1 022925*	112178	GS	LS	SN	B04	T	C	D	2	TORUS-RX BLDG OP SWCHS DPS-66A&B RUPTURED DIAPHRGM	NOT DESIGNED FOR DELTA P-CAT NO 1635-12	
G	OC1 172614B	120381	GS	PS	SA	B05	N	T	C	D	2	FAULTY EMRV PRESSURE SWITCH 1A83-A	MICROSWITCHES IN 1A83-A NOT RATED AT 125V
G	PB2 015143*	061976	MO	RR	NN	B09	N	T	C	D	2	REFUEL FLR EXH VENT RAD MON&RX BLDG EXH VENT RADIA	MON FAILED DOWNSCALE-COMMON PMR SUP FAIL
G	PB2 016270*	110176	GS	F6	SN	B02	T	C	D	2	CONT RM RAD SMPL SIGNLS NOT RCVD FRM FS-0760A&B	WIRING ERROR CSD IMP KSP TO LO FLO SIGNAL	
G	PB2 033340	112380	MO	RR	NN	B04	N	T	C	D	2	WIR IN OFF-GAS RAD MON SAMPLING SYS REDUCING FLOW	WATER PROBLEM CAUSD BY DRAIN MODIFICATION
G	PB2 036040	010381	CM	HT	PX	A02	N	T	C	D	2	APRM FLUX SCRAM SETPOINT FOUND 2.88 TO 5.6% HIGH	APRM GAINS NOT ADJUSTED PROPERLY
G	PB2 171564*	120581	GS	TS	SN	B01	N	T	C	D	2	TRP SETPTS FOR MSL TUNN TEMP SW RAISE FOR OP PRB	PERSONNEL ERROR
G	PB3 017480*	041177	GS	PS	SN	B11	N	T	C	D	4	MN STM LN SWCHS DPIS 3-2-116A,B,C&D FAILED DOWNSCLE	CON HI PRESS SNSG LINE WAS AIR BOUND
G	PB3 019180*	100177	GS	PS	SN	B02	N	T	C	D	2	PS-3-3-51C&D SCRAM BYPASS PRS SW FLD TO CLR ALARM	WATER LKG THRU CONDUIT FRM OPEN JCTN BOX
G	PB3 171567*	112181	TX	PS	SN	B04	N	T	C	D	2	PRESS XMTS P13508A AND 3508B WERE BLOWING FUSES	DESIGNED GRND IN THE PRNT CKT ASSMB UN TX
G	PI1 036127A	010781	MO	RR	NN	B11	N	T	C	D	2	MAIN STACK SAMPLE LOW FLOW ALARM RECEIVED	SUCTION LINE FOUND FROZEN
G	PI1 037053	041481	GS	PS	SL	B03	N	T	C	D	2	RECIRC SYS DELTA P INSTRUMENT 261-398 RENDERED IN-	-OPERABLE. PERSONNEL ERROR IN TESTING
G	PI1 037407	051281	MO	RR	NN	B07	N	T	C	D	4	STACK GAS RAD MON 1705 FAILED	VOLTAGE SURGE CREATED BY LIGHTNING STRIKE
G	PI1 037408	051481	TX	LS	IC	A02	N	T	C	D	2	TORUS WATER LEVEL FOUND OUT OF CAL	JARRING OF INSTRUMENT SAMPLE LINES
G	PI1 037538	060781	ZZ	DG	NN	B02	N	T	C	D	2	RPIS FOR ROD 42-35 WAS JUMPERED AT POSITION 14 AN-	-D NOT DOCUMENTED. PERSONNEL ERROR
G	QC1 171853	112681	GS	LS	SQ	B02	N	T	C	D	2	RCIC DRAIN POT LEVEL SW VLV FOUND LEAKING,RCIC IS-	-O SYS DECLARED INOP. POOR WELD
G	QC2 020942	022878	MO	RT	PX	B02	N	T	C	D	13	2D MAIN STEAM LINE RAD MON READING DOWNSCALE	HI VLTG LEAD TO MON WAS IMPRPRLY ATTACHED
G	QC2 025310*	042979	LS	DT	PX	A05	T	C	D	13	MSIV LIMIT SWITCHES FOUND OOC	SET IMPROPERLY AT MANUFACTURER	
G	QC2 036617	031281	ZZ	XG	IC	B02	N	T	C	D	8	SYS WHICH MAINTAINS DP BETWEEN DRYWELL AND SUPPRE-	-SSION CHAMBER WAS LOST. PERSONNEL ERROR
G	VY1 019855*	101977	GS	PS	SH	A02	N	T	C	D	8	HPCI & RCIC STEAM LOW PRESS SWITCHS IMPOPRLY CALIBR	DIDNT CONSIDER HEAD CORRECTION OF 23 PSI







RECURRING FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	CORE	COLUMNS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FACIL #	FAULT MODE DESCRIPTION		FAULT CAUSE DESCRIPTION	
B DB1	027869	112979	SE	DC	NN	B12	N	R	T			POSITION INDICATION LOST FOR GROUP 7 ROD 5	FAILURE OF REED SW DUE TO OXIDE BUILDUP		
B DB1	027915	113079	IN	NN	NN	A13	N	R	T			ROD 8-1(GROUP 8) INDICATED BY LOWER THAN GROUP AVE	FAULTY METER MOVEMENT		
B DB1	032030A	072080	AM	NN	NN	B09	N	R	T			NI-1 S/U RATE PEG HI THEN LO P SOURCE RNG IND ZERO	WEAK SIGNAL PULSES FROM A PRE-AMPLIFIER		
B DB1	032030B	080980	AM	NN	NN	B09	N	R	T			NI-1 S/U RATE PEG HI THEN LO & SOURCE RNG IND ZERO	WEAK SIGNAL PULSES FROM A PRE-AMPLIFIER		
B DB1	033273	112880	GS	PS	SN	B13	T	R	T			AFW SYS 1-2 INOP DUE TO INOP PSL1070	NAT'L WEAR OF ACTUATOR & ACTUATION SW		
B DB1	036396	021281	SE	DC	NN	B09	N	R	D			CNTRL ROD 1-3 API FLUCTUATING SIG DECLRD INOP	NOISE PICKED UP IN ELEC PENE MODULE		
B DB1	036729	052381	PS	DC	NN	B00	N	R	U			CNTRL ROD 4-7 API FLUCTUATING S S DECLRD INOP	PROBLM APPEARS TO BE IN ELEC PENE MODULE		
B DB1	037186	050581	MO	FC	NN	B13	N	R	U			FLO IND FYI-MP3A ROD W/ PUMP OFF & VLV CLOSED	BUFFR AMP FAILD DUE TO BAD -24VDC PMW SUP		
B DB1	038186	072781	MO	RS	NN	B13	N	R	T			RE-5030 PUMP TRIPPED DUE TO LOW FLOW	BAD BEARINGS DUE TO NAT'L END-OF-LIFE		
B DB1	038589A	082081	TX	LS	SN	B13	N	R	U			BWST-3 LVL FAILED W/ HIGH INDICATIONS	FAULTY PREAMP BOARD IN XMTR		
B DB1	038589B	082981	TX	LS	SN	B13	N	R	U			BWST-3 LEVEL FAILED W/ HIGH INDICATIONS	FAULTY PREAMP BOARD IN XMTR		
B DB1	038801	090981	MO	RR	NN	B00	N	R	T			POS ACCIDENT CNTRMNT RAD MON INOP DUE TO LO FLOW	PUMP FAILURE--NAT'L END-OF-LIFE		
B DB1	038991A	100381	IN	DC	NN	A00	N	R	U			API ON GROUP 4 ROD 7 FLUCTUATING 9-10% OF FULL RNG	UNKNOWN		
B DB1	039060A	101281	MO	R	NN	A08	N	R	T			RE-5029 PUMP NOT RUNNING	PUMP VANE WEAR--NORMAL WEAR		
B DB1	039060B	101381	MO	RR	NN	A08	N	R	T			RE-5029-5030 PUMP NOT RUNNING	PUMP VANE WEAR--NORMAL WEAR		
B DB1	038991B	102081	IN	DC	NN	A00	N	R	U			API ON GROUP 4 ROD 7 FLUCTUATING 9-10% OF FULL RNG	UNKNOWN		
B DB1	039060C	110381	MO	RR	NN	B08	N	R	T			RE-5030 PUMP NOT RUNNING	PUMP VANE WEAR--NORMAL WEAR		
B DB1	016400	112176	MO	RP	NN	913	T	R	T			RIA-43 PARTICULATE MONITOR INOPERABLE	LOG-RATE METER CARD BAD CAPACITOR		
B DB1	017600A	040977	TX	LG	SN	A11	N	R	U			BORATED WATER STORAGE TANK LEVEL INDICATE FLUCTUAT	CLOGGING BUILDUP OF BORIC ACID RESIDUE		
B DB1	017600B	041277	TX	LG	SN	A11	N	R	U			BWST LEVEL INDICATION FLUCTUATING	ENTRAINMENT OF BUBBLES IN LINE		
B DB1	017600C	041677	TX	LG	SN	A11	N	R	U			BWST LEVEL INDICATION FLUCTUATING	ENTRAINMENT OF BUBBLES IN LINE		
B DB1	017821	090677	IN	LG	SN	A00	N	R	U			BWST LEVEL CH 1 INDICATING LOW	POSSIBLY HEAT TRACE CONTROLLER INTERMITT		
B DB1	020070	122977	TX	PG	SN	A07	T	R	U			CH 1 WR PRESS INDICATING HIGH	SYM LEAK AFFECTED CALIBRATION 50PM XMTR		
B DB1	022226	080878	TX	PG	SN	A07	N	R	T			RB NAR RNG PRESS IND CH 1 INDICATING HIGH	DRIFT DUE TO EXTREMES OF TEMP/HUMIDITY		
B DB1	022348*	091478	TX	PG	SN	A07	T	R	U			PT 4 & 6 OUT OF CAL HIGH NON- CONSERVATIVE	EXCESSIVE TEMP/HUMIDITY INDUCED DRIFT		
B DB1	022918	102678	TX	PT	PX	A07	7	R	U			RPS CH A TRIP 9.6 HIGHER THAN TS	EXCESS TEMP/HUMIDITY INDUCED DRIFT		
B DB1	025179	012579	MO	RR	NN	B13	N	R	T			FLOW TO IRIA 47, 48 & 49 RAD MONITORS, RIA 47 SAMP	77LE PUMP SEIZED, TRIPPING COMMON PMP MOTOR		
B DB1	026397	061579	MO	RR	NN	B11	N	R	D			RB GASEOUS RADITION MONITORS RENDERED INOPERABLE	ISOLATION VALVE FAILED CLOSED		
B DB1	023650	040178	TX	PS	SN	A14	N	R	T			ES ANALOG CH 2 PRESS XMTR TRIP NON-CONSERVATIVE	XMTR AMP DRIFT		
B DB1	022914	102378	TX	PS	SN	A07	T	R	U			ES ANALOG CH 3 PRESS XMTR TRIP NON-CONSERVATIVE	EXCESS TEMP/HUMIDITY INDUCED DRIFT		
B DB1	025175A	011879	TX	PS	IC	A14	T	R	T			ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	INSTRUMENT DRIFT		
B DB1	025175B	012379	TX	PS	IC	A14	T	R	T			ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	INSTRUMENT DRIFT		
B DB1	025175C	012979	TX	PS	IC	A13	T	R	T			ES CHANNEL C RB NARROW RANGE FOUND OUT OF CAL	AMPLIFIER REPLACED		
B DB1	025338B	020579	TX	PS	IC	A14	N	R	T			CHANNEL C RX BLDG NARROW RANGE PRESS TRANSMITTER//	FOUND OOC. INSTRUMENT DRIFT		
B DB1	027168	092479	MO	RR	NN	B11	N	R	T			RB GASEOUS RAD MON RENDERED INOPERABLE	ISOLATION RETURN VALVE FAILED CLOSED		
B DB1	023379*	112978	TX	PS	SN	A07	T	R	T			ES CH A & C TRIPPED DUE TO APPARENT DRIFT NR PRESS	TEMP/HUMIDITY EXTREMES		
B DB1	023399	112978	TX	PS	SN	A07	T	R	T			ES CH B SPURIOUS TRIP, HPI, LPI, BLDG ISOLATION	TEMP/HUMIDITY EXTREMES		
B DB1	026104	042379	MO	RR	NN	B13	N	R	T			RB GASEOUS RAD MONITORS RENDERED INOPERABLE	INLET ISOLATION VALVE FAILED CLOSED		
B DB1	014065	020376	RE	XC	NN	B12	T	R	D			AUTO-ALUATH RELAY 62X3-RC3B IN RC CHNL 3B FAILD	MECHANICAL BINDING OF ARMATURE & CONTACTS		
B DB1	016831	051076	RE	PG	NN	B12	T	R	D			AUTO-ACT RELAY 6322C/RB2B IN RX BLDG PRESS CH. 2B	FAILD TO GO TO SAFEGUARD POSITION		
B DB1	015971	091676	TX	PT	PX	B13	N	R	U			RC PRESS TRIP SETPTS. CHAN B LESS CONSRVTV THAN TS	DEFECTY TRANSMITTERWEST. MODEL 59H)		
B DB1	018772	072679	MO	RR	SN	B00	N	R	D			RADIATION MONITOR RM-A2 OOS-R.B. SAMPLE NOT TAKEN	FAILD TO ENSURE O-RING IN PLACE		
C AR2	023289	120678	PS	DC	NN	B13	T	R	U			CEA CALCULATOR #2 DECLARED INOPERABLE	OSCILLATING REED SWITCH PO. XMTR PS		
C AR2	025157	010279	TX	LG	NN	B11	N	R	D			REFUELING WATER LEVEL TRANSMITTER FAILED HIGH	FROZEN SENSING LINE ON ZLT-5639-3		
C AR2	025510	010379	TX	LG	NN	B11	N	R	D			RWS LEVEL TRANSMITTER ZLT-5639-3 FOUND INOPERABLE	FROZEN SENSING LINE		
C AR2	025219	011479	TX	LG	NN	B11	N	R	D			RWS LEVEL TRANSMITTER ZLT-5639-3 FOUND INOPERABLE	HEAT LAHI WENT OFF, SENSING LINE FROZE		
C AR2	025209A	012879	PS	XT	PX	B00	N	R	U			CHANNEL "D" CPC FAILED	POWER SUPPLY WAS REPLACED, NO CAUSE GIVEN		
C AR2	025209B	012879	ZZ	XT	PX	B00	N	R	U			CHANNEL "C" CPC FAILED	NO CAUSE FOUND		
C AR2	026483*	062779	MO	RR	NN	B07	N	R	T			CONDENSER VACUUM RMS MONITORS WERE INOPERABLE	MOISTURE BUILDUP IN SENSORS		
C AR2	026490	071879	MO	RR	NN	B08	N	R	D			RADWASTE AREA RAD MONITOR 2RE-8542 FAILED	SAMPLE PUMP HAD BROKEN COUPLING		



































RECURRING FAILURE

DATE	NUMER	SAVE	LOGS	ABOLISHED	SYNOPSIS	MODE	CAUSE	ACTIVITY	CLASS	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
0201	0201	0201	0201	0201	0201	0201	0201	0201	0201	AIR EJECTOR RAD MON ZR2R26 PUMP FAILED	CAUSE NOT STATED FOR PUMP FAILURE
0202	0202	0202	0202	0202	0202	0202	0202	0202	0202	REPLACED XMT -- NO CAUSE FOUND YET	
0203	0203	0203	0203	0203	0203	0203	0203	0203	0203	NO CAUSE COULD BE FOUND	
0204	0204	0204	0204	0204	0204	0204	0204	0204	0204	DRIFT IN SENSIN LINES, TUNED OSCILATOR	
0205	0205	0205	0205	0205	0205	0205	0205	0205	0205	INSUR DRIFT	
0206	0206	0206	0206	0206	0206	0206	0206	0206	0206	INSUR DRIFT XMTS ARE F-ACCUMULATOR 2A	
0207	0207	0207	0207	0207	0207	0207	0207	0207	0207	FAULTY LOW VOLTAGE POWER SUPPLY	
0208	0208	0208	0208	0208	0208	0208	0208	0208	0208	LEAKING ROOT VALVE	
0209	0209	0209	0209	0209	0209	0209	0209	0209	0209	INSTRUMENT DRIFT OF 4.125% TO 4.7%	
0210	0210	0210	0210	0210	0210	0210	0210	0210	0210	DEFECTIVE LOW VOLTAGE POWER SUPPLY	
0211	0211	0211	0211	0211	0211	0211	0211	0211	0211	INSTRUMENT DRIFT	
0212	0212	0212	0212	0212	0212	0212	0212	0212	0212	DETECTIVE LOW VOLTAGE POWER SUPPLY	
0213	0213	0213	0213	0213	0213	0213	0213	0213	0213	HYPER TUBE MOVEMENT RESPOND NAT'L FOR	
0214	0214	0214	0214	0214	0214	0214	0214	0214	0214	HYPER TUBE MOVEMENT ADJUST TO PROPER SETG EGL	
0215	0215	0215	0215	0215	0215	0215	0215	0215	0215	ZERO SHIFT	
0216	0216	0216	0216	0216	0216	0216	0216	0216	0216	ZERO SHIFT	
0217	0217	0217	0217	0217	0217	0217	0217	0217	0217	ZERO SHIFT	
0218	0218	0218	0218	0218	0218	0218	0218	0218	0218	ZERO SHIFT	
0219	0219	0219	0219	0219	0219	0219	0219	0219	0219	ZERO SHIFT	
0220	0220	0220	0220	0220	0220	0220	0220	0220	0220	ZERO SHIFT	
0221	0221	0221	0221	0221	0221	0221	0221	0221	0221	ZERO SHIFT	
0222	0222	0222	0222	0222	0222	0222	0222	0222	0222	ZERO SHIFT	
0223	0223	0223	0223	0223	0223	0223	0223	0223	0223	ZERO SHIFT	
0224	0224	0224	0224	0224	0224	0224	0224	0224	0224	ZERO SHIFT	
0225	0225	0225	0225	0225	0225	0225	0225	0225	0225	ZERO SHIFT	
0226	0226	0226	0226	0226	0226	0226	0226	0226	0226	ZERO SHIFT	
0227	0227	0227	0227	0227	0227	0227	0227	0227	0227	ZERO SHIFT	
0228	0228	0228	0228	0228	0228	0228	0228	0228	0228	ZERO SHIFT	
0229	0229	0229	0229	0229	0229	0229	0229	0229	0229	ZERO SHIFT	
0230	0230	0230	0230	0230	0230	0230	0230	0230	0230	ZERO SHIFT	
0231	0231	0231	0231	0231	0231	0231	0231	0231	0231	ZERO SHIFT	
0232	0232	0232	0232	0232	0232	0232	0232	0232	0232	ZERO SHIFT	
0233	0233	0233	0233	0233	0233	0233	0233	0233	0233	ZERO SHIFT	
0234	0234	0234	0234	0234	0234	0234	0234	0234	0234	ZERO SHIFT	
0235	0235	0235	0235	0235	0235	0235	0235	0235	0235	ZERO SHIFT	
0236	0236	0236	0236	0236	0236	0236	0236	0236	0236	ZERO SHIFT	
0237	0237	0237	0237	0237	0237	0237	0237	0237	0237	ZERO SHIFT	
0238	0238	0238	0238	0238	0238	0238	0238	0238	0238	ZERO SHIFT	
0239	0239	0239	0239	0239	0239	0239	0239	0239	0239	ZERO SHIFT	
0240	0240	0240	0240	0240	0240	0240	0240	0240	0240	ZERO SHIFT	
0241	0241	0241	0241	0241	0241	0241	0241	0241	0241	ZERO SHIFT	
0242	0242	0242	0242	0242	0242	0242	0242	0242	0242	ZERO SHIFT	
0243	0243	0243	0243	0243	0243	0243	0243	0243	0243	ZERO SHIFT	
0244	0244	0244	0244	0244	0244	0244	0244	0244	0244	ZERO SHIFT	
0245	0245	0245	0245	0245	0245	0245	0245	0245	0245	ZERO SHIFT	
0246	0246	0246	0246	0246	0246	0246	0246	0246	0246	ZERO SHIFT	
0247	0247	0247	0247	0247	0247	0247	0247	0247	0247	ZERO SHIFT	
0248	0248	0248	0248	0248	0248	0248	0248	0248	0248	ZERO SHIFT	
0249	0249	0249	0249	0249	0249	0249	0249	0249	0249	ZERO SHIFT	
0250	0250	0250	0250	0250	0250	0250	0250	0250	0250	ZERO SHIFT	
0251	0251	0251	0251	0251	0251	0251	0251	0251	0251	ZERO SHIFT	
0252	0252	0252	0252	0252	0252	0252	0252	0252	0252	ZERO SHIFT	
0253	0253	0253	0253	0253	0253	0253	0253	0253	0253	ZERO SHIFT	
0254	0254	0254	0254	0254	0254	0254	0254	0254	0254	ZERO SHIFT	
0255	0255	0255	0255	0255	0255	0255	0255	0255	0255	ZERO SHIFT	
0256	0256	0256	0256	0256	0256	0256	0256	0256	0256	ZERO SHIFT	
0257	0257	0257	0257	0257	0257	0257	0257	0257	0257	ZERO SHIFT	
0258	0258	0258	0258	0258	0258	0258	0258	0258	0258	ZERO SHIFT	
0259	0259	0259	0259	0259	0259	0259	0259	0259	0259	ZERO SHIFT	
0260	0260	0260	0260	0260	0260	0260	0260	0260	0260	ZERO SHIFT	
0261	0261	0261	0261	0261	0261	0261	0261	0261	0261	ZERO SHIFT	
0262	0262	0262	0262	0262	0262	0262	0262	0262	0262	ZERO SHIFT	
0263	0263	0263	0263	0263	0263	0263	0263	0263	0263	ZERO SHIFT	
0264	0264	0264	0264	0264	0264	0264	0264	0264	0264	ZERO SHIFT	
0265	0265	0265	0265	0265	0265	0265	0265	0265	0265	ZERO SHIFT	
0266	0266	0266	0266	0266	0266	0266	0266	0266	0266	ZERO SHIFT	
0267	0267	0267	0267	0267	0267	0267	0267	0267	0267	ZERO SHIFT	
0268	0268	0268	0268	0268	0268	0268	0268	0268	0268	ZERO SHIFT	
0269	0269	0269	0269	0269	0269	0269	0269	0269	0269	ZERO SHIFT	
0270	0270	0270	0270	0270	0270	0270	0270	0270	0270	ZERO SHIFT	
0271	0271	0271	0271	0271	0271	0271	0271	0271	0271	ZERO SHIFT	
0272	0272	0272	0272	0272	0272	0272	0272	0272	0272	ZERO SHIFT	
0273	0273	0273	0273	0273	0273	0273	0273	0273	0273	ZERO SHIFT	
0274	0274	0274	0274	0274	0274	0274	0274	0274	0274	ZERO SHIFT	
0275	0275	0275	0275	0275	0275	0275	0275	0275	0275	ZERO SHIFT	
0276	0276	0276	0276	0276	0276	0276	0276	0276	0276	ZERO SHIFT	
0277	0277	0277	0277	0277	0277	0277	0277	0277	0277	ZERO SHIFT	
0278	0278	0278	0278	0278	0278	0278	0278	0278	0278	ZERO SHIFT	
0279	0279	0279	0279	0279	0279	0279	0279	0279	0279	ZERO SHIFT	
0280	0280	0280	0280	0280	0280	0280	0280	0280	0280	ZERO SHIFT	
0281	0281	0281	0281	0281	0281	0281	0281	0281	0281	ZERO SHIFT	
0282	0282	0282	0282	0282	0282	0282	0282	0282	0282	ZERO SHIFT	
0283	0283	0283	0283	0283	0283	0283	0283	0283	0283	ZERO SHIFT	
0284	0284	0284	0284	0284	0284	0284	0284	0284	0284	ZERO SHIFT	
0285	0285	0285	0285	0285	0285	0285	0285	0285	0285	ZERO SHIFT	
0286	0286	0286	0286	0286	0286	0286	0286	0286	0286	ZERO SHIFT	
0287	0287	0287	0287	0287	0287	0287	0287	0287	0287	ZERO SHIFT	
0288	0288	0288	0288	0288	0288	0288	0288	0288	0288	ZERO SHIFT	
0289	0289	0289	0289	0289	0289	0289	0289	0289	0289	ZERO SHIFT	
0290	0290	0290	0290	0290	0290	0290	0290	0290	0290	ZERO SHIFT	
0291	0291	0291	0291	0291	0291	0291	0291	0291	0291	ZERO SHIFT	
0292	0292	0292	0292	0292	0292	0292	0292	0292	0292	ZERO SHIFT	
0293	0293	0293	0293	0293	0293	0293	0293	0293	0293	ZERO SHIFT	
0294	0294	0294	0294	0294	0294	0294	0294	0294	0294	ZERO SHIFT	
0295	0295	0295	0295	0295	0295	0295	0295	0295	0295	ZERO SHIFT	
0296	0296	0296	0296	0296	0296	0296	0296	0296	0296	ZERO SHIFT	
0297	0297	0297	0297	0297	0297	0297	0297	0297	0297	ZERO SHIFT	
0298	0298	0298	0298	0298	0298	0298	0298	0298	0298	ZERO SHIFT	
0299	0299	0299	0299	0299	0299	0299	0299	0299	0299	ZERO SHIFT	
0300	0300	0300	0300	0300	0300	0300	0300	0300	0300	ZERO SHIFT	





































RECURRING FAILURE

CLASS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESSES	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	OC1	021933*	070478	MO	RR	NN	A14	T	R	T	2	AREA RAD MON RN04A-1 & 2 FOUND LESS CONSRV THAN TS	ATTRIBUTED TO INSTRUMENT DRIFT	
G	OC1	030341B	020580	MO	RR	NN	A14	N	R	T			RAD MON RN04A-2 SETPT FOUND LESS CONSRV THAN T.S.	INSTRUMENT DRIFT
G	OC1	031266	050780	GS	PS	SN	A14	N	R	T			SW RED3D LESS CONSERVATIVE THAN T.S.	ATTRIBUTED TO SENSOR REPEATABILITY
G	OC1	031449A	052380	SE	PS	SN	A14	N	R	T			SENSOR IAB3B EXCEED TECH SPEC SETPOINT	INSTRUMENT DRIFT
G	OC1	032047	071180	SE	PS	SN	A14	N	R	T			HI D/W PRESS SENSOR RV46B ACTUATED OOT	INSTRUMENT SETPOINT DRIFT
G	OC1	032387*	081480	GS	PS	IC	A14	T	R	T	2	HI D/W PRESS SW IP-15A-D TRIPPED HIGH	LACK OF INSTRUMENT REPEATABILITY	
G	OC1	032637	082680	GS	PS	IC	A14	T	R	T			RX TRIPLE LOW WATER LVL SENSOR RE18B TRIPPED HIGH	SENSOR REPEATABILITY
G	OC1	032671*	091180	GS	PS	IC	A14	T	R	T	3	HI D/W PRESSURE SW IP-15A,B,C TRIPPED HIGH	INSTRUMENT REPEATABILITY	
G	OC1	033126*	110180	GS	PS	IC	A14	T	R	T			HI D/W PRESS SW RV-46A,B,C,D TRIPPED HIGH	INSTRUMENT REPEATABILITY
G	OC1	033216*	110680	GS	PS	IC	A14	T	R	T	4	CNTNMNT SPRAY SYS HI D/W PRESS SW IP-15A-D OOC HI	INSTRUMENT REPEATABILITY	
G	OC1	033366*	111880	GS	PS	SN	A14	T	R	T	2	RX TRIPLE LD WTR LVL IND SW RE-18A-D TRIPPED HIGH	SENSOR REPEATABILITY	
G	OC1	033589*	120380	GS	PS	SN	A14	T	R	T	3	CORE SPRAY SYS HI D/W PRESS SW RV-46B,C,D OOT HIGH	INSTRUMENT REPEATABILITY	
G	OC1	033520A	120480	SE	PS	NN	A14	T	R	T			MSL HI FLO SENSOR RE-22C TRIPPED HIGH	INSTRUMENT REPEATABILITY
G	OC1	033590*	120580	GS	PS	SN	A14	N	R	T	4	CNTNMNT SPRAY HI D/W PRESSURE SW IP15A-D OOT HIGH	INSTRUMENT REPEATABILITY	
G	OC1	033656	121780	GS	PS	SN	A14	T	R	T			RX TRIPLE LOW WATER LEVEL IND SW RE-18A TRPD HIGH	INSTRUMENT DRIFT
G	OC1	036036	010281	GS	PS	SF	A14	T	R	T			CNTNMNT SPRAY SYS HI DRYWELL PRESS SW FOUND OOC HI	INSTRUMENT REPEATABILITY OF IP-15C
G	OC1	036037	010281	MO	RR	NN	B08	N	R	T			STACK GAS MONITOR FAILED	PUMP TRIPPED DUE TO WORN BEARINGS
G	OC1	036125	011580	GS	PS	SN	A14	T	R	T			RX TRIPLE LOW WATER LEVEL SW RE-18B FOUND OOC HI	INSTRUMENT REPEATABILITY/DRIFT
G	OC1	036623*	031381	GS	PS	SN	A14	T	R	T	2	ERV HIGH PRESSURE ACTUATION SWITCHES IAB3C,E OOC	INSTRUMENT REPEATABILITY	
G	OC1	036754	031981	GS	PS	SD	A14	T	R	T			CORE SPRAY HI DRYWELL PRESS SW RV46B FOUND OOC HI	INSTRUMENT REPEATABILITY
G	OC1	037537*	060381	GS	PS	SN	A14	T	R	T	3	HIGH PRESSURE SENSOR RE03B,C & D FOUND OOC	INSTRUMENT REPEATABILITY	
G	OC1	038295*	081581	GS	PS	SN	A14	T	R	T	2	ERV HIGH PRESSURE SWITCHES IAB3B & C FOUND OOC HI	INSTRUMENT REPEATABILITY	
G	OC1	039236	082481	MO	RR	NN	B08	N	R	T			STACK GAS MON "A" SAMPLE PUMP TRIPPED	VANES BECAME BRITLE AND FAILED
G	OC1	039454A	082881	MO	RR	NN	B08	N	R	T			STACK GAS MON "B" SAMPLE PUMP TRIPPED	LUBRICATION SYS FAILED
G	OC1	039454B	082881	GS	PS	NN	B13	N	R	U			FLOW SENSOR FOR STACK GAS MON "B" FAILED	LOW FLOW SWITCH ALARM CARD FAILED
G	OC1	039092*	101281	GS	PS	SF	A14	T	R	T	2	CNTNMNT SPRAY HIGH DRYWELL PRESS SW IP15A & C FOU-	-NO OOC. INSTRUMENT REPEATABILITY	
G	OC1	039208	101781	GS	PS	SN	A14	T	R	T			ERV HIGH PRESSURE SWITCH IAB3E FOUND OOC HI	INSTRUMENT DRIFT
G	OC1	039285	103181	GS	PS	SN	A14	T	R	T			ERV HIGH PRESSURE SWITCH IAB3B FOUND OOC HIGH	INSTRUMENT REPEATABILITY
G	OC1	171803*	111181	GS	PS	IC	A14	T	R	T	2	DRYWELL PRESSURE SWITCHES IP15B&D FOUND OOC HI O.-	-O3 & O-04 PSIG. INSTRUMENT DRIFT	
G	OC1	171826*	111181	SE	PS	SG	A14	T	R	T			ISOL CONDENSER PIPE BREAK SENSORS IB11A1&2 OOC HI	INSTRUMENT DRIFT
G	OC1	172285*	120181	SE	FG	NN	A14	T	R	T	3	MSL HI FLO SENSORS RE-22C,E,F OOC (HIGH)	INSTRUMENT REPEATABILITY AND DRIFT	
G	OC1	172026*	123081	GS	PS	SD	A14	N	R	T			CORE SPRAY HI D/W PRESS SW RV-46A,B,D OOC (HIGH)	INSTRUMENT REPEATABILITY
G	OC1	172027	123181	SE	PS	SG	A14	N	R	T			ISOL CONDENSER ISOL PIPE BREAK SENSOR IB11A1 OOC	INSTRUMENT REPEATABILITY
G	PB2	014181	020576	GS	FS	SG	A14	T	R	T			RCIC STM LINE HI FLO SW DPIS-13-83 STPT EXCD TS LT	SLIGHT SETPT DRIFT - MOD 288 DPIS
G	PB2	014182	020576	GS	FS	SG	A14	T	R	T			RCIC STM LINE HI FLO SW DPIS-13-84 STPT EXCD TS LT	SLIGHT SETPT DRIFT - MOD 288 DPIS
G	PB2	014401	040976	CA	PG	SN	B08	T	R	D			RELF VLV BELLOWES LK DET SW PS-2-2-71L FLO TO TRIP	BROKEN WIRE IN CONN PLUG-MOD 1482-V-40A-7
G	PB2	014659	042376	GS	PS	SN	A14	T	R	D			SECNRY CONT-TORUS VAC BKR DPIS-2503B OIL GT TS	SLIGHT SETPOINT DRIFT - MODEL 277 DPIS
G	PB2	014400	042676	GS	LT	IX	B13	T	R	D			RX LVL SW LIS 2-2-3-101B COULD NOT OBT ACC RESP TI	ME-DEFECTV MICRO SW - MODEL 288A LVL IND
G	PB2	014745	050476	MO	RR	NN	B13	N	R	U			GAMMA SCAN MULTI-CHANNEL ANALYZER FAILED	NO CAUSE, OTHER THAN COMPONENT FAILURE
G	PB2	015183	062876	GS	FS	SN	A12	N	R	D			MN STM LINE HI FLO SW DPIS 2-116A OPER HI ER THN TS	SLIGHT MECH BINDING-CLEARED WHEN EXERCISE
G	PB2	015233	071976	CL	XG	SH	B13	N	R	T			HPCI TURBINE SPEED CLD NOT BE CONT W CONTRLR OR PT	2 DEFCTV 2166 ZENER DIODES & 747 IC CHIP
G	PB2	015309	080376	MO	RR	NN	B13	N	R	T			CONT RM VENT MON RIS-0160A ABNML READNGS IN NDR&TS	IC FAILURE IN EXP CNTG CKI-DRM 100
G	PB2	015453	082376	MO	RR	NN	B13	N	R	U			DRYWELL RAD GAS SMPLE PMPs TRIPPED -RELAY FAIL'D	FAILED IN FAIL-SAFE POSITION; REPLACED
G	PB2	015743	090876	GS	LS	SF	B13	T	R	T			CONT SPRAY PRMSY SW LIS-2-2-3-73A FOUND TO BE INOP	CRACKED BELLOWES - MOD 4418CE LEVEL SWITCH
G	PB2	016079	091476	GS	FG	SH	A14	T	R	T			HPCI STM LINE HI FLO SW DPIS 2-23-76 TRIP GT TS	SETPOINT SHIFT - MOD 288 DIFF PRESS SWITCH
G	PB2	016332*	111576	GS	PS	SN	A14	T	R	T	2	MN STM LINE PRESS ISOL SWS PS-2-2-134A&B TRIPPED	BELOW TS-SETPT DRFT-MOD 821-A1255 PRES SW	
G	PB2	016569	121776	GS	FG	SH	A14	T	R	T			LO ST PT OF HPCI STM FLO SW DPIS-2-23-76 HIER THAN	TECH SPEC-SETPT DRFT-MODEL 288
G	PB2	017153	021077	GS	FS	SG	A14	T	R	T			RCIC STM LINE HI FLO SW DPIS-2-13-83 TRPD GT TS	SETPOINT DRIFT - MOD 288 DP SWITCH
G	PB2	017496	021077	GS	FS	SN	B12	T	R	D			MN STM LINE FLO SW DPIS-2-2-116A FAILED TO TRIP	BINDING IN THE SW LINKAGE-MOD 288 DP SWCH
G	PB2	018250	071977	MO	RR	NN	B09	N	R	U			VENT STACK RAD MON RIS-2979B BECAME INOPERABLE	BLOWN FUSE IN LOGIC POWER SUPPLY



RECURRING FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROV	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	P11	014125*	011276	GS	PS	SN	A14	T	R	T	2	PCIS SYS PS-261-30A6C SETPTS WERE 5 PSI ABOVE TS	MINOR SETPT DRFT - 50-1200 PSI-B2T-A1255
G	P11	014170*	011976	MO	RR	NN	B11	N	R	T	2	PLT STK PRCS RAD MON SYS LO SUCTION FLOW - TWICE	SAMPLE PUMP INLET LINE PLUGGED WITH ICE
G	P11	015109	070676	GS	PG	SL	A14	T	R	T		CS & LPCI INJ PS-263-92A SET POINT WAS GT TS	MINOR SETPOINT DRIFT
G	P11	016024	093076	MO	RR	NN	A07	N	R	T		PRI SYS CLT BNDRY LKG AIR SMPL SYS-ERRATIC INDICAT	CONDNSTN IN SAMPL PIPING CARRIED OVER
G	P11	016426	010777	GS	PG	SL	A14	T	R	T		CS & LPCI INJ PS-263-92A SETPT OF 363 VS 400 PSIG	SETPOINT DRIFT
G	P11	017165	020777	GS	PT	PX	A14	T	R	T		LO VAC SCRAM PRES SW PS-50386D SET AT 22.5 VS 23IN	MINOR SETPOINT DRIFT
G	P11	017371	031477	IN	RG	NN	B13	N	R	T		PRI SYS CLT BNDRY LKG AIR SMPL PUMP FAILED	PUMP REPLACED AND MOISTURE IN INST REMOVD
G	P11	017549	041377	GS	PG	SL	A14	T	R	T		RHR ISOL SIG PRES SW PS-263-23A ACTUATES GT TS	MINOR SETPOINT DRIFT
G	P11	018408	070577	GS	PG	SL	A14	T	R	T		CS & LPCI INJ PS-263-92A SETPT OF 444 VS 400 PSIG	LIMITED SET POINT DRIFT
G	P11	018469*	071477	GS	PG	SL	A14	T	R	T	2	RHR SYS PRESS SW PS-261-23A6B HAD TRIPS GT TS LMT	MINOR SET POINT DRIFT
G	P11	021099	041378	GS	PG	SH	A14	T	R	T		HPCI STEAM LN LO PRES SW 23-PS-2389C-61 VS 72 PSIG	SETPOINT DRIFT-REPETITIVE-WILL BE REPLCD
G	P11	021964*	071778	GS	PG	SL	A14	T	R	T	2	PRI SYS PRES SWS PS-261-23A6B HAD TRIP GT TS LIMRY	MINOR SETPOINT DRIFT - 0-1500 MOD B2TA125
G	P11	025127	012079	MO	RR	NN	B11	N	R	D		PLANT STACK PROCESS RAD MON HAD LOW FLOW	FROZEN SENSING LINES
G	P11	027701	010799	MO	RR	NN	B07	N	R	D		RX COOLANT LEAK DETECTING SYS(19) IND LOW FLOW	MOISTURE IN SAMPLING LINE, STEAM LEAK
G	P11	030758	031280	GS	PS	SN	A14	T	R	T		LP PERMISSIVE PS-263-92A SETPOINT DRIFTED (LOW)	SETPOINT DRIFT
G	P11	030737	031380	GS	PT	PX	A14	T	R	T		CONDENSER LO VACUUM PS-503D SETPOINT DRIFTED LOW	SETPOINT DRIFT
G	P11	032644	082680	MO	RR	NN	B07	N	R	T		RX CLNT LEAK DET AIR SAMP SYS C-19 INOP EXCESSV //	MOIST IN SENSING LINES, VLV PCK LEAK
G	P11	032811	093080	MO	RR	NN	B07	N	R	T		RX CLNT LEAK DET AIR SAMP SYS C09 INOP	CONDENSATE IN SAMP LINES SATURATING C-19
G	P11	036127B	010781	MO	RR	NN	B09	N	R	U		MAIN STACK SAMPLE LOW FLOW ALARM RECEIVED	SAMPLE PUMP POWER SUPPLY FUSE BLEW
G	P11	036497	021781	MO	RR	NN	B08	N	R	U		RX COOLANT LEAK DETECTOR AIR SAMPLING SYS DECLARE-	-D INOPERABLE, FUSES BLEW, WORN BEARINGS
G	P11	037734A	061781	MO	RR	NN	B08	N	R	T		RBV SAMPLE PUMP "A" TRIPPED	INTERNAL FRICTION DUE TO NORMAL WEAR
G	P11	037734B	061881	MO	RR	NN	B08	N	R	T		RBV SAMPLE PUMP "A" TRIPPED	INTERNAL FRICTION DUE TO NORMAL WEAR
G	P11	037736A	061881	MO	RR	NN	B08	N	R	T		MAIN STACK SAMPLE PUMP "A" TRIPPED	INTERNAL FRICTION DUE TO NORMAL WEAR
G	P11	037736B	061981	MO	RR	NN	B08	N	R	T		MAIN STACK SAMPLE PUMP "A" TRIPPED	INTERNAL FRICTION DUE TO NORMAL WEAR
G	P11	038259*	070981	GS	PS	SN	A14	T	R	T	2	PS PS-263-92A & 93A FOUND OOC/PERMISSIVE FOR CORE-	-SPRAY AND LPCI) FOUND OOC, INST DRIFT
G	P11	038207	072081	GS	PS	SN	A14	T	R	T		PRESSURE SW PS-261-23A FOUND OOC 3PSI HIGH	INSTRUMENT DRIFT
G	QC1	015347	072776	GS	PS	IC	A14	T	R	T		RX BLDG/SUP CHBR VAC BKR PS-1-1622B TRIPPED GT TS	SETPOINT DRIFT-MOD 12R2KK015-V, RNG +20PSI
G	QC1	017469	030577	GS	LG	AS	B08	T	R	U		LEVEL SWITCH FOR CIRC WATER PUMP FOUND INOPERABLE	MOTION OF SW RESTRICTD BY FRICTNGSMAL WIRE
G	QC1	018108	042277	GS	PS	IC	A14	T	R	T		RX BLDG/SUP CHBR VAC BKR TRPD AT 0.527 VS 0.5 PSID	INSTRUMENT SETPOINT DRIFT
G	QC1	018458	052577	GS	LG	AS	B08	T	R	U		COND HTWL FLD PROTCH LVL SW FAILED TO ALARM IN CR	SMALL WIRE BIND AGST COVER-PRVNT MOVEMENT
G	QC1	018581	072877	GS	PS	IC	A14	T	R	T		RX BLDG/SUP CHBR VAC BKR PRES SW TRIPPED GT TS LMT	INSTRUMENT SETPOINT DRIFT
G	QC1	018747	081677	GS	LS	SD	B08	T	R	U		LO-LO RX VSL WTR LVL SW WOULD NOT TRIP	MISALGNMT OF SW COVER CAUSES GAP BTWN SW
G	QC1	019684	102677	GS	PS	IC	A14	T	R	T		RX BLDG/SUP CHBR VAC BKRTS(1-1622B) TRPD GT TS	INSTRUMENT DRIFT-MFR SUGGSTS 5-YR REPLCMT
G	QC1	020941	032078	GS	PG	NM	B11	M	R	T		PRESS SW PS-1-1001-88A WAS FOUND FAILED	OBSTRUCTION OF THE SENSING LINE
G	QC1	021786	061578	GS	LT	PX	B08	T	R	U		LO-LO RX WTR LVL SW LIS-1-263-72A FAILED TO OPERATE	MERCOLD SWCH MISALGND W CAM-MNTD MAGNET
G	QC1	021982*	071878	GS	LS	SD	A08	T	R	U	2	LO-LO RX WTR LVL SWS LIS-1-263-72A6B TRPD GT TS	MERCOLD SWCH MISALGND W CAM-MNTD MAGNET
G	QC1	022188	072678	GS	PS	SN	A14	T	R	T		RX BLDG/SUP CHBR VAC BKR PS-1-1622B ACTUATE GT TS	SETPOINT DRIFT OF PRESSURE SWITCH
G	QC1	022191*	080178	GS	TG	NN	A14	T	R	T	5	5 OF 16 HPCI TURB AREA HI TEMP ISOL SWS SET GT TS	INSTRUMENT SETPOINT DRIFT
G	QC1	022814	092978	MO	RR	NN	B13	N	R	T		A S JAE OFF GAS LOG RAD MON FAILED DOWNSCALE	HI VLTG PS CAPCTRS LOUSENED-NO CNTCT W CH
G	QC1	023382	112278	GS	PT	PX	A14	T	R	T		EHC PRESS SW 1-5600-PS-3 TRPD AT 880 VS 900# DECRE	INSTRUMENT SETPOINT DRIFT
G	QC1	025053	010779	GS	FS	SQ	B13	N	R	T		HIGH SL FLOW SWITCH DPIS-1-1360-1 FAILED CAUSED //	ISOLATION, FAILED MICRO SWITCH IN PR SW
G	QC1	025427*	021479	RF	PS	JA	B14	T	R	T	2	ADS TIMERS 287-105A & B FOUND OOC HIGH	INSTRUMENT DRIFT--ONE TIMER REPLACED
G	QC1	027104	072479	RF	PS	JA	B14	T	R	T		SUPPRESSION CHAMBER RB VACUUM BKR /RESS SW PS 1-//	1622B FOUND OOC HI, INSTRUMENT DRIFT
G	QC1	027103	081379	RF	PS	JA	B14	T	R	T		HPCI TURBINE AREA HI TEMP SWITC TS 1-2371A OOC HI	SETPOINT DRIFT
G	QC1	027559	092979	MO	RR	NN	B13	N	R	T		FALSE HIGH RADIATION SIGNAL RECEIVED	BURNED COIL IN RELAY
G	QC1	031102	041580	GS	LT	PX	A14	T	R	T		RX LO WTR LVL SW LIS-263-57A OUT (LOW)	INSTRUMENT SETPOINT DRIFT
G	QC1	031103	042380	GS	PT	PX	A14	T	R	T		PRESS SW 1-5600-PS-3 TRPD BELOW TECH SPEC LIMITS	INSTRUMENT SETPOINT DRIFT
G	QC1	033867	090380	GS	TS	SN	A14	T	R	T		TEMP SW TS-1-2371A TRPD ABOVE TECH SPEC LIMITS	INSTRUMENT SETPOINT DRIFT
G	QC1	037448	011681	GS	LT	PX	A14	T	R	T		RX LOW-LOW LEVEL SWITCH LS-1-263-57A FOUND OOC HI-	-8.7 SIN, INSTRUMENT DRIFT
G	QC1	165990	040781	GS	TS	SQ	B13	N	R	U		RCIC HIGH STEAM FLOW SW OPSI 1-1360-1B FAILED	MICROSWITCH FAILED





COMMAND FAULT

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
B CR3	025935	040479	MO	RR	NN	A00	N	N	S	D		BRK FOR RX BLDG RAD MON FOUND OPEN	NO CAUSE FOUND
B LR3	027271	092579	SE	NT	PX	A07	N	N	S	D		POWER RANGE INST CH NI-5 WAS ERRATIC	LOSS OF AREA COOLING AROUND DETECTOR
B CR3	037477	052281	TX	FG	CT	B09	N	N	S	D		EMERG FW ULTRASONIC FLOWRATE IND WOULD NOT RESET	FAILED POWER SUPPLY BOARD IN TRANSMITTER
B OB1	019378	101177	PS	NT	PX	B06	N	N	S	D		RPS CHANNEL 1 ACCIDENTALLY DEENERGIZED DURING TEST	ERROR IN MAINTENANCE WORK ORDER
B OE1	033363	112480	IN	LG	AS	A07	N	N	S	D		LOST LVL INDICATION TO STATION EMST	WTR IN AIR COMPRESSOR PROVIDES INSTRU AIR
B DE3	030567	030280	TX	LG	NN	B07	N	N	S	U		BWST LVL CH 1 FAILED HI LVL XMITR BELLOWS FROZE	XMITR BOX CVR REMOVD REASON UNDETERMINED
B TI1	014677	021976	HS	RR	NN	B03	N	N	S	D		FLOW RECORDER FR-123 NO OUTPUT TO CLOSE WDG-V47	TEST SWITCH FOR RECORDER LEFT IN TEST POS.
B CC1	014901	051176	IN	NG	PX	A04	N	N	S	D		CH A RPS VUPT RESETTING AUTOMATICALLY	ELECTRICAL NOISE FROM ANNUNCIATOR
B CC1	023651B	080178	LM	DC	NN	B13	N	N	S	D		COMPUTER FAILED CAUSING LOSS OF CEA PULSE COUNT PD	COOL. FAN FAILURE CAUSING SUPPLY CBK OPEN
B CC2	026396A	061979	NO	RR	NN	A00	N	N	S	D		CONT GASEOUS AND PART RAD MON SAMPLE PUMP TRIPPED	THOUGHT TO BE SPURIOUS HIGH FLOW ALARM
C CC2	026396B	061979	MO	RR	NN	A00	N	N	S	D		CON GAS AND PART RAD MON STBY PUMP FAILED TO START	THOUGHT TO BE SPURIOUS HIGH FLOW ALARM
C CC2	031031	042880	TX	LG	NN	A08	M	N	S	D		ERRATIC LVL IN PRESSRZR LVL CNTRL S LT-110X/Y	XMITR 2-LT-110Y DRAIN VLV'S LEAKING THRU
C FC1	026653	072479	PS	NT	PX	N00	N	N	S	D		'D' CHANNEL WIDE RANGE NUC INST FAILED	MAIN POWER FUSES #2 BUSS MOL-1'S BLOWN
C PA1	031394	052180	TX	FS	SN	B00	N	N	S	D		LOOP 2A HPS1 FLD INDCN (FT-0312) INOP	RUPTURED B' FLOWS CAUSED FLO XMITR TO FAIL
C SL1	014849	050476	IM	DC	NH	B04	T	S	D		DATA PROCESSOR MALFNCTN. CAUSN LOSS OF CEA PULSE	CONT. PROGRAM SKIPPED 160K OF WORDS	
C SL1	014350	051276	ZZ	DC	SN	B04	N	S	D		POWER DEPEND. INSERTION LIMIT CHANGN IN NONCONSERV	DIR. AS POWER INCREASED ERROR IN WIRING U.	
C SL1	017921	071276	LM	XG	NN	B02	N	S	D		DIGITAL DATA PROCESSOR MOMENTARILY DEENERGIZED	PERSONNEL TURNED OFF POWER SUPPLY	
C SL1	017871	050577	CM	PS	SN	A06	T	S	D		SETPNT OF BISTABLE TRIP FOR S/G PRESS LT. TS LMT	SETPNT NOT CHECKED DUE TO ERROR IN PROC	
C SL1	033188	081380	TI	XG	NN	B07	N	S	D		CEM 7 FAILED CAUSG ITS DUAL CEA TO FULLY INSERT	TIMING MOD OVERHEATD LACK OF VENTILATION	
W BV1	014691	051376	CM	TT	PX	B02	T	S	D		LOOP 1A OVERTEMP DT BISTABLE TRIPPED CAUSING RX TR	VOLTAGE SPIKE CAUSED BY PERSONNEL (MAIN.)	
W BV1	015915	083076	CA	XG	NN	B05	T	S	D		CONTROL SYS. DID NOT SHUT VALVE WHEN REQUIRED	WIRING DID NOT CONFORM TO SYSTEM LOGIC	
W BV1	017694	042777	SE	NC	NN	B01	N	N	S	D		DECTOR #2 ALIGNED TO WRONG THIMBLE OF APDM SYSTEM	OPERATOR SELECTED WRONG THIMBLE
W BV1	020794	022878	HS	NT	PX	B01	N	N	S	D		POWER RANGE CHANNEL N43 INDICATED ZERO	POWER SUPPLY NOT RESET AFTER LOSS OF PWR
W DC1	016386	111976	MO	FG	NN	B02	N	N	S	D		TOTAL CHLORINE RESIDUAL INDICATED ABOVE LIMITS	PERSONNEL ERROR-RATE CONTROLLER SET HIGH
W IP2	032932	101780	SE	NT	PX	B07	N	S	D		PWR RNG NI CHNL N42 DRIFTING INDICATION	DFCTY DET DUE TO MOISTURE IN ITS CONNECTR	
W JF1	026716	062779	MO	RR	NN	B00	N	S	D		FUEL STORAGE RAD MONITOR R-5 DECLARED INOPERABLE	FEED BREAKER FOUND OPEN, NO CAUSE FOUND	
W JF1	027182	091279	MO	RR	NN	B07	T	T				CNTNMNT GAS ACT-PURGE & EXHAUST MON R24-B INOP	VIBRATION CLOSED EXHAUST BYPASS VLV
W JF1	030458	022980	CM	PT	PX	B12	T	T				B/S ERRATIC SETPT PZR PRESS CHNL DECLRD INOP	DIRTY GAIN POTENTMTR FOR LEAD/LAG CONTRLR
W JF1	032917B	100980	PS	XG	NN	B13	T	D				NO MANUAL CNTRL OF D/G FREQ BLOWN FUSES IN PWR SUP	SHORT CKT IN VOLTAGE REGULATOR
W JF1	036874	040481	TX	FT	PX	B08	T	U				FW FLD LOOP FT-486 INOP FAILD TOLERANCE REQUIREMNT	XMITR FT-486 ROOT VLV PLUG ASSMBLY CLOSED
W JF1	038363	081381	MO	RR	NN	B09	N	S	U			R-11,-12 DEENERGIZED	MCC 600/280V POWER XFMR FAILED
W JF2	038184	072781	TX	FT	PX	B08	N	S	U			2B S/G STM FLO XMITR FT-485 INOP	VLV PLUG CLOSED WHEN VLV HANDWHEEL OPEN
W JF2	038932	080181	TX	LG	NN	B00	N	S	U			RWST LT-501 INOP WHEN LI-4075A FAILED HIGH	NOIST IN XMITR JUNCTN BOX DURG RAINSTORM
W MGL	038416	081481	TX	LT	PX	B12	N	S	D			PZR LEVEL CH 3 FOUND INDICATING 30% HIGH	FITTING IN REFERENCE LEG FOUND LEAKING
W N41	030511	020880	CM	PS	SN	B09	T	S	D			CNTNMNT HI-HI PRESS CHNL 2 B/S FAILED TO TRIP	CRD COMP REGULATES 15V PWR SUP SHORTED
W N41	031436	061280	TX	LT	PX	A08	N	S	U			"A" SG LVL IND LI-1474 READ 5% HIGH	STM LEAK ON UPPR XMITR ISOL ROOT VALVE
W N41	032860	092680	TX	LT	PX	B08	N	S	U			PZR LVL XMITR LI-1461 FAILED HIGH	FAILURE IN TEMP COMPENSATUR ON D/P UNIT
W NA2	031827	07108C	IN	DG	NN	A14	N	S	U			MORE THAN 12 STEP DIFF BTWN RPI N7 & GRP DEMND IND	VOLTAGE DRIFT IN SIG CONDITIONING CARD
W PR2	018818	081977	IN	XG	SN	B04	T	S	D			AUX BLDG VENT "NOT READY" MON LITES DID NOT ENERGZ	OPENING FAN BRKR DEGNRGS LITE-DESIGN ERR
W PR2	019895	120877	TX	PS	SN	A03	R	S	D			HEAD CURRCN FOR PSZR PRESS XMITRS NOT APPLIED-CAL	PERSONNEL ERROR IN ESTAB CAL DATA-INI S/U
W PT1	025586	033079	LM	NG	NH	B01	N	S	D			PLANT COMPUTER INITIALIZED INCORRECTLY RESULTING//	IN AXIAL FLUX NOT MONITORED. PERSONNEL
W SA1	017017	012077	ZZ	FT	PX	B05	N	S	D			NO 12 RX COOLANT FLOW CHANNEL 1 BECAME INOPERABLE	SWAGELOK TUBE FITNG BACKED OFF-CUNST EROR
W SE2	171661	111281	SE	PG	NN	B11	N	S	D			2-P1-68-69 RCS WIDE RANGE PRESS HOTLEG WAS INOP	LEAK IN THE TUBING DUE TO A LOOSE FITTING
W SU1	015548*	072176	GS	PG	NN	B06	R	S	D			2 PRESS.-SW. JUMPERED OUT--CLS CONTNMNT HI SIGNAL	JUMPER LOG NOT REVIEWD AT PROPER TIME
W TR1	014252*	011876	TX	FS	SH	B03	N	S	D			"C" STEAM LOOP FLOW XMITR ISOLATED CAUSN CONST OUTP	DID NOT RETURN XMITRS TO SERVICE
W TR1	019113	090377	SE	NT	PX	B13	N	S	U			SOURCE RANGE CHAN N-31 FAILD TO ENERGIZE AT 10-10A	REMOVED & REPLACED FUSES OPERATED OK THEN
W TU3	032888	092680	ZZ	FG	CT	A07	N	S	D			"A" AWP FAILD TO COMPLETELY DELIVER REQUIRED FLOW	IA DRYER OOS WTR IN AIR CNTRL FRM IA SYS
W YR1	020973*	032378	MO	RR	NN	A02	T	D				ALL 4 STEAM GEN RAD.MONTR.SET AT 100 CPS VS 80 CPS	SETP'S NOT RETURNED TO TS LIMIT AFTER TEST
G BF1	016053	092376	GS	FS	SD	B02	T	C				CORE SPRAY SPARGER/VESSEL DP INST FLOW ALARMING	DP SWITCH FOUND VALVED OUT (LOOP 2)
G BF1	033812	100780	RC	TG	NN	B13	N	S	U			AIR DIFF TEMP REC TDR-90-103/104 FAILED	COMP FAILURE IN MODEL 3450 DIGIT VOLTMR





RECURRING COMMAND FAULT

PLANT	NUMBER	DATE	COMP	SYSTEM	MODE	CAUSE	STATUS	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
00000	02299	010976	MO	IC	406	00000	00000	MON-11 NOT CRCTLY SAMP RX 8LDG AINOS DUE TO// TECHNICALS LEFT COVER PLATE AINOS TO// SPURIOUS CLEAR POSITION INDICATIONS EFFECTS TO DEVIATION IN PRESS CHAL INDICATIONS TRIP INOPERABL	MAINT PROC W/ DET REMOVE REPLICAC. DFCT PROC TRAPED. PROC W/ DET REMOVE REPLICAC. DFCT PROC TRAPED. PROC W/ DET REMOVE REPLICAC. DFCT PROC TRAPED. PROC W/ DET REMOVE REPLICAC. DFCT PROC TRAPED. PROC W/ DET REMOVE REPLICAC. DFCT PROC
00000	02299	010977	MO	IC	401	00000	00000	MON-11 INCORE ALARM SETPOINTS USED FOR 61/4HR DEFLECTOR NOT MOVED WHEN REQUIRED. RELAY ON 4// DEFLECTOR FLUX YLT INSTR. CHNL MTRIP AND M12 PUMP FOR RAD MON R11 AND R12	USE D INCORRECT FLUX SETPOINTS FOR SETPOINTS DEFLECTOR NOT MOVED WHEN REQUIRED. RELAY ON 4// DEFLECTOR FLUX YLT INSTR. CHNL MTRIP AND M12 PUMP FOR RAD MON R11 AND R12
00000	02299	010978	MO	IC	401	00000	00000	MON-11 INDICATED HIGH CHNL LEVELS J1 NUMBER OF CRD ACCUMULATED HIGH SW 1, 2, 3 ON L15-58A DID NOT OPER AT PROP SETPT	HI XMITR OUTPUT DUE TO LEAKG ROOT ISOL VLV HI XMITR OUTPUT DUE TO LEAKG ROOT ISOL VLV HI XMITR OUTPUT DUE TO LEAKG ROOT ISOL VLV
00000	02299	010979	MO	IC	402	00000	00000	EDIPA DRUM INTGRN ERRONEOUS INDICATIONS DRA 21222A WAS FOUND VALVED OUT - ISOL COND LOGIC DRA 21222A WAS FOUND VALVED OUT - ISOL COND LOGIC DRA 21222A WAS FOUND VALVED OUT - ISOL COND LOGIC	XMITR DRIFT AIR IN INSTRMT LINE XMITR DRIFT AIR IN INSTRMT LINE XMITR DRIFT AIR IN INSTRMT LINE
00000	02299	010980	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010981	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010982	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010983	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010984	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010985	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010986	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010987	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010988	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010989	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010990	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010991	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010992	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010993	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010994	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010995	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010996	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010997	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010998	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	010999	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION
00000	02299	011000	MO	IC	812	00000	00000	TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN TORQUE VALV 2480310 FOUND OPEN	EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION EXPOSURE TO PROCESS ENVIRONMENT CORROSION

COMMON CAUSE COMMAND FAULT

STATUS	PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROB	SYMPT	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #		FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
B	AR1	038482	080481	ZZ	NT	PX	A02	M	U	D				B RPS SCALD DIFF IN AMP GAIN SETTING ERRONEOUS	WRNG POTENTIOMETER ADJSTD IN PREVIOUS CAL
BB	CR3	036319	020981	IN	LG	NN	A07	T	U	D			4	RC DRAIN TANK LVL IND ERRATIC	VAPOR CONDENSATE IN INSTR SENSING LINES
B	CR3	037941*	072281	ZZ	NT	PX	A14	T	U	D				ALL PWR RNG NI LESS CNSRVTY THAN ACCEPT CRITERIA	ROD INDEX CHANGE IN END-OF-CYC CR W/DRAWL
B	CR3	173642	092181	MD	RR	NN	B02	M	U	D				RAD MON RM-AS RENDERED INOPERABLE	PERSONNEL SHORTED FUSE
B	DB1	030262	012280	SE	NC	NN	B04	N	U	D				NI-7 IND ON CMPTR GRP 38 RDG BELOW HEAT BALNC PWR	DESIGN ERROR EXTIRMLY TIGHT 100% CAL BAND
B	DB1	031417	053180	IN	FG	SH	A03	T	U	D				LOSS OF DECAY HEAT FLOW IND FI-DH28	TEST PERFORMED W/O SHIFT SUPER KNOWLEDGE
B	DB1	031472	060680	IN	LG	NN	A04	T	U	D				SPENT FUEL POOL LVL BELOW TECH SPEC	IMPROPER ALARM SETPOINT
B	DB1	031897	070980	MD	RR	NN	B02	T	U	D				SHRT CKT LOST Y3 THUS SFAS CHNL 3 CNTNMNT RAD INOP	PERS ERROR WRONG INSULATED ALLIGATOR CLIP
B	DB1	031906	080380	CH	X5	SN	B02	N	U	D				B/S BA413 REMOVED & CLOSED OH11 STOPPING FLOW	ERROR BY MAINTENANCE SPECIALIST
B	DB1	033097	102780	SE	PT	PX	B02	N	U	D				RPS-1 TRIPPED ON S/D/BYPASS HP TRIP	CNSTRCTN PERS BUMPED PRESS DET HOUSING
B	DB1	037654	061681	MO	RR	NN	B02	N	U	D				CNTNMNT RAD POST ACCIDENT MON RES030 NOT RUNNING	BYPSS DSCHRG HOSE KNOCKED OFF DURING MAINT
B	DB1	036395B	071281	MO	SS	SN	B00	T	U	D				DEFECTIVE CURRENT BUFFER	RAD -24 VDC POWER SUPPLY
B	DB1	038238	071781	TX	XG	CT	A06	R	U	D				AFW PUMP DSCHRG VLV SPEED ODC (HIGH)	SPEED ELEMENT PROBE NOT ADJSTD/PROC INADQ
B	DE3	019884	122877	SE	PT	PX	B06	N	U	D				XMTX LEFT VALVED OUT AFTER REPAIR TO TEST TEE	INCORRECT/INCOMPLETE VALVE CHECKLIST
B	RS1	032315	081380	CM	NT	PX	A01	N	U	D				RFS IN S/D BYPASS MODE & NUC OVERPWR TRP SETPT IN/	/CORRECT. OPERATOR ERROR
B	RS1	172867	121181	ZZ	XT	PX	B03	T	U	D				RPS CHANNEL INOP DUE TO TESTING ERROR	MAINT PERS INCORRECTLY TRPD BRKR
C	AR2	025208	012779	CA	DG	NN	A02	T	U	D				CEAC DEVIATION ALARMS WERE RECEIVED.//WHILE TROUBL	E SHOOTING CPC #81 CABLES IN CEACL DSTRBD
C	AR2	027033	090479	PS	LG	NN	B01	N	U	D				CNTNMNT BLDG SUMP LEVEL IND 2LI-3645-1 INOPERABLE	POWER TURNED OFF FROM POWER SUPPLY
C	AR2	033376A	120180	IM	XT	PX	B02	M	U	D				CPC "A" FAILED ON LOW VOLTAGE	MAINT PERS SHORTED SIGMA FLOW INDICATOR
C	AR2	033376B	120180	SE	DT	PX	B02	M	U	D				CEAC #1 FAILED ON LOSS OF REED SW POSITION IND	MAINT PERS SHORTED SIGMA FLOW INDICATOR
C	AR2	037472*	052081	SE	NG	NN	A05	N	U	D			2	SOURCE RNG NEUTRON FLUX MON SIG INCRSD NOISE INT//	RRFNC. DUE TO WELDER INTERFERENCE
C	CC1	037178	042481	CM	PS	SN	B02	M	U	D				ESFAS ZD CNTNMNT PRES. SENSOR D05 LOST +15 PWR SUP	ISOLATOR FAILD. INDUCED IN MODIFICATION
C	CC1	037290	052781	IN	FG	NN	B02	N	U	D				PZR SAFETY VLV ACOUSTIC FLO INDICATOR INOP	HEAVY OBJECT SEVERED HARDLINE CABLE
C	CC1	037494	061281	GS	L5	SN	A02	N	U	D				RWT LEVEL SWITCH I-LS-4142C WAS ISOLATED	FAILURE TO RETURN LVL SW TO PROPR LINEUP
C	CC2	027535	102279	TX	PS	SL	A02	N	U	D				TECHNICIAN INSERTED DUMMY SIGNAL TO WRONG PRESS //	XMITTER CAUSING SI-651-MOV TO GO SHUT
C	CC2	036027	011881	TX	PG	NN	B02	N	U	D				PRESS XMTX 2-PT-103-1 FAILD HI CAUSG PORV TO OPEN	LOOSE OSCILLATOR/AMP ASSEMBLY W/ IN XMTX
C	CC2	038272	080481	ZZ	NT	PX	B02	N	U	D				NI POWER SPIKES CAUSG SPURIOUS RPS TRIPS	OVERTIGHT FUSEHOLDER INTERNALS BROKEN
C	M12	033801	040380	CM	PT	PX	A04	N	U	D				A-RPS LO SG PRES BYPS REHVL B/S CARD HIGH SETPOINT	HI SENSVTY TO CHANGE IN INPUT RESISTANCE
C	M12	033118	102580	CM	NT	PX	A02	N	U	D				B/S SETPOINT DRIFTED HAD BEEN LEFT AT HI LIMIT	NONLIC. OPERATOR PERSONNEL ERROR
C	M12	172388*	122981	MD	RR	NN	B01	M	U	D			3	REQ # OF CNTNMNT RAD MON NOT OPERABLE	OPERATOR ERROR
C	MY1	026021	052479	CM	PT	PX	A02	R	U	D				RPS S/G LOW PRESSURE BISTABLE SETPOINT FOUND LOW	INCORRECTLY SET DURING PAST CALIBRATION
C	MY1	027009	091079	MD	RR	NN	A04	R	U	D				LIQUID RAD WASTE RAD MONITOR DID NOT RESPOND PROP	INSTALLED CHECK SOURCE TO SMALL
C	PA1	031954	071080	IN	XR	NN	A06	N	U	D				NI-03 NOT DCLOD OPERABLE PRIOR TO RX S/D	ADMIN CNTRL MECHANISM (EOR) NOT CLEARED
C	PA1	032156	071980	IN	FG	SN	B06	N	U	D				HSP1 FLO TO LOOP 2B (FT-0313) INOP	INSRMM1 EQUALIZ VLV NOT CLOSD AFTER CAL
C	SL1	031397	041980	MD	RR	NN	B01	N	U	D				LIO WASTE DISCHARGE MONITOR ISOLATED	OPER PERS UNHAWARE MONITOR WAS DISABLED
C	SL1	031695	050780	RE	XG	NN	B02	T	U	D				IA D/G DIDN'T SYNCHRONIZE TO EMERGENCY BUS	FREQ PERMISSIVE RELAY K49 SET INCORRECTLY
C	SL1	031646*	052080	LM	DG	NN	B00	N	U	D				ODPS MALFUNC LOST CEA BACK-UP POSITION INDICATION	PROGRAMMING ERROR
C	SL1	172200	121081	SE	NG	NN	B04	T	U	D				IN-CORE DETECTOR ALARM SET POINTS INCORRECT	COMPUTER SOFTWARE USED WRONG FLUX INPUTS
W	BV1	014606A	051276	CM	NT	PX	B01	N	U	D				OVERPOWER BISTABLE NOT TRIPPED WHEN REQUIRED	OPERATOR FAILED TO TRIP BISTABLES
W	BV1	014606B	051276	CM	TT	PX	B01	N	U	D				OVERTEMP BISTABLE NOT TRIPPED WHEN REQUIRED	OPERATOR FAILED TO TRIP BISTABLES
W	BV1	027398	111079	MD	RR	NN	B02	R	U	D				PARTICULATE RAD MON DECLARED INOP CNTNMNT ACCESS//	COVER NOT INSTALLED PROPERLY
W	BV1	033253A	112180	CL	FG	CT	A02	N	U	D				CNTRL PROB WITH BYPASS & MAIN FEED REG VLVS	CNTRL MODIF FOR VLVS NOT PROPERLY TUNED
W	BV1	033308	112280	TX	FT	PX	B01	N	U	D				MAIN STM FLO IND FI-MS-484 FAILED LOW	TRANSB BYPS VLV NOT CLOSD PERSONL ERROR
W	BV1	033487	120580	SE	TS	SN	A05	N	U	D				LO THERMOUPLE RDNGS BY BIT OUTLET ISOL VLVS NOT//	7 IN FULL PIPE CONTACT. CNSTRCTN ERROR
W	BV1	036045*	101881	SE	TS	SN	A06	T	U	D			2	RWT RECIRC LINE FROZEN	HEAT TRACE CKT THERMUSTATS IN OFF POS
W	BV1	038232	071981	GS	X5	SN	A06	M	U	D				B SSPS INOP DUE TO ERRATIC RX TRP & SI SIGNALS	WIRING CHANGE TO OUTPUT RELAY SELECTOR SW
W	BV1	171812	111681	HS	FT	PX	B02	N	U	D				RCP UNDERVOLTAGE RX TRIP FOUND DISABLED BY SWITCH	PERSONNEL ERROR
W	DC1	026820	012279	GS	NS	SN	A02	N	U	D				APDMS ALARM SETPOINT SWITCH SET AT WRONG SETPOINT	PERSONNEL ERROR
W	DC1	026506A	072079	SE	FG	AG	A02	N	U	D				BORIC ACID FLOWMETER NOT INDICATING PROPERLY	METER WAS NOT PROPERLY CALIBRATED
W	DC1	027607	111179	CM	FT	PX	A02	N	U	D				WRONG STEAM FLOW CHANNEL PLACED IN TRIPPED CONDIT//	/ION. LABELS WRONG OR PERSONNEL ERROR







COMMON CAUSE COMMAND FAULT

PLANT	CONTROL NUMBER	EVENT DATE	JOB #	SOUR	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #		FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	QC1	032485	081980	SC	PS	IC	A02	N	U	D			PRESS SENSOR PN-4 NOT SENSING FLOW PROPERLY	MISALIGNED DUE TO WELD LEAD ACROSS TUBING
G	QC1	038699*	090581	SC	PS	PX	B00	N	U	D	2		DEVIATION OCCURED BETWEEN INDEPENDENT LEVEL IND	HEAD CHANGE OF REFERENCE COLUMN
G	QC1	172614A	120381	SC	PS	SH	B02	R	U	D			ONE ADS TRIP SYSTEM INOPERABLE	REMOVAL OF DIR CURR CONTROL POWER FUSES
G	PB2	025742*	032379	PS	SH	B12	N	U	U		4		C TRIP LOGIC TEMP SWITCHES (TS-4941C, 2C, 3C, 4C) FO//	UND READING LOW, DIRTY CONTACTS IN PS
G	PB2	025663*	042879	HO	RR	SN	B13	N	U	T	2		CH D, REFUELING AREA & RB AREA VENT RAD MON'S FAIL	DEFECTIVE CONVERTER IN COMMON POWER SUP.
G	PB2	025882	050379	CL	TG	NN	A06	N	U	D			TEMP OF SOLUTION IN SBLCS FOUND OUT OF SPEC	TEMP CONTROLLER SETPOINT SET WRONG
G	PB2	036346	012781	HO	RR	NN	B03	N	U	D			DRYWELL RAD MONITOR FOUND OUT-OF-SERVICE	SAMPLE FLOW VALVE NOT REOPENED AFTER TEST
G	PB2	036797*	040181	TR	PT	PX	B02	N	U	D			3 OF 8 DRYWELL PRESSURE TRANSMITTERS FOUND ALMOST-	-VALVED OUT, PERSONNEL
G	PB3	032052	052080	GS	PT	PX	A02	T	U		3		PS-51218 NOT CAL WITHIN TECH SPEC LIMITS	INSTR TECH TESTED WRONG PRESSURE SWITCH
G	P11	031761	071680	SE	PG	NN	A01	R	U	D			RX PRESS BNDRY LEAK DETCTN MON C-19 INOP	PERS CLOS'D CNTNNT SAMP ISOL VLVS
G	P11	032227	081880	GS	XT	PX	B04	N	U	D			MODE SW IN S/D TRP FUNC OF RPS FAILED WHEN B VITAL/	/ MG SET TRPD. DESIGN CHANGE IN PROGRESS
G	P11	038832*	092681	SE	LG	NN	B07	N	U	D	2		YARWAY LEVEL INDICATORS STARTED OSCILLATING	EXTREME TEMPERATURES INOUCED FLASHING
G	QC1	026049A	042779	GS	PS	IC	B02	N	U	D			SUPPRESSION CHAMBER PRES SW ES, PS-1-1622468 MADE//	INOPERABLE, PERSONNEL VALVED OUT
G	QC1	026049B	042779	TX	PS	IC	B02	N	U	D			TORUS PRESS INDICATING TRANS PIT-1-1623 MADE INOP	PERSONNEL VALVED OUT
G	QC1	030261	011180	TX	PS	SN	A01	T	U	D			D/P XMTR 1-8741-51 DID NOT INDICATE PROPERLY	PERSONNEL ERROR
G	QC1	032394	081880	CL	FG	SQ	A01	N	U	D			FLOW CONTROLLER INADVERTENTLY LEFT IN MANUAL	LICENSED OPERATOR FAILED TO PLACE IN AUTO
G	QC2	039250	032281	LS	DT	PX	B12	T	U	D			LIMIT SWITCH FOR MSIV AQ-2-203-2A CH B FAILED TO -	-GIVE HALF SCRAM, CONTACTS STICKING

RECURRING COMMON CAUSE COMMAND FAULT

STATUS	PLANT	CONTROL NUMBER	EVENT DATE	CODE	ARCUS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
B	CR3	025934	040479	MO	RR	NN	A02	M	V	D			DISCOVERED SENSOR FOR RX BLDG RAD MON MIS-POSITION	NOT POSITIONED CORRECTLY AFTER MAINTENAN.
B	CR3	030297	013080	TA	TS	SN	B05	N	V	D			TEMP XMITTR C1-563-TT STUCK DUE TO OPER OUT OF TE/	/MP RNG. IMPROPERLY LOCATED XMITTER
B	CR3	032855B	102980	MO	RR	IC	A02	N	V	D			RAD MON-41 NOT CRCTLY SAMP RX BLDG ATMOS	VALVE MISALIGNMENT PERSONNEL MAINTENANCE
B	CR3	039102	071881	IN	FG	NN	A04	N	V	D			EMERG FW ULTRASONIC FLO IND OUT OF ZERO CHECK LD//	LMT. UNABLE TO CONSISTENTLY IND ZERO FLOW
B	CR3	172159	120881	IN	FG	CT	A04	N	V	D			EMERGENCY FW ULTRASONIC FLO IND FW-313-FI DRIFTED	DESIGN ERROR
B	DB1	033357	120380	ZZ	XG	SN	B04	T	V	D			SHRT CKT LOST Y3 THUS RPS-3 & SFAS-3 INOP	DESIGN ERROR ALLIGATOR CLIPS TOO SMALL
B	DEL	022174A	080678	CM	NI	PX	A01	N	V	D	4		POWER TO FLOW TRIPS NOT RESET	OPERATOR FAILED TO RESET TRIP
B	DEL	022174B	080678	CM	NI	PX	A01	N	V	D	4		OVERPOWER TRIPS NOT RESET	OPERATOR FAILED TO RESET TRIP
C	CC1	030227	012980	TX	PS	SN	A03	N	V	D			SPURIOUS HI PRESSURE SIG FROM XMITTR PT-103-1	XMITTR JOLTED BY REMOVAL OF CVR IN REVIEW
C	CC1	037997	071681	TX	PG	NN	A01	N	V	D			PORV OPENED ON AN ERRONEOUS HI PRESSURE SIGNAL	XMITR PT-103-1 WAS BUMPED & SENT SIGNAL
C	CC1	038329	080381	IM	XC	NN	B07	N	V	T			FAILED PLANT COMPUTER CAUSG INOP INCORE DET SYSTEM	RAD XMISSION ERROR DUE TO HI AMBIENT TEMP
C	CC1	039582	082681	IM	XC	NN	B07	T	V	D			PLANT COMPUTER FAILD CAUSG INOP INCORE MON SYSTEM	RAD XMISSION ERROR DUE TO HI AMBIENT TEMP
C	FC1	032471*	080480	MO	RR	IC	A03	N	V	D	2		STACK PRICLT RMO-61 SETPT SELCTR SW IN WRONG POS	PERS ERR SW NOT RETURNED TO POS AFTER TEST
C	MY1	036856	041779	MO	RR	NN	B01	N	V	D			VLV IN TEMP LINE OFF CNTNMNT APD FOUND OPEN 9 DAYS	VLV NOT RETURNED TO NORMAL STATUS
C	MY1	037567A	071281	MO	RR	NN	B01	N	V	D			PRIMARY VENT STACK PARTICULATE SAMPLE FILTER FOU//	ND NOT INSTALLED. PERSONNEL ERROR
C	MY1	037567B	071681	MO	RR	NN	B01	N	V	D			PRIMARY VENT STACK PARTICULATE SAMPLE FILTER FOU//	ND NOT INSTALLED. PERSONNEL ERROR
W	DC1	172094A	121081	IN	TC	NN	B04	N	V	D	2		2 RCS HOT LEG TEMP INDICATIONS RDG LOW	DESIGN ERROR IN MODIFICATION
W	DC1	172094B	121081	IN	TC	NN	B04	N	V	D	2		2 RCS WIDE RANGE PRESS INDICATN RDG LOW	DESIGN ERROR IN MODIFICATION
W	DC2	172093A	121081	IN	TC	NN	B04	N	V	D	2		2 RCS HOT LEG TEMP INDICATION RDG LOW	DESIGN ERROR IN MODIFICATION
W	DC2	172093B	121081	IN	TC	NN	B04	N	V	D	2		2 RCS WIDE RANGE PRESS INDICATION RDG LOW	DESIGN ERROR IN MODIFICATION
W	JF1	172222A	121551	MO	RR	NN	A06	M	V	D			CNTNMNT PURGE VLV NOT CLOSU WHEN RAD MON R24A INOP	PROCEDURAL INADEQUACY
W	JF1	172222B	121781	MO	RR	NN	A06	M	V	D			CNTNMNT PURGE VLV NOT CLOSU WHEN RAD MON P24A INOP	PROCEDURAL INADEQUACY
W	MG1	173372	122481	ZZ	PS	SN	B02	M	V	D			TECHNICIANS INADV INITIATED LU STM LIN PRESS SI	PROCEDURAL DEFICIENCY
W	NA1	032775A	080780	TX	LT	PX	A04	N	V	D			PZR PROTCN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSING DRIFT
W	NA1	032275B	080880	TX	LT	PX	A04	N	V	D			PZR PROTCN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSG DRIFT
W	NA1	032275C	080980	TX	LT	PX	A04	N	V	D			PZR PROTCN CH 3 LVL INDICATION RDG HIGH	STM IMPINGED ON LVL XMITR CAUSG DRIFT
W	SF1	032167	072880	MO	RR	NN	B02	N	V	D			WST GAS EFF 0-RM-90-118 INOP	MAINT PERS REMVD MON FROM LINE IMPROPERLY
W	SF1	032876A	100480	TX	LG	NN	B04	N	V	D			PZR RELIEF TANK LI-68-312C INOP	XMITTER DRY LEG FULL OF WATER
W	SF1	032876B	101180	TX	LG	NN	B04	N	V	D			PZR RELIEF TANK LI-68-312C INOP	XMITTER DRY LEG FULL OF WATER
W	SF1	036296	020781	MO	RR	NN	B02	N	V	D			RAD MON 2-R-90-100 DISCOVERED INOP WHILE DISCHR	POWER SUPPLY BKR WAS DEENERGIZED
W	SF1	036842	040881	MO	RR	NN	B02	N	V	D			CONDENSATE DEMIN DISCHR RAD MON 0-RM-90-225 FAILED	FUSE IN POWER SUPPLY NOT INSTALLED
W	SU1	037219*	050481	TX	LT	PX	B02	N	V	D	3		PZR LEVEL CH 1-L-68-339,325C & 326C DECLARED INOP	ERROR IN SENSING LINE TUBING
W	SU1	037554	052281	MO	RR	NN	B01	N	V	D			CONTROL ROOM INTAKE TO TURBINE BLDG RAD MON ALARM-	-ED, FOUND DEENERGIZED. PERSONNEL
W	SU1	027331*	102979	MO	RR	NN	B06	T	V	D	2		RADIATION ALARM SETPOINT FOR CCW SYS MONITORS FO//	UND GREATER THAN TWICE BACKGROUND.
W	SU1	036670*	031680	MO	RR	NN	B02	N	V	D	6		POWER LOST TO SIX RADIATION MONITORS	TEST LEAD SHRTD TO GRND BLEW SUPPLY FUSE
W	SU1	033034*	101980	MO	RR	NN	A01	N	V	D	2		RM-CC-105/106 ALRM SETPTS GREATER THAN TWICE BACK/	/GROUND. SETPTS RESET NO CAUSE GIVEN
W	SU1	033606*	122380	MO	RR	NN	A01	N	V	D	2		RM-CC-105/106 ALRM SETPTS GREATER THAN TWICE BACK/	/GROUND. SETPTS RESET NO CAUSE GIVEN
W	SU1	036221	012281	MO	RR	NN	A01	T	V	D			RAD MON RM-CC-105 FOR CCW ALARM SETPOINT FOUND OOC	ALARM SETPOINT NOT REDUCED W/BACKGROUND
W	SU1	036222*	012281	MO	RR	NN	B01	T	V	D			2 RAD MON'S RM-CC-105 & 106 SETPOINT FOUND TOO HIGH	SETPOINTS NOT REDUCED WITH BACKGROUND
W	SU1	037067*	041581	MO	RR	NN	B01	T	V	D			2 ALARM SETPOINTS FOR RM-CC-105 & 106 FOUND OOC	SETPOINTS NOT REDUCED WITH BACKGROUND
W	SU1	038771*	091581	MO	RR	NN	B01	M	V	D	8		ALARM SETPOINTS FOR CCW RAD MON RM-CC-105, 106 OOC	SETPOINTS NOT CHANGED WITH BACKGROUND
W	SU1	170035A	100281	MO	RR	NN	A01	T	V	D			CCW RAD MON RM-CC-105 AND 106 SET PTS EXCEED BCKGR	FLUCUATIONS IN CCW ACTIVITY
W	SU1	170035B	100981	MO	RR	NN	A01	T	V	D			CCW RAD MON RM-CC-105 AND 106 SET PTS EXCEED BCKGR	FLUCUATIONS IN CCW ACTIVITY
W	SU1	171165	112681	MO	RR	NN	A01	T	V	D			CCW RAD MON RM-CC-105 AND 106 SETPTS EXCEED BCKGRD	FLUCUATIONS IN CCW ACTIVITY
W	SU2	020546	012978	TR	RR	NN	B13	N	V	T			SOLA TRANSFRMR SUPPLYNG PWR TO RAD.CAB. 2-2 FAILED	CAPACITOR RUPTURED IN ONE OF THE 2 TRNFRM
W	SU2	032198*	081980	TX	FG	NN	A03	N	V	D	6		STM FLO XMITRS FI-474/5, 484/5, 494/5 ISOLATED	LEFT ISOLATED AFTER TYPE A TESTING
W	SU2	163635*	010681	MO	RR	NN	B13	N	V	D	4		LIQUID WASTE RAD MON FAILED(RM-CW-101,102, RM-VG-	--103,104, RM-SW 107&RM-LW-108). FUSE FAIL
W	SU2	036380	021281	MO	RR	NN	B01	N	V	D			ALARM SETPOINT FOR RM-CC-106 FOUND OOC HIGH	SETPOINTS WERE NOT PROPERLY VERIFIED
W	SU2	036648	032081	MO	RR	NN	B01	T	V	D			CCW RAD MONITOR RM-CC-106 ALARM SETPOINT FOUND OOC	SETPOINT NOT REDUCED WITH BACKGROUND
W	SU2	037325	051581	MO	RR	NN	B01	T	V	D			ALARM SETPOINT FOR CCW RAD MON RM-CC-106 FOUND OOC	SETPOINT NOT REDUCED WITH BACKGROUND







RANDOM FAILURE

N S S	P L A N T	CONTROL NUMBER	EVENT DATE	C O M P	P R O C E S S	S Y S T E M	M O D E	C A U S E	A C T I V I T Y	C L A S S	F A I L #		FAULT MODE DESCRIPTION		FAULT CAUSE DESCRIPTION	
													TYPE	CLASS	TYPE	CLASS
8	CR3	039187B	101481	SE	NG	NN	A14	I	T	T			RATE OF CHANGE AMP OOT	INSTRUMENT DRIFT		
8	CR3	039187C	101481	SE	NG	NN	A14	I	T	T			SOURCE RANGE DETECTOR LOOP OOT	INSTRUMENT DRIFT		
8	CR3	039032D	101581	TX	LG	NN	A14	T	T	T			REM S/D MON INSTR RC-1-LT1 OOT-OF-TOLERANCE	INSTRUMENT DRIFT		
8	CR3	039371D	101781	TX	PT	PX	A14	T	T	T			RPS INSTR RC-148-DPT2 OUT-OF-TOLERANCE	INSTRUMENT DRIFT		
8	CR3	039371E	102081	TX	PT	PX	A00	T	U	U			RPS INSTR RC-148-DPT3 OUT-OF-TOLERANCE	LOOSE TEST POINT OUTPUT TERMINAL		
8	CR3	039371F	102681	TX	PT	PX	A14	T	T	2			RPS INSTR RC-38-PT1,-PT2	INSTRUMENT DRIFT		
8	CR3	039371G	102781	TX	PT	PX	A14	T	T				RPS INSTR RC-3A-PT1	INSTRUMENT DRIFT		
8	CR3	171140	120581	RE	FT	PX	B00	N	U	U			B RPS CHNNL TOT FLOW NOT PROPERLY FUNCTIONING	RELAY FAILURE		
8	CR3	172133	121881	AM	LG	NN	B00	N	U	U			S/G LEVEL SENSOR FAILS	LEVEL TRANSMITTER AMPLIFIER FAILED		
8	DB1	019380	092477	ZZ	DC	NN	A00	N	U	U			HALF TRIP OF STEAM & FEEDWATER RUPTURE CONTROL SYS	CAUSE UNKNOWN-POSSIBLE LOOSE CONNECTORS		
8	DB1	019637	110777	CN	XT	PX	B13	T	T				RPS CHANNEL TWO DECLARED INOPERABLE AND TRIPPED	CURRENT TO VOLTAGE TRANSUCER FAILED		
8	DB1	020268	010378	SE	DC	NN	B13	N	T				CONTROL ROD GROUP 5, ROD 12 POSITION IND INOPERABLE	FAILURE OF REED SWITCH		
8	DB1	020292	010778	AM	PG	NN	B13	N	T				CH 1 S/G TO FEEDWATER D/P TRIP	NO.2 CIRCUIT ON INPUT BUFFER FAILED		
8	DB1	020276	011578	SE	XT	PX	B13	T	T				RPS CH 1 REACTOR COOLANT PUMP MONITOR OUT OF TOLER	DEFECTIVE PUMP MONITOR MODULE		
8	DB1	020450	013178	GS	PG	NN	A14	T	T				FEEDWATER SG 1 CH 2 D/P SWITCH 2686D DID NOT ACTUA	DRIFT-PCIS 2686D OUT OF TOLERANCE		
8	DB1	020703	022478	IN	TG	PX	A12	N	T				RPS CH 2 HIGH TEMP INDICATION SPIKED TRIPPING CHAN	DIRTY CONTACTS ON LINEAR BRIDGE MODULE CU		
8	DB1	021174	041778	CN	RR	NN	A14	T	U				HIGH RAD TRIP FOR SFAS CH 4 OUT OF TOLERANCE	BISTABLE DRIFTED FROM MANUAL SETPOINT		
8	DB1	021175*	041778	MO	RR	NN	A00	N	U				RAD MONITORS RE5029 A,B,C AIR FLOW OSCILLATING	CAUSE UNKNOWN		
8	DB1	021986	042878	CA	PG	NN	B13	T	U	3			RCS PRESSURE FELL TO ZERO AFTER TEST SWITCH MOVED	BROKEN WIRE ON TEST SWITCH SFAS CH 2		
8	DB1	021571	060278	AM	LG	NN	B13	N	T	T			CH 2 BWST LEVEL INDICATION FAILED HIGH	AMP ASSEMBLY OF LEVEL TRANSMITTER FAILED		
8	DB1	021855	061878	CL	XG	SF	B13	T	U				COHT SPRAY PUMP FAILED TO START AUTO ON SEQUENCE	SFAS OUTPUT MODULE FAILED		
8	DB1	021856	061978	CN	LS	SN	A14	T	U				SFAS CH 1 BWST LOW LEVEL TRIP OUT OF TOLERANCE	LEVEL TRIP MODULE FAILED-LIMIT SW DRIFTED		
8	DB1	021854	062078	RE	XG	NN	B05	T	U				SFAS CH 2 LOGIC TO SEQUENCER WIRING ERROR (E648)	FACTORY WIRED RELAY SOCKET INCORRECTLY		
8	DB1	023238	120878	IN	DC	NN	B13	N	T				GROUP 3 ROD 4 API ERRATIC	POSITION INDICATOR TUBE FAILURE		
8	DB1	023239	121578	CL	LS	SN	B13	N	U				SFAS CH 3 BWST LEVEL FAILED-FROZEN	ELECTRICAL OPEN CIRCUIT-HEAT TRACE CONTROL		
8	DB1	023423	123078	AM	DC	NN	A12	N	U				GROUP 5 ROD 4 ASYMMETRIC INDICATION RECEIVED	DIRTY CONTACTS ON API AMPLIFIER MODULE		
8	DB1	025807*	010279	MO	RR	NN	A14	R	T	2			STATION VENTILATION MON RE202462025 ALERT SETPOINT	//FOUND OOC - INSTRUMENT DRIFT		
8	DB1	025059*	010679	RE	XG	SN	B00	T	U				OUTPUT RELAY K51A IN SFAS CHANNEL 4 FOUND FAILED	RELAY REPLACED		
8	DB1	025527	030379	RE	XG	SN	B00	T	U				OUTPUT RELAY K21B IN SFAS CH 4 FAILED CAUSING ? //	OUT OF 4 LOGIC TO BE SAT WITH ONLY ONE CH		
8	DB1	025529	031079	AM	NT	PX	A14	T	U				RPS CHANNEL 3 INTERMEDIATE RANGE RATE OF CHANGE //	AMP VOLTAGE FOUND OOC. INSTRUMENT DRIFT		
8	DB1	025939	062379	CN	PT	PX	B12	T	T				RELAY K-4 DID NOT RESET RX COOLANT PRESS BISTABLE//	/B103. RELAY WAS STICKING		
8	DB1	026256B	052179	GS	PG	CT	A14	T	U	3			AFW SUCTION PRESS SW'S PSL4929A&4929B&4931A SET-//	POINTS FOUND OOT. INSTRUMENT DRIFT		
8	DB1	026598	070579	PS	XG	NN	B00	N	U				24 VDC POWER SUPPLY PS02 IN SGLIC CHANNEL 1 FAILED	NO CAUSE GIVEN		
8	DB1	026594	070779	GS	PG	CT	B04	T	D				PSL-4929B AFW PUMP 1-2 SUCTION BEFORE STRAINER SW/	/FAILED. WRONG MATERIAL USED IN DIAPHRAM		
8	DB1	027372	091779	AM	XG	CT	B00	N	T				INOPERABLE OPTICAL ISO FOUND ON RELAY DRIVER BOARD	NO CAUSE GIVEN		
8	DB1	027334A	092579	IN	DG	CT	B09	T	T				MS 106(INLET VLV TO AFP) INDICATION WAS LOST	LOOSE LAMP RETAINER RING GROUNDED		
8	DB1	027334B	092679	RE	XG	CT	B00	T	U				MS106A(CROSS-CONNECT) WOULDN'T OPERATE DUE TO A //	FAULTY R2 RELAY. NO CAUSE GIVEN		
8	DB1	027336	100579	PS	XG	CT	B00	N	U				SFRCs CHANNEL 4 15 VDC POWER SUPPLY FAILED	NO CAUSE FOUND.		
8	DB1	027925A	121279	PS	XG	CT	A13	N	U				SFRCs CHANNEL 4 15 VDC POWER SUPPLY FAILED	OVERVOLTAGE TRIP SETPOINT TO LOW (PS-4)		
8	DB1	027916	121979	SE	TT	PX	B13	N	U				RPS CH 2 TH INDICATION FAILED LOW	ELEMENT SHORTED OUT DUE TO INLEAKAGE		
8	DB1	030052	010380	IN	DG	NN	B00	N	T				DEMIN WTR VLV & SAM LIGHT IND IMPROPERLY	POS IND SW OUT OF ADJST LOOSE LUCKING NUT		
8	DB1	027925B	010680	PS	XG	CT	B00	N	U				SFRCs CHANNEL 4 15 VDC POWER SUPPLY FAILED (PS-4)	NO CAUSE FOUND		
8	DB1	030299	013180	PS	XG	CT	A09	N	T				HALF TRIP ON SFRCs CHANNELS 1/3	ERRATIC TRP OF PWR SUPP PS/3 IN SGLIC		
8	DB1	030371	020880	ZZ	DC	NN	B00	N	U				CNTRL ROD 5-11'S API NOT RESPONDING	BLWN FUSE F14 FOR 5 VAC API SUPPLY		
8	DB1	030781	032780	PS	DC	NN	B09	N	T				CNTRL ROD GRPS 3,4 MOVED IN ON THEIR OWN	"B" PS FAILED IN PROGRAM CNTRLR DRW		
8	DB1	030869	033180	PS	XG	CT	B09	N	T				HALF TRP OF SFRCs CHNL 1/3	FAILURE OF PS PS03 IN SG LVL INSTR CBNT 1		
8	DB1	030932	040780	RE	NT	PX	B09	N	T				RPS CHNL 2 INOP	K1 RELAY CONTACTS DIDN'T MEET IF REENERGZO		
8	DB1	030930	041180	GS	PG	CT	B14	T	T				AUX FEED PMP TURB 1 5TH INLET PSL-U068 OOC	INSTRUMENT DRIFT		
8	DB1	031019*	041880	TX	LG	CT	A14	T	T	2			SG LVL XMITTR-SP9A/B6 OOC	ZERO SHIFT		
8	DB1	031184	051180	ZZ	NC	NN	B00	T	U				SOURCE RANGE CHNL 1 NI-2 OOC & DECLRD INOP	COMPONENT FAILURE IN TEST MODULE		



RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #		FAULT MODE DESCRIPTION		FAULT CAUSE DESCRIPTION	
													FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION		
B	0853	171540	120281	IM	FT	PX	B13	T	T	3		3	CHANNEL C PMP POWER MO FAILED TO SEND A TRIP SIGNAL	A FAILED IC ON LOGIC BOARD OF PMP PWR MO		
B	RS1	014503A	040576	TX	PT	PX	A14	T	T			1	3 RPS PRESS XMTRS READ OUTSIDE OF TS - LOW	INST DRIFT-VERITRAK MOD 59 PH 443-7050		
B	RS1	014503B	040576	TX	PT	PX	A14	T	T			1	1 RPS PRESS XMTR READ OUTSIDE OF TS - HIGH	INST DRIFT-VERITRAK MOD 59 PH 443-7050		
B	RS1	018006	041977	ZZ	NT	PX	A14	T	T			2	RPS CH A FLUX/IMBALANCE/FLOW TRIP ENVELOPE OUTSD TS	DRIFT OF FUNCTION GEN MOD 6625027A1		
B	RS1	019581*	101977	RE	XT	PX	A00	T	U			2	2 OF 4 RCP "C" PHASE BAL RELAYS FOUND OUT OF CAL	NO CAUSE GIVEN - MOD 21-1721'S 009, 011		
B	RS1	022607	092578	TX	FG	SH	B13	T	U				HPI LOOP A FLD XMTR FT-23807 WAS INOPERABLE	BROKEN BELLOWS IN THE FLOW TRANSMITTER		
B	RS1	027887	121679	SE	FG	CT	A05	N	T				FLOW INDICATION APPARENTLY IN FEED AND CONDENSATE/	/SYS FOUND INACCURATE, EROSION WEAR		
B	RS1	031459A	061980	CM	NT	PX	A14	T	U				OVERPOWER B/S VOLTAGE SETTING DRIFTED OUT	VOLTAGE RESET & DAILY CHECK INSTITUTED		
B	RS1	031459B	062380	CM	XT	PX	800	N	U				B/S VOLTAGE SETTING DRIFTED	B/S MODULE SEMI CONDUCTR VOLIG REG MALFUN		
B	RS1	032581	082380	CL	XG	SN	A00	T	U				UNIT DID NOT ACHIEVE RATED VOLTAGE	ATTRIBUTED TO THE VOLTAGE REGULATOR		
B	RS1	032580	091180	TX	FT	PX	800	N	T				RCS B LOOP FLD IND FOR RPS D CHNL IND ZERO FLOW	AMP IN ELECTRONIC CKT OF XMTR FAILED		
B	RS1	036285	020381	RE	X5	SF	A14	T	T				"B" RBS PUMP FAILED TO START WITHIN TIME LIMIT	TIMER RELAY WAS OOC		
B	RS1	036470*	030381	GS	PT	PX	A14	T	U			4	RX BLDG PRESSURE TRIPS CH'S A, B, C & D FOUND OOC HI	INSTRUMENT DRIFT, MAY OOC WAS 0.05 PSIG		
B	RS1	038793	093081	RE	XG	NN	802	N	U				RELAY WHICH CONTROLS PZR HEATERS FAILED	TERMINAL SCREW WASHER WAS MISORIENTED		
B	RS1	171761*	111081	TX	PT	PX	A14	T	T			2	RPS RX PRESSURE TX'S IN B & C CHANNELS FOUND OOC	INSTRUMENT DRIFT		
B	RS1	171627	120881	TX	PT	PX	B14	N	T				XMTR IN RPC C FAILED (PRESSURE)	DRIFT		
B	T11	015866	083076	CA	NT	PX	809	N	T				"D" CHANL TRIPPED (FLUX/IMBALANC/FLOW); "C" IN BYPAS	SHORT IN JUNCTION BOX; "C" PLACED IN NORML		
B	T11	015866*	083176	TX	PT	PX	A14	T	T			2	R/X COOLNT PRESS SETPOINTS LESS CONSERV THAN T.S.	RPS CHAN B&C CALIB. DRIFT(MINOR)		
B	T11	016306	102776	CA	TT	PX	B12	T	Y				RELAY HI TEMP BISTABLE CHAN "C" FAILED TO TRIP	DIRTY CONNECTOR ON BISTABLE; CLEANED CONN		
B	T11	022381	090178	TX	LG	SN	A14	N	T				DURIN CALIBRTN OF TRANSMITTR; BURATD WATR L.T. T.S.	ACT. LEVEL 12.42 FT ; T.S. LEVEL 12.55 FT		
B	T12	022380	090878	TX	LG	NN	A11	T	T				NAOH TANK LEVEL XMTR LOW READING LEAKY O-RINGS	REPLACED O-RINGS & RECALIBRATED XMTR		
B	T12	021009	020878	AM	DC	NN	B13	N	U				FAILURE OF AMPLIFIER PRODUCD ERRONEOUS READINGS-ROD	ROD 5 OF GROUP 8		
B	T12	021276	040878	TX	PS	SN	807	T	Y				RCS PRESS XMTR RC-3A-PT4 FAILED/TRIPD CHAN RC2A/B	MOISTURE INDUCD SHORT IN XMTR CIRCUIT		
B	T12	021612	041778	SE	NT	PX	805	N	Y				RPS CHAN C HI FLUX TRIP INTERMITTENT-DETECTOR NI-7	NI-7 DAMAGD DURN INITIAL INSTLLTN-REPLAC		
B	T12	021608	051278	GS	PS	IC	A14	T	Y				SETTING OF BS-PS-3260 GT. TECH SPECS	INSTRUMENT DRIFT DURN SURVEILLNC TIME		
B	T12	022387	083178	CM	PS	SN	B13	N	U				SI CHANL "C" DID NOT TRIP LT. 1640# SETPOINT	FAULTY BI-STABLE REPLACED		
B	T12	023083	101478	PS	NS	SN	B13	N	U				CRD BKRS CLOSED WITH ONLY 1 SOURCE RANGE DETECTOR	INOPRBL PS FOR ONE SOURCE RANGE CHANNEL		
B	T12	023082*	110778	GS	LG	SN	A14	T	U			2	DURN CALIB. BWSI LEVEL SETPOINTS EXCEEDED TECH SP.	TRIPPD IN CONSERVATIVE DIRECTION		
B	T12	023431	121578	MO	RR	NN	807	N	U				PUMP FOR HP-R-227 SEIZED (AREA MONITOR)	WATER IN SAMPLE LINES		
B	T12	025504*	011779	GS	FG	CT	A14	T	U			2	FEEDWATER LINE RUPTURE SW'S, FM-DPIS-7883-1 & 2, FO/	/UND OUT OF CAL. INSTRUMENT DRIFT		
C	AR2	023486	123078	CA	NT	PX	806	N	D				UPPER AND LOWER NI LEADS SWAPPED	LEADS INITIALLY INSTALLED BACKWARDS		
C	AR2	023487	123078	TX	PG	NN	800	T	U				CONT. BLDG PRESSURE TRANSMITTER FAILED TO OPERATE	TRANSMITTER RETURNED TO SERVICE		
C	AR2	025214	011379	TX	DT	PX	813	T	T				CPC "B" WAS DECLARED INOPERABLE	BAD MULTIPLEXER CARD IN TRANSMITTER		
C	AR2	025215	012179	RE	XT	PX	800	T	U				CHANNEL "C" RPS TRIP PATH SOLID STATE RELAY FAILED	NO CAUSE GIVEN FOR FAILED RELAY		
C	AR2	025210	012479	ZZ	LG	SN	A00	N	T				NAOH TANK LOW LEVEL ALARM AND INDICATING CIRCUIT//	WAS FOUND OUT OF ALIGNMENT, NO CAUSE		
C	AR2	025820	032679	CA	PG	NN	A12	N	T				CH "D" PZR PRESSURE VARIABLE SETPOINT FAILED TO //	TRACK, DIRTY CONTACTS ON CARD EDGE		
C	AR2	026062	051478	SE	PG	NN	A11	N	T				LEAK DISCOVERED IN REACTOR COOLANT PUMP SEAL CAVI//	//TY PRESSURE SENSING LINE FOR 2PT-6006		
C	AR2	026296	052779	TX	PT	PX	809	N	T				"A" S/G PRESSURE INDICATOR FAILED HIGH, 2PT-1041-4N	ELECTRONIC PORTION OF TRANSMITTER FAILED		
C	AR2	026547	070379	IN	NG	NN	A12	N	T				S/U RATE METER 211-9000 INDICATED INCORRECTLY	WIPE ARM CLEANED, INDICATOR EXERCISED		
C	AR2	026544	070879	ZZ	XT	PX	807	N	D				"B" CPC FAILED TRIPPING DNBR AND LPD TRIPS	LOST BIT DUE TO FAILED AIR CONDITIONER		
C	AR2	026891	080479	ZZ	XG	NN	800	N	U				CEA #39 WOULD NOT MOVE DUE TO FAILED CEA ENABLE //	CARD, NO CAUSE GIVEN		
C	AR2	026914	082079	CA	XC	NN	A12	N	T				CEAC SPURIOUS PENALTY FACTORS EXPERIENCED	DIRTY INPUT CARD CONTACTS		
C	AR2	026907*	082179	PS	DG	NN	800	N	U			2	RSPT GIVEN ERRONEOUS OUTPUT	NO CAUSE GIVEN FOR POWER SUPPLY FAILURES		
C	AR2	027032	082879	ZZ	XT	PX	A02	M	Y				INADVERTANT RAS TRIP SIGNAL WHEN LEAD LIFTED	WRONG RESISTOR REMOVED, PERSONNEL ERROR		
C	AR2	027184	092279	CA	FT	PX	B12	N	T				"C" CPC FAILED DUE TO RCP "D" SPEED INPUT FAULTY	SPEED INPUT PULSE SHAPER CONTACTS DIRTY		
C	AR2	027806A	112879	PS	LG	NN	800	N	U				CNTNMNT BLDG SUMP LEVEL INDICATOR PS FAILED	NO CAUSE GIVEN		
C	AR2	027806B	112879	CM	LG	NN	800	N	U				CNTNMNT BLDG SUMP LEVEL INDICATOR CONVERTER FAILED	NO CAUSE GIVEN		
C	AR2	028077	123079	AN	NT	PX	800	N	U				B PPS LOG POWER FAILED LOW	EX-CORE CH "B" PRE AMP FAILED, NO CAUSE		
C	AR2	030225*	010780	SE	DG	AG	800	N	U			2	CONTAINMENT ISOL VLV 25V-5876-2 FAILED TO CLOSE	VLV POS IND FAULTY DUE TO TWO BAD REED SW		
C	AR2	025218	010980	IM	XT	PX	800	N	U				CHANNEL "B" CPC DECLARED INOPERABLE	ROOT CAUSE COULD NOT BE DETERMINED		



RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	CLASS	FAIL #		RANDOM FAILURE	
												FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
C	CC1	025593A	031879	GS	DC	NN	A14	T	T			CEA 27 WOULD NOT CAUSE MOTION INHIBIT WITHIN 7.5IN	INSTRUMENT DRIFT
C	CC1	025593B	031879	GS	DC	NN	A14	T	T			CEA MOTION INHIBIT FAILED TO PREVENT CEAS 35 & 36//	FROM MOVING GREATER THAN 7.5 IN. DRIFT
C	CC1	026531	071279	SE	TT	PX	B00	N	U			RPS CHANNEL B T-HOT FAILED CAUSING TRIP FROM RPS//	CH B HI POWER TEMP DETECTOR 1-TE-122HB
C	CC1	026535	071279	LN	DG	NN	B09	T	U			COMPUTER DID NOT OUTPUT POSITION FOR CEA 65 AFTER//	POSITION 42. ELECTRONIC FAILURE IN RRT
C	CC1	026718	080679	GS	PG	AG	B13	N	T			#12 RHR PUMP WOULDNT START DUE TO FAULTY PRESS SW	LOW SUCTION PRESS SW INTERNALS WORN OUT
C	CC1	026784*	081279	CA	NT	PX	A00	T	D	2		WIDE RANGE NUCLEAR INST CH D WOULD NOT IND IN TEST	DISCONNECTED TEST AND POWER CABLES
C	CC1	027538	093079	AM	NT	PX	B00	N	T			CH A LOWER POSITIVE PWR DISTRIBUTION SETPOINT DE//	CREASING. FAILED BUFFER DUE TO EOL
C	CC1	027372	101979	SE	MT	PX	A00	N	U			SPURIOUS TRIPS RECEIVED FROM CH A HI POWER DUE TO//	FAILED DETECTOR OR LOOSE TERMINATIONS
C	CC1	027798	112279	AM	PT	PX	A00	N	U			RPS CH C CNTNMNT PRESSURE SIGNAL DEVIATED BY -1 VO	//LTS DUE TO ISOLATOR 1-E/E-5313C FAILURE
C	CC1	027799	112679	SE	TT	PX	A00	N	U			SPURIOUS TRIPS ON CH A HI POWER OCCURED DUE TO //	SPIKES ON T-COLD INPUT. FAILED DETECTOR
C	CC1	030674	022580	AM	PT	PX	B00	T	U			#M CNTNMNT HP TRIPPED OUT OF SPEC DECLARED INOP	FAILED SIGNAL ISOLATOR 1-E/E-5313D
C	CC1	031000	032580	PS	NT	PX	B00	T	U			#M WRNI D/O NOT RESPOND IN THE CALIBRATION MODE	PWR SUPPLY FAILED CAUSED PREAMP FAILURE
C	CC1	031042	043080	CM	NG	NN	B00	T	U			#M WRNI B/S PRINTED CKT BRD A9 HAD NO OUTPUT RE//	LAY ACTUATION. CAUSE UNKNOWN
C	CC1	032462	080680	IM	PT	PX	B00	N	U			TRIP SIGNAL TO #M CTS LOGIC MODULES	ACTUATION #M ISOL MOD W/IN #ZE# FAILED
C	CC1	032760	092580	TX	PT	PX	B00	N	U			ESFAS PZR PRESS "ZD" OUT OF SPEC ISOL XMITTR /	1-E/E-102A OUTPUT SIG USCLLING. UNKNOWN
C	CC1	033560B	122180	SE	TT	PX	B00	N	U			RPS #B# HI PWR TM/LP AXL FLX BYPS TO FIX TCOLD IN//	/PUT. 1TE112CB HAD HI RESISTANCE CONNCTN
C	CC1	033705A	122280	CM	XS	SN	B00	N	U			VOLTAGE DEVIATION	UNKNOWN
C	CC1	033705B	122280	IN	XG	SN	A14	N	T			ESFAS SENSOR "ZE" FOR #12 SG PRESSURE PLACED OOS	#M B/S VOLTMR ZERO SHIFTED OUT OF TOL
C	CC1	036268	011281	AM	FS	SN	B00	N	U			FM FLD XMR FAILED TO MAINTAIN CAL. OUTPUT LOW	ISOLATOR 1-E/E-1023B FAILED
C	CC1	037340	011481	TX	PG	CT	A00	N	U			INTERMITTENT FAILURES OF RPS #M# PRESSURE SIGNAL	NO REASON FOR SHIFT IN CALIBRATION
C	CC1	036390	021281	SE	PT	PX	A09	M	U			ESFAS "ZD" #12 SG PRESS 1-E/E-1023A ISOLATOR OOC	HI RESISTNC CNCTN AT SIG DEV RESISTOR
C	CC1	036451	021781	AM	PS	SN	B00	N	U			RPS B TCOLD INPUT TE-122CB RDG ERRATIC TM/LP TRIPS	ISOLATOR HAD NON-LINEAR OUTPUT
C	CC1	036675	030981	SE	TT	PX	B00	N	U			FAULTY #M# POWER RANGE INSTRUMENT	CHANGING TEMPERATURE DETECTOR RESISTANCE
C	CC1	037495	060181	CA	NT	PX	B00	N	D			PZR LVL GREATER THAN 3% PROGRAMMED BAND PZR LVL //	NORMAL USE CAUSED LOOSE CABLE CONNECTOR
C	CC1	037882	062681	CL	PG	NN	A00	N	U			ESFAS ZE PZR PRESS & #11 SUBCOOLD MARGIN MON OOS//	CONTROLLER ADJUSTED. NO SPECIFIC CAUSE
C	CC1	037996	070181	TX	PT	PX	A14	N	T			CNTNMNT RMS PUMP TRPD ON LO FLD LOST GAS/PART MON	ISOL XMR NARROW RNG OUTPUT DRIFTED LOW
C	CC1	037881	070281	MD	RR	NN	A00	N	U			CONTROL ELEMENT ASSEMBLY #1 DROPPED INTO THE CORE	NO CAUSE FOR MOMENTARY FLD DECREASE
C	CC1	038583	082681	GS	XC	NN	B00	M	U			CEA #57 INSERTED FARTHER THAN OTHER GROUP 1 CEA'S	CEDS CONTROL PANEL OFF SW FAILED
C	CC1	039025	100981	CL	DC	NN	B09	N	U			CH C S/G WATER LEVEL DISCOVERED ERRATIC	ELECTRONIC FAILR OF INDIVIDUAL CNTRL MOD
C	CC2	017111	120976	TX	LG	NN	A11	N	D			#21 S/G ISOL TRANSFORMER TO ESFAS OUTPUT LOW	FOREIGN MATERIAL IN HIGH & LOW SIDE OF TX
C	CC2	016727	122176	TR	XS	SN	B13	N	D			CHANNEL B THERMAL MARGIN/LP SPURIOUS TRIPS	FAILED DIODE-2-E/E-101D CH ZG
C	CC2	016996*	011777	CA	NT	PX	A09	N	T			FLUX PROBLEMS EXPERIENCED IN CH B HI POWER, TM/LP	TH SIGNAL LEADS WERE LOOSE
C	CC2	017206	012577	SE	TT	PX	B13	N	T			CH A AXIAL FLUX OFFSET POSITIVE LIMIT FAILED HIGH	(CONT) & AXIAL FLUX OFFSET.FAIL DET TUBE
C	CC2	017207	012677	AM	NT	PX	B13	N	T			FEED WATER FLOW TO 22 S/G 600,000#/HR BELOW EXPECT	FAILED AMPLIFIER
C	CC2	017005	021377	ZZ	FG	CT	A00	N	U			RPS CH C RX COOLANT FLOW-LOW TRIP,TRIPPED	CAUSE UNKNOWN
C	CC2	017823	051677	IM	FT	PX	B13	N	T			RPS CH D TC DISCOVERED READING HIGH	FAILED FLOW SIGNAL CHARACTERIZER
C	CC2	017625	051677	SE	TT	PX	B13	N	T			SPURIOUS TRIPS ON RPS CH C RECEIVED	BROKEN LUG CONNECTION ON RTD,RTD REPLACED
C	CC2	017800	051777	TX	PT	PX	A09	N	U			CH A S/G PRESSURE, PI-1023A, INDICATED LOW	NOISE FROM TH RTD,CAUSE UNDETERMINED
C	CC2	018224	062077	TX	PT	PX	A14	N	T			CHANNEL A SIAS ACTUATION SIGNAL,ACTUATED	ZERO SHIFT IN PRESSURE TRANSMITTER
C	CC2	018878	081877	AM	XS	SN	B13	N	T			CH A AXIAL FLUX OFFSET POS LIMIT TRIP FOUND INOP.	FAILED ISOLATION MODULE
C	CC2	018949	082977	HS	PT	PX	B08	T	D			ESFAS S/G #2 SGIS CH ZD TRIPPED	MULTIPLIER/DIVIDER FOUND LIMITING APD SIG.
C	CC2	019028	090577	CM	PS	SN	B13	N	T			RPS CH B WIDE RANGE NEUT. INDI COULD NOT BE ALIGH	MOUNTING HARDWARE FOR PUSHBUTTON LOUSE
C	CC2	020560	022178	CA	NT	PX	B09	T	T			SMOKE ISSUED FROM RPS/PC PANEL FROM CH C RPS	CH ZD PRESSURE SENSOR BISTABLE MOD. FAIL
C	CC2	021846	070478	IN	XG	PX	B13	N	D			CONTAINMENT PARTICULATE MONITOR READING LOW	HIGH CAPAC CONNECTION
C	CC2	022245	081778	MD	RR	NN	B13	N	T			INADVERTANT RAS ACTUATION OCCURED	FAILED DIODE CAUSE TRANSFORMER FAILURE
C	CC2	022604	092478	IN	LG	SN	A14	N	T			CONTAINMENT SAMPLE PUMP TRIPPED REN RAD MON INOP	LEVEL INDICATOR 12" OOC ON RWT
C	CC2	023313	121278	MD	RR	NN	B13	N	T			CEA-18 DID NOT DRIVE DOWN ELECTRICALLY	NORMAL END OF LIFE BEARING FAILURE
C	CC2	023315	121778	TI	DC	NN	B13	T	T			RPS CH D FLOW XMITTR OUTPUT LOW	TIMER MODULE FAILURE
C	CC2	025171	012979	TX	FS	SN	A13	N	D				HEAT DUE TO VLV LEAK WARPED BELLOWS

RANDOM FAILURE

DATE	TIME	CONTROL NUMBER	EVENT	COBA	PROCESS	SYSTEM	MODE	ACTIVITY	TYPE	CLASS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	1	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	2	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	3	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	4	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	5	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	6	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	7	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	8	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	9	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR
020713	0000	020713	0000	0000	0000	0000	0000	0000	0000	0000	10	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR	RELAY ON REAR CARD FOR 8 INCH GROUP DEVIATION / PORTION OF CHILLY ANOMALY NEAR







RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODULE	CAUSE	ACTIVITY	TYPE	CLASS	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
C	PA1 032488A	082680	ZZ	XG	NN	800	T	U	GRP 1	RODS W/DREW CAUSD UNPLANND REACTIVITY INSRIN	CAUSE OF PRIMARY DATA LOGGER FAILURE UNKN		
C	PA1 032488B	082680	ZZ	XG	NN	812	T	U	GRP 1	RODS W/DREW CAUSD UNPLANND REACTIVITY INSRIN	SECONDARY DATA LOGGER TYPER BECAME STUCK		
C	PA1 036162	010781	RE	XG	SH	812	N	U	DBA	SEQUENCER(34-3) FAILED	DIRTY CONTACTS		
C	PA1 036345	020581	RE	XG	NN	800	N	U	PIP	DATALOGGER BECAME IMPERABLE DUE TO MERCURY W-SI TANK T-82B WATER LEVEL INICATOR FAILED TO ALARM	-TIRED RELAY FAILURE. NO CAUSE GIVEN		
C	PA1 039292	04C281	AM	LG	SN	A14	N	U			DRIFT OF NARROW RANGE AMPLIFIER		
C	PA1 166528*	052181	RC	XG	NN	813	N	U	2	PRIMARY & SECONDARY DATALOGGERS FAILED	FAILED CIRCUIT BOARD AND TYPER BELIEVED TO BE CABLE CONNECTORS		
C	PA1 039053	100681	MO	RR	IC	813	T	U		RAD MON RIA 2316 FAILED			
C	PA1 172196	120481	PS	XG	NN	800	R	U		SI ACTUATES DUE TO LOSS OF BLOCK SIGNAL	SHIFTG OF PMR SUP FOR PREFERO AC BUS Y-20		
C	SL1 015499	053176	LM	XG	NN	813	N	U		DIGITAL DATA PROCESSOR MALFUNCTIONED	FAULTY CARD IN BUFFER INTERFACE CONTROLLE		
C	SL1 016879	121476	MS	LG	NN	813	N	U		FAULTY SW ON OPERATOR'S CONSOLE, SENT INTER SIG CPU	DEFECTIVE SW FOR #6 PUSHBUTTON		
C	SL1 019502*	080177	CH	LG	SN	A14	T	2		2 OF 4 RWT-LOW SETPOINTS FOUND HIGH (1.62-25 IM)	SETPOINTS FOR INITIATION OF CONT.SUMP REC		
C	SL1 020619	020278	MO	RR	NN	809	N	T		1 OF 4 CHAN. RAD. MON. FOR C/M-ISO. SIGNAL SPIKING	HIGH VOLTAGE TO GROUND--VERIFY WHEN ACCE		
C	SL1 021114	032678	PS	PC	SN	804	N	T		1 CHAN. OF S/G LO PRESS FOR MAIN STEAM ISO. FAILED	POWER SUPPLY FAILD--REQUEST DESIGN CHANG		
C	SL1 021523	042378	TX	LG	NN	801	N	D		OPERATOR BLEW DOWN SENS. LINES TO 1B BART LEVEL IN	IMPROPER OPERATION OF INST. DURN BLOWDOWN		
C	SL1 021832	060878	ZZ	DC	NN	800	T	U		CEA#68 DROPPED FOLLOWING REFUELING OUTAGE	POSSIBLE PMR.SUPP.# TIMER OR COIL TIME MU		
C	SL1 028093	120379	PS	NT	PX	800	N	U		MB LINEAR POWER RANGE CHANNEL DISCOVERED INOP	FAILED POWER SUPPLY, NO CAUSE GIVEN		
C	SL1 033804	010280	CA	XG	NN	812	T	U		1A D/G FUEL TRANSFER PUMP FAILED TO START	DIRTY STARTER CONTACTOR		
C	SL1 030180	010480	PS	XC	NN	800	N	U		CEA 22 DROPPED TO FULL INSERTION	FAILD 15V PMR SUPPLY IN COIL PMR PROGRAMR		
C	SL1 030181A	010680	CA	DC	NN	809	N	D		CEA 30 REED SW POS INDICATION CHNL FAILED	REPLACED SHORTED POWER CABLE		
C	SL1 030380	020480	TI	CG	NN	800	T	U		CEA 19 DROPPED TO FULL INSERTION WHEN WITHDRAWN	FAILD TIMER MODULE IN COIL PMR PROGRAMMER		
C	SL1 030828	021980	TX	LS	SN	A14	N	T		ESFAS "DM" FOR RWT LVL DRIFTED BELOW LO LVL SETPT	LVL XMITR GAVE ERRONEOUS LVL SIGNAL		
C	SL1 030181B	030980	SE	DC	NN	800	N	U		CEA 30 REED SW POS IND CHNL FAILD INSTLD REED SW//	MODULE. NO SPECIFIC PROBLEM FOUND		
C	SL1 030988	010480	AM	TC	IC	800	N	U		6B2 HEATER FOR SBVS DISCOVERED INOP	DFCTY THERMOCOUPLE AMPLIFIER IN CNTRL CKT		
C	SL1 031398*	051180	PS	XC	NN	800	N	U	2	CEA 19, 58 DROPPED TO FULL INSERTION	FAILD 15V POWER SUPPLIES		
C	SL1 033886	053180	PS	PT	PX	800	N	U		CHNL A OF 1A SG LOW PRESSURE TRIP FAILED	ASSOCIATED POWER SUPPLY FAILED		
C	SL1 031648	060380	PS	DG	NN	800	N	U		METRASCOP CRT DISPLAY BEGAN TO FADE	FAILING HIGH VOLTAGE POWER SUPPLY		
C	SL1 031647	061180	CA	XG	NN	809	N	T		GROUND IN HCV-14-6 CKT CAUSG IT TO FAIL CLOSED	MOISTURE INTO TERMINAL BOX GRND TERMINALS		
C	SL1 032494	080180	PS	DG	NN	800	N	U		CEA 41 DROPPED TO FULL INSERTION	CORE PMR PROGRAMMER 15V PMR SUPPLY FAILD		
C	SL1 032495	080480	PS	DG	NN	800	N	U		CEA 16 DROPPED TO FULL INSERTION	CORE PMR PROGRAMMER 15V PMR SUPPLY FAILD		
C	SL1 032496	080580	PS	DG	NN	800	N	U		CEA 23 DROPPED TO FULL INSERTION	CORE PMR PROGRAMMER 15V PMR SUPPLY FAILD		
C	SL1 032583	082180	PS	DC	NN	800	N	U		CEA 53 DROPPED PARTIALLY INTO THE CORE	FAILING 15V POWER SUPPLY		
C	SL1 033190	082180	PS	DC	NN	800	N	U		CEA 39 FAILD DROPPED ITS CEA TO FULL INSERTION	CORE PMR PROGRAMMER 15V PMR SUPPLY FAILD		
C	SL1 032584	082480	LM	NG	NN	800	N	U		DDPS FAILD DUE TO COMPUTER HALTING MID CALCULATN	NO CAUSE DETERMINED		
C	SL1 032585	082680	PS	DC	NN	800	N	U		CEA 24 DROPPED TO FULL INSERTION	FAILD 15V POWER SUPPLY UNIT		
C	SL1 032588	082680	PS	DC	NN	800	N	U		CEA 51 DROPPED TO FULL INSERTION	FAILD 15V POWER SUPPLY UNIT		
C	SL1 032593	082680	PS	XT	PX	808	N	D		POWER SUPPLY TO #1 CPC FAILD	BENT FUSE CLIP DIDN'T ALLOW SUFFCNT CNTCT		
C	SL1 032586	082780	PS	DC	NN	800	N	U		CEA 33 DROPPED TO FULLY INSERTED POSITION	FAILD 15V PMR SUPPLY IN COIL PMR PRGRMMR		
C	SL1 032589	090480	PS	DC	NN	800	N	U		CEA 21 DROPPED TO FULL INSERTION	FAILD 15V POWER SUPPLY UNIT		
C	SL1 032590*	090480	SC	DC	NN	802	N	D	2	CEA 42 PMR SUP CHNGD CEA 44 DROP POSSIBLE SPIKE	MAINT PERS NOT TOLD OF CEA 44 DROP		
C	SL1 032591	090480	SE	XG	NN	809	N	U		CEA 33 DROPPED TO FULL INSERTION	FUSE BLEW DUE TO SLIGHT TRANSIENT		
C	SL1 033463A	110780	TX	PT	PX	A14	N	T		INCR PRESS IND ON C PZR PRESSURE CHNL	INSTRUMENT DRIFT		
C	SL1 033463B	111080	TX	PT	PX	800	N	U		DRIFTG PRESS IND FOR C PZR PRESS CHNL	FAULTY PRESS SIG XMITTER ON PI-1102C		
C	SL1 033762	122280	IN	LG	NN	812	T	U		"A" SG LVL IND READ 0% INSTEAD OF 65%	LEVEL INDICATOR HAD STUCK MOVEMENT		
C	SL1 033732	122680	CN	XG	NN	800	N	U		10% STM BYPS VLV FAILD OPEN CAUSG RX PMR INCRS	VOLTAGE/CURRENT CONVERTER FAILD		
C	SL1 036773	021681	PS	TT	PX	813	N	U		"B" HOT LEG RTD OUTPUT LOOP 1B FAILD LOW	BLOWN FUSE IN POWER SUPPLY		
C	SL1 037350	042481	SE	PT	PX	813	N	T		CH MB CONTAINMENT PRESSURE DETECTOR FAILD	FORCE MOTOR BURNED OUT		
C	SL1 037338	043081	CA	PG	NN	812	T	T		TRIP UNIT (PZR PRESS) FAILD TO ILLUMINATE	CONNECTOR WAS CLEANED		
C	SL1 037609	051481	MO	RR	NN	814	T	T		FUEL HANDLING BLDG AREA RAD MONITOR FOUND ODC	INSTRUMENT DRIFT		
C	SL1 167580	052881	ZZ	PT	PX	814	T	T		S/G PRESSURE CHANNEL MC SETPOINT FOUND ODC	INSTRUMENT DRIFT		
C	SL1 167608	052981	SE	DC	NN	800	K	U		LINEAR REED SWITCH FOR CEA #30 FAILD	NO CAUSE FOUND		



RANDOM FAILURE

UNIV	PLANT	CONTROL NUMBER	EVENT DATE	AREA	FUNCTION	MODE	CAUSE	ACTIVITY	CLASS	FAIL	FAULT NODE DESCRIPTION	FAULT CAUSE DESCRIPTION	
W	BV1	033254	120380	CL	TG	SN	A00	N	U		BORON INJECTION TANK DOS (HI) TEMP CNTRLRS SET HI	CAUSE OF HI SETPOINT UNKNOWN	
W	BV1	033538	121580	CL	TG	SN	A14	N	T		CHNL "C" LVL IND READING HIGH	LVL TRANSMITTER ZERO DRIFT	
W	BV1	036225	012181	CL	TG	SN	A09	N	D		RCS-1 LO FLO ANNUNC FLASH ALRM CH-414 REMVD FRM S/	7ERVICE- LO VOLTAGE TO XMTR	
W	BV1	036709	030581	CL	TG	SN	A14	N	T		RHR LOW FLOW ALARM ACTUATED	INDICATR DRIFT DUE TO REF LEG EVAPORATION	
W	BV1	036982	041681	CL	TG	SN	B00	N	U		"C" RWST LVL IND ROG HIGH DECLRD INOP	LEVEL INDICATOR RECALIBRATED	
W	BV1	166420	042981	LS	DG	NN	B08	N	D		PORV PCV-RC-455C POSITION IND LIMIT SW FAILED	BENT PINION GEAR AND SHAFT	
W	BV1	037168	042981	LS	DG	NN	B00	M	U		COMPARATOR MODULE ACTUATES ON HI-HI CONT PRES INOP	DISLODGED FUSE	
W	BV1	037169	043081	LS	DG	NN	B00	N	U		C RWST LEVEL INDICATOR READING HIGH DECLRD INOP	FAULTY INDICATION TRACED TO LVL TRANSHTR	
W	BV1	037559	052981	LS	DG	NN	A14	T	U		IC ST ACC DRIFT'D ABOVE HI LEVEL ALARM LIMIT	INSTRUMENT DRIFT	
W	BV1	037636A	060181	LS	DG	NN	B00	N	U	2	"A" CHEMICAL ADDITION TANK LT-05-101A FAILED LOW	UNKNOWN REASONS	
W	BV1	037755	061081	PS	XS	SN	B00	M	U		"C" MAIN STM BREAK PRCTN RATE MODULE PS FAILED	BAD TRANSISTOR ON POWER SUPPLY & RATE CRD	
W	BV1	037756	061081	PS	XS	SN	B13	N	U		RWST LI-05-100A FAILED LOW	FAILED FORCE MOTOR W/IN LOOP LVL XMTR	
W	BV1	037890	061981	TX	LS	CT	B11	M	U		AU FLO PATH TO 1A SG ISOLATED FOR REPAIR	LEAKING FEED FLO XMTR INSTR LINE PENETRA	
W	BV1	037836B	071081	TX	LS	CT	B00	N	U		"A" CHEMICAL ADDITION TANK LT-05-101A FAILED LOW	XMR ELECTRONIC ADJSTD LOOP PWR SUP REPLC	
W	BV1	038526	081581	ZZ	LG	SN	B00	N	U		RWSY LVL CH 4 L-05-100B OUTPUT DEFEATED	FAILURE IN CNTRL BRO DEMULTIPLEXING UNIT	
W	BV1	038588	082381	TX	LS	SN	A14	N	T		RWST "D" LVL INDICATOR SLIGHTLY BELOW TOLERANCE	INSTRUMENT DRIFT IN LVL XMTR LT-05-100D	
W	BV1	038800	090681	PS	NT	PX	B07	N	T		NI POWER RANGE CH #4 FAILED LOW PWR SUP FAILED	ELEVATED CNTRL RM TEMP A/C SYS IN MAINT	
W	BV1	038774	092281	MO	RR	NN	B09	N	D		CNTRMT ATMOSPHERIC RR-215A/B FAILED LOST SUP POWER	FRAYED PWR CABLE CAUSD GRND BTWN MONITOR	
W	BV1	039355	110281	MO	RR	NN	B11	N	U		CNTRMT PARTICULATE RR-215A ROG BELOW NORMAL	MAN THROTLG VLV OPEND INCRSD SAMPLE FLOW	
W	BV1	172087	121081	PS	XG	NN	B00	N	U		CORE COOLING MON SCM-RC-100 FAILED	POWER SUPPLY FAILED	
W	DC1	013938	011876	RC	KG	SN	B12	N	U		CONTAINMENT AREA MONITOR CHANNEL 2 FAILED LOW	DIRTY CABLE CONNECTOR AT DETECTOR	
W	DC1	014528*	041976	RC	KG	SN	B13	T	2		TWO RECORDING ACCELEROMETERS FAILED	NORMAL COMPONENT DETERIORATION	
W	DC1	014723	051376	TM	NT	PX	A14	T	U		EXCESSIVE ERROR IN SQUARE ROOT EXTRACTOR(IF-521B)	SET POINT DRIFT	
W	DC1	015095	070976	MO	LG	NN	B13	T	U		ALLOWABLE CHLORINE RESIDUAL LIMIT EXCEEDED	WATER LEVEL CONTROL	
W	DC1	015281*	072076	TX	FG	CT	A14	T	2		FEED FLOW TRANSMITTERS EXCEEDED MAXIMUM ERROR	SETPPOINT DRIFT (FFC-200&240)	
W	DC1	015342*	081976	ZZ	RR	NN	B13	N	D	2		LIQUID RELEASE MADE WITHOUT GAMMA ANALYSIS	NEITHER GELLI GAMMA SPECTRUM UNIT OPERAT
W	DC1	015860	091376	TX	FG	CT	B13	T	T		FEED WATER FLOW INDICATION HIGH WITH NO FLOW TO SG	LINKAGE DISTORTION (FFC-241)	
W	DC1	015969	091376	TX	LT	PX	A14	T	T		L-05 LEVEL TRANSMITTER EXCEEDED LIMITS (BLP-120)	ZERO SETTING SHIFTED AND REOCCURRED	
W	DC1	015858	091676	TX	LT	PX	A14	T	T		PRESSURIZER LEVEL TRANSMITTER EXCESSIVE ERROR	ZERO HAD DRIFTED LOW ON TRANSMITTER	
W	DC1	015859	091676	TX	LT	PX	A14	T	T		PRESSURIZER LEVEL TRANSMITTER EXCESSIVE ERROR	ZERO HAD DRIFTED LOW ON TRANSMITTER	
W	DC1	015978	092876	AM	DC	NN	B13	T	T		ROD POSITION INDICATING BELOW DEMAND INDICATION	AMPLIFIER INTEGRATED CIRCUIT FAILED (F-6)	
W	DC1	016771	010177	TX	FT	PX	A14	T	U		REACTOR COOLANT FLOW TRANSMITTER ERROR EXCESSIVE	SETPOINT DRIFT (ET-426)	
W	DC1	016770	010377	TX	NT	PX	B13	T	U		S/S LEVEL TRANSMITTER ERROR EXCESSIVE (BLP-120)	RUST FORMATION AT FLEXURE BAR PLATE	
W	DC1	017145	020777	HS	NT	PX	B06	T	D		POWER WAS LOST TO BOTH SOURCE RANGE CHANNELS	PROCEDURE FOR TEST WAS DEFECTIVE (N-31632)	
W	DC1	018491	072377	CN	DC	NN	A14	T	U		POSITION INDICATION FOUND IN EXCESS OF STEP LIMIT	SIGNAL CONDITIONING MODULE DRIFTED (B-10)	
W	DC1	018536	080377	CN	DC	NN	A14	T	T		POSITION INDICATION IN EXCESS OF STEP LIMIT (M-8)	SIGNAL CONDITIONING MODULE OUT OF ADJUSTM	
W	DC1	017142	091677	CN	DC	NN	A14	N	T		POSITION INDICATION STEP DEVIATION FROM BANK POSIT	SIGNAL CONDITIONING MODULE READ LOW (F-6)	
W	DC1	019231*	100577	IN	DG	NN	A12	T	2		POSITION INDICATION DID NOT MOVE WITH BANK INDICAT	STICKING INDICATORS-POINTERS BINDING ON S	
W	DC1	019767*	112377	ZZ	NT	PX	B00	N	U	2		TWO SOURCE RANGE CHANNELS INOPERABLE FOR ABOUT 1 H	CAUSE UNKNOWN-FAILURE COULD NOT BE LOCATE
W	DC1	119869	120377	TX	LT	PX	A08	T	U		PRESSURIZER LEVEL DEVIATION BETWEEN INDICATING CMA	PARTIAL LOSS OF TRANSMITTER REFERENCE LEG	
W	DC1	020108	120577	CN	DC	NN	A14	N	T		POSITION INDICATION HIGHER THAN BANK POSITION	EXCESSIVE DRIFT IN SIGNAL CONDITIONING MU	
W	DC1	021974	071478	SE	DG	NN	B02	T	D		HEAT TRACE CKT READING BELOW MINIMUM SPECIFICATION	WORKMEN MOVED INDICATOR BULB (CKT#249)	
W	DC1	022935	092478	CA	NT	PX	B09	N	U		SOURCE RANGE CHANNEL BECAME INOPERABLE (N-31)	CHANGED CABLE FROM DETECTOR TO DRAWER	
W	DC1	023306	121478	IN	DG	NN	A09	T	T		INDICATOR FLEW ON GREATER THAN ALLOWABLE STEP	VARIABLE SHUNT RESISTOR OUT OF ADJUSTMENT	
W	DC1	123404	123378	ZZ	TX	PX	B13	T	U		SOLID STATE PROTECTION SYSTEM UNSATISFACTORY	TEST CARD FAILED AND WAS REPLACED	
W	DC1	025038	012779	IN	RR	NN	B00	N	U		AXIAL FLUX DIFFERENCE ALARM DID NOT ALARM	NO CAUSE GIVEN	
W	DC1	025202	020779	MO	RR	NN	B08	N	T		CNTRMT AIR MON SYS PUMP KEPT TRIPPING	BYPASS FLOW ADJUSTMENTS MISALIGNED	
W	DC1	025685	041679	CM	FT	PX	A14	T	T		YEAR AND FEED FLOW MISMATCH SETPOINT FOUND OOC	BISTABLE HAD DRIFTED	
W	DC1	025686	041979	CM	TT	PX	B14	T	T		OVERPOWER DELTA-TEMPERATURE TRIP SETPOINT OOC	BISTABLE DRIFTED EXCESSIVELY	
W	DC1	026506B	072079	SE	FG	AG	B00	N	U		BORIC ACID FLOWMETER REPLACED	UNKNOWN	

RANDOM FAILURE

STATUS	PLANT	CONTROL NUMBER	EVENT DATE	CODE	ARC/CUMS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS #	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
W	DC1	027194	092979	CM	LT	PX	B14	T	T	T			STEAM GEN WATER LEVEL-LOW-LOW(SET 3 LOOP 3) OOC	DEFECTIVE BISTABLE, EXCESSIVE DRIFT
W	DC1	027280	100179	TX	LT	SM	B13	N	D	U			#4 SG HIGH LEVEL IND XMITTR FOUND OOC HI	DRIFT DUE TO FILL FLUID LEAKING OUT
W	DC1	027323	101279	CM	LT	PX	B00	N	T	U			LOOP 3 CHANNEL 4 SG LEVEL WAS LOST	CINMNT CABLE PENETRATION FOUND FAULTY
W	DC1	027352	101379	CM	LT	PX	A14	T	T	U			DELTA T/AVG PROTECTION SET II BISTABLE TRIPS OOC	T-HOT RESISTANCE TO VOLTAGE CONVERTER DFT
W	DC1	027608	111179	TX	LT	PX	B13	N	U	U			#4 SG STEAM FLOW CH I FOUND 21X OOC LOW	TRANSMITTER BELLOWS FAILED
W	DC1	030281	012580	SE	TT	PX	B00	N	U	U			LOOP 3 T-AVG & DELTA-T INDICATION DECRS & INOP	RTD GIVING ERRONEOUS TEMP RDGS.
W	DC1	030641	031180	SE	NG	NN	B08	T	T	U			APDMS INOPERABLE	DET HAD STRICHD HELIX & DAMGD DRIVE WHEEL
W	DC1	031414	053180	MO	RR	NN	A13	N	T	U			CNT ATMOS AIR PART & GAS RAD MON SYS PMP TRP LO	FLOWMETER IND NORMAL WEAR
W	DC1	031534	061680	TX	LT	PX	A14	N	T	U			LD FLO ALRM ON RAD MON R-11/12 DECLARED INOPERABLE	INSTRUMENT DRIFT
W	DC1	032602	090680	MO	RR	NN	B08	N	D	U				FAILED LOVEJOY L-100 SHAFT COUPLING
W	DC1	032603	091680	TX	LS	SN	B11	N	T	U			SG 2 CH 3 LVL IND LO XMITTR OUTPUT DRIFTING DOWN	LEAK IN XMITTR (8LP-122) IMPULSE LINE
W	DC1	037694	060981	PS	NT	PX	B09	N	U	U			SOURCE RNG DET N-32 EXPERIENCED A LOSS OF VOLTAGE	LOST AC TO DRAWER CAUSG LOSS OF HI VCLTG
W	DC1	038169	072781	TX	PT	PX	A14	N	T	U			PZR PRESS CHNL NPP-153 INDICATING HIGH	PZR PRESS XMITR NPP-193 CALIBRATN DRIFTED
W	DC1	038580	081481	AM	NT	PX	B00	N	U	U			B/S TRPD WHEN "4" PWR RNG INSTR DRAWER W/DREW	LOOSE CONNECTOR IN ISOLATION AMPLIFIER
W	DC1	038818	091981	IM	XS	SN	B00	T	U	U			SSPS "A" LOGIC TEST POSITION TESTED UNSATISFACTORY	UNIVERSAL CARD A-210 FAILED
W	DC1	171636B	1111781	CN	TT	PX	A00	T	U	U			LOOP 4 OVERPWR OVER TEMP DELTA T SETPTS WENT LOW	UNKNOWN
W	DC1	171789	122981	SE	TT	PX	B00	N	U	U			RTD FOR LOOP 3 FAILED	NO CAUSE GIVEN
W	DC1	172327*	123081	SE	RR	NN	B00	N	U	2			LO FLO ALARM REC'D FOR CINMNT AIR DET R-11/R-12	UNKNOWN
W	DC2	020829	031578	IN	DG	NN	A00	N	U	U			POSITION INDICATION EXCEEDED STEP LIMIT (L-13)	CAUSE UNKNOWN
W	DC2	020931	040178	IM	TT	PX	B13	N	T	U			REACTOR COOLANT LOOP 1 DELTA T OVERTEMPERATURE FAI	MODULE 2TY-411C FAILED
W	DC2	021631	060378	IN	DG	NN	B00	N	U	U			ROD 8 BOTTOM POSITION INDICATION FAILED TO INDICAT	CAUSE UNKNOWN
W	DC2	021946	071078	TX	FT	PX	B14	T	T	U			STEAM FLOW CHANNEL HFC-120 WAS READING LOW	TRANSMITTER HAD A ZERO SHIFT
W	DC2	021793	071278	IN	LG	AG	B13	N	T	U			RWST LEVEL INDICATION FAILED (LOW ALARM FUNCTION)	BAD RESISTOR IN THE CURRENT REPEATER
W	DC2	022106*	080978	CM	FG	NN	B13	T	U	2			APDMS COMPUTER FAILED TO PRINT OUT ALL F(I)Z) SCANS	FAULTY CARD WAS IDENTIFIED AND REPLACED
W	DC2	022502	091378	CM	PT	PX	B13	T	D	U			PRESSURIZER PRESSURE HIGH REACTOR TRIP BISTABLE FA	BISTABLE FAILED DUE TO A BAD TRIAC
W	DC2	022696*	092978	ZZ	XT	PX	B13	T	U	2			SEVERAL BAD SWITCH POSITIONS-TRAIN-8 SOLID STATE P	BAD UNIVERSAL LOGIC CARD
W	DC2	022580	100578	CA	DC	NN	B12	T	T	U			ROD C-9 RPI DID NOT SHOW ANY MOTION DURING TESTING	INDICATOR CONNECTOR PINS WERE TARNISHED
W	DC2	022790*	102478	ZZ	XT	PX	B13	T	U	2			SOLID STATE PROTECTION SYSTEM 3 LOGIC TEST POSITIO	A UNIVERSAL LOGIC CARD AND A TEST CARD FA
W	DC2	023113	112378	CA	NT	PX	B12	N	T	U			SOURCE RANGE NEUTRON FLUX CHANNEL 1-31 INOPERABLE	HIGH VOLTAGE & SIGNAL CABLE CONN CLEANED
W	DC2	025039	011779	IM	XS	SN	B00	T	U	U			TRAIN 3 SOLID STATE PROTECTION SY TEST POSITION//	TESTED UNSAT. LOGIC CARD A-214 FAILED
W	DC2	025284A	021379	CM	PS	SN	A14	T	I	U			CINMNT PRESSURE HI-HI BISTABLE TRIP SETPOINT OOC	INSTRUMENT DRIFT, BISTABLE RECALIBRATED
W	DC2	025284B	021579	CM	PS	SN	B14	T	T	U			CINMNT PRESSURE HI-HI BISTABLE TRIP SETPOINT OOC	INSTRUMENT DRIFT, BISTABLE REPLACED
W	DC2	026353A	070679	CM	PS	SN	A14	T	T	U			CINMNT PRESSURE PROTECTION-SET IV BISTABLE 2P3-//	934B SETPOINT DRIFTED. INSTRUMENT DRIFT
W	DC2	026353B	071279	CM	PS	SN	A14	T	T	U			SETPOINT FOR CINMNT PRESS BISTABLE HAD DRIFTED	SETPOINT DRIFT, BISTABLE RECALIBRATED
W	DC2	026353C	071379	CM	PS	SN	B14	T	T	U			SETPOINT FOR CINMNT PRESS BISTABLE HAD DRIFTED	SETPOINT DRIFT, BISTABLE REPLACED
W	DC2	027021A	091179	CM	PT	PX	A14	T	T	U			PZR HIGH PRESSURE RX TRIP SETPOINT FOUND OOC	INSTRUMENT DRIFT.
W	DC2	027021B	091879	CM	PT	PX	B14	T	T	U			PZR HIGH PRESSURE RX TRIP SETPOINT FOUND OOC LOW	DETERMINED INOPERABLE (EXCESS DRIFT)
W	DC2	027427	103179	MO	RR	NN	A13	N	U	U			CINMNT APD (R-11) TRIPPED ON LOW FLOW	FLOW TRIP SWITCH FOUND IN NON-VERTICA DIM
W	DC2	030378	110279	TX	FT	PX	A14	R	T	U			RX COOLANT FLOW LOOP 1 FOUND OOC NON-CONSERVATIVE	INSTRUMENT DRIFT
W	DC2	030336*	111379	TX	PT	SN	A14	R	T	2			DIFFERENTIAL STEAM LINE PRESS SP FOR LOOPS 3&4 //	FOUND OOC. XMITTERS FOUND DRIFTED
W	DC2	030335	012980	CM	PS	SN	A14	T	T	U			PZR PRESS PROICTN SET 3 B/S 2-PB-457D TRIPPED HIGH	INSTRUMENT DRIFT
W	DC2	030609	030780	MO	RR	NN	B03	N	T	U			RAD MON R-11/12 INOP	RUBBER SPIOR FAILED IN L-100 COUPLING
W	DC2	030744	032180	RE	XG	CT	B08	N	D	U			TOAEP & THRILL VLV TRP & COOLDN'T RESET	DFCTV RESET SOLENOID
W	DC2	031047	042180	TX	PS	SN	A14	N	T	U			STEAM GENERATOR MISMATCH XMITR NPP-210 DRIFTED	INSTRUMENT DRIFT
W	DC2	031341	051680	MO	RR	NN	A13	N	T	U			SAMPLE PUMP FOR R-11/12 WOULD NOT RESTART CAUSE //	INACCURATE FLOWMETER NAT'L END OF LIFE
W	DC2	033807*	120780	TX	PT	PX	A14	N	T	3			PZR PRESS XMITTR NPP-151, 153 & NPS 153 OOC	INSTRUMENT DRIFT
W	DC2	036049	011281	IN	FG	NN	B13	N	U	U			FLO LOST TO RAD MON R-19 FROM #21 S/G	BAD DIAPHRAGM IN ROTOMETER'S FLO REGULATR
W	DC2	036452	030181	TI	XG	NN	B00	N	U	U			2-E ESW PUMP FOUND INOPERABLE	DEFECTIVE TIMER
W	DC2	036870	041181	TX	PS	SN	A14	R	T	U			STM LINE PRESS XMITR DATA EXCEEDS DP BTWN STM LIN//	LCD VALUE. INSTRUMENT DRIFT
W	DC2	037003	041581	TX	LT	PX	A14	T	T	U			SG LVL-PROTECTN SET 3 XMYR OOC (LOW)	INSTRUMENT DRIFT

RANDOM FAILURE

FAULT NUMBER	DATE	TIME	CODE	SYMBOL	MODE	CAUSE	ACTIVELY	STATUS	DESCRIPTION	FAULT CAUSE DESCRIPTION
0001	02/27/77	00:00	0001	0001	0001	0001	Y	Y	DETECTOR FOUND INOP	CAUSE OF FAILURE NOT GIVEN
0002	02/27/77	00:00	0002	0002	0002	Y	Y	DETECTOR FOUND INOP	HAS HISTORY OF DRIFTING SETPOINT	
0003	02/27/77	00:00	0003	0003	0003	Y	Y	DETECTOR FOUND INOP	UNKNOWN INSTRUMENT DRIFT	
0004	02/27/77	00:00	0004	0004	0004	Y	Y	DETECTOR FOUND INOP	NORMAL INSTRUMENT DRIFT	
0005	02/27/77	00:00	0005	0005	0005	Y	Y	DETECTOR FOUND INOP	HEAT TRACE ON SENSING LINE REMOVED SAME	
0006	02/27/77	00:00	0006	0006	0006	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0007	02/27/77	00:00	0007	0007	0007	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0008	02/27/77	00:00	0008	0008	0008	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0009	02/27/77	00:00	0009	0009	0009	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0010	02/27/77	00:00	0010	0010	0010	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0011	02/27/77	00:00	0011	0011	0011	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0012	02/27/77	00:00	0012	0012	0012	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0013	02/27/77	00:00	0013	0013	0013	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0014	02/27/77	00:00	0014	0014	0014	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0015	02/27/77	00:00	0015	0015	0015	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0016	02/27/77	00:00	0016	0016	0016	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0017	02/27/77	00:00	0017	0017	0017	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0018	02/27/77	00:00	0018	0018	0018	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0019	02/27/77	00:00	0019	0019	0019	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0020	02/27/77	00:00	0020	0020	0020	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0021	02/27/77	00:00	0021	0021	0021	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0022	02/27/77	00:00	0022	0022	0022	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0023	02/27/77	00:00	0023	0023	0023	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0024	02/27/77	00:00	0024	0024	0024	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0025	02/27/77	00:00	0025	0025	0025	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0026	02/27/77	00:00	0026	0026	0026	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0027	02/27/77	00:00	0027	0027	0027	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0028	02/27/77	00:00	0028	0028	0028	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0029	02/27/77	00:00	0029	0029	0029	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0030	02/27/77	00:00	0030	0030	0030	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0031	02/27/77	00:00	0031	0031	0031	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0032	02/27/77	00:00	0032	0032	0032	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0033	02/27/77	00:00	0033	0033	0033	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0034	02/27/77	00:00	0034	0034	0034	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0035	02/27/77	00:00	0035	0035	0035	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0036	02/27/77	00:00	0036	0036	0036	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0037	02/27/77	00:00	0037	0037	0037	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0038	02/27/77	00:00	0038	0038	0038	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0039	02/27/77	00:00	0039	0039	0039	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0040	02/27/77	00:00	0040	0040	0040	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0041	02/27/77	00:00	0041	0041	0041	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0042	02/27/77	00:00	0042	0042	0042	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0043	02/27/77	00:00	0043	0043	0043	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0044	02/27/77	00:00	0044	0044	0044	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0045	02/27/77	00:00	0045	0045	0045	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0046	02/27/77	00:00	0046	0046	0046	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0047	02/27/77	00:00	0047	0047	0047	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0048	02/27/77	00:00	0048	0048	0048	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0049	02/27/77	00:00	0049	0049	0049	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	
0050	02/27/77	00:00	0050	0050	0050	Y	Y	DETECTOR FOUND INOP	VELOCIMETER SENSING LINE REMOVED SAME	

RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	CODE	DESCRIPTION	STATUS	CAUSE	ACTIVITY	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
W	IP3 033241*	102580	TX	WG	NN	A14	N	T	2 TWO ACC LVL XMITRS-934B,-935B OOT HI ON LO LVL SIG	INSTRUMENT DRIFT
W	IP3 033428	111580	TX	WG	NN	A14	N	T	PRESSURE TRANSMITTER PT-456B OOT (HIGH)	INSTRUMENT DRIFT
W	JF1 019056	082277	IM	TS	PX	A14	N	T	LOOP C LO-LO TAG TB-432E SETPOINT OUT OF TOLERANCE	TB-432E OUT OF CALIBRATION
W	JF1 019059	082377	GS	LG	NN	B13	N	T	LS11 HI & LOW SWITCHES ACTUATED, PUMP WON'T START	DEFECTIVE SWITCH
W	JF1 019061	082777	IN	DG	NN	B09	N	T	DRPI FAILED, DID NOT AGREE WITH DEMAND POS IND	DRPI CARD ASSY SHORTED TO GROUND
W	JF1 019358	090777	CM	FT	PX	A14	T	T	PZR LEVEL 1B-459A(2) SETPOINT OUT OF TOLERANCE	INSTRUMENT DRIFT
W	JF1 019364	092177	IM	FT	PX	A14	T	T	TB-432B-1 SETPOINT OUT OF TOLERANCE	INSTRUMENT DRIFT
W	JF1 019369	100277	RE	XG	NN	B12	T	T	CONTAIN COOLER FAN IC FAILED TO DROP TO LOW SPEED	SEQUENCER RELAY CONTACT STICKING
W	JF1 019334	102777	IM	TS	PX	B13	T	T	SIM PRESS LOOPS CH II INOPERABLE	LEAD/LAG CARD PY-474B FAILED
W	JF1 019696	111177	IM	TS	PX	B13	N	T	PZR LEVEL IND LT-461 READING LOW	DELTA-P UNIT LT-461 DEFECTIVE
W	JF1 019697	111777	CM	HT	PX	A14	T	T	HIGH LEVEL TRIP BISTABLE NC206 IN EXCESS OF T.S.	B/S RELAY DRIVER NC206 INST DRIFT
W	JF1 019848	120277	IM	FT	PX	A14	N	T	STM FLOW IND FI-484 READING LOW	NMD CARD FY-484 OUT OF CALIBRATION
W	JF1 020239A	122077	IM	PS	NN	A14	T	T	SIM PRESS LOOP 1,2,3 CH III LEAD/LAG CARD O.O.CAL	(NLL) PY-485B INST DRIFT
W	JF1 020239B	122077	CM	PS	NN	A14	T	T	STM PRESS LOOP 1,2,3 CH III COMP CARD O.O. CALIBRA	(NAL) PB-485A SETPOINT DRIFT
W	JF1 020238	122777	CM	PS	NN	A14	T	T	PZR PRESS SAFETY INJECT COMP PB-457B BELOW T.S.	COMP CARD PB-457B SETPOINT DRIFT
W	JF1 020282*	011278	CM	FT	PX	A14	T	T	2 STM VS FEED FLOW MISMATCH TRIP LESS CONSERVATIVE	CARDS FB-498B & FY-497 NORMAL DRIFT
W	JF1 020285	011778	IM	PS	NN	B13	T	T	SI ACTUATION SIGNAL COMP PB-485A NON-CONSERVATIVE	LEAD-LAG CARD PY-485B HAD DEFECTIVE POT
W	JF1 020285	011978	CM	PS	NN	A14	N	T	SIM LINE DELTA-P SI SIGNAL COMP LESS CONSERVATIVE	CARD PB-486B SETPOINT DRIFT
W	JF1 021234	042478	SE	NT	PX	A14	T	T	INTERMEDIATE RANGE N35 HIGH FLUX TRIP LESS CONSERV	NEW DETECTOR LESS SENSITIVE TH. ORIGINAL
W	JF1 021977	070678	AM	DC	NN	B13	T	T	CONTROL ROD BANK A WOULD NOT MOVE ON DEMAND	SUPERVISOR MEMORY BUFFER CARD FAILED
W	JF1 022236	081578	RE	XT	PX	B02	T	D	UNDERVOLT RELAY 27-3 TRIPPED/DAMAGED DURING MAINT	ACCIDENTAL SHORT WITH TEST LEADS
W	JF1 022632	091278	IN	PG	NN	B08	T	U	PI-474A INDICATING ZERO WHILE OTHER 2 IND. NORMAL	STUCK METER MOVEMENT
W	JF1 022634A	091378	PS	FVS	NN	B13	N	T	FEEDWATER FLOW INST FAILED LOW	CARD PQY-976 (NLP) PWR SUP FAILED
W	JF1 022634B	091378	IM	FVS	NN	B13	N	T	FEEDWATER FLOW INST FAILED LOW	NMD CARD MULT/DIV/SQ RT INST DRIFT
W	JF1 022635A	092078	HS	NT	PX	B04	T	U	2 LOSS OF H.V. TO BOTH SOURCE RANGE NIS CHANNELS	SWITCH WIRING DESIGN
W	JF1 022993	101678	RE	XT	PX	A14	T	T	RCP 1A UNDERVOLT RELAY 27-1 FAIL TO TRIP AS REQUIR	SETPOINT DRIFT NON-CONSERVATIVE
W	JF1 025431	022179	CM	FT	PX	A14	T	T	STEAM FLOW/FEED FLOW BISTABLE FB478A FOUND OOC	INSTRUMENT DRIFT
W	JF1 027481A	110679	TX	LS	NN	A14	N	T	RWST LEVEL TRANSMITTER FOUND OUT OF CALIBRATION	INSTRUMENT DRIFT
W	JF1 027481B	110679	TX	LS	NN	B14	N	T	RWST LEVEL TRANSMITTER FOUND OUT OF CALIBRATION	UNCORRECTABLE INSTRUMENT DRIFT
W	JF1 027852	112279	TX	LT	PX	A11	N	T	SG B LEVEL CHANNEL 486 READING 8X LOWER THAN OTHER	LEAKING EQUALIZING VALVE
W	JF1 027834	120279	CM	PS	JC	B00	N	U	CNTNMNT PRESS HI-162 TRIP STATUS LIGHTS FOR ONE //	CHANNEL FOUND ENERGIZED, FAIL COMPARTOR
W	JF1 027912	121379	CM	PS	NN	B00	T	U	SL DP SI INITIATION SIGNAL COMPARTOR FOUND INOP	REPLACED B486B. NO CAUSE GIVEN(NSL 162)
W	JF1 027914	122079	CA	PS	IC	B12	T	T	CNTNMNT PRESS CHANNEL (PT950) FOUND INOPERABLE	FILM BUILDUP ON CONNECTION
W	JF1 030067	010600	MO	RR	NN	B14	N	T	FUEL STRG POOL AREA RAD MON R-5 INOP HI ALRM SETP/	/T HIGH. INSTRUMENT DRIFT
W	JF1 030161	011800	IM	LT	PX	B00	T	U	1B HI-HI SG LVL LOGIC FAILED	FAILD UNIVERSAL CARD IN B TRAIN SS PS
W	JF1 030282	012680	MO	RR	NN	B12	N	T	CONT ATMOS PART RAD MON-11 INOP FILTR PAPER NOT A/	/DVANCG. CARBON DUST IN PAPER DRIVE MTR
W	JF1 030324	020180	HS	XG	NN	B06	T	U	"A" COMPONENT COOLING WATER SYS INOP	CCW PMP HANDSW INCRCCTLY POSITIONED
W	JF1 030558	021780	CL	XG	NN	B00	N	U	DEH SYS MALFUNCTN CAUSG LOAD INCRS & DECRS (TAVG)	UNDER INVESTIGATION
W	JF1 030560	022280	LS	DG	NN	A14	N	T	TOAFWP INOP TURBINE TRIPPED IN OVSPEED	TURB SIM SUP VLV LMT SW OUT OF ADJUSTMENT
W	JF1 032035A	022480	RE	XG	NN	A14	R	T	1B RCP 27-3 UNDERVOLTAGE RELAY OOT (LOW)	INSTRUMENT DRIFT
W	JF1 030911	040580	ZZ	TT	PX	B00	N	U	ERRONEOUS UOTD ALARM LEAD/LAG CRD GAVE UNSTBL OUT	NO CAUSE FOR DFCIV LEAD/LAG CRD C1-130
W	JF1 030910	040680	PS	PS	NN	A14	T	U	TURB 1ST SG PRESS B/S PB447E OOT LOOP PS CRD PQY/	/447 OUT OF ADJSTMNT. INSTRUMENT DRIFT
W	JF1 031333	043080	CA	NT	PX	A00	T	U	INTERMED RNG NIS CHNL N-35 INOP DUE TO POWER LOSS	LOOSE WIRE
W	JF1 031344	051180	ZZ	DC	NN	B00	N	U	DRPI INOP WHEN LOST INDICATION IN TROUBLESHOOTING	NO REASON GIVEN
W	JF1 032035B	052780	RE	XG	NN	A14	R	T	IC RCP 27-3 UNDERVOLTAGE RELAY OOT (LOW)	INSTRUMENT DRIFT
W	JF1 033277	071280	CM	PT	PX	A12	N	T	PZR PT-457 B/S FAILD TO MEET LD PRESS SETPT REQ	DIRTY ELEC CNTCTS BTWN CARD & CHASSIS
W	JF1 032331	081380	PS	FS	NN	B00	N	U	STM FLD CHNL ASSOC W/ FT-475 INOP WHEN FAILED LOW	DFCTV LOOP POWER SUPPLY CARD PQY-476
W	JF1 032417	082080	ZZ	FT	PX	B00	N	U	RX TRIP INSTR CH ASSOC W/ RCS LOOP FT-434 LOST IND	DFCTV TRANSISTORS ON CARD C1-242
W	JF1 032561	090980	ZZ	XG	SF	B09	T	U	CNTNMNT SPRAY AUTO ACTUATION LOGIC INOP	UNIVERSAL CARD HAD AN INTEGRATED CKT FAIL
W	JF1 032917A	100980	CL	XG	NN	B09	T	D	NO MANUAL CNTRL OF D/G FREQUENCY	SHORT CKT IN VOLTAGE REGULATOR



















RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	CORE	PROCESS	SYSTEM	MODULE	CAVITY	ACTIVITY	CLASS	TYPE	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
W	SUZ	033227	110280	GS	PG	AS	B11	N	T			LO DISCHARGE PRESSURE ALARM FAILED TO ANNUNCIATE	CLOGGED PRESS SW SENSING LINE
W	SUZ	033349	112280	GS	XG	NN	B12	N	T			NOV-CW-200A FAILED W/ VLV APPROX 75% OPEN	CORRODED TORQUE SW STUCK IN OPEN POSITION
W	SUZ	163642	010781	CH	XZ	PX	B13	T	U			REACTOR TRIP BKR FAILED TO OPEN	FAILED UNDER VOLTAGE DEPICE
W	SUZ	036299	021081	CH	NT	PX	A14	T	U			INTERMEDIATE RANGE CH H36 HI LEVEL TRIP FOUND OOC	INSTRUMENT SETPOINT DRIFT
W	TR1	016798	010777	AM	LT	PX	B13	T	U			C STEAM GEN LO LEVEL BI-STABL 537C FAIL TO TRIP	OPERATIONAL AMPLIFIER ON CKT BRD FAILD
W	TR1	017575*	031677	CL	FG	NN	B00	T	U	2		BOTH TRAINS OF EMERG. VENTILATN FAILD REQRO AIP FL	AIR FLOW CONTROLLRS ADJUSTD
W	TR1	017573*	033177	CL	DC	NN	B13	T	U	2		CONTROL BANK D RODS COULD NOT BE MOVED	FAILD SUP. BUFFER MEMORY & IN/OUT PULS CARD
W	TR1	017759A	050477	GS	PT	PX	A14	T	U			PS-6309X EXCEEDED ALLOWABLE SETPOINT LIMIT	INSTRUMENT SETPOINT DRIFT
W	TR1	017759B	050477	GS	PT	PX	A14	T	U			PT-456 SETPOINT EXCEEDED ALLOWABLE LIMITS	INSTRUMENT SETPOINT DRIFT
W	TR1	018908	061277	TX	LC	NN	B13	N	U			COOLING TOWER LEVEL XNTR FAILD HIGH	PREVENTD AUTO MAKE/UP OF LEVEL IN TOWER
W	TR1	018586	070877	CM	LT	PX	A14	T	T			S/G LEVEL PROTECTN SET IV LB-537C TRIPPN LOWER LEV	FOUND TO HAVE HI RATE OF SETPOINT DRIFT
W	TR1	021199A	032578	RC	LG	SL	B01	N	D			RC FLOW LOST WHILE SYSTEM PARTIALLY DRAIN(D IN RHR)	PRESS GAUGE OUT OF CALIBRATION
W	TR1	021312*	040578	TX	LT	PX	A14	T	D	4		FOUR OF 12 S/G LEVEL INST OUT OF CALIBRATION	NORMAL INST. DRIFT
W	TR1	021199B	041778	TX	LG	SL	B01	N	D			LEVEL INST WRONG READING; RC FLOW LOST WHILE IN RHR	REFERENCE LEG H2O LEVEL LOW
W	TR1	026118A	050479	TX	LC	PX	A14	T	U			D S/G LEVEL TRANSMITTER FLOW OUT OF CAL HIGH	INSTRUMENT DRIFT OF LT-549
W	TR1	026118B	050479	TX	PT	PX	A14	T	T			PZR PRESSURE TRANSMITTER FOUND OUT OF CAL HIGH	INSTRUMENT DRIFT OF PT-458
W	TR1	026118C	050479	TX	FT	PX	A14	T	T			RX COOLANT FLOW TRANSMITTER FOUND OUT OF CAL HIGH	INSTRUMENT DRIFT OF FT-426
W	TR1	036302A	013081	NS	NT	PX	B13	N	T			*A* SOURCE RANGE CHANNEL FAILED	PULSE HEIGHT DISCRIMINATOR WAS ODA
W	TR1	036302B	013081	NS	NT	PX	B00	N	T			*B* SOURCE RANGE CHANNEL FAILED	NORMAL WEAR
W	TR1	036802	031681	PS	PT	PX	B13	T	U			STEAM LINE PRESSURE CH 516 SETPOINT FOUND ERRATIC	FAILED CAPACITOR
W	TR1	038286	090281	TX	PT	PX	A14	T	T			TURBINE FIRST STAGE PRESSURE CH 506 FOUND OOC	INSTRUMENT DRIFT
W	TU3	015007	051976	CM	LT	PX	A14	T	U			PRZR LEVEL COMP. LC-459A TRIPPN AT 4.685V VS. 4.68	SETPOINT DRIFT; WILL ADJUST TO COMPENSATE
W	TU3	017590*	012777	CM	LT	PX	A14	T	U	2		TRIP SETPTS OF OVERPR COMP. IC-3-432B & 432C LOW	SETPOINT DRIFT; EXACT CAUSE OF DRIFT UNKN
W	TU3	020644	013078	GS	PS	SN	B08	T	U			HI/HI CONTINMT PRESSIPS-3-20581 OPERATD GT. 308	MALFUNCT OF ACTUATN DEVICE; ROOT CAUSE UNK
W	TU3	025850	032879	ZZ	LC	AG	B00	N	U			LEVEL INDICATION FOR *C* CYCS HOLD-UP TANK FOUND//	ERRONEOUS. NO CAUSE GIVEN
W	TU3	025980A	042979	IN	LG	SN	B13	N	T			RWST LEVEL INDICATOR FAILED	FAILED TRANSDUCER OF DIGITAL LEVEL IND.
W	TU3	025980B	042979	ZZ	LG	SN	A14	N	T			HIGH AND LOW LEVEL ALARMS FOUND OUT OF CAL FOR RW/	1ST LEVEL. INSTRUMENT DRIFT
W	TU3	031299*	051180	CM	PS	SN	A14	T	T	2		B/S BS-3-475, 485A NONCONSERVATIVE SETPOINTS	INSTRUMENT DRIFT
W	TU3	032528	081380	MO	RR	NN	B11	N	D			PROCESS RAD MON R-11/12 OOS	PLUGGED SUCTION LINE BLOWER OVERHEATED
W	TU3	032887	091880	CA	NT	PX	B09	N	D			PWR RNG NIS ON CHNL N-43 DETERMINED TO BE LOW	PARTIAL GRND ON CABLE ASSOC W/ CHNL N-43
W	TU4	014878	013076	IM	TT	PX	B13	T	U			CHAN 2 DELTA-T TRIP SETPT 1 DEG HIGHR THAN ALLOWD	2 FILTR CAP. FAILD IN SIGNAL SUM. TM-4-422F
W	TU4	014877	021476	IN	LG	SN	A04	T	D			REF. WATER ST. TNK 1 PERCENT LOWR THAN ALLOWD T.S.	LEVEL GAGE IS WIDE RANGE; INSTALL NARROW R
W	TU4	019807	110177	CM	PS	SN	A14	T	T			SETPT FOR COMPTRT PC-4-485A LT. MIN ALLOWED	RANDOM SETPNT DRIFT OF STEAM LINE PRESS.
W	TU4	030920	033180	MO	RR	NN	B00	N	T			PROCESS RAD MON 11/12 OOS	NORMAL WEAR OF AIR SAMPLING BLOWER
W	TU4	030945	040780	TX	PG	CT	A14	T	T			*A* AFWP DELIVERED LOW FLOW RATE TO UNIT 4 S/G	CNTRL CKT CAL D/P XMITR RECAL
W	YR1	172036	122881	RC	XG	NN	B00	M	U			BIT HEAT TRACING RECORDER INOP CKT 548 OPEN/GRNDED	ROOT CAUSE COULD NOT BE DETERMINED
W	YR1	015007	011677	IN	LG	SN	B13	N	T			VAPOR CONTAINR DRAIN TANK LEVEL XMITR DIAPRAM FAILED	SENSIN LINES HAD EXCSV CRUD; REPLACD XMT
W	YR1	017336	030677	MO	RR	NN	B13	N	T			#2 S/G BLOWDOWN ALARM SETPT COULDN'T BE ADJUSTED	PLASTIC HOLDER FAILD FROM MATERIAL FATIGU
W	YR1	018509	072077	CM	LT	PX	A14	T	T			S/G WTR LO LEVEL SCRAM B/S FUNCTND .9 INCHS LT. TS	INSTRUMENT DRIFT OF #3 CHANNEL; READJUSTD
W	YR1	018856	081077	CH	LT	PX	A14	T	T			PZR WIDE RANGE LEVL SCRAM SETPT OUT OF TOLERANCE	INSTRUMENT DRIFT; REPETITIVE OCCURANCE
W	YR1	019139	090777	GS	PS	SH	A14	T	T			SI ACTUATN HI CONT PRESS SENSOR OUT OF TOLERANCE	SETPOINT DRIFT DUE TO NORMAL DETERIORATIN
W	YR1	020093	121977	IN	NG	PX	B00	N	U			#5 INTERMEDIATE RANGE PWR CHNL FAILD IND EQ 0	NOT KNOWN AT THIS TIME
W	YR1	020421	012778	TX	PT	PX	A08	N	T			MAIN COOLNT PRESS INDICATION 1330 VS 975 PSIG	LOOSE CONNCTNS ON MECH. LINKAGES OF XMITR
W	YR1	021684	060778	MO	RR	NN	A05	N	D			#1 STEAM GEN RAD MONITR OPERATED ERRATICALLY	DEFECTIVE SOLDER CONN. IN COMPUTR-INDICAT
W	YR1	025299*	020679	SE	DC	NN	B12	N	T	3		RPI LIGHTS FOR POS 84", 87", 89" FOR ROD #6 NOT LIT	DIRTY TERMINAL CONTACTS FOR COILS
W	YR1	025532	031279	RE	XS	SN	A12	T	T			TIME DELAY RELAY TDC-2 FOUND TO OPERATE SLOW	DUST BUILDUP ON RELAY CONTACTS
W	YR1	027401A	101979	CM	PT	PX	A14	T	T			COOLANT PRESSURE CH LP SCRAM SETPOINT FOUND OOC LO	INSTRUMENT DRIFT
W	YR1	027401B	101979	CM	PS	SN	A14	T	T			COOLANT PRESSURE CH LP SIAS SETPOINT FOUND OOC LOW	INSTRUMENT DRIFT
W	YR1	027401C	101979	TX	PT	PX	A14	T	T			COOLANT PRESSURE CH TRANSMITTER FOUND OOC	INSTRUMENT DRIFT OF TRANSMITTER AMPLIFIER
W	YR1	027502	110979	RE	XS	SN	B04	T	D			SI ACCUMULATOR TIME DELAY RELAY FOUND OOC	DESIGN DEFICIENCY OF CAPACITOR IN PS





RANDOM FAILURE

UNIQUE	PLANT	CONTROL NUMBER	EVENT DATE	CDWP	PROGRAM	SYSTEM	MODULE	CAUSE	ACTIVITY	CLASS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
W	Z11	032696	091280	MD	RR	NN	A00	N	N	U		AUX BLDG AREA MON ERRATIC RDG & PERIODIC ALARMS	UNKNOWN
W	Z11	032989	100180	CH	FT	PX	A14	N	N	T		IC RX COOLANT FLO CHNL IF-424 COMPARATOR SETPT LOW	INSTRUMENT DRIFT
W	Z11	033351	111080	TX	FT	PX	A14	N	N	T		SG 2B FEED FLO CH 2F-540 RDG HIGH	ZERO SHIFTING OF XMTR
W	Z11	033483	111780	MD	RR	NN	B00	N	N	U		FIRE SUMP PROCESS RAD MON DRT-PR25 INCRSD TO HI //	ALRM. CAUSE UNDETERMINED
W	Z11	164405	010681	MD	RR	NN	B00	N	N	U		SERV BLDG RAD MON DPRO36 BLOWER FOUND OFF	UNKNOWN
W	Z11	037071	041281	MD	RR	NN	A14	N	T	T		FUEL BLDG AREA RAD MON DPE-0005 ALARMED HIGH	SETPOINT DRIFT OF HIGH VOLT POWER SUPPLY
W	Z11	037227	042581	MD	RR	NN	B13	N	T	U		FIRE SUMP RAD MON DRTPR25 FAILED	FAILED RESISTOR & TRANSISTORS IN PS
W	Z11	037689	061581	MD	RR	NN	B13	N	N	U		STACK GAS RAD MONITOR DRE-0014 BEGAN SPIKING	GM TUBES REPLACED
W	Z11	038053	070881	MD	RR	NN	B00	N	N	U		RADIATION MONITOR 1RE0019 WAS INOPERABLE	NO CAUSE GIVEN
W	Z11	038209	080381	MD	RR	NN	A14	N	T	U		GAS DECAY TANK CUBICLE RAD MON DRT-PROZB INDICATE-	-D HIGH. INSTRUMENT DRIFT
W	Z11	038615A	083081	IM	TT	PX	B14	N	T	T		LOOP B OVER/DELTA TEMP FOUND READING 5% HIGH	FUNCTION GENERATOR DDC, LATER REPLACED
W	Z11	038615B	090581	IM	TT	PX	B00	N	N	U		LOOP "B" OVER-TEMP DELTA 1 FOUND READING HIGH 10%	FUNCTION GENERATOR REPLACED
W	Z11	039374	111781	MD	RR	NN	B13	T	U	U		GAS DECAY TANK PARTICULATE RAD MON DRT-PR10C FAIL-	-ED SOURCE CHECK. POWER SUPPLY FOW LOW
W	Z11	171129	112881	PS	NT	PX	B00	N	U	U		HIGH VLTG PWR SUP IN N42 PWR RANGE DRWR DEFECTIVE	UNKNOWN
W	Z12	014490	012376	TX	LT	PX	A14	T	U	T		ZLT-528 2C S/G LEVEL XMTR OUT OF TOL (NONCONSERVATIVE)	SCALE SHIFT IN XMTR; RECALIBRATED
W	Z12	014943	052576	TX	LT	PX	B13	N	U	U		LEVEL XMTR ZLT-539 FOUND OUT OF TOL FOLLOWNG RX TRIP	REPLACED XMTR WITH SPARE
W	Z12	015190	070976	TX	LT	PX	B08	N	T	T		S/G LEVEL XMTR ZLT-547 FAILED HI	STICKY INTERNAL COMPONENT PARTS
W	Z12	016048	090376	ZZ	PS	SN	B00	T	U	U		2PSH-CS21A FOR CONTMNT PRESS HI WOULDNT TRIP	CAUSE OF MODULE FAILURE UNKNOWN
W	Z12	016050	091476	CM	PT	PX	B13	N	U	U		COMPARTR 2PC-456A PZR HIGH RX TRIP FOUND HIGH	COMPRTR WAS REPLACED WITH SPARE
W	Z12	016180*	100176	TX	FG	NN	A14	T	U	U		6 FLOW XMTRS OUT OF TOL--2FT-424,425,426,444,445,446	ZERO POINT DRIFT AND RANGE DRIFT
W	Z12	016969	012277	TX	LT	PX	A14	T	T	T		PZR LEVEL XMTR ZLT-461 FOUND LOW BY 7%	DRIFT OUT OF TOLERANCE
W	Z12	017250	020377	IM	TT	PX	A14	T	T	T		SQUARE ROOT EXTRACTR LOOP B STEAM FLOW FOUND HIGH	DRIFT OF LOW END SETTING OF SQ. RT. EXTRACTR
W	Z12	017249	020777	IM	TT	PX	A14	T	T	T		SQ. ROOT EXTRACTR FOR LOOP D STEAM FLOW FOUND HIGH	DRIFT OF LOW END SETTING 2FM-5308
W	Z12	018055	032777	TX	LS	SN	A14	T	T	T		PZR LEVEL INDICATR ZLI-459A HIGHR THAN 461 (NONCON)	ZERO SHIFT IN XMTR
W	Z12	018054	041177	AM	PT	PX	B13	T	T	T		COMPARATR 2PC-456A WOULD NOT TRIP; PUT IN TRIP MOD	BAD OPERATIONAL AMPLIFIER A-3
W	Z12	017810	050977	CM	PS	SN	B13	T	U	U		STEAM PRESS CHNL 2P-516 SETPT OUT OF TOL	FAULTY PARTS IN SIGNAL COMPARATOR
W	Z12	018210	060477	CA	TC	NN	A09	T	U	U		NIS CHANL 4, B/S FOR HI ROD STOP & TURBIN RUN BACK	FOR LOOP B DELTA 1; LOOSE WIRE PIN CONNCT
W	Z12	018209	061477	AM	TC	NN	B13	N	T	U		LOOP A TEMP COLD LOG READING LOW & FAILED LO LEVEL	AMPLIFIER; TWO BAD CAPACITORS; REPLACED
W	Z12	022222	090177	TX	LT	PX	A14	T	T	T		S/G LEVEL CHNL ZL-7 FOUND READING HIGH (NONCONSR)	XMTR DRIFT; RECALIBRATED
W	Z12	019522	102077	TX	FT	PX	A14	N	T	T		FEED FLOW INDICATR ZFI-540 NONCONSERVATIVE	DRIFT OF XMTR & RECALIBRATED
W	Z12	019779	111777	SE	NT	PX	B13	N	U	U		SOURCE RANGE DETECTR 2N-32 AUTO ENERGIZED & FAILED	CHECKD CHNL ELECTRICALLY; REPLACED DETECTR
W	Z12	023616	120177	IN	LG	PX	B00	N	U	U		S/G LEVEL IND. ZLT-547 FAILED HI (NONCONSERV FOR S1)	PROBLEM COULD NOT BE DUPLICTD; REPLACD CAP
W	Z12	019998	120677	TX	LT	PX	A08	N	T	T		2B S/G LEVEL IND. ZLT-547 READING HI (NONCONSERVTV)	STICKING INTERNAL PARTS
W	Z12	020197	121477	TX	PS	SN	A09	N	T	T		2D S/G PRESS IND 2PT-534 READING HIGH (NONCONSERVTV)	GROUNDSD OUTPUT ALSO OUT OF CAL XMTR
W	Z12	020350	012178	TX	FT	PX	B13	N	T	T		FW FLOW IND 2FI-510A DRIFTD HI (NONCONSERV)	FAILED OSCILLATOR AMPLIFIER IN XMTR
W	Z12	023499	022078	CM	LT	PX	B07	T	D	T		PZR LEVEL CHANL ZL-460 OUT OF TOL HI AND LO ENDS	REVERSD DIODE CAUSN IMPRPR VOLT REGULATIN
W	Z12	021344	042578	MD	RR	NN	A14	N	T	T		PZR LEVEL CHANL ZL-459 OUT OF TOL HIGH NONCONSERVTV	RANGE SHIFT OF XMTR
W	Z12	021543	031878	MD	RR	NN	A14	N	T	T		S/G BLOWDOWN MON ZRE0019 SPIKING & ALARMING HIGH	DRIFT IN HI VOLT PWR SUPPLY
W	Z12	022522	081178	NL	RR	NN	A09	N	D	T		CONTMNT APD ZRE0011 SPURIOUS ALARMS; NO RESPONSE	LOOSE WIRE ON "OPERATION" SELECTR SWITCH
W	Z12	022802	091578	PS	NT	PX	B13	N	T	T		PWR RANGE CHANL N42 READING LOW; NONCONSERV TRIP	BAD 25 VOLT PWR SUPPLY
W	Z12	025385A	021479	TX	LS	SN	A14	N	T	4		ZLT-460 FOUND TO BE DDC 4 TIMES BETWEEN 2/14 +0 //	2/18. INSTRUMENT DRIFT
W	Z12	025385B	021479	TX	LS	SN	B00	N	T	U		ZLT-459 WAS INOPERABLE	NO CAUSE GIVEN
W	Z12	025656A	010379	TX	LS	SN	B13	N	T	T		ZLI-460 FOUND OUT OF CALIBRATION HIGH	LOOSE ZERO POTENTIOMETER
W	Z12	025656B	030379	TX	LS	SN	B08	N	T	T		ZLI-460 FOUND OUT OF CALIBRATION	LEAKING DRAIN PLUG
W	Z12	025658	031179	MD	RR	NN	B11	T	D	T		CONTMNT PARTICULATE & GAS MON ZRE0011 & 12 BECAME/	INOPERABLE. SAMPLE ISOLATION VLV FAILED
W	Z12	026070	050879	ZZ	XT	PX	B08	N	T	U		TRAIN A REACTOR TRIP BREAKER FAILED TO OPEN	PLUNGER IN VV COIL FOUND OUT OF ADJUST
W	Z12	026749	072379	MD	RR	NN	B00	N	U	U		PURGE PARTICULATE MONITOR ZRT-PR09C TAKEN DDC	NO CAUSE GIVEN
W	Z12	026463	072479	PS	LT	PX	B00	N	U	U		S/G LEVEL ZL-538 FOUND TO BE INDICATING 20% HIGH	FAULTY POWER SUPPLY, NO CAUSE GIVEN
W	Z12	026748	080679	PS	LT	PX	A14	N	T	U		S/G LEVEL ZLI-538 READ OVER 4% HIGH	EXCESSIVE INSTRUMENT DRIFT
W	Z12	027410	102579	TX	PS	SN	B00	N	U	U		S/G PRESSURE CHANNEL 2P-516 FAILED HIGH	TRANSMITTER FAILED WITH NO CAUSE FOUND



RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	AREA	FUNCTION	SYSTEM	ROOM	CABLE	CHANNEL	STATUS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
BBN	019395	101977	SW	PT	PX	A14	T	T	T		DRYWELL PRESSURE SWITCH DRIFTED BEYOND SET POINT	SETPOINT DRIFT OF PS-64-56C
BBN	020379	110378	SW	PT	NN	B08	T	T	T		RX PRESS SW PS-68-95 WOULD NOT FUNCTION	MOISTURE CAUSED CORROSION OF CONTACTS
BBN	022863	110378	SW	PT	NN	B08	T	T	T		RX PRESS SW PS-68-96 SW 1 FAILED TO OPERATE	SWITCH NEEDED TO BE EXERCISED
BBN	025176	021479	SW	PT	NN	B13	N	T	T		ROD POSITION INDICATION LOSS	POWER SUPPLY FAILED DUE TO LOSS OF FAN
BBN	025675	041479	SW	PT	NN	A13	T	T	T		RX BLOC, TURBINE BLOC & REFUEL ZONE EXHUST MON RM-7	190-250 FAILED. INPUT CARD REPLACED
BBN	025954	051079	GS	LT	PX	B00	T	T	U		SCRAM ACC LEVEL SWITCH LS-2-85-34 WOULD NOT OPERATE	CAUSE OF THE SWITCH FAILURE IS UNKNOWN
BBN	026332	061579	GS	LT	PX	A14	T	T	T		RX HIGH PRESSURE SWITCH PS-5-220 EXCEEDED TS LIMIT	SWITCH HAD DRIFTED
BBN	026610	080279	GS	LT	PX	A14	T	T	T		SETPOINT FOR PRESSURE SWITCH PS-64-57A OOC	INSTRUMENT DRIFT
BBN	027741	112179	GS	LT	IC	A14	T	T	T		VCIS L P MAIN STEAM LINE PS SETPOINT FOUND OOC LOW	SETPOINT DRIFT
BBN	027849	120579	GS	LT	SW	A14	T	T	T		MAIN STEAM LINE HIGH FLOW SW PD15-1-500 OOC	MODEL 278 SWITCH HAD DRIFTED
BBN	028021	122379	IN	PG	IC	B13	N	U	U		DRYWELL TO TORUS DP IND POI-64-137 FOUND INOPERABLE	BLOWN FUSE, NO CAUSE GIVEN FOR BLOWN FUSE
BBN	030416	021380	MO	RM	PX	B09	N	U	U		SW # 1 ON LITS-3-580, RX WTR LEVEL, FAILED TO OPERATE	NO CAUSE GIVEN FOR SW FAILURE
BBN	030635A	021380	MO	RM	PX	B00	N	U	U		"B" STM LINE 2-RM-90-138 FAILED DWN SCL	LOSS OF PWR OUTPUT FROM PWR DRAWER
BBN	030635B	030980	SW	XC	PX	B00	N	U	U		ROD BLOCK MONITOR "A" BYPASSED	COLD SOLDER JOINT REPAIRED
BBN	030893	041380	AN	FT	PX	B14	N	T	T		FLOW SIG TO APRM CH A, C, & E HIGHER THAN NORMAL	OUTPUT OF PROPORTIONAL AMP DRIFTED HIGH
BBN	031097	042180	GS	LT	SW	A14	N	T	T		RX HP SW PS-3-220 EXCEEDED SETPOINT	SETPOINT DRIFT
BBN	031890	071280	LS	VD	IC	B12	N	T	T		LIMIT SW ON MSIV 1-38 INOPERABLE	CORROSION FROM STM TUNNEL WARM, MOIST AIR
BBN	032024	071580	LS	VD	SD	A14	N	T	T		CORE SPRAY DISCHARGE PS 2-PS-75-35 OOC	INSTRUMENT DRIFT
BBN	032899A	100980	GS	LC	NN	B00	M	U	U		SCRAM ACC LVL SW REPLACED	RANDOM FAILURE
BBN	033713*	111980	CA	NT	PX	B00	N	U	3		IRM'S B, D, & H DID NOT RESPND CABLE ON H & CONNECTO	//RS ON B & D REPAIRED. UNKNOWN CAUSE
BBN	033547	121580	GS	LT	PX	A14	N	T	T		RX WTR LLS-3-56A SW 2 SETPOINT OOC	MODEL 4418C SETPOINT DRIFTED
BBN	033694	123080	TX	TC	NN	A14	N	T	T		FLOW SYSTEM DECLARED INOPERABLE	MODEL 555 XMITTR FT77-16 INSTRU DRIFT
BBN	036008B	012081	GS	LC	SW	A14	T	T	T		2 SCRAM DSCHRG VOL 2-LS-85-45C/O OOC	SETPOINT DRIFT
BBN	036625	032581	GS	LC	NN	B00	N	U	U		HPCI TURBINE OOS TO REPAIR DEFCTV SW 2-LS-73-5	NO CAUSE GIVEN FOR DEFECT
BBN	036777	040681	GS	LC	NN	A14	T	T	T		LEVEL SWITCH 2-LS-85-45A SETPOINT OOT (HIGH)	SETPOINT DRIFT
BBN	037176	050581	IN	PG	IC	A00	T	T	T		ANNUNCIATOR FAILED TO OPERATE	RELAY 23AK51 FAILED
BBN	166660	051281	GS	LT	SW	B08	T	U	U		SCRAM DISCHR VOLUME LEVEL SW 2-LS-85-45A FAILED	FLOAT HAD BECOME DISCONNECTED
BBN	038010	060481	GS	LT	SW	A14	T	T	T		SWITCH 2-PD15-75-56 OOT (LOW)	MODEL 288 D/P SW SETPOINT HAD DRIFTED
BBN	037832	070281	GS	LT	SW	B12	T	U	U		RX LP PRSSV SW 2-PS-68-96 #1 FAILED TO OPERATE	STUCK SWITCH-REASON UNKNOWN
BBN	038931*	100581	TX	IC	IC	A14	T	T	2		TORUS WATER 2-LT-64-54,-66 OOT	CALIBRATION HAD DRIFTED
BBN	039243	102981	IN	PG	IC	A14	N	T	T		D/W TORUS D/P OOT (LOW)	SETPOINT DRIFT
BBN	172030	123181	GS	LT	NN	B00	T	T	T		SCRAM DSCHRG LVL SW 2-LS-85-45E FOUND INOPERABLE	SWITCH FAILURE
BBN	016057	042376	CA	NT	SW	B13	T	T	T		RHR PUMP 3C FAILED TO START	OPEN CABLE IN RHR LOGIC, CABLE REPLACED
BBN	017529	031479	CA	NT	SW	A14	T	T	T		DRYWELL HIGH PRESS SWITCH PS-64-56A EXCEED TS LIM.	SETPOINT DRIFT
BBN	022087	070878	IN	DG	SG	B09	N	T	T		RCICS DISCHARGE VALVE IND. LIGHT WAS NOT ON	SHORT CIRCUIT IN AN INDICATING LIGHT CIR.
BBN	022456	091178	CA	NT	SG	B09	T	T	T		RCIC TUR. HIGH STEAM FLOW SW PD15-71-18 FOUND INOP	BROKEN WIRE DUE TO LOOSE CONNECTION
BBN	025088	011179	GS	LT	NN	B14	T	T	T		SW ON LLS-3-56B, RRP MOTOR GEN FIELD TRIP FAILED	FOUND TO BE OUT OF CALIBRATION
BBN	026399	062779	CA	NT	SG	B00	T	T	T		NO SPEED INDICATION AVAILABLE FOR RCIC PUMP	BROKEN WIRES ON MAGNETIC PICKUP
BBN	026618	072379	CA	NT	PX	A14	T	T	T		RX LOW PRESSURE SWITCH 68-96 SW #1 SETPOINT LOW	INSTRUMENT DRIFT
BBN	028032A	121679	ZZ	NT	PX	A14	T	T	T		APRM "B" HIGH FLUX WAS FOUND TO BE GREATER THAN //	120 PERCENT. INSTRUMENT DRIFT
BBN	028032B	121679	IN	NC	IC	A00	T	T	T		APRM "D" INOP ROD BLOCK AND ANNUNCIATOR TRIPPED //	WITH 12 INSTEAD OF 13 INPUTS. UNKNOWN
BBN	030888	040480	RE	XS	IC	B07	N	T	T		PRIMARY CNTNMT ISOL SYS VLVS FAILED CLOSED	RELAY OVERHEATED
BBN	031324	051980	GS	LT	SL	A14	N	T	T		RX LP SW PS-3-748 SW 1 OUT OF TOLERANCE	INSTRUMENT SETPOINT DRIFT
BBN	031407	052780	TX	TC	NN	B00	N	U	U		DRYWELL SUMP FLD XMITTR FT-77-16 OUTPUT SIG SHIFT	CAUSE OF SHIFT UNKNOWN
BBN	032459	082980	RE	TS	SL	B00	M	U	U		3A RHR PMP AREA COOLER FAN THRML OVKLD RLY FAILED	RANDOM FAILURE DEFECTIVE OVERLOAD RELAY
BBN	033052	101780	GS	LT	PX	A14	N	T	T		DRYWELL HP PS-64-588 SW 2 ABOVE TECH SPEC LIMIT	MODEL 12NAA4 DRIFTED OUT OF TOLERANCE
BBN	033354	111880	GS	LT	SL	A14	N	T	T		RECIRC DSCHRG VLV ACTVN 3-PS-68-95 SW 1 BELOW TS	MODEL 821-M1255 SETPOINT DRIFTED
BBN	033746	121080	MO	RR	NN	B09	N	T	T		CAM 3-RM-90-250 INOP	WINDOW CRD IN MODEL AM-331(BF) MALFUNC
BBN	036312	021381	GS	LT	SL	A14	T	T	T		D/W HP SW 3-PS-64-58C (LPCI PRSSV) OOT (HIGH)	SETPOINT DRIFT

RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	SYSTEM	SYSTEM	CAUSE	CLASS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	BF3 036778	040881	IN	LG	SN	B12	M	U	RX WTR 3-LI-3-468 OOS FOR MAINTENANCE	FAULTY BRG CAUSED IND MOVEMENT TO STICK
G	BF3 036991	041481	NO	NC	NN	A14	N	T	CNPLPD EXCEEDED TECH SPEC LIMIT	LPRM DRIFT DURING/PRIOR TO CALIBRATION
G	BF3 038427	082281	NO	RT	PX	A14	T	U	MAIN STM LINE RADIATION "M" HI ALRM OOT (HIGH)	SETPOINT DRIFT
G	BF3 038540	083081	GS	LS	SN	B00	T	U	SDV 50 GALLON SCRAM SW 3-LS-85-458 FAILED TO OPER	NO CAUSE GIVEN
G	BF3 038712	090881	IN	TC	IC	A14	N	U	INDICATOR 3-TI-64-55 GAVE ERRONEOUS INDICATION	INDICATOR CALIBRATION HAD DRIFTED
G	BF3 038939	093081	GS	PS	IC	A14	T	I	PS-64-67 (D/W HP) OPERATED ABOVE TECH SPEC LIMITS	CALIBRATION HAD DRIFTED
G	BF3 038999	100781	GS	LN	CT	A14	T	U	RX WATER LIS-3-58D #1 (LPC1 & CORE SPRAY INIT) OOT	CALIBRATION HAD DRIFTED
G	BF3 172156	122181	IN	LG	CT	B00	T	U	FW LVL INDICATOR LI-3-468 OOC BY 1.3 INCHES	INTERNAL PROBLEMS
G	BF3 018101	090377	IN	SA	SA	B13	N	T	ACT. CIRCUITRY, CH4 OF RX DEPRESS. SYS. FAILED	FAILED DUE TO FAILED POWER SUPPLY
G	BF3 018663	072677	SE	LS	SA	A14	N	U	STEAM DRUM LOW LEVEL SENSOR EXCEEDED TRIP SETPOINT	SETPOINT DRIFT
G	BP1 018883*	081277	PS	FG	SF	B13	T	D	BOTH CONT. SPRAY FLOW TRANSM. GROSSLY INACCURATE	TRANSISTOR FAILURES IN D&C PWR SUPPLY
G	BP1 020937	040778	GS	PT	PX	A14	T	U	VACUUM SWITCH SETPOINT FOUND TO BE OUT OF T/S TOL.	SETPOINT DRIFT (MINOR)
G	BP1 021438	051278	GS	PG	SN	B13	N	U	ACCUMULATOR PRESSURE SWITCH OPERATING TOO LOW	CAUSE UNKNOWN (DRIVE A5)
G	BP1 021986	071278	IN	PS	SN	B13	N	U	ANNUNCIATOR CIRCUITRY FAILED BLOWING PS FUSE	FAILED DIODES IN AMPLIFIER
G	BP1 027986	103079	IN	XS	IC	B13	N	U	POWER SUPPLY ES 8501A FAILED	TRANSISTOR FAILED
G	BP1 030238	012380	ZZ	XS	SA	A00	N	U	AUTO TST CKT ALRM IND "M" RX DEPRESS SYS WAS REMVD	// FOR TRBLSTNG. UNKNOWN CAUSE & CGMP
G	BP1 032022	071380	IN	PC	IC	A13	N	U	VISUAL ALRM ON CONT PRES IND ON UNIT P15-173	DEFECTIVE ELECTRONIC COMPONENTS IN UNIT
G	BP1 033693	123080	IX	LS	IC	A00	N	U	CHTRMNT BLDG LVL XMITTER INDICATED LO LVL OUTPUT	EXACT CAUSE OF XMITTER DEFICIENCY UNKNOWN
G	BP1 036893	040781	IN	PC	IC	B00	N	U	CNTRL UNIT IND PORTION INADO PRES DISPLAY PUT OOS	DEFECTIVE NEON LAMP ELEMENT
G	BP1 037357	050781	CL	TC	SN	B13	N	U	RX VESSEL LVL SENSING CHAMBER TEMP OOT (HIGH)	FAILED CAP IN TEMP CNTRL CKT OF TEMP SW
G	BP1 037801	061781	PS	XS	SA	B00	M	U	"M" RX DEPRESSURIZG SYS INVERTER PWR SUP REMVO F//	OR MAINT. DEFCTV ELECTRONIC COMPONENTS
G	BP1 018827	111876	GS	FG	NN	B13	T	T	VACUUM SWITCH FOUND TO BE OUT OF T/S TOL.	4 BAD TRANSISTORS, TRANSISTORS REPLACED
G	BP1 018851	121576	MD	RT	PX	B13	T	T	MAIN STEAM LINE D RAD MON. DISCOVERED OUT OF CAL.	COMPONENT FAILURE, MONITOR RECALIBRATED
G	BP1 018934	011077	AM	NC	SN	B13	N	T	ROD BLOCK MONITOR B HAD EXCESSIVELY LOW READING	FAILED AMPLIFIER
G	BP1 017082	012677	GS	PT	PX	A05	T	D	HIGH DRYWELL PS C71-PS-N002C FOUND TO HAVE FOR.SUB	FOREIGN SUBSTANCE BEEN THERE SINCE INSTAL
G	BP1 017600	021077	GS	PS	SD	A14	T	T	RX LOW PRES. SW B21-PS-N021A SET TO HIGH	SETPOINT DRIFT (CORE SPRAY VALVE OPENING)
G	BP1 018544	071377	MD	RT	PX	A14	T	T	MS LINE HIGH RADIATION INST. FOUND OUT OF CAL.	SETPOINT DRIFT, D12-RM-K603C
G	BP1 018889	081577	MD	RT	PX	A00	T	U	HIGH STEAMLINE RAD MONITOR SETPOINT FOUND TO BE HI	UNKNOWN CAUSE, INST. ID D12-RM-K603A
G	BP1 019148	092377	GS	LG	CT	B05	T	D	CONDENSATE STORAGE TANK LOW LEVEL SW FAILED TO OP.	SLUDGE IN FLOAT CHAMBER, E41-LS-N002
G	BP1 019332	092777	MD	RR	NN	B00	T	U	RX BLDG VENT EXHUST RAD MONITOR FAILED DOWNSCALE	UNKNOWN CAUSE, INST ID D12-RM-N010A
G	BP1 019388	101277	ZZ	NC	SN	B09	N	T	FUSE F1 ON RBM "A" BLEW	FUSE REPLACED, RBM "A" RETURNED TO SERVICE
G	BP1 019561	103177	CH	LS	SN	A14	T	T	RX LOW LEVEL #2 GROUP 1 ISOLA. SW SETPOINT WRONG	SETPOINT DRIFT, INST. ID B21-LS-N0248
G	BP1 019826	112477	GS	TC	SQ	B00	T	U	SUPP POOL AREA VENT HIGH DRYWELL ISOLA SW FAILED	UNKNOWN CAUSE, SWITCH ID E91-TS-N6048
G	BP1 020384A	011778	IN	NG	PX	A14	T	T	IRM "A" METER FOUND OUT OF CALIBRATION	METER RECALIBRATED AND RETURNED TO SERVIC
G	BP1 020384B	011778	IN	NG	PX	B00	N	U	IRM "C" WAS FOUND TO BE NOT RESPONDING	CAUSE NOT SPECIFIED
G	BP1 020679	012878	CH	NT	PX	A14	T	T	APRM CHANNEL E TRIPED AT >120 PERCENT (122 PER)	SETPOINT DRIFT
G	BP1 020680	021478	CH	NT	PX	A14	T	T	APRM CHANNEL C SETPOINT FOUND ABOVE TS LIMIT	SETPOINT DRIFT
G	BP1 020769	030278	ZZ	NC	SN	B13	N	T	ROD BLOCK MONITOR INDICATED DOWNSCALE, INE ROD BLOC	BAD I.C. CHIP
G	BP1 020767	030578	MD	RR	NN	B00	T	U	RM D12-RM-N010B WOULD NOT ISOLATE RX BLDG VENT	INST TECH CHECKED LOGIC CIRCUITS, TEST SAT
G	BP1 021187	041478	MD	RT	PX	A00	T	U	MAIN STEAM LINE RAD MON D12-RM-N603C OUT OF SPECS	INST RECALIBRATED, RETURNED TO SERVICE
G	BP1 021188	041778	CA	DC	NN	B09	N	T	CONTROL ROD POSITION FOR ROD 22-39 READING ERRATIC	GROUNDING WIRE
G	BP1 022701	100678	GS	LG	CT	B14	T	T	CONDENSATE LOW WATER LEVEL SW FAILED TO ACTUATE	INSTRUMENT OUT OF CAL, ID E41-LS-N003
G	BP1 023194	120278	GS	DC	NN	B00	N	T	POSITION IND FOR NOTCH 18 & 28 INOP FOR ROD 02-23	SWITCH 48 HAD A GROUND
G	BP1 025669	042579	CA	DC	NN	A00	N	D	NO INDICATION FROM NOTCH 34 ON CONTROL ROD 34-27	CUT IN WIRE FROM REED SWITCH
G	BP1 025880	042979	GS	DC	NN	A09	T	D	ROD 10-07 HAD NO INDICATION AT NOTCH 47	SWITCH WAS FOUND GROUNDING FOR NOTCH 47
G	BP1 025892	050479	ZZ	DG	NN	A00	N	U	FULL IN OR FULL OUT INDICATION FOR ROD 22-47 LOST	NO CAUSE FOUND
G	BP1 025984	050879	SE	FS	IC	B11	M	D	IND FOR MS LINE FLOW SW, B21-OPIS-N008A PEGGED HI	BLOCKED SENSING LINE
G	BP1 025961	051079	RC	FC	NN	B13	N	T	DRYWELL EQUIP DRAIN RECORDER FOUND DRIVING DOWN-//	SCALE. MOTOR DRIVE AMP TRANSISTOR FAILED
G	BP1 025985	051379	LM	XG	NN	B09	N	T	COMPUTER FAILED TO VERIFY APLMGR, MIPF, MCPR & LHGR	SCANNING SYSTEM OF COMPUTER WAS CALIBRATE
G	BP1 025960	051579	IN	NC	NN	A14	T	T	APRM "A" UPSCALE ROD BLOCK ALARM WAS OOC HIGH	INSTRUMENT DRIFT





## RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	CODE	ALARM	STATUS	CAUSE	ACTIVITY	CLASS	FAULT #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G BR2	026733	081574	GS	PS	SN	A14	T	T		B21-PS-NO210, RX LOW PRESS, FOUND OUT OF TOLERANCE	INSTRUMENT DRIFT
G BR2	026771	081874	GS	PS	NN	A00	N	U		LOW FLOW INDICATED ON 2-CAC-1263	NO CAUSE FOUND
G BR2	026953B	091079	GS	NT	PX	B00	T	U		APRM "B" OUT OF SERVICE DUE TO OPEN SIGNAL LEAD	NO CAUSE GIVEN, APRM "B" WILL BE REPLACE
G BR2	027714	101979	GS	NT	PX	B00	T	U		TORUS LEVEL HIGH/LOW ALARM DID NOT ALARM	ANNUNCIATOR CARD LOGIC INCORRECT
G BR2	027442	110474	IC	DC	IC	B00	T	U		DRYWELL TO TORUS VCM BKR 2-CAC-X180 HAD NO CLOSE	INDICATION DUE TO BAD LIMIT SWITCH.
G BR2	027680	112079	AM	NT	PX	A14	N	T		PRE-AMP FOUND OUT FOR IRM "D"	INSTRUMENT DRIFT
G BR2	027785	112079	AM	DC	NN	A00	N	U		FULL-OUT INDICATION NOT RECEIVED FROM ROD 06-27	DEFECTIVE OPTICAL ISOLATOR
G BR2	027844	121479	AM	DC	IC	B00	T	U		DRYWELL-TORUS VAC BKR CLOSE IND FAILED TO L-ENERG	SIZE, LIMIT SWITCH FAILED (INDICATION)
G BR2	030025	010280	RC	DC	NN	A00	N	U		RSCS WOULDNT PULL RODS UNTIL ROD 34-27 WAS BYPASS	DEFCTV "FULL-IN" ROD 34-27 REED SWITCH
G BR2	030039A	010380	AM	DC	NN	A00	N	U		NO POS IND AT NOTCH 48 FOR CONTROL ROD 26-07	FAULTY REED SW IN PIP PROBE
G BR2	030044	010580	GS	PG	NN	B00	N	U		ISOL VLV FOR PS 2-E11-PS-NO100 SHUT	UNKNOWN CAUSE FOR VLV BEING SHUT
G BR2	030039B	010980	MD	DC	NN	A00	N	U		NO POS IND AT NOTCH 7 FOR CONTROL ROD 34-35	FAULTY REED SW IN PIP PROBE
G BR2	030035A	011080	RC	TC	NN	B00	N	U		COMPUTER HAD SOFTWARE STALL & COULDNT STAY ON LIN	UNKNOWN
G BR2	030035B	011080	RC	TC	NN	B00	N	U		TEMPERATURE RECORDER CAC-TR-1258 POINT 14 INOP	UNKNOWN
G BR2	030188	011680	CS	LS	SN	B14	N	T		LEVEL SW E41-LSH-NO15A INOP	DOC DUE TO INSTRUMENT DRIFT
G BR2	030203	011780	RC	LG	SN	A00	N	U		TORUS LVL RECORDER 2-CAC-LR-2602 RDG ERRONEOUSLY	MISSING SCREW ON PIN MOUNTING ASSEMBLY
G BR2	030452A	021980	MD	RR	SN	B00	N	U		CHTNMNT ATMS MON CAC-AT-1263 INOP DUE TO LO FLOW	UNKNOWN
G BR2	030452B	022780	MD	RR	SN	B00	M	U		CHTNMNT ATMS MON CAC-AT-1263 WOULD NOT CALIBRATE	UNKNOWN
G BR2	030790	032980	GS	LC	NN	B09	T	D		LEAK DET VLV SW FOR HCU 26-47 DID NOT ACTUATE	SW CONTACTS WERE NOT MAKING
G BR2	031091A	042480	IM	NT	PX	B00	M	U		IRM A FAILED UPSCALE	DEFCTV CAL AND DIODE LOGIC MODULE
G BR2	031174B	050280	PS	NT	PX	B00	M	U		IRM "H" INOP DUE TO POWER SUPPLY PROBLEM	UNKNOWN TROUBLESHOOTING CONTINUING
G BR2	031273A	051680	ZZ	NG	NN	B00	T	U		SRM A DIDNT GIVE FULL IN OR OUT INDICATION	BLOWN DRIVE CIRCUIT FUSES
G BR2	031273B	051680	SE	NT	PX	A07	T	T		SRM D PRODUCED ERRATIC INDICATIONS	MOISTURE IN THE DETECTOR CONNECTOR
G BR2	031731	070180	GS	PS	IC	A14	T	T		PS 2-C72-PS-NO028 ACTUATES OUT OF TOLERANCE	INSTRUMENT DRIFT
G BR2	032548*	090380	ZZ	DC	SN	A13	N	U	3	3 CNTRL RODS 22-31, 26-23, 26-19 HAD POS IND PROBLEMS	DEFCTV TRANSISTOR IN INSTRUMENTAIN EQUIP
G BR2	033878	090380	TX	FS	SL	B00	M	T		SQR ROOT XMITTR 2E11-FY-3338 INOPERABLE	DFCTV RESISTOR R5 NAT'L END OF LIFE
G BR2	032708B	091580	IN	LG	SN	A14	T	T		TORUS HIGH LVL ALARM OUT OF CALIBRATION	INSTRUMENT DRIFT
G BR2	032905	101180	RE	DC	NN	B12	T	T		SRM "C" WOULD NOT WITHDRAW	STICKING RELAY IN DET DRIVE CONTROL CKT
G BR2	032999	101980	MD	RR	IC	B11	T	T		RIP ISOL VLV X768 CLOSED CAC MON 1259-61 INOP	LOSS OF SAMPLE FLOW THROUGH PENETRATION
G BR2	033055	102280	GS	PS	SL	B11	N	T		"A" LOOP OF RHR SERVICE WTR SYS INOPERABLE	CRACKED SENSING LINE ON 1-SW-PS-1176
G BR2	033058*	102680	HS	XC	NN	B00	M	U	2	2 RODS 34-23, 18-23 WOULD NOT SELECT	ROD SELECT SWITCHES FAILED END OF LIFE
G BR2	033089	110280	SE	DC	NN	B00	N	U		CNTRL ROD 30-11 INDICATION PROBLEMS	REED SW IN ROD POS IND PROBE FAILED
G BR2	033835	120280	CN	FG	NN	A14	N	T		DRYWELL EQUIP DRAIN LEAKAGE INTGRTR IND INCORRECT	DRYWELL EQUIP DRAIN SQ ROOT CONVERTER DOC
G BR2	033556	121280	AM	DC	NN	B13	N	T		NO "FULL-OUT" POS IND ON ROD 26-35	LIGHT ISOL OF ROD GRP AUX BFFR BRD FAILED
G BR2	033704	122980	TX	LG	NN	A14	N	T		RX LVL INSTRU 2-B21-LI-R604A NOT RDG PROPERLY	LVL XMITTER 2-B21-LI-NO26A DRIFTED DOC
G BR2	033700	123180	GS	PS	SA	A14	T	T		2-E11-PS-NO10A ACTUATED OUT OF SPEC	INSTRUMENT DRIFT
G BR2	033702	123180	GS	PS	NN	A13	N	U		CNTRL ROD 38-11 FAULTY POS IND AT POS "48"	REED SW PROBLEM IN ROD PIP PROBE
G BR2	033758	123180	LS	DC	NN	A00	N	U		LPRM 36-21C GAVE FAULTY INPUT SIG TO "A" RBM	UNKNOWN
G BR2	036090	010481	GS	DC	IC	B00	T	U		VAC BRKR X-18A HAD OPEN-CLOSE POS IND WHILE OPENED	PROBLEM W/ VAC BRKR POSITION LIMIT SW
G BR2	036091A	011081	PS	NT	PX	B13	N	U		IRM "A" DID NOT RESPOND TO CHANGES IN INPUT SIG	2 FA.LD CAPACITORS IN HI VOLTG PWR SUPPLY
G BR2	036091B	011081	ZZ	NT	PX	B00	N	U		IRM "C" INDICATED DOWNSCL WHEN ON RANGE 7	FAILED HI FREQ CHNL TRANSISTOR
G BR2	036091C	011181	CA	NT	PX	B00	N	U		IRM "E" INDICATED DOWNSCALE	OPEN SIG AT MONITOR PRE-AMP CONNECTOR
G BR2	036449	020681	GS	PS	IC	A14	N	T		BUTTERFLY VLV 2-CAC-V17 OPENED ERRONEOUSLY	AUTO-OPEN ACTUAIN SW 2CAC-DPS4423 DRIFTED
G BR2	036518	022281	IN	DC	NN	B00	N	U		ROD 26-39 FULL-OUT POSITION IND NOT ACHIEVED	CAUSE COULD NOT BE DETERMINED
G BR2	036562*	022381	GS	FT	PX	B13	N	T	2	2 RPS MSL HI FLO INSTR 2-B21-DPIS-NO08A/B ISOLATED	FW CNTRL INSTR BOURDON TUBE RUPTURED EOL
G BR2	036656	030381	CN	LS	IC	B00	N	U		PRIMARY CAC SUPPRESSION POOL LVL IND RDG DOWNSCALE	BLOWN PWR SUPPLY FUSE IN SIG CONVERTER
G BR2	036935	041081	PS	XSS	SQ	B00	T	U		RCIC TURBINE TRIPPED DUE TO OVSPEED	OPEN VLTG DROPG RESISTR TO 48 VDC PWR SUP
G BR2	037493	061181	CN	FS	IC	A14	N	T		DWFD SUMP FLO INTEGRATOR IND FLO W/D PUMP RUNNING	FLO INTGRTR SQ ROOT CNVRTR DOC -- DRIFT
G BR2	038156	070481	SE	DS	IC	B00	N	T		CNTRL ROD 14-27 NO FULL-IN POS IND LIGHTS LIT	FAILED REED SW IN DRYWELL
G BR2	037957	071481	IM	FS	IC	A14	N	T		D/W EQUIP DRAIN FLO INTEG IND W/D PUMPS RUNNING	INSTRUMENT DRIFT OF INTEGRATOR























RANDOM FAILURE

N S S	P L A N T	CONTROL NUMBER	EVENT DATE	CORR	PROGRAM	SYSTEM	MODE	CALC	ACTIVITY	CLAS	FAIL	#	FAULT MODE DESCRIPTION		FAULT CAUSE DESCRIPTION	
													FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION		
G	M11	038662	090581	GS	PG	NN	A14	T	T				ISOLATION CONDENSER PRESSURE SW 13498 FOUND OOC	SETPOINT DRIFT		
G	M11	038804	090881	GS	PG	SN	B00	T	T				REACTOR LOW LOW WATER LEVEL SW 263-738 FOUND STUCK	NO CAUSE FOUND		
G	M11	038998	100681	GS	PG	IC	A14	T	T				REACTOR LOW LOW WATER LEVEL SW 263-77A FOUND OOC HIGH	INSTRUMENT DRIFT		
G	M11	039432	111281	GS	PG	PX	A14	T	T				HIGH DRYWELL PRESSURE SCRAM & CNTNMNT ISO SWITCH//	FOUND OOC, INSTRUMENT DRIFT OF 2206-16210		
G	M11	171599	112481	REF	PS	IC	B13	N	T				HFA RELAY 595-102D RLY CKT FUSE BLEW MSL CHAN B	A DEFECTIVE RELAY COIL BURNED OUT		
G	M01	014446	040576	GS	PG	SO	A07	T	U				RCIC TURBINE TRIPS SPURIOUS AT 25, RAISED TO 40PSI	HIGH EXHAUST LINE PRESS TRIP PI TOO LOW		
G	M01	015941	091976	LS	DT	PX	B13	T	T				MSIV NOT-FULL-OPEN SCRAM RELAY DID NOT ENERGIZE	LIMIT SWITCH REPLACED		
G	M01	017364	030177	TX	LG	IC	B13	T	T				LEVEL DISCREPANCY OF 2 TORUS LEVEL INDICATORS	5551118A43ABA DP XMTR FAILED BELLOWS		
G	M01	017373*	032177	ZZ	RR	NN	B01	N	D	2			AIR-EJECT SAMPLE SYSTEM FOUND ISOLATED, INOPERATIVE	WORK CONTROL PROCESS, SU PROC TO BE REVISED		
G	M01	018465	062377	CL	FG	NN	B04	N	D				SGTS "A" INADEQUATE FLOW AS REQUIRED BY T.S.	ISOL VALVE CONTROL IMPROPER INSTALLATION		
G	M01	018670	080577	PS	XC	IC	B13	T	T				HPCI GOVERNOR CONTROL INOPERATIVE	FAILED RESISTOR IN PWR SUPPLY		
G	M01	019226*	100277	GS	TS	SN	A14	T	T	3			3 MN STM LINE AREA TEMP SW TRIP ABOVE T.S.	17002-40 TEMP SWITCH SETPOINT DRIFT		
G	M01	022725	100278	GS	TS	SN	A14	T	T				HPCI ISOL TEMP SW FAIL TO TRIP	LOOSE WIRE INSIDE SW 17023-6		
G	M01	023391	121478	RE	PS	IC	B08	N	Y				RX HIGH PRESS INST CHANNEL RELAY FAIL TO ENERGIZE	CR095 SOCKET CONTACT LOOSE FROM SOCKET		
G	M01	027391	103078	RE	PS	IC	B08	N	Y				RCIC ISOLATION TEMPERATURE SWITCH FOUND OOC HIGH	INSTRUMENT DRIFT		
G	M01	030125	011780	GS	PS	IC	B08	T	T				MSL LP ISOL SW PS2-134C SETPOINT DRIFT	SETPT SCREW MACHINING RING CAUSED DRIFT		
G	M01	030476	030980	LS	DG	NN	B06	N	U				ROD WITHDRAWAL BLOCK NOT RECEIVED	ACTUATING ARM OF LIMIT SW OUT OF ADJUSTMNT		
G	M01	037151	050881	ZZ	PG	SA	A06	N	D				AC INTERLOCK PERMITTING AUTO BLOWDOWN FOR ADS ACT-	-DATED, PRESSURE TAP PLACED IN WRONG		
G	M01	039110	102281	RE	FG	NN	B11	N	D				FLOW SENSOR AT OFF-GAS STACK FAILED	PLUGGED SENSING LINES		
G	M01	039050	102481	RE	FS	IC	B13	N	T				CNTNMNT ISOLATION SYS LOGIC RELAY FAILED NONCONSE-	-RVATIVELY, COIL FAILED DUE TO NRML EOL		
G	NM1	014248	020776	GS	PT	PX	A14	T	T				HIGH DRYWELL PRESS TRIP 3.35 VICE 3.5 PSIG	BARTON INSTRUMENT SETPOINT DRIFT		
G	NM1	014248	021076	MS	RR	NN	B13	T	T				REFUEL PLATFORM RAD MONITOR IND 350 VICE 800 MR/HR	DETECTOR FAILED AND REPLACED		
G	NM1	014248	021376	GS	PT	SH	B02	N	D				LOSS OF HPCI DUE TO INOPERABLE PUMP SUCTION SWITCH	LINKAGE ARM DISCONNECTED		
G	NM1	014573	030376	GS	PT	PX	B13	N	T				IRM #13 ERRATIC OPERATION	LOW DETECTOR RESISTANCE, REPLACED		
G	NM1	014583	032176	CM	FT	PX	A02	N	D				APRM B18 FAILED TO TRIP AT 20% FLOW POINT	TEST METER OFFSET CAUSED BAD CALIBRATION		
G	NM1	014667	042376	GS	FS	SH	A14	T	T				EMER COOL HIGH FLOW SW TRIP AT 20.4 VICE 19 PSI	SETPOINT DRIFT WITHIN EXPECTED RANGE		
G	NM1	015170*	061376	CM	FT	PX	A14	T	T	2			2 OF 8 APRM FAILED TO TRIP AT REQUIRED FLOW BIAS	APRM 17 & 18 SETPOINT DRIFT		
G	NM1	015171*	062776	CM	FT	PX	A14	T	T				APRM 11 & 15 FAIL TO TRIP AT REQUIRED FLOW BIAS	SETPOINT DRIFT LESS THAN 1%		
G	NM1	017398	030477	GS	LT	PX	A14	T	T				RX LEVEL LO-LO-LO TRIP AT 119 VICE 125 INCH	INSTRUMENT SETPOINT DRIFT		
G	NM1	017436	031777	GS	PG	SL	B13	T	T				412 FM PUMP DISCH PRESS SW FAILED IN CLOSED POS	SWITCH FAILURE		
G	NM1	017442	032077	GS	LT	PX	A14	T	T				RX LOW-LOW LEVEL TRIP AT 1 IN VICE 5 INCH	SETPOINT DRIFT		
G	NM1	017443	032677	MO	RR	NN	A14	T	T				EMERG CONDENSER VENT MONITOR INDICATING HIGH	OUTPUT OF DETECTOR RESET TO CONFORM		
G	NM1	018165	060477	GS	LT	PX	A14	T	T				RX LOW-LEVEL TRIP OUT OF ADJUSTMENT DID NOT TRIP	SWITCH OUT OF ADJUSTMENT		
G	NM1	018389	072277	GS	LS	SN	A14	T	T				RX LO-LO-LO LEVEL IND SW TRIP 129 VICE 125 INCH	BARTON 288 IND SW SETPOINT DRIFT		
G	NM1	018593	073177	ZZ	NT	PX	A14	T	T				BYPASS 6 VICE 5 LPRMS TO GET APRM-16 INOP LIGHT	APRM 216X91362 SETPOINT DRIFT		
G	NM1	018594	080177	GS	FS	SN	A14	N	T				MN STM HI FLOW TRIP AT 101 VICE 105 PSID CONSERV	BARTON DP 278 INST DRIFT		
G	NM1	019150	092377	GS	FS	SN	A12	T	T				RX HIGH-LOW LEVEL IND SW TRIP 33 VICE 33	CORROSION ON RELAY CONTACTS		
G	NM1	019585	110477	GS	FS	SN	A14	T	T				TURB ANTC TRIP LOW OIL PRESS SW LOW	SQUARE-D PRESS SW DRIFT 170 TO 165 PSI		
G	NM1	020110	011378	GS	FS	SN	A14	T	T				MN STM HIGH FLOW SW SETPOINT HIGH	RE22G BARTON 288 DP SW SETPOINT DRIFT		
G	NM1	022834	110378	GS	LS	SL	A14	T	T				RX LO-LO LEVEL SW TRIP +2 VICE 5 INCH WATER	4316 LEVEL SW SETPOINT DRIFT		
G	NM1	025285	021879	CM	FC	NN	B00	T	U				FLOW COMPARTOR #11 DID NOT GIVE ROD BLOCK AT 14%	REPLACED COMPARTOR, NO CAUSE GIVEN		
G	NM1	026137	061079	RE	XS	SN	B13	T	D				TIME DELAY RELAY IN ECCS SYSTEM FAILED TO OPERATE	BAD CLUTCH COIL		
G	NM1	026460	072679	GS	PS	IC	A00	N	U				VACUUM SWITCH, 68-12B, FAILED TO OPERATE AT DESIRED/	7 SETPOINT, NO CAUSE FOUND		
G	NM1	027405	102779	CM	FT	PX	B00	T	U				FLOW CONVERTER FOR # 2 APRM COULD NOT BE ZEROED	NO CAUSE GIVEN		
G	NM1	030003	010980	TX	TG	NN	A14	N	T				CONDENSER INLT/SCREENWELL DSCHRG D/T OOT (HIGH)	DIFF RECORDER TRANSMITTER OOC		
G	NM1	030199	012480	ZZ	TG	NN	B00	N	U				CONDENSER INLT/CIRC WTR DSCHRG DELTA T OOT (HIGH)	FAILED INSTRUMENT/TRANSITIONAL PLNT OPER		
G	NM1	031841	041980	GS	PT	PX	A14	T	T				RX SCRAM SW 02-13A OPERATING OUTSIDE SETPOINT	INSTRUMENT DRIFT		
G	NM1	032382*	080880	GS	PT	PX	A14	T	T	2			RX SCRAM SW 02-13B/D OOC (HIGH)	INSTRUMENT DRIFT		
G	NM1	033287	092780	JE	NT	PX	B09	N	D				#18 APRM UNIT INOP LPRM DETECTOR HAD FAILED	INTERNAL SHURTING IN DETECTOR		
G	NM1	036339	020981	MO	RT	PX	B00	N	U				MSL RAD MONITOR FOR #11 RPS TRIP SYS DECLARED INOP	NO CAUSE GIVEN		



RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	COMP	PROCESS	SYSTEM	MODE	CAUSE	ACTIVITY	TYPE	CLASS #	RANDOM FAILURE	
											FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	PB2 017647	041377	PS	NC	SN	B09	N	R	T	1	POWR SUP FOR RBM "A" FAILED MAKING RBM "A" INOPERABLE	SHORT BETWEEN PWR SUPPLY AND GROUND
G	PB2 017774	041777	IM	NC	SN	A14	T	T	T	1	APRM A INOP TRIP DID NOT OCCUR IAW TS 2 VS 8 LPRM	SETPT SHIFT - MOD GEM-32537A APRM
G	PB2 019182	092277	SE	NC	SN	A14	T	T	T	1	SEVERAL SETPTS ON RBM "B" APPROX 2 PCT GT ALLOWED	SETPT SHIFT-MOD 376A1724 ROD BLOCK MONITR
G	PB2 019329	101077	MD	RT	SN	A14	T	T	T	1	2C MN STM LN RAD MON HI-HI TRIP OUTSIDE TS LIMIT	SETPOINT DRIFT-RECAL & RETURNED TO SERVIC
G	PB2 019412	101777	IM	FG	SH	B12	T	T	T	1	LOGIC CARD FOR HPCI TURB LK DET FLD TO PERF ISOLAT	MON CONN STRIP HAD DIRTY CONT-MOD 653
G	PB2 019415*	102077	GS	PG	AS	B01	N	D	T	2	OP SWS DPIS-2-14-43A&B VALVED OUT OF SERV FOR MAIN	REPAIR LEAK ON COMMON SENSING LINE
G	PB2 019717	111077	GS	PG	SQ	A15	N	T	T	2	RCIC ISOL SW PS-213-87C SETPT OUTSIDE TS LIMIT	SETPT SHIFT-DEF MICROSW INTER TO INSTRUMT
G	PB2 020160	010478	MO	RR	NN	A13	N	T	T	2	OFF-GAS RAD MON "A" RIS-2-17-190A1 DEVLV A ZERO SH	ZERO SHIFT IN CONSERVATIVE DIRECTION
G	PB2 021192	032178	RE	LS	SN	A13	T	T	T	2	LO-LO LEVEL TRIP LVS-2-3-99D INOPERABLE/FAILD RELY	CAUSE TO BE DETERMINED BY MANUFACTURER
G	PB2 021707	070578	CM	NT	PX	A14	T	T	T	2	SCRAM CLAMP TRIP STPT FOR "A" APRM WAS 1 PCT GT TS	SETPOINT DRIFT-IMMEDIATELY RECALIBRATED
G	PB2 022283*	090178	RE	XS	SA	A14	T	T	T	2	TESTING ADS-TIMERS "A" & "B" OUTSIDE TIME LIMIT	SETPOINT DRIFT OF TD RELAYS
G	PB2 022588	091878	RE	DC	NN	B13	T	U	U	2	WHEN 1 CONT ROD SELECTED OTHER CR FLD TO DESELECT	1 CONTICI IN SLD RELAY-ROD CONT CKT-FLO CL
G	PB2 023188	120478	RE	FS	SN	B08	T	U	U	2	"A" CHNL MAIN STEAM LINE HI FLOW CKT IN CONTMNT IS	RELAY SA-K30A RETURN SPRING OUT OF ADJUST
G	PB2 023297	121878	SE	NC	SN	B09	T	U	U	2	"B" ROD BLK MON SET POINTS SHIFTED UP 15 PERCENT	FAILURE OF ZENER DIODE IN FLO BIAS CKTRY
G	PB2 025185	021979	ZF	FG	NN	A00	N	U	U	2	A "4 MBS./HR. DELTA BETWEEN REAL AND COMPUTER SC/	FANNED FEEDWATER FLOW. PWR LIMIT EXCEEDED
G	PB2 025640	032779	GS	PS	SN	A14	T	T	T	2	DRYWELL HI PRESSURE SWITCH 2-10-101D FOUND OOC HI	INSTRUMENT DRIFT
G	PB2 025743	041079	LS	DT	PX	B00	T	U	U	2	LIMIT SWITCH OF MSIV 2-2-86A FOR RPS B LOGIC FOUR	NO INOPERABLE. NO CAUSE FOUND
G	PB2 026000	052479	MO	RR	NN	B13	N	T	T	2	OFF GAS STACK RAD MON'S MADE INOPERABLE	BROKEN BELT ON SAMPLE PUMP
G	PB2 026406	062279	MO	RR	NN	B13	N	D	T	2	MAIN STACK SAMPLING SYSTEM WAS LOST	LIGHTNING BLEW ISO VLV PWR SUPPLY FUSES
G	PB2 026725*	081279	MO	RR	NN	B00	T	U	U	2	A & B CONTROL ROOM AIR RAD MONITORS FAILED	FAILED TRANSISTOR CIRCUITS IN BOTH
G	PB2 028030*	121379	PS	TG	NN	B00	N	U	U	4	FOUR B CHANNEL MSL TEMPERATURE MONITORS INOPERABLE	INSUFFICIENT OUTPUT FROM POWER SUPPLY
G	PB2 030275	012380	ZZ	XC	SN	B00	N	U	U	4	"B" FLO BIASED ROD W/DRAWL BLCK SETPT ON RBM OOT	FAILED DIODE IN RBM ANALOG CIRCUIT
G	PB2 030483	030680	GS	PG	NN	A14	N	U	U	4	PRESS SW PS-2-2-134C SETPOINT OOT (LOW)	SETPOINT DRIFT
G	PB2 032157	080880	IN	LS	SN	A00	N	U	U	4	LVL GAUGE ROD INCORRECTLY IN "A" DIESEL STRG TANK	NO CAUSE GIVEN
G	PB2 032751	091880	IN	FG	SH	A14	T	U	U	4	HPCI TURB STM LINE HI FLO TRIP INSTRUMT HI SETPT	SETPOINT DRIFT
G	PB2 032956	101580	GS	PS	SN	A14	T	T	T	2	DPIS-2-14-43B SETPOINT BELOW T.S. LIMIT	SETPOINT DRIFT
G	PB2 033128*	110380	GS	PS	SQ	A14	T	T	T	2	RCIC TURB STM LN HI "LO DPIS-2-13-83.84 OOC HIGH	SETPOINT DRIFT
G	PB2 033129	110580	PS	PS	SH	B09	T	U	U	2	HPCI DECLARD INOPERABLE	OPEN RESISTOR IN PWR SUP TO HPCI TURB EGM
G	PB2 033521	120280	GS	PS	SN	A14	T	T	T	2	MSL LP SW PS-2-2-134C SETPOINT OOC (LOW)	SETPOINT DRIFT
G	PB2 033596	120980	GS	TG	NN	A14	T	T	T	2	RCIC TURB WATER INLET TEMP SW SETPOINT HIGH	SETPOINT DRIFT
G	PB2 033627	121780	GS	PS	SH	A14	T	T	T	2	DPIS-2-23-77 OOC HIGH	SETPOINT DRIFT
G	PB2 033628*	121880	GS	XC	NN	B00	N	U	U	2	"B" SBGTS FILTR TRAIN HEATR MAN & AUTO RESET SW //	INOP. CAUSE NOT GIVEN
G	PB2 036005	010581	IM	FS	SO	B00	N	U	U	2	FAILED SQUARE ROOT EXTRACTOR FOUND IN FLOW CONTROL	LLER. NO CAUSE GIVEN
G	PB2 036165A	011781	MO	RT	PX	B00	N	U	U	2	"D" MSL RAD MONITOR FAILED IN TRIPPED CONDITION	NO CAUSE GIVEN
G	PB2 036348	013181	RC	TG	NN	B13	N	U	U	2	MULTI-POINT TEMPERATURE RECORDER FOUND INOPERABLE	BOUND DRIVE MOTOR
G	PB2 165185	020281	MO	RT	PX	B14	N	T	T	2	D MSL RADIATION MONITOR FOUND OOC LOW 50%	INSTRUMENT DRIFT
G	PB2 036349	020381	MO	RT	PX	A14	N	T	T	2	MSL RAD MONITOR "A" FOUND READING 15% LOW	INSTRUMENT DRIFT
G	PB2 036913	032981	TX	PT	PX	B13	N	U	U	2	"D" DRYWELL PRESSURE TRANSMITTER FOUND FAILED	CIRCUIT BOARDS REPLACED
G	PB2 036972	040781	ZZ	FG	NN	A00	N	U	U	2	RECIRC PUMP DRIVE FLOW INCREASED 10%	NO CAUSE FOUND
G	PB2 038511	082781	SE	NT	PX	B00	N	U	U	2	ONE LPRM FAILED UPSCALE AT "C" LEVEL	NO CAUSE GIVEN, CAUSED HALF SCRAM
G	PB3 013987	010676	MO	RT	PX	A14	T	T	T	2	MN STM LN RAD MON RIS-251A DID NOT TRIP WHEN DESIR	SMALL STPT DRFT ON LOG SCL-194X629G007
G	PB3 014212	011776	GS	DC	SN	B02	T	D	T	2	ROD WITHDRAW PERM INTLK'S DID NOT PREV WITHDL OF SEC	ROD-WIRING ERROR-FLO IC CHIPS&GRNDSD WIRE
G	PB3 014743	050576	GS	LG	SH	B08	N	U	U	2	VALVE SV 3-23-54 DID NOT AUTO OPEN-HPCI TURB EX DR	FLO MICRO SW-MOD 83844-B1 LEVEL SWITCH
G	PB3 014683	050776	ZZ	NT	PX	A09	T	U	U	2	CH "E" APRM TRPD AT FLUX LVLS HIER THAN LICENSE TS	SETPT SHIFT - DEF IN4734A ZENER DIODE
G	PB3 014986	060276	PS	YS	SQ	B08	T	U	U	2	CH "D" RCIC TEMP IND FOR STM LK DET WAS INOPERABLE	LOOSELY SECURED MOD G52 PWR SUPPLY BOARD
G	PB3 015C84	061276	RE	NT	PX	B13	T	U	U	2	"F" APRM ROD BLOCK NOT OBTND FRM SIM HI FLUX CONDT	FAILURE OF MOD 35AT600 4R1 RELAY
G	PB3 015880	092776	GS	PT	PX	A14	T	U	U	2	COND LO VAC SW PS-3-5-11A TRPD 0.26 IN BELOW TS	SETPOINT DRIFT-BARKSDALE MOD DIT-H1855 PS
G	PB3 016174	101176	AM	NT	PX	A09	N	U	U	2	CORE FLO BIAS INPUT TO THE A LOGIC APRM STRNG - HI	ABSENCE OF OFFSET SIGNAL IN FLO BIAS AMP
G	PB3 017548	041677	CM	NT	PX	A14	T	U	U	2	DOWNSCALE TRIP FOR APRM E FOUND AT 2.3, TS IS 2.9PCT	SETPOINT DRIFT ON A MOD GEM-32537A APRM
G	PB3 017718	042377	TX	LS	SF	A14	N	T	T	2	CONHT SPRAY PERMSV LT-3-2-3-73A FOUND OUT OF CAL	SETPOINT DRIFT-TRIP WAS 302 VS 312 INCHES





RANDOM FAILURE

PLANT	CONTROL NUMBER	EVENT DATE	AREA	SYSTEM	MODE	CLASS	ACTIVITY	FAIL #	FAULT MODE DESCRIPTION	FAULT CAUSE DESCRIPTION
G	QC2 019683	103177	TX	LG	IC	A07	N	T	TORUS LEVEL XMTR OUTPUT WAS 0.0 IN ACTUAL LVL -4IN	SLUDGE ACCUM ON BELLOWS SURFACE OF XMTR
G	QC2 020584	021178	GS	PG	SH	A14	T	T	HPCI TURB AREA HI TEMP SW 1S 2-2370D FLD TO TRIP	INSTRUMENT SETPOINT DRIFT
G	QC2 020719	022778	GS	PG	SL	A14	T	T	RHR PUMP DISCH PRESS SW PS 2-10530 TRPD 104 VS 100	INSTRUMENT SETPOINT DRIFT
G	QC2 020720*	030278	GS	PG	NN	B05	N	T	JET PUMP INSCR DP SW DP 2-201-3446C SENSING LIT	TS INCRECTLY INSTLD-OCCRD DURNNG STA CONSTR
G	QC2 021789	092478	GS	PG	SL	B13	T	T	RHR PUMP DISCH PRESS SW PS 2-10530 FAILED TO OPER	EQUIPMT FAILURE-INTERNAL DIRTY-RSTRCTD UP
G	QC2 022667	083178	MO	RT	PX	A14	N	T	MN STM LN RAD MON 2-1705-2D FLD IN DWNCL CONDIYN	INST DRIFT ENHANCED BY HI TEMPERATURES
G	QC2 023384	122178	GS	PS	NN	A14	T	T	MN STM LN LD PRES ISO SW PS 2-261-30C TRPD LT TS	INSTRUMENT DRIFT - MOD B21-A1255 PRESS SW
G	QC2 025308	021079	GS	PG	SH	A14	T	T	HPCI TURBINE AREA HI TEMP SW 1CH 2-2373A OOC HIGH	INSTRUMENT DRIFT
G	QC2 026052	040979	IN	LS	IC	A14	T	T	SUPPRESSION CHAMBER LEVEL INDICATOR FOUND OOC	INSTRUMENT DRIFT
G	QC2 027102	081579	GS	PG	SH	A14	T	T	HPCI TURBINE AREA HI TEMP SWITCH 2-2372A FOUND OOC	INSTRUMENT DRIFT HIGH
G	QC2 027101	082279	LS	DG	IC	B00	T	U	VACUUM BKR AD-2-1601-32A FAILED TO ALARM WHEN OPEN	FAILED LIMIT SWITCH, CAUSE NOT GIVEN
G	QC2 027554	100579	GS	DS	IC	B00	T	U	VACUUM BREAKER AD-2-1601-32B FAILED TO IND OPEN	POSITION SWITCH PROBLEM
G	QC2 027553	101679	GS	LS	NN	B00	T	U	REACTOR LOW-LOW MTR LEVEL SW LIS 2-253-72A FAILED	NO CAUSE GIVEN
G	QC2 027550	102279	GS	PT	PX	A14	T	T	PRESSURE SWITCH PS-2-504C, TURBINE FIRST STAGE LP//	TRIP FOUND OOC HI BY 1#, SETPOINT DRIFT
G	QC2 030541	030380	RE	XS	SL	G13	T	T	TIMER 10A-M2A DIDN'T ACTUATE RELAY K21A	TIMER MICRO-SW DRIFTED FROM INITIAL ADJST
G	QC2 033852	082980	CL	FG	SH	B13	T	U	HPCI MTR GEAR UNIT WOULDN'T COME OFF HI SPEED STOP	FAILED COMPONENT IN FLU CNTRLR 2-2340-1
G	QC2 036133	011681	GS	PT	PX	A14	T	T	DRYWELL PRESSURE SWITCH PS-1-1001-88D FOUND OOC HI	-1 BY -13PSI, INSTRUMENT DRIFT
G	QC2 036611	022481	GS	FG	SH	B00	T	U	RCIC SL HIGH FLOW ISOLATION SW OPS-2-1360-1A FAI	-BY 9 DEGREES F, INSTRUMENT DRIFT
G	QC2 039112	110381	GS	TS	NN	A14	T	T	HPCI AREA HIGH TEMP SWITCH 2-2373C FOUND OOC HIGH	INSTRUMENT DRIFT
G	QC2 039282	110681	RE	XG	NN	A14	T	T	VLVS FOR OFF GAS SYS CLOSED 15 SECONDS LATE	TIMER HAD SETPOINT DRIFT
G	VY1 015741	083076	GS	PT	PX	A14	T	T	DRYWELL HI PRESS SCRAM/ISOLATION SWCHS 01 OF 4SW1	SETPT DRIFT MODEL # 12N-AA4
G	VY1 016484	112176	LS	XT	PX	B04	T	D	RPS RELAY 5A-K3F DEENERGZD NORMLY BUT THEN RESET	MSIV-2-80C LIMIT SW, INSILLD WEAKR SPRING
G	VY1 016610	113076	TX	PG	SN	B08	T	D	SW #1 OF PS2-3-52D DIDNT ACTUAT AT SETPT	ROLLER OF SW ASSEMBLY BECAME DISLDED
G	VY1 016602	120778	TX	PG	IC	B13	N	D	TORUS PRESS IND. ON RECORDER PR-16-19-44 INOPERABLE	FUSE BLEW TO TORUS PRESS XMTR
G	VY1 017138	020177	GS	PT	PX	A14	T	T	DRYWELL HI PRESS SCRAM/ISOLATN SW 2.03#VS.2.0#	DRIFTD .1 PSI OVER ONE MONTH
G	VY1 018026	052077	MO	RR	NN	B09	N	T	STACK GAS II FAILED WHILE GAS I WAS BEING CALIBRATD	LOOSE CONNECTION; I RETURNED TO SERVICE
G	VY1 018061	052577	ZZ	NT	PX	A14	N	T	4PRM FLOW BIAS HI FLUX TRIP OUT OF SPEC & ALARMED	FLOW CNVRTR REPLACED, NO REASON FOR DRIF
G	VY1 017955	061377	IM	RR	NN	B13	T	D	HIHI TRIP ON "A" SJAE OFF-GAS FAILED TO ENERGZ TMR	DEGRADED INTEGRATED CIRCUIT
G	VY1 020486	112377	MO	RR	NN	B13	N	D	CONT AIR MONITR RECORDER PR-108-4 INDICATN DECREASED	TEMP LOSS OF LG VOLT POWR TO LUG RATE MTR
G	VY1 020809	030578	RE	XT	PX	A08	T	D	RELAY 5A-K3A FAILED TO DEENERGZ DUKIN MSIV-80A	LOOSE ACTUATING ARM ON VALV STEM
G	VY1 023142	120578	MO	RR	NN	A00	N	U	AEOG MONITR "A" ERRATIC, REPLACD WITH SPARE UNIT	CAUSE COULD NOT BE DETERMINED
G	VY1 025002	011179	MO	RR	NN	B11	N	T	RAD MONITORS 17-150A&B FOUND INOPERABLE	FLOW METER HAD FLOW BLOCKAGE
G	VY1 025307	021479	TX	LS	IC	B12	T	T	TORUS LEVEL TRANSMITTER LT 16-19-30A WOULD NOT CAL	ACCUMULATION OF RUST AND CRUD
G	VY1 025517	030779	GS	DS	IC	B12	T	U	VACUUM BKR ALARM FOR VU6-19-5J FOUND INOPERABLE	MICRO SWITCH ACTUATOR PLUNGER BOUND
G	VY1 025814*	032879	GS	DC	NN	B08	N	U	ROD WITHDRAW PERMISSIVE LIGHT FOUND ERRATIC	MISALIGNMENT OF REFUEL PLATFORM TRACK SW.
G	VY1 026426	071079	CA	XS	SL	B00	T	T	"A" RHR SUBSYS LOGIC FAILED TO ENERGIZE RELAY 10A/	7-KV6, LEAD CAME OFF CONTACT IN CON CIR
G	VY1 030021	010280	GS	PS	SL	A14	N	T	LPCI SYSTEM PRESSURE SW ACTUATED OOF LOW	SETPOINT DRIFT
G	VY1 030086	010980	PS	DG	NN	B13	N	U	LOST ALL ROD POSITION INDICATION	COOLING FAN IN PWR SUPPLY FAILED
G	VY1 030089*	012280	MO	RR	NN	B00	N	U	SAMPLING SYS FLD DISTURBANCE CAUSE BOTH RAD MON //	INOP, FLOW BLOCKAGE
G	VY1 030734	032680	CL	FG	SN	B00	T	U	TURBINE SPEED WOULD NOT INCRS ABOVE APPROX 800 RPM	FLOW CONTROLLER FAILED
G	VY1 031153*	051680	MO	RR	NN	A01	T	D	AEOG RAD MON 17-150A/B INOP IN CNTRLD CONDITIONS	PERS VIOLATED T.S. WHILE EVALUATG PROBLEM
G	VY1 031760	063080	MO	RR	NN	B08	N	U	INCOMPLETE SAMPLES COLLECTED	DAMAGED BRG IN PUMPS CAUSD PUMP FAILURE
G	VY1 033196	102780	GS	LS	SN	A01	N	D	LIS-2-3-72A ISOLATED W/O FIRST FAILG TRIP SYS	LICENSED/SENSOR OPERATOR ERROR
G	VY1 033611	121180	LS	DG	NN	B08	N	T	CHIRL ROD BLOCK NOT REC'D AS REQUIRED	LMT SW ARM LOOSEN & BENT BY PLATFORM
G	VY1 036361*	012781	GS	PS	SN	A14	T	T	ATWS/RPT HIGH PRESSURE TRIP FOUND OOC HI	INSTRUMENT DRIFT OF PT-2-3-568M, CH, & DM
G	VY1 036362	020581	GS	PS	IC	A14	T	T	TORUS-RB VCUUM BREAKER DELTA P SWITCH FOUND OOC HI	SETPOINT DRIFT

APPENDIX H  
RESULTS OF COMPONENT LER RATE ESTIMATIONS



## CONTENTS

RESULTS OF COMPONENT LER RATE ESTIMATIONS .....	H-5
Reduced Capability—Command Faults Included .....	H-001
Core Flux Sensors .....	H-001
Temperature Sensors .....	H-006
Transmitters .....	H-010
Conditioning Systems .....	H-015
Bistables .....	H-020
Switches .....	H-025
Radiation Monitors .....	H-029
Inoperable—Command Faults Included .....	H-031
Core Flux Sensors .....	H-031
Temperature Sensors .....	H-036
Transmitters .....	H-040
Conditioning Systems .....	H-045
Bistables .....	H-050
Switches .....	H-055
Radiation Monitors .....	H-059
Reduced Capability—Command Faults Excluded .....	H-061
Core Flux Sensors .....	H-061
Temperature Sensors .....	H-066
Transmitters .....	H-070
Conditioning Systems .....	H-075
Bistables .....	H-080
Switches .....	H-085
Radiation Monitors .....	H-089
Inoperable—Command Faults Excluded .....	H-091

Core Flux Sensors .....	H-091
Temperature Sensors .....	H-096
Transmitters .....	H-100
Conditioning Systems .....	H-105
Bistables .....	H-110
Switches .....	H-115
Radiation Monitors .....	H-119

## APPENDIX H

### RESULTS OF COMPONENT LER RATE ESTIMATIONS

Using the factors of the LER rate point estimate given in the Final Statistics section, the upper and lower bounds can be determined as follows:

multiply X.X times Y.YE-YY to obtain upper 95% confidence limit

and

divide Z.Z into Y.YE-YY for lower 5% confidence limit

where

X.X = upper 95% confidence multiplier

Y.YE-YY = LER rate point estimate and

Z.Z = lower 5% confidence divisor.

NOTE: Table 18 provides this information.

BABCOCK&WILCOX

CORE FLUX SENSORS-REDUCED CAPABILITY-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
AR1	8	52608	0	420864	5.4E-07
CR3	8	43512	1	348096	2.9E-06
DB1	8	38472	0	307776	7.4E-07
DE1	8	52608	0	420864	5.4E-07
DE2	8	52608	0	420864	5.4E-07
DE3	8	52608	0	420864	5.4E-07
RS1	8	52608	0	420864	5.4E-07
TI1	8	28368	0	226944	1.0E-06
TI2	8	8760	0	70080	3.2E-06
		TOTALS	1	3057216	AVG. 3.3E-07

H-001

COMBUSTION ENGINEERING

CORE FLUX SENSORS--REDUCED CAPABILITY--COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
AR2	12	26952	0	323424	7.0E-07
CC1	20	52608	0	1052160	2.2E-07
CC2	20	44592	2	891840	2.2E-06
FC1	20	52608	0	1052160	2.2E-07
MI2	20	52608	2	1052160	1.9E-06
MY1	16	52608	0	841728	2.7E-07
PA1	10	52608	0	526080	4.3E-07
SL1	20	49920	0	998400	2.3E-07
		TOTALS	4	6737952	AVG. 5.9E-07

H-002

H-7

## CORE FLUX SENSORS-REDUCED CAPABILITY-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
BV1	12	49488	1	593856	1.7E-06
DC1	12	52608	0	631296	3.6E-07
DC2	12	33432	0	401184	5.7E-07
HN1	8	52608	0	420864	5.4E-07
IP2	12	52608	0	631296	3.6E-07
IP3	12	50304	0	603648	3.8E-07
JF1	12	38544	1	462528	2.2E-06
JF2	12	5784	0	69408	3.3E-06
KE1	12	52608	0	631296	3.6E-07
MG1	12	3504	0	42048	5.4E-06
NA1	12	32808	2	393696	5.1E-06
NA2	12	13632	1	163584	6.1E-06
PR1	12	52608	4	631296	6.3E-06
PR2	12	52608	0	631296	3.6E-07
PT1	12	52608	0	631296	3.6E-07
PT2	12	52608	0	631296	3.6E-07
RG1	12	52608	0	631296	3.6E-07
RO2	12	52608	1	631296	1.6E-06
SA1	12	44328	0	531936	4.3E-07
SA2	12	12264	0	147168	1.5E-06
SE1	12	13080	0	156960	1.4E-06
SE2	12	1368	0	16416	1.4E-05
SO1	8	52608	0	420864	5.4E-07
SU1	12	52608	0	631296	3.6E-07
SU2	12	52608	0	631296	3.6E-07
TR1	12	52608	0	631296	3.6E-07
TU3	12	52608	0	631296	3.6E-07
TU4	12	52608	0	631296	3.6E-07
YR1	12	52608	0	631296	3.6E-07
ZI1	12	52608	0	631296	3.6E-07
ZI2	12	52608	0	631296	3.6E-07
		TOTALS	10	15156192	AVG. 6.6E-07

GENERAL ELECTRIC

CORE FLUX SENSORS-REDUCED CAPABILITY-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
BF1	188	52608	0	9890304	2.3E-08
BF2	188	52608	0	9890304	2.3E-08
BF3	188	47328	0	8897664	2.6E-08
BP1	8	52608	0	420864	5.4E-07
BR1	140	45864	1	6420960	1.6E-07
BR2	140	52608	1	7365120	1.4E-07
CO1	140	52608	1	7365120	1.4E-07
DA1	98	52608	1	5155584	1.9E-07
DR1	9	24840	1	223560	4.5E-06
DR2	180	52608	1	9469440	1.1E-07
DR3	180	52608	0	9469440	2.4E-08
EN1	140	52608	0	7365120	3.1E-08
EN2	140	30648	0	4290720	5.3E-08
FP1	140	52608	3	7365120	4.1E-07
MI1	136	52608	2	7154688	2.8E-07
MO1	112	52608	0	5892096	3.9E-08
NM1	128	52608	0	6733824	3.4E-08
QC1	128	52608	6	6733824	8.9E-07
PB2	188	52608	0	9890304	2.3E-08
PB3	188	52608	0	9890304	2.3E-08
PI1	136	52608	0	7154688	3.2E-08
QC1	180	52608	0	9469440	2.4E-08
QC2	180	52608	0	9469440	2.4E-08
VY1	94	52608	0	4945152	4.6E-08
		TOTALS	17	170923080	AVG. 9.9E-08

H-004

FINAL STATISTICS

CORE FLUX SENSORS-REDUCED CAPABILITY-COMMAND FAULTS INCLUDED

	OPERATING FAULT RATE (FAULTS/HOUR)
	4.7
BAB.CWIL.	3.3E-07
	19.5
	2.3
COMB.ENG.	5.9E-07
	2.9
	1.7
WESTINGH.	6.6E-07
	1.8
	1.5
PWR'S	6.0E-07
	1.6
	1.5
GE (PWR'S)	9.9E-08
	1.6
	1.3
OVERALL	1.6E-07
	1.4

X.X - UPPER 95% CONFIDENCE MULTIPLIER

Y.YE-YY - LER RATE ESTIMATE

Z.Z - LOWER 5% CONFIDENCE DIVISOR

H-005



The remainder of Appendix H is provided on microfiche.

APPENDIX I  
RESULTS OF CHANNEL LER RATE ESTIMATIONS

# CONTENTS

RESULTS OF CHANNEL LER RATE ESTIMATIONS .....	I-5
Reduced Capability—Command Faults Included .....	I-001
Analog Channels .....	I-001
Nuclear Core Flux .....	I-001
Temperature .....	I-006
Flow .....	I-010
Level .....	I-015
Pressure .....	I-018
Digital Channels .....	I-022
Level .....	I-022
Pressure/Vacuum .....	I-024
Inoperable—Command Faults Included .....	I-028
Analog Channels .....	I-028
Nuclear Core Flux .....	I-028
Temperature .....	I-033
Flow .....	I-037
Level .....	I-042
Pressure .....	I-045
Digital Channels .....	I-049
Level .....	I-049
Pressure/Vacuum .....	I-051
Reduced Capability—Command Faults Excluded .....	I-055
Analog Channels .....	I-055
Nuclear Core Flux .....	I-055
Temperature .....	I-060
Flow .....	I-064
Level .....	I-069
Pressure .....	I-072
Digital Channels .....	I-076
Level .....	I-076
Pressure/Vacuum .....	I-078
Inoperable—Command Faults Excluded .....	I-082
Analog Channels .....	I-082

Nuclear Core Flux .....	1-082
Temperature .....	1-087
Flow .....	1-091
Level .....	1-096
Pressure .....	1-099
Digital Channels .....	1-103
Level .....	1-103
Pressure/Vacuum .....	1-105

## APPENDIX I

### RESULTS OF CHANNEL LER RATE ESTIMATIONS

Using the factors of the LER rate point estimate given in the Final Statistics section, the upper and lower bounds can be determined as follows:

multiply X.X times Y.YE-YY to obtain upper 95% confidence limit

and

divide Z.Z into Y.YE-YY for lower 5% confidence limit

where

X.X = upper 95% confidence multiplier

Y.YE-YY = LER rate point estimate and

Z.Z = lower 5% confidence divisor.

NOTE: Table 19 provides this information.

BABCOCK&WILCOX

CORE FLUX CHANNELS(ANALOG)-RED. CAP.-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
AR1	4	52608	1	210432	4.8E-06
CR3	4	43512	8	174048	4.6E-05
DB1	4	38472	0	153888	1.5E-06
OE1	4	52608	17	210432	8.1E-05
OE2	4	52608	0	210432	1.1E-06
OE3	4	52608	4	210432	1.9E-05
RS1	4	52608	1	210432	4.8E-06
T11	4	28368	0	113472	2.0E-06
T12	4	8760	0	35040	6.5E-06
		TOTALS	31	1528608	AVG. 2.0E-05

I-001

COMBUSTION ENGINEERING

CORE FLUX CHANNELS(ANALOG)-RED. CAP.-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
AR2	4	26952	0	107808	2.1E-06
CC1	8	52608	4	420864	9.5E-06
CC2	8	44592	4	356736	1.1E-05
FC1	8	52608	1	420864	2.4E-06
MI2	8	52608	5	420864	1.2E-05
MY1	8	52608	0	420864	5.4E-07
PA1	6	52608	2	315648	6.3E-06
SL1	8	49920	0	399360	5.7E-07
		TOTALS	16	2863008	AVG. 5.6E-06

I-002

WESTINGHOUSE

CORE FLUX CHANNELS(ANALOG)-RED. CAP.-COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)	
	POPULATION	HOURS	FAULTS	HOURS		
BV1	8	49488	2	395904	5.1E-06	
DC1	8	52608	0	420864	5.4E-07	
DC2	8	33432	1	267456	3.7E-06	
HN1	6	52608	2	315648	6.3E-06	
IP2	8	52608	2	420864	4.8E-06	
IP3	8	50304	1	402432	2.5E-06	
JF1	8	38544	4	308352	1.3E-05	
JF2	8	5784	0	46272	4.9E-06	
KE1	8	52608	0	420864	5.4E-07	
MG1	8	3504	0	28032	8.1E-06	
NA1	8	32808	3	262464	1.1E-05	
NA2	8	13632	6	109056	5.5E-05	
PR1	8	52608	4	420864	9.5E-06	
PR2	8	52608	0	420864	5.4E-07	
PT1	8	52608	0	420864	5.4E-07	
PT2	8	52608	1	20864	2.4E-06	
RG1	8	52608	0	420864	5.4E-07	
RO2	8	52608	1	420864	2.4E-06	
SA1	8	44328	1	354624	2.8E-06	
SA2	8	12764	0	98112	2.3E-06	
SE1	8	13080	1	104640	9.6E-06	
SE2	8	1758	0	10944	2.1E-05	
SO1	6	52608	0	315648	7.2E-07	
SU1	8	52608	0	420864	5.4E-07	
SU2	8	52608	2	420864	4.8E-06	
TR1	8	52608	0	420864	5.4E-07	
TU3	8	52608	0	420864	5.4E-07	
TU4	8	52608	0	420864	5.4E-07	
YR1	3	52608	0	157924	1.4E-06	
ZI1	8	52608	4	420864	9.5E-06	
ZI2	8	52608	0	420864	5.4E-07	
			TOTALS	35	9911232	AVG. 3.5E-06



GENERAL ELECTRIC

## CORE FLUX CHANNELS ANALOGS - RED. CAP. - COMMAND FAULTS INCLUDED

PLANT	COMPONENT		POPULATION		OPERATING FAULT RATE (FAULTS/HOUR)
	POPULATION	HOURS	FAULTS	HOURS	
BF1	18	52608	0	946944	2.4E-07
BF2	18	52608	0	946944	2.4E-07
BF3	18	47328	1	851904	1.2E-06
BP1	8	52608	0	420864	5.4E-07
BR1	18	45864	13	825552	1.6E-05
BR2	18	52608	2	946944	2.1E-06
CO1	18	52608	4	946944	4.2E-06
DA1	16	52608	7	841728	8.3E-06
DR1	9	24840	16	223560	7.2E-05
DR2	18	52608	6	946944	6.3E-06
DR3	18	52608	20	945944	2.1E-05
EN1	18	52608	1	946944	1.1E-06
EN2	18	30648	7	551664	1.3E-05
FP1	18	52608	16	946944	1.7E-05
MI1	18	52608	4	946944	4.2E-06
MO1	18	52608	4	946944	4.2E-06
NM1	16	52608	6	841728	7.1E-06
OC1	16	52608	6	841728	7.1E-06
PB2	18	52608	4	946944	4.2E-06
PB3	18	52608	2	946944	3.2E-06
PI1	18	52608	0	946944	2.4E-07
QC1	18	52608	0	946944	2.4E-07
QC2	18	52608	0	946944	2.4E-07
VY1	16	52608	0	841728	2.7E-07
		TOTALS	120	20444616	AVG. 5.9E-06

FINAL STATISTICS

CORE FLUX CHANNELS(ANALOG)-RED. CAP.-COMMAND FAULTS INCLUDED

	OPERATING FAULT RATE (FAULTS/HOUR)
	1.3
BAB.&WIL.	2.0E-05
	1.4
	1.5
COMB.ENG.	5.6E-06
	1.6
	1.3
WESTINGH.	3.5E-06
	1.4
	1.2
PWR'S	5.7E-06
	1.2
	1.2
GE (BWR'S)	5.9E-06
	1.2
	1.1
OVERALL	5.8E-06
	1.1

X.X - UPPER 95% CONFIDENCE MULTIPLIER

Y.YE-YY - LER RATE ESTIMATE

Z.Z - LOWER 5% CONFIDENCE DIVISOR

I-005

The remainder of Appendix I is provided on microfiche.

<small>NRC FORM 325 12-841 NRCM 1102 3201, 3202</small> <b>BIBLIOGRAPHIC DATA SHEET</b> <small>SEE INSTRUCTIONS ON THE REVERSE</small>		<small>U.S. NUCLEAR REGULATORY COMMISSION</small> <small>REPORT NUMBER (Assigned by TRC, add Vol. No., if any)</small> <b>NUREG/CR-1740 Rev. 1</b> <b>EGG-2307</b>	
<b>2. TITLE AND SUBTITLE</b> Data Summaries of Licensee Event Reports of Selected Instrumentation and Control Components at U.S. Commercial Nuclear Power Plants January 1, 1976 to December 31, 1981		<b>1. LEAVE BLANK</b>	
<b>5. AUTHOR(S)</b> Mike Trojovsky Sharon R. Brown		<b>4. DATE REPORT COMPLETED</b> MONTH: March      YEAR: 1984 <b>6. DATE REPORT ISSUED</b> MONTH: July      YEAR: 1984	
<b>7. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</b> EG&G Idaho, Inc. P. O. Box 1625 Idaho Falls, ID 83415		<b>8. PROJECT/TASK/WORK UNIT NUMBER</b>  <b>9. FIN OR GRANT NUMBER</b> FIN No. A6393	
<b>10. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</b> Division of Risk Analysis and Operations Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555		<b>11a. TYPE OF REPORT</b> Technical <b>b. PERIOD COVERED (Inclusive Dates)</b> January 1, 1976, to December 31, 1981	
<b>12. SUPPLEMENTARY NOTES</b>			
<b>13. ABSTRACT (200 words or less)</b>  This report describes a computer-based data file developed from Licensee Event Reports (LERs) of instrumentation and control (I&C) components in United States commercial nuclear power plants for the period January 1, 1976, to December 31, 1981. In addition to the creation of the file, summaries of data contained in the file were made to obtain data for risk assessment and statistical purposes. Gross constant fault (failure and command fault) rates were estimated for major components and channels that provide a direct reactor trip. Explanations, figures, and summary tables of the results are provided. This report updates and supersedes the original May 1981 edition of NUREG/CR-1740.			
<b>14. DOCUMENT ANALYSIS - a. KEYWORDS/DESCRIPTORS</b> Licensee Event Report (LER) Instrumentation and Control (I&C) Components Fault Rates		<b>15. AVAILABILITY STATEMENT</b> Unlimited	
<b>b. IDENTIFIERS/OPEN-ENDED TERMS</b>		<b>16. SECURITY CLASSIFICATION</b> <small>(This page)</small> Unclassified <small>(This report)</small> Unclassified	
		<b>17. NUMBER OF PAGES</b>	
		<b>18. PRICE</b>	

120555078677 1 LANIRG115  
US NRC  
ADM-DIV OF TIDC  
POLICY & PUB MGT BR-PDR NUREG  
w-501  
WASHINGTON DC 20555

EG&G Idaho, Inc.  
P.O. Box 1625  
Idaho Falls, Idaho 83415