



Log # TXX-95306  
File # 916 (2.0)  
10010  
Ref. # 10CFR50.90  
10CFR50.59

C. Lance Terry  
Group Vice President

December 15, 1995

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
Docket NOS. 50-445 AND 50-446  
SUBMITTAL OF CHANGES IN BASES SECTION 2.2.1  
FOR UNIT 1 AND UNIT 2 TECHNICAL SPECIFICATIONS

Gentlemen:

The purpose of this letter is to transmit the enclosed approved changes to the BASES Section 2.2.1 of the CPSES Unit 1 and Unit 2 Technical Specifications.

The changes delete the specific statements regarding the response time for the RCP Undervoltage (1.2 seconds) and Underfrequency (0.3 seconds) from Technical Specifications BASES 2.2.1.

TU Electric has determined via the 10CFR50.59 process that these changes do not involve an unreviewed safety question. The changes were incorporated in the Unit 1 and Unit 2 Technical Specifications on December 12, 1995.

Enclosure 1 includes a detailed description and a marked up copy of the affected Technical Specifications (NUREG-1468).

TU Electric requests that the NRC incorporate these changes in a future license amendment for CPSES Unit 1 and Unit 2.

180043

9512180165 951215  
PDR ADOCK 05000445  
P PDR

D229


TXX-95306

Page 2 of 2

Should you have any questions, please contact Mr. Manu Patel at  
(214) 812-8298.

Sincerely,

C. L. Terry

By:   
D. R. Woodlan  
Docket Licensing Manager

MCP/grp

Enclosure: 1. Technical Specifications BASES, 2.2.1

c - Mr. L. J. Callan, Region IV  
Mr. W. D. Johnson, Region IV  
Resident Inspectors, CPSES  
Mr. T. J. Polich, NRR

Mr. Arthur C. Tate  
Bureau of Radiation Control  
Texas Department of Public Health  
1100 West 49th Street  
Austin, Texas 78704