

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

August 20, 1984

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with 10 CFR Part 50.90, we are enclosing 40 copies of a requested amendment to the operating license, DPR-77 and DPR-79, to change the Sequoyah Nuclear Plant units 1 and 2 technical specifications (T/S). The proposed changes are provided in Enclosure 1. These proposed changes allow use of a fifth vital battery to satisfy limiting conditions for operation (LCO) when one of the trained vital batteries is out of service. The justification for the proposed T/S changes is provided in Enclosure 2.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12. The amendment application fee is being wired to the Nuclear Regulatory Commission, Attention: Licensing Fee Management Branch.

This requested amendment has been evaluated pursuant to 10 CFR 50.92 and no significant hazards considerations are involved.

If you have any questions concerning this matter, please get in touch with Jerry Wills at FIS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. H. Shell
R. H. Shell, Supervisor
PWR Projects

Sworn to and subscribed before me
this 20th day of Aug. 1984.

Paulette H. White
Notary Public

My Commission Expires 9-5-84
Enclosures (40)

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

*A015 w/check \$150.00
#22631*

8408270156 840820
PDR ADOCK 05000327
P PDR