

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

84 JUL 25 A 8:20

July 19, 1984

U.S. Nuclear Regulatory Commission
Region II
ATTN: James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Dear Mr. O'Reilly:


Please refer to my letter to you dated May 9, 1984 which contained our response to Inspection Report Nos. 50-259/84-10, 50-260/84-10, 50-296/84-10 for the Browns Ferry Nuclear Plant. Enclosed is a revised response which provides clarification for Item 3, "Corrective Steps Which Have Been Taken and Results Achieved." This was discussed with the NRC Resident Inspector, G. R. Paulk.

If you have any questions, please call Jim Domer at FTS 858-2725.

To the best of my knowledge, I declare the statements contained herein are complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

Enclosure

ENCLOSURE

REVISED RESPONSE
NRC INSPECTION REPORT NOS.
50-259/84-10, -260/84-10, AND -296/84-10
D. M. VERRELLI'S LETTER TO H. G. PARRIS
DATED APRIL 9, 1984

3. Corrective Steps Which Have Been Taken and Results Achieved

The instructions specified in this report (SI 4.8.B.2-3a, TI-38, Procedure 1053 and 1053A) have been revised to correct the procedural violations as follows:

- a. SI 4.8.B.2-3a has been revised to correct and clarify items 6 and 7.
- b. TI-38, Procedure 1053 has been revised to correct items 1, 2, 3 and 4.
- c. TI-38, Procedure 1053A has been revised to correct item 5.

Also, more detailed continuous air monitor diagrams and sampling valve lineups have been incorporated into TI-38, Procedure 1053 to assist radiochemistry laboratory personnel in performing their duties correctly and more efficiently. Identification tags (item 3) have been attached to all continuous air monitor sampling valves in order to eliminate the possibility of an incorrect valve alignment when obtaining a gaseous sample.

4. Corrective Steps Which Will Be Taken to Avoid Further Violations

Chemical Unit personnel are currently in the process of reviewing and revising all surveillance instructions and supportive portions of Technical Instructions (TI-18, -19, and -38) performed in total or in part by the radiochemical laboratory. Instruction changes will be initiated as problem areas are identified.

5. Data When Full Compliance Will Be Achieved

All procedure review and revisions will be completed by September, 1984.