

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of
NEW YORK POWER AUTHORITY)
James A. FitzPatrick Nuclear Power Plant) Docket No. 50-333

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

The New York Power Authority requests an amendment to the Technical Specifications contained in Appendix A to Facility Operating License DPR-59 for the James A. FitzPatrick Nuclear Power Plant. This application is filed in accordance with Section 10 CFR 50.90 of the Nuclear Regulatory Commission's regulations.


This application for an amendment to the James A. FitzPatrick Technical Specifications (TS) proposes to incorporate the inservice testing requirements of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (B&PV) Code. The proposed change adds a new surveillance requirement, 4.0.E, which refers to the requirements of Section XI of the ASME B&PV Code and Addenda established by 10 CFR 50.55a(f). Ancillary changes are also required since the proposed Specification 4.0.E replaces the surveillance testing requirements of safety related pump and motor operated valves and extends the surveillance testing frequency of other components from once every month, to coincide with the ASME Section XI requirements.

Quarterly pump and valve testing is required by the 1980 Edition of the ASME Code and the applicable sections of 10 CFR 50.55a. These changes will result in an appropriate test interval for assuring component operability, will not significantly impact system reliability, and make the FitzPatrick Technical Specifications more consistent with the Standard Technical Specifications.

Editorial changes have been made on the pages being revised by the incorporation of ASME Section XI. These changes include correction of typographical/punctuation errors, editorial clarifications, and the deletion of blank pages.

The proposed changes to the Technical Specifications are Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II. A markup of the affected Technical Specification pages is included as Attachment III.

New York Power Authority




William J. Cahill, Jr.

Chief Nuclear Officer
QUEEN E. O'CONNOR
Notary Public, State of New York
No. 4991062

Qualified in Westchester County
Commission Expires January 21, 1996

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 14th day of December 1995.


Notary Public