

Wayne H. Jens  
Vice President  
Nuclear Operations

Detroit  
Edison

Fermi-2  
6430 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-4150

August 8, 1984  
EF2-66735

Mr. C. J. Paperiello, Chief  
Emergency Preparedness and  
Radiological Safety Branch  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Paperiello:

- Reference: (1) Fermi 2  
NRC Docket No. 50-341
- (2) NRC Letter C. J. Paperiello to  
D. A. Wells, February 1, 1984
- (3) Letter, W. H. Jens to C. J. Paperiello,  
January 4, 1984, EF2-66773, "Detroit  
Edison's Response to Inspection Report  
No. 50-341/83-24"

Subject: Detroit Edison's Response to Inspection Report  
No. 50-341/83-24, Open Item 16, Appendix A


In response to your letter of February 1, 1984,  
(Reference 2) Detroit Edison will incorporate numerical  
values into the EALs. These values will represent the  
instrument readings the operator will use in determining an  
emergency classification. Edison has discussed this  
response (Reference 3) to Item 16, Appendix A, with  
M. Phillips and J. Patterson of your office and clarified  
the issue. This action will be completed prior to fuel  
load.

We will keep you informed of the completion of all Appendix  
A open items required for fuel load so that a timely  
re-inspection can be performed by your group.

Should you have any further questions, please contact  
Mr. Lewis P. Bregni (313) 586-5083.

8408270352 840822  
PDR ADock 05000341  
g PDR

Sincerely,



cc: P. M. Bryon  
R. C. Knop  
USNRC, Document Control Desk  
Washington, D.C. 20555

AUG 13 1984