

UNITED STATES NUCLEAR REGULATORY COMMISSIONSEQUOYAH NUCLEAR PLANT, UNIT 1DOCKET NO. 50-327NOTICE OF WITHDRAWAL OF AN AMENDMENT REQUEST
TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (NRC) has approved the withdrawal of a Technical Specification (TS) amendment request by the Tennessee Valley Authority (TVA or the licensee) for an amendment to Facility Operating License No. DPR-77, issued to the Sequoyah Nuclear Plant, Unit 1. The plant is located in Soddy-Daisy, Tennessee. Notice of Consideration of Issuance of this amendment was published in the FEDERAL REGISTER on February 27, 1992 (57 FR 6748).


The application being withdrawn was originally submitted by an amendment request dated February 20, 1992. The licensee requested temporary changes related to the Reactor Coolant System (RCS) resistance temperature detector (RTD) allowable values (overtemperature differential temperature, overpower differential temperature, loop differential temperature) and the channel calibration requirements for the RCS RTDs. The proposed change was needed due to test instrument errors that occurred during Unit 1 startup following the Cycle 6 refueling outage that invalidated the RCS RTD sensor calibration. By letter dated April 13, 1992, the licensee withdrew its license amendment application.

For further details with respect to this action, see (1) the application for amendment dated February 20, 1992, (2) the licensee's letter of withdrawal dated April 13, 1992, and (3) the staff letter dated April 23, 1992.

These documents are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, N.W. Washington, DC 20555 and at the Chattanooga-Hamilton County Library, 1001 Broad Street, Chattanooga, Tennessee 37402.

Dated at Rockville, Maryland this 23rd day of April 1992.

FOR THE NUCLEAR REGULATORY COMMISSION



David E. LaFarge, Senior Project Manager
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Distribution

Docket File

NRC PDR

Local PDR

S. Varga 12-G-18

G. Lainas 14-E-4

F. Hebdon

D. LaBarge

M. Sanders

OGC 15-B-18

D. Hagan MNBB-3302

ACRS(10)

OPA 2-G-5

OC/LFMB MNBB-9112

SQN Rdg. File

L. Reyes RII