



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 65
License No. NPF-49

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated December 16, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 65 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 24, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 65

FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 3-43

3/4 3-45

Insert

3/4 3-43

3/4 3-45

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS

<u>FUNCTIONAL UNIT</u>	<u>CHANNELS TO TRIP/ALARM</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM/TRIP SETPOINT</u>	<u>ACTION</u>
1. Containment					
a. Containment Area Purge and Exhaust Isolation	1	2	5, 6	≤ 1 R/h	26
b. RCS Leakage Detection					
1) Particulate Radioactivity	N.A.	1	1, 2, 3, 4	N.A.	29
2) Gaseous Radioactivity	N.A.	1	1, 2, 3, 4	N.A.	29
2. Fuel Storage Pool Area Monitors					
a. Radiation Level	1	2	*	≤ 15 mR/h	28

MILLSTONE - UNIT 3
0055

3/4 3-45

Amendment No. 48, 65

TABLE 4.3-3

RADIATION MONITORING INSTRUMENTATION FOR PLANT
OPERATIONS SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG</u>		<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
			<u>CHANNEL OPERATIONAL TEST</u>		
1. Containment					
a. Containment Area Purge and Exhaust Isolation	S	R	M		5, 6
b. RCS Leakage Detection					
1) Particulate Radio- activity	S	R	H		1, 2, 3, 4
2) Gaseous Radioactivity	S	R	M		1, 2, 3, 4
2. Fuel Storage Pool Area Monitors					
a. Radiation Level	S	R	M		*

TABLE NOTATIONS

* With fuel in the fuel storage pool area.