

84 JUL 25 A 8:21



July 18, 1984  
LI-84-182

Mr. James P. O'Reilly  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, GA 30323

Dear Mr. O'Reilly:

Re: St. Lucie Units 1 and 2  
Docket Nos. 50-335, 50-389  
IE Bulletin 84-02

Florida Power & Light Company has reviewed IE Bulletin 84-02 (Failures of General Electric Type HFA Relays In Use in Class 1E Safety Systems) as it applies to St. Lucie Units 1 and 2.

Action Item 1 requested FPL to develop plans and schedules for replacing (1) nylon or Lexan coil spool-type HFA relays used in normally energized safety related applications and (2) nylon coil spool-type HFA relays used in normally de-energized safety related applications.

For St. Lucie Unit 1 all involved HFA relays were identified and replaced with the new Tefzel series relays. All relays now installed in Unit 2 were manufactured after January 1979. GE has informed us that relays made after this time period are made with Tefzel spools.

In addition, the site's spare parts specifications have been upgraded and parts on hand were reviewed for proper date codes.

8408280058 840718  
PDR ADOCK 05000335  
G PDR

Mr. James P. O'Reilly  
July 18, 1984  
Page 2

This completes our efforts in response to the subject bulletin. Should you or your staff have any questions on this information, please contact us.

Very truly yours,

*for C. Woody*  
J. W. Williams, Jr.  
Group Vice President  
Nuclear Energy

JWW/PLP/js

Attachment


cc: U. S. NRC Document Control Desk  
PNS-LI-84-247

STATE OF FLORIDA    )  
                          )    ss.  
COUNTY OF DADE    )

C. O. Woody, being first duly sworn, deposes and says:


That he is Vice President Nuclear Operations of Florida Power & Light Company, the licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

  
\_\_\_\_\_  
C. O. Woody

Subscribed and sworn to before me this

19 day of JULY, 1984.

  
\_\_\_\_\_  
NOTARY PUBLIC, in and for the County of  
Dade, State of Florida.

NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP. FEB 14, 1988  
BONDED THRU GENERAL INS. UND.

My commission expires: 2/14/88