

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power Corporation
Crystal River 3

Docket No. 50-302
License No. DPR-72

The following violations were identified during an inspection conducted on May 15-18, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 20.203(c)(3) requires in part that each entrance or access point to a high radiation area shall be established in such a way that no individual will be prevented from leaving a high radiation area.

Contrary to the above, on May 16, 1984, the inspector observed the use of a chain and pad lock to control the access to containment which is a high radiation area. This type of locking device if locked while individuals were inside the high radiation area would prevent individuals from leaving the high radiation area.

This is a Severity Level V violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: JUN 13 1984

8408280077 840719
PDR ADDCK 05000302
Q PDR