

NOTICE OF DEVIATION

Commonwealth Edison Company
Braidwood Station
Braceville, Illinois

Docket Nos. 50-456; 50-457
License Nos. NPF-72; NPF-77

During an NRC inspection conducted on October 1 through November 14, 1995, deviation of your Generic Letter 89-13 commitment was identified. In accordance with the "General Statement of Policy and Procedures for NRC Enforcement Actions, the deviation is listed below:

Braidwood Station response to Generic Letter 89-13, dated October 27, 1994, included a commitment to continuously inject sodium hypochlorite into the essential service water system for a five-week period as the cooling lake transitioned through 65 degrees fahrenheit.

Contrary to the above, during Fall 1995, the cooling lake transitioned through 65 degrees fahrenheit and sodium hypochlorite was not continuously injected into the essential service water system for a five-week period.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, in writing within 30 days of the date of this Notice, (1) the reason for the deviation, or if contested, the basis of disputing the deviation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further deviations, and (4) the date when your corrective action will be completed. where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 8th day of December 1995

9512210096 951208
PDR ADOCK 05000456
Q PDR